



FPL

OCT 08 2003

L-2003-259
10 CFR 50.4

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Control Room Habitability
Generic Letter 2003-01 60-Day Response - Supplement

By letter L-2003-212, dated August 11, 2003, Florida Power and Light Company (FPL) provided its 60-day response to Generic Letter (GL) 2003-01, *Control Room Habitability*, for Turkey Point Units 3 and 4. The purpose of this letter is to supplement FPL's response based on the results of the control room envelope (CRE) testing completed on August 20, 2003.

Turkey Point completed maintenance activities to address CRE potential deficiencies and performed the CRE test using the methods of American Society of Testing and Materials (ASTM) Standard E471, *Standard Test Method for Determining Air Change in a Single Zone by Means of a Tracer Gas Dilution*. The results of the test successfully confirmed the current design basis in-leakage assumptions for Turkey Point Units 3 and 4. Therefore, Turkey Point will provide the requested information by the required December 9, 2003 180-day GL response date. As such, submittal of proposed license amendments to adopt the 10 CFR 50.67 alternative source term (AST) methodology for assessing the radiological consequences of design basis events is not required to meet the GL commitment.

If you have any questions, please contact Walter Parker at (305) 246-6632.

Very truly yours,

Handwritten signature of Terry O. Jones in cursive.

Terry O. Jones
Vice President
Turkey Point Nuclear Plant

OIH

cc: USNRC, Regional Administrator, Region II
Senior Resident Inspector, USNRC, Turkey Point Plant

A102