

2.C.(6) Deleted per Amendment No. 21, 7-3-79

2.C.(7) Prior to startup following the first regularly scheduled refueling outage, Florida Power Corporation shall modify to the satisfaction of the Commission, the reactor coolant system flow indication to meet the single failure criterion with regard to pressure sensing lines to the flow differential pressure transmitters.

2.C.(8) Within three months of issuance of this license, Florida Power Corporation shall submit to the Commission a proposed surveillance program for monitoring the containment for the purpose of determining any future delamination of the dome.

2.C.(9) Fire Protection

Florida Power Corporation shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report for the facility and as approved in the Safety Evaluation Reports dated July 27, 1979, January 22, 1981, January 6, 1983, July 18, 1985 and March 16, 1988, subject to the following provisions:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

2.C.(10) The design of the reactor coolant pump supports need not include consideration of the effects of postulated ruptures of the primary reactor coolant loop piping and may be revised in accordance with Florida Power Corporation's amendment request of April 24, 1986.

2.C.(11) A system of thermocouples added to the decay heat (DH) drop and Auxiliary Pressurizer Spray (APS) lines, capable of detecting flow initiation, shall be operable for Modes 4 through 1. Channel checks of the thermocouples shall be performed on a monthly basis to demonstrate operability. If either the DH or APS system thermocouples become inoperable, operability shall be restored within 30 days or the NRC shall be informed, in a Special Report within the following fourteen (14) days, of the inoperability and the plans to restore operability.

2.C.(12) Florida Power Corporation shall assure that the Cycle 14 core for CR-3 is designed using the methods specified in and operated within the Core Operating Limits Report limits developed from Topical Reports BAW-10164P-A, Revision 4, and BAW-10241P, Revision 0, in addition to those methods allowed by Improved Technical Specification 5.6.2.18.

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

- 2.1.1.1 In MODES 1 and 2, the maximum local fuel pin centerline temperature shall be $\leq 5080 - (6.5 \text{ E-3}) \times (\text{Burnup MWD/MTU})^\circ\text{F}$. Operation within this limit is ensured by compliance with the AXIAL POWER IMBALANCE protective limits preserved by the Reactor Protection System setpoints in LCO 3.3.1, "Reactor Protection System (RPS) Instrumentation," as specified in the COLR.
- 2.1.1.2 In MODES 1 and 2, the departure from nucleate boiling ratio (DNBR) shall be maintained greater than the limits of 1.3 for the BAW-2 correlation, 1.18 for the BWC correlation and 1.132 for the BHTP correlation. Operation within this limit is ensured by compliance with SL 2.1.1.3 and with the AXIAL POWER IMBALANCE protective limits preserved by the RPS setpoints in LCO 3.3.1, as specified in the COLR.
- 2.1.1.3 In MODES 1 and 2, Reactor Coolant System (RCS) core outlet temperature and pressure shall be maintained above and to the left of the SL shown in Figure 2.1.1-1.

2.1.2 RCS Pressure SL

In MODES 1, 2, 3, 4, and 5, the RCS pressure shall be maintained ≤ 2750 psig.

2.2 SL Violations

The following actions shall be completed:

- 2.2.1 In MODE 1 or 2, if SL 2.1.1.1, SL 2.1.1.2 or SL 2.1.1.3 is violated, be in MODE 3 within 1 hour.
- 2.2.2 In MODE 1 or 2, if SL 2.1.2 is violated, restore compliance and be in MODE 3 within 1 hour.
-