

Exelon Generation Company, LLC www.exeloncorp.com
Braidwood Station
35100 South Rt 53, Suite 84
Braceville, IL 60407-9619
Tel. 815-417-2000

October 3, 2003
BW030082

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Braidwood Station, Unit 1
Facility Operating License No. NPF-72
NRC Docket No. STN 50-456

Subject: Submittal of Licensee Event Report Number 2003-003-00, "Licensed Maximum Power Level Exceeded Due To An Error In A Westinghouse Supplied Calorimetric Calculation Constant"

The enclosed Licensee Event Report (LER) is being submitted in accordance with Braidwood Station Unit 1 License Condition 2.G due to violating license condition 2.C(1), "Maximum Power Level." License Condition 2.G requires an LER to be submitted within 30 days after discovery of the event; therefore, this report is being submitted by October 3, 2003.

Should you have any questions concerning this submittal, please contact Kelly Root, Regulatory Assurance Manager, at (815) 417-2800.

Respectfully,



Michael J. Pacifico
Site Vice President
Braidwood Station

Enclosure: LER Number 2003-003-00

cc: Regional Administrator - Region III
NRC Braidwood Senior Resident Inspector

JE22

NRC FORM 366 (7-2001)		U.S. NUCLEAR REGULATORY COMMISSION		APPROVED BY OMB NO. 3150-0104 EXPIRES 7-31-2004 Estimated burden per response to comply with this information collection request: 50.0 hrs. Reported lessons learned are incorporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the Records Management Branch (T-6 E6), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by Internet e-mail to bis1@nrc.gov , and to the Desk Officer, Office of Information and Regulatory Affairs, NOEB-10202 (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.					
LICENSEE EVENT REPORT (LER)									
1. FACILITY NAME Braidwood, Unit 1				2. DOCKET NUMBER STN 05000456		3. PAGE 1 of 3			
4. TITLE Licensed Maximum Power Level Exceeded Due To An Error In A Westinghouse Supplied Calorimetric Calculation Constant									
5. EVENT DATE MO DAY YEAR 09 03 2003			6. LER NUMBER YEA SEQUENTIAL NUMBER REV NO 2003-003-00		7. REPORT DATE MONTH DAY YEAR 10 03 2003		8. OTHER FACILITIES INVOLVED FACILITY NAME DOCKET NUMBER Braidwood Unit 2 05000457 FACILITY NAME DOCKET NUMBER		
9. OPERATING MODE 1		10. POWER LEVEL 100		11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check all that apply)					
		<input type="checkbox"/> 20.2201(b)		<input type="checkbox"/> 20.2203(a)(3)(i)		<input type="checkbox"/> 50.73(a)(2)(i)(C)		<input type="checkbox"/> 50.73(a)(2)(vii)	
		<input type="checkbox"/> 20.2201(d)		<input type="checkbox"/> 20.2203(a)(3)(ii)		<input type="checkbox"/> 50.73(a)(2)(ii)(A)		<input type="checkbox"/> 50.73(a)(2)(viii)(A)	
		<input type="checkbox"/> 20.2203(a)(1)		<input type="checkbox"/> 20.2203(a)(4)		<input type="checkbox"/> 50.73(a)(2)(ii)(B)		<input type="checkbox"/> 73.73(a)(2)(viii)(B)	
		<input type="checkbox"/> 20.2203(a)(2)(i)		<input type="checkbox"/> 50.36(c)(1)(i)(A)		<input type="checkbox"/> 50.73(a)(2)(iii)		<input type="checkbox"/> 73.73(a)(2)(ix)(A)	
		<input type="checkbox"/> 20.2203(a)(2)(ii)		<input type="checkbox"/> 50.36(c)(1)(ii)(A)		<input type="checkbox"/> 50.73(a)(2)(iv)(A)		<input type="checkbox"/> 50.73(a)(2)(x)	
		<input type="checkbox"/> 20.2203(a)(2)(iii)		<input type="checkbox"/> 50.36(c)(2)		<input type="checkbox"/> 50.73(a)(2)(v)(A)		<input type="checkbox"/> 73.71(a)(4)	
		<input type="checkbox"/> 20.2203(a)(2)(iv)		<input type="checkbox"/> 50.46(a)(3)(ii)		<input type="checkbox"/> 50.73(a)(2)(v)(B)		<input type="checkbox"/> 73.71(a)(5)	
		<input type="checkbox"/> 20.2203(a)(2)(v)		<input type="checkbox"/> 50.73(a)(2)(i)(A)		<input type="checkbox"/> 50.73(a)(2)(v)(C)		<input checked="" type="checkbox"/> OTHER Specify in Abstract below or in NRC Form 366A	
		<input type="checkbox"/> 20.2203(a)(2)(vi)		<input type="checkbox"/> 50.73(a)(2)(i)(B)		<input type="checkbox"/> 50.73(a)(2)(v)(D)			
12. LICENSEE CONTACT FOR THIS LER NAME: Carl Dunn, Engineering Manager TELEPHONE NUMBER (Include Area Code): (815) 417-3800									
13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO epix	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO EPIX
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14. SUPPLEMENTAL REPORT EXPECTED Yes (If yes, complete EXPECTED SUBMISSION DATE). X NO						15. EXPECTED SUBMISSION DATE MONTH DAY YEAR			

16. ABSTRACT (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)

Braidwood Station received Nuclear Safety Advisory Letter (NSAL) 03-06, "High Net Heat Input," from Westinghouse informing the Station that an error had been found in calculations that may result in the use of a non-conservatively high Net Heat input value in the calorimetric calculations. The Net Heat input is the difference between the reactor core power and the Nuclear Steam Supply System (NSSS) power. It consists of energy provided by the reactor coolant pump to the reactor coolant, heat supplied by the pressurizer heaters, and other minor heat removal and additions such as the cooling provided by the reactor coolant pump seal injection. The result of using a non-conservatively high Net Heat input value in the calorimetric calculations was that both Unit 1 and Unit 2 operated at higher than licensed core power levels on several occasions. The Westinghouse evaluation determined that the increase in Net Heat input could be as much as 0.4 Mwt. This condition applies to both Unit 1 and Unit 2.

In accordance with Braidwood Station Unit 2 License Condition 2.G a notification was made to the NRC at 1557 CST on September 3, 2003, due to violation of license condition 2.C(1), "Maximum Power Level."

FACILITY NAME (1)		DOCKET (2)		LER NUMBER (6)			PAGE (3)	
Braidwood, Unit 1		STN 05000456		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	2 of 3	
				2003 - 003 - 00				

No structures, systems or components were inoperable at the start of the event that contributed to the event.

The Net Heat value is the amount of heat, seen at the Steam Generators (NSSS Heat), which is not supplied by the reactor. It consists of items such as the heat supplied by the reactor coolant pumps, the heat supplied by the pressurizer heaters, and other minor heat removals and additions such as the cooling provided by the reactor coolant pump seal injection. The Net Heat value is used in the calorimetric calculation as follows:

As discussed in the NSAL, heat removed from the NSSS via reactor coolant pump seal leak off, although small, was non-conservatively omitted. The NSAL estimated that this error could be as high as a 0.4 MWT larger Net Heat value.

A Westinghouse calculation for the Net Heat input into the calorimetric calculation non-conservatively omitted the small amount of heat removed from the NSSS via the reactor coolant pump seal leak off flow.

The safety analyses impact of the error is low. The uncertainty calculation for the calorimetric yields a total uncertainty of 1.79% of rated thermal power (RTP). The power-limited safety analyses assume a 2% RTP uncertainty.

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)	DOCKET (2)	LER NUMBER (6)			PAGE (3)
Braidwood, Unit 1	STN 05000456	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	3 of 3
		2003 - 003 - 00			

Braidwood's licensed RTP is 3586.6 MWt. The magnitude of the 0.4 MWt for Braidwood is less than 0.02% RTP. Therefore, the safety analyses assumptions bounded the overpower condition.

This event did not result in a safety system functional failure.

E. Corrective Actions:

The immediate corrective action was to reduce and limit reactor power to 99.98%.

The Net Heat constant in the plant process computer, which is an input value into the calorimetric calculation, was conservatively reduced by 0.8 MWt.

The Net Heat input calculation is being revised to provide the appropriate Net Heat value to be used in the calorimetric calculation.

F. Previous Occurrences:

There have been no previous occurrences where incorrect calorimetric calculations resulted in exceeded licensed thermal power.

G. Component Failure Data:

<u>Manufacturer</u>	<u>Nomenclature</u>	<u>Model</u>	<u>Mfg. Part Number</u>
N/A	N/A	N/A	N/A