

DSSA
me

6/29/02

LIST OF ISSUES FROM JUNE 29, 2002 MEETING WITH NEI CONCERNING MANUAL ACTIONS

Resolution of generic issue of manual actions with NEI

Lack of criteria for feasible manual actions (for example location, environment, timeline analysis, lighting, ect)

Difference in type of manual actions (early, complex, and critical versus late and simple, inspection identified examples would be manual DG start with no control power needed ASAP compared to locally controlling fuel oil transfer to the DG day tank needed after about 3 hours).

Consult OGC concerning whether language of current regulation permits the use of manual actions for redundant shutdown

If not permitted under current regulation, consider expedited rulemaking.

Questioned by an attendee whether a Regulatory Information Summary was planned

Desired suspension of pending issues.

D/23