From: Rebecca Nease / EIV
To: Russ Bywater
Date: 8/11/01 12:59PM
Subject: Re: ANO Appendix R Issues

Hi,

I have completed 1 week of a 2-week training course at TTC. Per Charlie, I am to revise the report to combine the compliance and the risk significance together into one URI. (I just completed this) This way, we'll get the report out and interface with NRR/OGC/OE on compliance and risk when I get back to the office.

I brought some of the SERs with me, but did not bring any of their submittals. I would prefer to table this effort until I get back into the office.

For fire zone 98J, I think we still have enough info to support a potential non-compliance - we have an SER that says the room has only one train A redundant cable, and that ANO agreed to wrap it, so an exemption is not necessary.

I appreciate your help in all this. Keep me informed of any salient information - I don't know if I've missed any significant discussions which would affect the outcome of this issue.

Thanks,
Rebecca

CC: Smith, Linda

D/65