

VEPCO

VIRGINIA ELECTRIC AND POWER COMPANY
Surry Power Station
P.O. Box 315
Surry, Virginia 23883

April 28, 1975

Director of Regulatory Operations
230 Peachtree Street
Suite 818
Atlanta, Georgia 30303

This is to inform you by telecopy of an Abnormal Occurrence that was noted on April 27, 1975 at Surry Nuclear Power Station.

With Unit #2 at intermediate shutdown, an accumulator discharge valve failed to open when a safety injection signal was initiated during Performance Test 18.2.

E. M. Sweeney, Jr.
E. M. Sweeney, Jr.
Station Manager

8402270649 750502
PDR ADOCK 05000281
8 PDR

50-281