

# Vepco

VIRGINIA ELECTRIC AND POWER COMPANY

Surry Power Station  
P.O. Box 315  
Surry, Virginia 23883

April 14, 1975

*Unit 2*

Director of Regulatory Operations  
230 Peachtree Street  
Suite 818  
Atlanta, Georgia 30303

This is to inform you of an Abnormal Occurrence that occurred on April 13, 1975 at the Surry Power Station.

At 0430 on April 13, 1975, the Process Vent System Gaseous Radiation Indicator was found in the "Calibrate" mode. It was discovered that this condition had existed since about 0500 on April 12, 1975. Therefore, the process vent system was unmonitored for radioactive gaseous waste for about twenty-four hours. During the time that the gaseous radiation indicator was in "calibrate", the Process Vent Particulate Activity monitor showed no unusual activity levels.

*E. M. Sweeney, Jr.*  
E. M. Sweeney, Jr.

8402280076 750416  
PDR ADOCK 05000280  
8 PDR

50-280

IF files

Letter to N. C. Moseley from Virginia Electric and Power Company dated April 14, 1975.

v

DISTRIBUTION:

50-280

H. D. Thornburg, IE

→ IE:HQ3 (4)

Office of Standards Development

Central Files

Division of Reactor Licensing (4)

PDR

Local PDR

NSIC

TIC

STATE