

Memco

VIRGINIA ELECTRIC AND POWER COMPANY

Surry Power Station
P.O. Box 315
Surry, Virginia 23883

April 3, 1975

Director of Regulatory Operations
230 Peachtree Street
Suite 818
Atlanta, Georgia 30303

Dear Sir:

This is to officially inform you by telecopy within twenty-four (24) hours of an Abnormal Occurrence that occurred on April 2, 1975 at Surry Power Station.

The core differential flux exceeded the target band, requiring F_z surveillance when core power exceeded 50%. The initiation of F_z surveillance was delayed for three (3) hours, such that six (6) iterations of the procedure were not obtained.

E. M. Sweeney, Jr.

E.M. Sweeney, Jr.
Station Manager

8402280101 750408
PDR ADOCK 05000280
8 PDR

840-05