

Veeco

Unit 1

VIRGINIA ELECTRIC AND POWER COMPANY
Surry Power Station
P.O. Box 315
Surry, Virginia 23883

March 14, 1975

Director of Regulatory Operations
230 Peachtree Street
Suite 818
Atlanta, Georgia 30303

This is to inform you by telecopy of an Abnormal Occurrence that was noted on March 14, 1975 at Surry Nuclear Power Station.

An uncontrolled and unplanned release of radioactive material was made to the discharge canal when a primary grade water tank overflowed. The release was less than 1 per cent of the maximum permissible concentration.

E. M. Sweeney, Jr.

E. M. Sweeney, Jr.
Station Manager

8402280176 750320
PDR ADOCK 05000280
8 PDR