

**Veeco**

*Unit 1*

VIRGINIA ELECTRIC AND POWER COMPANY  
Surry Power Station  
P.O. Box 315  
Surry, Virginia 23883

March 14, 1975

Director of Regulatory Operations  
230 Peachtree Street  
Suite 818  
Atlanta, Georgia 30303

This is to inform you by telecopy of an Abnormal Occurrence that was noted on March 14, 1975 at Surry Nuclear Power Station.

An uncontrolled and unplanned release of radioactive material was made to the discharge canal when a primary grade water tank overflowed. The release was less than 1 per cent of the maximum permissible concentration.

*E. M. Sweeney, Jr.*

E. M. Sweeney, Jr.  
Station Manager

8402280176 750320  
PDR ADOCK 05000280  
8 PDR