

October 27, 2003

Mr. John L. Skolds
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE
REVIEW OF THE DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3,
AND QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2, LICENSE
RENEWAL APPLICATION

Dear Mr. Skolds:

By letter dated January 3, 2003, Exelon Generation Company, LLC (EGC) submitted, for the Nuclear Regulatory Commission's (NRC's) review, an application pursuant to 10 CFR Part 54, to renew the operating license for the Dresden Nuclear Power Station (DNPS), Units 2 and 3, and Quad Cities Nuclear Power Station (QCNPS), Units 1 and 2. By letters dated July 21, August 4, August 7, 2003, and September 9, 2003, the NRC staff issued requests for information for areas where additional information is needed to complete its review of the license renewal application.

Subsequently, the staff has identified further information needed to complete its review of the license renewal application. Specifically, the enclosed request for additional information is related to scoping and screening/aging management review of certain electrical components.

We have discussed this request with Messrs. R. Stachniak and F. Polaski of your staff on October 1, 2003. The staff is willing to meet with EGC prior to the submittal of the responses to provide clarifications of the staff's RAIs.

Sincerely,

/RA/

Tae Kim, Senior Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-237, 50-249, 50-254,
and 50-265

Enclosure: As stated

cc w/enclosures: See next page

October 27, 2003

Mr. John L. Skolds
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE REVIEW OF THE DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3, AND QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

Dear Mr. Skolds:

By letter dated January 3, 2003, Exelon Generation Company, LLC (EGC) submitted, for the Nuclear Regulatory Commission's (NRC's) review, an application pursuant to 10 CFR Part 54, to renew the operating license for the Dresden Nuclear Power Station (DNPS), Units 2 and 3, and Quad Cities Nuclear Power Station (QCNPS), Units 1 and 2. By letters dated July 21, August 4, August 7, 2003, and September 9, 2003, the NRC staff issued requests for information for areas where additional information is needed to complete its review of the license renewal application.

Subsequently, the staff has identified further information needed to complete its review of the license renewal application. Specifically, the enclosed request for additional information is related to scoping and screening/aging management review of certain electrical components.

We have discussed this request with Messrs. R. Stachniak and F. Polaski of your staff on October 1, 2003. The staff is willing to meet with EGC prior to the submittal of the responses to provide clarifications of the staff's RAIs.

Sincerely,

/RA/

Tae Kim, Senior Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos.: 50-237, 50-249, 50-254,
and 50-265

Enclosure: As stated

DISTRIBUTION: See next page

Document Name: C:\ORPCheckout\FileNET\ML033020029.wpd

**Cover letter only

Accession No: **ML033020029**

OFFICE	LA:RLEP:DRIP	PM:RLEP:DRIP	SC:EEIB:DE	SC:RLEP:DRIP	PD:RLEP:DRIP
NAME	YEdmonds**	TKim	RJenkins	SLee	PTKuo
DATE	10/27/2003	10/16/2003	10/17/2003	10/27/2003	10/27/2003

OFFICIAL RECORD COPY

DISTRIBUTION: Supplemental Request for Additional Information Re: Dresden, Units 2 and 3 and quad Cities, Units 1 and 2 Renewal Application: Dated: October 27, 2003

ML033020029

HARD COPY

RLEP RF

T. Kim

E-MAIL:

PUBLIC

J. Craig

D. Matthews

F. Gillespie

RidsNrrDe

R. Barrett

C. Grimes

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

R. Jenkins

P. Shemanski

H. Nieh

J. Fair

S. Black

B. Boger

D. Thatcher

G. Galletti

C. Li

J. Moore

R. Weisman

M. Mayfield

A. Murphy

S. Zane

S. Smith (srs3)

S. Duraiswamy

Y. Li

RLEP Staff

L. Rossbach

M. Banerjee

M. Ring, RIII

L. Kozak, RIII

Dresden and Quad Cities Nuclear Power Stations

cc:

Site Vice President - Quad Cities Nuclear
Power Station
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Nuclear Power Station Plant
Manager
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Regulatory Assurance Manager - Quad Cities
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Resident Inspectors Office
U.S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, IL 61242

William D. Leech
Manager - Nuclear
MidAmerican Energy Company
P.O. Box 657
Des Moines, IA 50303

Vice President - Law and Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, IA 52808

Chairman
Rock Island County Board of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, IL 61201

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Document Control Desk-Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Engineering
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Chief Operating Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Counsel, Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden and Quad
Cities
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Robert E. Stachniak
Sr. Engineer - License Renewal Prog.
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Mr. Fred Emerson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708

Site Vice President - Dresden Nuclear
Power Station
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Dresden Nuclear Power Station Plant
Manager
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Regulatory Assurance Manager - Dresden
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Dresden Resident Inspectors Office
U.S. Nuclear Regulatory Commission
6500 N. Dresden Road
Morris, IL 60450-9766

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, IL 60450

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, IL 62704

Vice President - Licensing and
Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Frederick W. Polaski
Manager - License Renewal Program
Exelon Generation Company, LLC
200 Exelon Way, KSA 1-N-3
Kennett Square, PA 19348

DRESDEN AND QUAD CITIES
LICENSE RENEWAL APPLICATION
SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION

RAI 2.5-2

- (a) Paragraph 2.5.1.1, "Cables and Connections," of the License Renewal Application states in part that "as appropriate, electrical cables and connections were excluded from aging management if they were identified as feeding an electrical component that performed no license renewal intended function. Please clarify whether your aging management review for cables have included in scope those cables that "performed no license renewal intended function," but share same cable trays/raceways with cables that do perform license renewal intended function. If those cables were excluded, then provide justification for exclusion from aging management review; otherwise, submit an aging management review for the subject cables.

- (b) It appears that certain electrical components, such as, switchyard bus, high voltage transmission conductor connections, and uninsulated ground conductors were excluded from the scope of license renewal aging management review. Provide justification for excluding these components from aging management review; otherwise, submit an aging management review for the subject components.