

Jeffrey T. Gasser
Vice President

Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Tel 205.992.7721
Fax 205.992.0403



October 27, 2003

Docket No. : 50-424

NL-03-2200

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant
Technical Specification Report 1-2003-1
Number of Steam Generator
 Tubes Plugged During 1R11

Ladies and Gentlemen:

In accordance with the requirements of Vogtle Electric Generating Plant Technical Specification 5.6.10, Southern Nuclear Operating Company submits this report of the number of steam generator (SG) tubes plugged during the Unit 1 eleventh maintenance/refueling outage (1R11).

As a result of the SG tube inservice inspections completed on October 14, 2003, a total of three (3) tubes were plugged in SG No. 3.

This letter contains no NRC commitments. If you have any questions, please advise.

Sincerely,

A handwritten signature in black ink that reads "Jeffrey T. Gasser". The signature is written in a cursive style with a long horizontal stroke at the end.

Jeffrey T. Gasser

JTG/TEW/DRG

cc: Southern Nuclear Operating Company
Mr. J. D. Woodard, Executive Vice President
Mr. W. F. Kitchens, General Manager – Plant Vogtle
Mr. M. Sheibani, Engineering Supervisor – Plant Vogtle
Document Services RTYPE: CVC7000

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. F. Rinaldi, NRR Project Manager – Vogtle
Mr. J. Zeiler, Senior Resident Inspector – Vogtle

~~A001~~
A047