

From: Peter Tam
To: Dennis E Vandeputte; John J Dosa; Steven Leonard
Date: 10/28/03 2:43PM
Subject: Request for Conference Call Re. NMP2 Proposed SLCS Amendment **(TAC MC0595)**

Dennis:

We are reviewing the subject amendment application dated 8/28/03. Our reviewer, Matthew Langschwager, has developed the following draft questions. Please set up a conference call with me to discuss these questions and address their disposition:

1. In Section 2.0, PROPOSED CHANGE, page 2 of 7, and again in section 4.0 TECHNICAL ANALYSIS, page 4 of 7, the licensee refers to a minor adjustment being made to one of the coordinates of the Acceptable Operation region in Figure 3.1.7-1. This concerns a lower coordinate increase from 4275 gallons to 4288 gallons. The licensee cites different roundoff techniques from a prior calculation as justification for this change. The NRC staff believes that a quantitative explanation may be needed, elaborating the differences between the prior calculation and the present calculation.

Additionally, if the aforementioned change is approved, the staff expects USAR Figure 9.3-18 be revised to reflect the coordinate change, in accordance with 10 CFR 50.71.

2. In Section 4.0, TECHNICAL ANALYSIS, the final paragraph of page 4 mentions that Technical Specification SR 3.1.7.2 and SR 3.1.7.3 require verification that the temperature of the SLC system sodium pentaborate solution is greater than or equal to 70 degree F. Earlier on page 3 of 7, the licensee states that "[t]he GNF analysis demonstrates that, with a minimum concentration equivalent to 780 ppm natural boron at 68 degree F, sufficient shutdown margin is maintained in the reactor to assure that the SLC system design function of bringing the reactor to a subcritical condition is achieved."

(a) The NRC staff believes these two statements do not clearly express the minimum temperature necessary for the SLC sodium pentaborate solution. Please explain this discrepancy.

(b) What is the quantifiable definition of a "sufficient" shutdown margin?

This e-mail aims solely to prepare you and others for the proposed conference call. It does not formally convey an NRC staff position, nor does it formally request for additional information.

Peter S. Tam, Senior Project Manager
Project Directorate I-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

e-mail: pst@nrc.gov Tel.: 301-415-1451

Mail Envelope Properties

(3F9EC6DF.B35 : 10 : 20510)

Subject: Request for Conference Call Re. NMP2 Proposed SLCS Amendment
(TAC MC0595)
Creation Date: 10/28/03 2:43PM
From: Peter Tam

Created By: PST@nrc.gov

Recipients	Action	Date & Time
nmp.cn.com	Transferred	10/28/03 02:43PM
Dennis.Vandeputte (Dennis E Vandeputte)		
John.Dosa (John J Dosa)		
Steven.Leonard (Steven Leonard)		

nrc.gov		
owf2_po.OWFN_DO	Delivered	10/28/03 02:43PM
MTL3 CC (Matthew Langschwager)	Opened	10/28/03 02:54PM

nrc.gov		
owf4_po.OWFN_DO	Delivered	10/28/03 02:43PM
TRT CC (Theodore Tjader)	Opened	10/28/03 03:00PM

Post Office	Delivered	Route
owf2_po.OWFN_DO	10/28/03 02:43PM	nmp.cn.com
owf4_po.OWFN_DO	10/28/03 02:43PM	nrc.gov
		nrc.gov

Files	Size	Date & Time
MESSAGE	3757	10/28/03 02:43PM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened

CC: Matthew Langschwager; Theodore Tjader