



October 24, 2003

L-PI-03-094  
Technical Specification 5.6.7

U S Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

**PRAIRIE ISLAND NUCLEAR GENERATING PLANT**  
**DOCKET NO. 50-306**  
**LICENSE NO. DPR-60**  
**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**


In accordance with Technical Specification 5.6.7.1, the number of tubes plugged or sleeved in each steam generator is provided in Table 1.

Prairie Island Unit 2 RFO22 Plugs and Sleeves						
Type of Repair	EOC 21		2003 Repairs		BOC22	
	21 SG	22 SG	21 SG	22 SG	21 SG	22 SG
Tubes Plugged	223	240	7	10	230	250
Tubes Sleeved	0	0	0	0	0	0

Table 1

In accordance with Technical Specification 5.6.7.4, the identification of F\* and EF\* tubes and the location and extent of degradation are included in Attachment 1 to this letter. There are 2064 tubes classified as F\* tubes and 14 tubes classified as EF\* tubes.

In this letter we have made no new Nuclear Regulatory Commission commitments. Please contact Jeff Kivi (651-388-1121) if you have any questions related to this letter.



Joseph M. Solymossy  
Site Vice President, Prairie Island Nuclear Generating Plant

CC Regional Administrator, USNRC, Region III  
Project Manager, Prairie Island Nuclear Generating Plant, USNRC, NRR  
NRC Resident Inspector – Prairie Island Nuclear Generating Plant

Attachment

A047

**ATTACHMENT 1**

**NUCLEAR MANAGEMENT COMPANY, LLC  
PRAIRIE ISLAND NUCLEAR GENERATING PLANT  
DOCKET 50-306**

**October 24, 2003**

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

**46 pages follow**

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

**CODES**

**Location (Landmark)**

TRH = Top of OEM Hard Roll Hot Leg  
 1BH = Bottom of Additional Hard Roll 1  
 2BH = Bottom of Additional Hard Roll 2  
 EBH = Bottom of Additional Elevated Hard Roll

**Types of F and EF Stars**

EF\* = EF\* Tube with Elevated Additional Roll Expansion  
 F\*0 = F\* Tube without Additional Roll Expansion  
 F\*1 = F\* Tube with One Additional Roll Expansion  
 F\*2 = F\* Tube with Second Higher Additional Roll Expansion

**Indication Code**

MAD = Multiple Axial Indication – No Longer Detectable  
 MAI = Multiple Axial Indication  
 MAN = Multiple Axial Indication – No Change  
 SAD = Single Axial Indication – No Longer Detectable  
 SAI = Single Axial Indication  
 SAN = Single Axial Indication – No Change  
 SCN = Single Circumferential Indication - No Change  
 SVN = Single Volumetric Indication - No Change

21 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	21	H	1	2	SAN	TRH	-2.26	-2.16	F*0
2	21	H	2	2	SAI	TRH	-2.8	-2.73	F*0
3	21	H	1	4	SAN	TRH	-2.69	-2.36	F*0
4	21	H	1	5	SAN	TRH	-2.81	-2.71	F*0
5	21	H	2	5	SAI	TRH	-2.81	-2.71	F*0
6	21	H	1	6	SAN	TRH	-2.72	-2.43	F*0
7	21	H	1	7	SAN	TRH	-2.83	-2.72	F*0
8	21	H	2	7	MAN	TRH	-2.88	-2.48	F*0
9	21	H	4	7	SAI	TRH	-2.89	-2.84	F*0
10	21	H	13	7	SAI	TRH	-2.82	-2.76	F*0
11	21	H	5	8	SAN	TRH	-2.47	-2.35	F*0
12	21	H	24	8	SAI	TRH	-2.48	-2.45	F*0
13	21	H	12	9	SAN	TRH	-2.56	-2.48	F*0
14	21	H	20	9	MAI	TRH	-2.75	-2.63	F*0
15	21	H	25	9	SAN	TRH	-2.6	-2.54	F*0
16	21	H	2	10	SAN	TRH	-2.37	-2.24	F*0
17	21	H	14	10	SAI	TRH	-2.93	-2.82	F*0
18	21	H	15	10	SAN	TRH	-2.96	-2.77	F*0
19	21	H	16	10	SAI	TRH	-2.83	-2.77	F*0
20	21	H	25	10	SAN	TRH	-2.66	-2.57	F*0
21	21	H	26	10	SAN	TRH	-2.62	-2.56	F*0
22	21	H	27	10	MAI	TRH	-2.7	-2.63	F*0

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
23	21	H	28	10	MAI	TRH	-2.83	-2.7	F*0
24	21	H	7	11	SAN	TRH	-1.74	-1.59	F*0
25	21	H	19	11	SAI	TRH	-2.6	-2.52	F*0
26	21	H	27	11	SAN	TRH	-2.4	-2.32	F*0
27	21	H	29	11	MAN	TRH	-2.68	-2.52	F*0
28	21	H	5	12	SAN	TRH	-2.53	-2.41	F*0
29	21	H	15	12	SAN	TRH	-2.8	-2.66	F*0
30	21	H	26	12	SAI	TRH	-2.5	-2.47	F*0
31	21	H	27	12	MAI	TRH	-2.48	-2.36	F*0
32	21	H	28	12	MAN	TRH	-2.53	-2.39	F*0
33	21	H	1	13	MAN	TRH	-2.94	-2.76	F*0
34	21	H	6	13	SAN	TRH	-2.59	-2.42	F*0
35	21	H	7	13	MAN	TRH	-2.68	-2.45	F*0
36	21	H	23	13	SAI	TRH	-2.38	-2.34	F*0
37	21	H	25	13	SAI	TRH	-2.34	-2.31	F*0
38	21	H	1	14	MAN	TRH	-3.03	-2.8	F*0
39	21	H	6	15	SAI	TRH	-2.56	-2.51	F*0
40	21	H	7	15	SAN	TRH	-2.54	-2.43	F*0
41	21	H	20	15	SAI	TRH	-2.49	-2.43	F*0
42	21	H	28	15	MAI	TRH	-2.19	-2.16	F*0
43	21	H	2	16	SAN	TRH	-2.57	-2.36	F*0
44	21	H	6	16	SAN	TRH	-2.45	-2.36	F*0
45	21	H	15	16	SAN	TRH	-2.74	-2.59	F*0
46	21	H	16	16	SAI	TRH	-2.43	-2.32	F*0
47	21	H	28	16	MAI	TRH	-2.67	-2.63	F*0
48	21	H	5	17	MAN	TRH	-2.99	-2.89	F*0
49	21	H	7	17	MAN	TRH	-2.62	-2.39	F*0
50	21	H	7	18	SAN	TRH	-2.53	-2.46	F*0
51	21	H	7	19	MAN	TRH	-2.61	-2.42	F*0
52	21	H	26	19	MAN	TRH	-2.76	-2.66	F*0
53	21	H	8	20	SAN	TRH	-2.54	-2.47	F*0
54	21	H	25	20	MAN	TRH	-2.56	-2.38	F*0
55	21	H	31	20	SAN	TRH	-2.75	-2.68	F*0
56	21	H	33	20	MAN	TRH	-2.63	-2.52	F*0
57	21	H	29	21	SAI	TRH	-2.56	-2.5	F*0
58	21	H	32	21	MAN	TRH	-2.71	-2.57	F*0
59	21	H	6	22	MAN	TRH	-2.4	-2.31	F*0
60	21	H	7	22	SAN	TRH	-2.46	-2.33	F*0
61	21	H	7	23	SAN	TRH	-2.49	-2.38	F*0
62	21	H	31	24	MAN	TRH	-2.59	-2.48	F*0
63	21	H	33	24	SAN	TRH	-2.54	-2.43	F*0
64	21	H	1	25	MAN	TRH	-2.43	-2.37	F*0
65	21	H	24	25	MAN	TRH	-2.47	-2.3	F*0
66	21	H	33	25	SAN	TRH	-2.46	-2.37	F*0
67	21	H	33	30	SAN	TRH	-2.58	-2.41	F*0
68	21	H	17	32	SAN	TRH	-2.64	-2.53	F*0
69	21	H	1	34	SAN	TRH	-2.5	-2.4	F*0

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

21 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
70	21	H	1	35	SAN	TRH	-2.53	-2.44	F*0
71	21	H	1	40	SAI	TRH	-2.51	-2.47	F*0
72	21	H	25	41	SAN	TRH	-2.42	-2.23	F*0
73	21	H	1	47	MAN	TRH	-2.56	-2.17	F*0
74	21	H	21	47	MAN	TRH	-2.5	-2.4	F*0
75	21	H	1	58	SAI	TRH	-2.44	-2.35	F*0
76	21	H	27	60	MAI	TRH	-2.6	-2.5	F*0
77	21	H	28	60	SAN	TRH	-2.52	-2.34	F*0
78	21	H	33	60	MAI	TRH	-2.77	-2.64	F*0
79	21	H	26	61	SAN	TRH	-2.59	-2.53	F*0
80	21	H	27	61	MAN	TRH	-2.44	-2.35	F*0
81	21	H	15	62	SAN	TRH	-2.58	-2.43	F*0
82	21	H	23	62	MAN	TRH	-2.55	-2.43	F*0
83	21	H	28	62	SAN	TRH	-2.45	-2.36	F*0
84	21	H	32	62	SAN	TRH	-2.58	-2.45	F*0
85	21	H	33	62	SAN	TRH	-2.65	-2.52	F*0
86	21	H	21	63	SAN	TRH	-1.86	-1.74	F*0
87	21	H	26	63	SAN	TRH	-2.42	-2.38	F*0
88	21	H	27	63	SAN	TRH	-2.47	-2.41	F*0
89	21	H	29	63	SAN	TRH	-2.7	-2.58	F*0
90	21	H	23	64	SAN	TRH	-2.58	-2.46	F*0
91	21	H	25	64	SAI	TRH	-2.71	-2.63	F*0
92	21	H	26	64	MAI	TRH	-2.46	-2.4	F*0
93	21	H	32	64	MAN	TRH	-2.54	-2.41	F*0
94	21	H	33	64	SAN	TRH	-2.71	-2.53	F*0
95	21	H	3	65	SAN	TRH	-2.77	-2.74	F*0
96	21	H	15	65	SAN	TRH	-2.7	-2.64	F*0
97	21	H	23	65	SAN	TRH	-2.64	-2.57	F*0
98	21	H	24	65	SAN	TRH	-2.63	-2.56	F*0
99	21	H	26	65	MAN	TRH	-2.48	-2.3	F*0
100	21	H	30	65	SAN	TRH	-2.42	-2.29	F*0
101	21	H	1	66	MAN	TRH	-2.61	-2.2	F*0
102	21	H	2	66	SAN	TRH	-1.92	-1.87	F*0
103	21	H	23	66	SAI	TRH	-2.51	-2.44	F*0
104	21	H	27	66	SAN	TRH	-2.42	-2.31	F*0
105	21	H	32	66	SAI	TRH	-2.51	-2.39	F*0
106	21	H	17	67	SAN	TRH	-1.57	-1.42	F*0
107	21	H	1	68	SAN	TRH	-2.41	-2.31	F*0
108	21	H	6	68	SAN	TRH	-2.63	-2.51	F*0
109	21	H	8	68	SAN	TRH	-2.7	-2.61	F*0
110	21	H	27	68	SAN	TRH	-2.49	-2.11	F*0
111	21	H	2	69	SAI	TRH	-2.59	-2.48	F*0
112	21	H	24	69	MAN	TRH	-2.49	-2.34	F*0
113	21	H	32	69	SAI	TRH	-2.76	-2.7	F*0
114	21	H	8	70	SAI	TRH	-2.61	-2.52	F*0
115	21	H	23	70	MAN	TRH	-2.45	-2.38	F*0
116	21	H	24	70	SAN	TRH	-2.46	-2.34	F*0

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
117	21	H	27	70	SAN	TRH	-2.39	-2.26	F*0
118	21	H	30	70	SAN	TRH	-2.53	-2.38	F*0
119	21	H	23	71	SAN	TRH	-2.46	-2.39	F*0
120	21	H	29	71	SAN	TRH	-2.55	-2.41	F*0
121	21	H	27	72	SAN	TRH	-2.3	-2.23	F*0
122	21	H	31	72	MAN	TRH	-2.43	-2.23	F*0
123	21	H	1	73	SAN	TRH	-2.61	-2.55	F*0
124	21	H	25	73	SAN	TRH	-2.48	-2.34	F*0
125	21	H	30	74	SAI	TRH	-2.47	-2.32	F*0
126	21	H	32	74	SAN	TRH	-2.53	-2.38	F*0
127	21	H	1	75	SAN	TRH	-2.58	-2.43	F*0
128	21	H	16	75	SAN	TRH	-2.71	-2.54	F*0
129	21	H	23	75	SAI	TRH	-2.45	-2.31	F*0
130	21	H	27	75	SAI	TRH	-2.36	-2.3	F*0
131	21	H	31	75	SAI	TRH	-2.29	-2.24	F*0
132	21	H	1	76	SAN	TRH	-2.57	-2.42	F*0
133	21	H	6	76	SAN	TRH	-2.35	-2.09	F*0
134	21	H	14	76	SAI	TRH	-2.31	-2.26	F*0
135	21	H	16	76	SAN	TRH	-2.34	-1.88	F*0
136	21	H	21	76	SAN	TRH	-2.56	-2.52	F*0
137	21	H	26	76	MAN	TRH	-2.43	-2.28	F*0
138	21	H	27	76	MAN	TRH	-2.49	-2.34	F*0
139	21	H	29	76	SAI	TRH	-2.45	-2.31	F*0
140	21	H	1	77	SAN	TRH	-2.55	-2.36	F*0
141	21	H	8	77	SAI	TRH	-2.64	-2.47	F*0
142	21	H	27	77	SAI	TRH	-2.12	-2.08	F*0
143	21	H	1	78	MAN	TRH	-2.56	-2.46	F*0
144	21	H	16	78	SAI	TRH	-2.32	-2.27	F*0
145	21	H	17	78	SAI	TRH	-2.34	-2.31	F*0
146	21	H	22	78	SAN	TRH	-2.34	-2.27	F*0
147	21	H	23	78	SAI	TRH	-2.04	-2.02	F*0
148	21	H	27	78	SAI	TRH	-2.53	-2.35	F*0
149	21	H	29	78	SAI	TRH	-2.5	-2.36	F*0
150	21	H	32	78	MAI	TRH	-2.63	-2.52	F*0
151	21	H	14	79	SAN	TRH	-2.54	-2.48	F*0
152	21	H	20	79	SAN	TRH	-2.53	-2.37	F*0
153	21	H	26	79	MAI	TRH	-2.47	-2.34	F*0
154	21	H	25	80	MAN	TRH	-2.75	-2.65	F*0
155	21	H	31	80	SAI	TRH	-2.61	-2.49	F*0
156	21	H	5	81	SAN	TRH	-2.6	-2.41	F*0
157	21	H	25	81	SAN	TRH	-2.51	-2.41	F*0
158	21	H	16	82	SAN	TRH	-2.18	-2.09	F*0
159	21	H	22	82	SAN	TRH	-2.32	-2.25	F*0
160	21	H	23	82	MAI	TRH	-2.18	-2.13	F*0
161	21	H	1	83	SAN	TRH	-2.57	-2.42	F*0
162	21	H	6	93	SAN	TRH	-2.28	-2.21	F*0

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	21	H	3	3	SAD	1BH	-1.53	0	F*1
2	21	H	14	3	MAD	1BH	-1.63	0	F*1
3	21	H	6	4	SAD	1BH	-1.16	0	F*1
4	21	H	7	4	SAD	1BH	-1	0	F*1
5	21	H	3	5	SAD	1BH	-1.58	0	F*1
6	21	H	7	5	MAD	1BH	-1.16	0	F*1
7	21	H	3	6	SAN	1BH	-1.61	-1.57	F*1
8	21	H	7	7	SAN	1BH	-1.77	-1.71	F*1
9	21	H	17	7	MAD	1BH	-1.16	0	F*1
10	21	H	1	8	MAD	1BH	-1.31	0	F*1
11	21	H	2	8	SAN	1BH	-1.62	-1.58	F*1
12	21	H	13	8	MAD	1BH	-1.35	0	F*1
13	21	H	3	9	SAN	1BH	-1.63	-1.56	F*1
14	21	H	4	9	MAD	1BH	-1.48	0	F*1
15	21	H	5	9	SAD	1BH	-1.37	0	F*1
16	21	H	7	9	MAD	1BH	-1.22	0	F*1
17	21	H	11	9	MAD	1BH	-1.34	0	F*1
18	21	H	13	9	SAD	1BH	-1.27	0	F*1
19	21	H	18	9	MAD	1BH	-1.49	0	F*1
20	21	H	1	10	MAD	1BH	-1.39	0	F*1
21	21	H	4	10	SAD	1BH	-1.39	0	F*1
22	21	H	5	10	SAD	1BH	-1.1	0	F*1
23	21	H	12	10	SAD	1BH	-1.25	0	F*1
24	21	H	19	10	SAD	1BH	-1.05	0	F*1
25	21	H	20	10	SAD	1BH	-1.33	0	F*1
26	21	H	1	11	SAD	1BH	-1.48	0	F*1
27	21	H	2	11	SAD	1BH	-0.9	0	F*1
28	21	H	3	11	SAN	1BH	-1.67	-1.56	F*1
29	21	H	5	11	MAN	1BH	-1.23	-1.18	F*1
30	21	H	6	11	SAN	1BH	-1.41	-1.37	F*1
31	21	H	10	11	SAD	1BH	-1.14	0	F*1
32	21	H	13	11	SAD	1BH	-0.78	0	F*1
33	21	H	14	11	MAD	1BH	-1.12	0	F*1
34	21	H	15	11	MAD	1BH	-1.3	0	F*1
35	21	H	23	11	MAD	1BH	-1.5	0	F*1
36	21	H	24	11	MAD	1BH	-1.3	0	F*1
37	21	H	1	12	SAD	1BH	-1.32	0	F*1
38	21	H	2	12	SAN	1BH	-1.49	-1.44	F*1
39	21	H	4	12	SAD	1BH	-1.06	0	F*1
40	21	H	7	12	SAD	1BH	-1.07	0	F*1
41	21	H	9	12	SAD	1BH	-1.33	0	F*1
42	21	H	11	12	SAD	1BH	-1.06	0	F*1
43	21	H	14	12	MAN	1BH	-1.22	-1.05	F*1
44	21	H	22	12	SAD	1BH	-1.4	0	F*1
45	21	H	23	12	MAD	1BH	-1.43	0	F*1
46	21	H	2	13	MAN	1BH	-1.36	-0.96	F*1
47	21	H	4	13	SAN	1BH	-1.21	-1.13	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
48	21	H	5	13	SAN	1BH	-1.52	-1.44	F*1
49	21	H	8	13	MAD	1BH	-1.12	0	F*1
50	21	H	11	13	MAD	1BH	-1.33	0	F*1
51	21	H	13	13	SAD	1BH	-1.4	0	F*1
52	21	H	14	13	SAD	1BH	-1.33	0	F*1
53	21	H	15	13	MAD	1BH	-1.19	0	F*1
54	21	H	21	13	SAD	1BH	-1.24	0	F*1
55	21	H	2	14	SAI	1BH	-1.09	-1.03	F*1
56	21	H	4	14	MAD	1BH	-1.22	0	F*1
57	21	H	5	14	SAD	1BH	-2.14	0	F*1
58	21	H	7	14	SAN	1BH	-3.9	-3.81	F*1
59	21	H	9	14	MAD	1BH	-1.35	0	F*1
60	21	H	11	14	MAN	1BH	-1.27	-1.14	F*1
61	21	H	13	14	SAD	1BH	-1.17	0	F*1
62	21	H	15	14	MAD	1BH	-1.21	0	F*1
63	21	H	22	14	SAD	1BH	-1.17	0	F*1
64	21	H	23	14	SAD	1BH	-1.3	0	F*1
65	21	H	1	15	MAN	1BH	-1.04	-0.84	F*1
66	21	H	2	15	SAD	1BH	-1.38	0	F*1
67	21	H	4	15	MAD	1BH	-1.02	0	F*1
68	21	H	5	15	SAD	1BH	-1.17	0	F*1
69	21	H	8	15	SAD	1BH	-1.21	0	F*1
70	21	H	10	15	SAD	1BH	-1.37	0	F*1
71	21	H	11	15	SAD	1BH	-0.89	0	F*1
72	21	H	13	15	MAN	1BH	-1.32	-0.92	F*1
73	21	H	14	15	SAD	1BH	-1.26	0	F*1
74	21	H	15	15	SAD	1BH	-0.9	0	F*1
75	21	H	16	15	MAN	1BH	-1.25	-1.15	F*1
76	21	H	18	15	MAN	1BH	-1.23	-1.14	F*1
77	21	H	19	15	MAD	1BH	-1.21	0	F*1
78	21	H	22	15	SAD	1BH	-1.22	0	F*1
79	21	H	23	15	SAD	1BH	-1.18	0	F*1
80	21	H	26	15	SAD	1BH	-0.85	0	F*1
81	21	H	27	15	SAD	1BH	-1.31	0	F*1
82	21	H	1	16	SAD	1BH	-1.34	0	F*1
83	21	H	3	16	SAD	1BH	-1.16	0	F*1
84	21	H	4	16	MAN	1BH	-1.27	-1.15	F*1
85	21	H	5	16	SAN	1BH	-1.29	-1.1	F*1
86	21	H	7	16	SAD	1BH	-0.8	0	F*1
87	21	H	8	16	MAD	1BH	-1.2	0	F*1
88	21	H	10	16	SAD	1BH	-0.88	0	F*1
89	21	H	12	16	MAD	1BH	-1.23	0	F*1
90	21	H	13	16	MAD	1BH	-1.16	0	F*1
91	21	H	14	16	MAD	1BH	-1.35	0	F*1
92	21	H	17	16	SAD	1BH	-1.28	0	F*1
93	21	H	18	16	SAD	1BH	-1.24	0	F*1
94	21	H	24	16	MAD	1BH	-1.39	0	F*1



2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
95	21	H	26	16	MAD	1BH	-1.4	0	F*1
96	21	H	29	16	MAN	1BH	-1.16	-1.09	F*1
97	21	H	1	17	MAN	1BH	-1.17	-0.88	F*1
98	21	H	2	17	SAD	1BH	-1.4	0	F*1
99	21	H	6	17	SAD	1BH	-0.92	0	F*1
100	21	H	10	17	SAD	1BH	-1.37	0	F*1
101	21	H	11	17	SAD	1BH	-1.32	0	F*1
102	21	H	13	17	SAD	1BH	-1.31	0	F*1
103	21	H	19	17	SAD	1BH	-1.32	0	F*1
104	21	H	22	17	SAD	1BH	-1.35	0	F*1
105	21	H	25	17	SAN	1BH	-1.06	-0.94	F*1
106	21	H	1	18	MAD	1BH	-1.21	0	F*1
107	21	H	2	18	SAD	1BH	-0.89	0	F*1
108	21	H	3	18	SAN	1BH	-1.06	-0.95	F*1
109	21	H	4	18	MAN	1BH	-1.37	-1.14	F*1
110	21	H	5	18	MAN	1BH	-1.05	-0.85	F*1
111	21	H	10	18	MAD	1BH	-1.25	0	F*1
112	21	H	11	18	SAD	1BH	-1.4	0	F*1
113	21	H	13	18	SAD	1BH	-1.3	0	F*1
114	21	H	16	18	SAD	1BH	-1.44	0	F*1
115	21	H	18	18	MAD	1BH	-0.82	0	F*1
116	21	H	20	18	SAD	1BH	-0.85	0	F*1
117	21	H	22	18	SAD	1BH	-1.15	0	F*1
118	21	H	25	18	SAD	1BH	-2.11	0	F*1
119	21	H	31	18	SAD	1BH	-1.22	0	F*1
120	21	H	33	18	SAN	1BH	-1.04	-1.01	F*1
121	21	H	1	19	MAN	1BH	-1.16	-0.82	F*1
122	21	H	2	19	SAD	1BH	-1.39	0	F*1
123	21	H	4	19	SAD	1BH	-1.2	0	F*1
124	21	H	8	19	SAD	1BH	-1.32	0	F*1
125	21	H	9	19	MAD	1BH	-1.2	0	F*1
126	21	H	11	19	MAD	1BH	-1.37	0	F*1
127	21	H	12	19	MAD	1BH	-1.2	0	F*1
128	21	H	14	19	SAD	1BH	-0.85	0	F*1
129	21	H	15	19	SAN	1BH	-1.14	-1.08	F*1
130	21	H	16	19	SAD	1BH	-1.2	0	F*1
131	21	H	17	19	MAD	1BH	-0.86	0	F*1
132	21	H	19	19	MAN	1BH	-1.13	-1.04	F*1
133	21	H	20	19	SAD	1BH	-1.21	0	F*1
134	21	H	22	19	MAD	1BH	-0.93	0	F*1
135	21	H	23	19	SAD	1BH	-1.06	0	F*1
136	21	H	24	19	SAD	1BH	-0.9	0	F*1
137	21	H	25	19	MAD	1BH	-1.25	0	F*1
138	21	H	27	19	MAD	1BH	-1.1	0	F*1
139	21	H	30	19	SAD	1BH	-1.37	0	F*1
140	21	H	31	19	MAD	1BH	-1.3	0	F*1
141	21	H	32	19	SAD	1BH	-1.42	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
142	21	H	33	19	SAD	1BH	-1.38	0	F*1
143	21	H	4	20	SAD	1BH	-0.95	0	F*1
144	21	H	6	20	SAD	1BH	-0.9	0	F*1
145	21	H	7	20	MAN	1BH	-1.25	-1.1	F*1
146	21	H	9	20	SAD	1BH	-1.16	0	F*1
147	21	H	11	20	SAD	1BH	-1.06	0	F*1
148	21	H	13	20	MAN	1BH	-1.23	-1.04	F*1
149	21	H	16	20	SAD	1BH	-1.2	0	F*1
150	21	H	17	20	MAN	1BH	-1.2	-1.11	F*1
151	21	H	18	20	SAD	1BH	-1.29	0	F*1
152	21	H	19	20	SAD	1BH	-1.4	0	F*1
153	21	H	20	20	SAD	1BH	-1.23	0	F*1
154	21	H	23	20	MAD	1BH	-1.42	0	F*1
155	21	H	29	20	MAN	1BH	-1.14	-0.97	F*1
156	21	H	30	20	SAD	1BH	-1.4	0	F*1
157	21	H	34	20	SAD	1BH	-1.34	0	F*1
158	21	H	35	20	SAD	1BH	-1.27	0	F*1
159	21	H	36	20	MAD	1BH	-1.37	0	F*1
160	21	H	37	20	MAD	1BH	-1.35	0	F*1
161	21	H	6	21	MAN	1BH	-1.17	-1.1	F*1
162	21	H	8	21	SAD	1BH	-1.15	0	F*1
163	21	H	11	21	SAD	1BH	-1.21	0	F*1
164	21	H	12	21	MAD	1BH	-1.27	0	F*1
165	21	H	14	21	MAN	1BH	-0.56	-0.21	F*1
166	21	H	16	21	MAN	1BH	-1.18	-1.12	F*1
167	21	H	17	21	MAN	1BH	-1.16	-1.07	F*1
168	21	H	20	21	MAD	1BH	-0.88	0	F*1
169	21	H	23	21	MAD	1BH	-1.41	0	F*1
170	21	H	24	21	MAN	1BH	-1.12	-0.94	F*1
171	21	H	26	21	SAD	1BH	-1.25	0	F*1
172	21	H	27	21	SAD	1BH	-1.47	0	F*1
173	21	H	28	21	SAD	1BH	-0.85	0	F*1
174	21	H	30	21	SAD	1BH	-1.4	0	F*1
175	21	H	31	21	SAD	1BH	-1.27	0	F*1
176	21	H	33	21	SAD	1BH	-1.26	0	F*1
177	21	H	36	21	SAD	1BH	-1.25	0	F*1
178	21	H	1	22	MAN	1BH	-1.11	-0.99	F*1
179	21	H	2	22	MAN	1BH	-1.27	-1.13	F*1
180	21	H	4	22	MAN	1BH	-1.26	-1.16	F*1
181	21	H	5	22	SAD	1BH	-0.84	0	F*1
182	21	H	8	22	MAN	1BH	-1.26	-1.12	F*1
183	21	H	9	22	SAD	1BH	-1.16	0	F*1
184	21	H	10	22	SAD	1BH	-0.9	0	F*1
185	21	H	13	22	MAD	1BH	-1.2	0	F*1
186	21	H	14	22	MAN	1BH	-1.21	-1.11	F*1
187	21	H	17	22	MAN	1BH	-1.13	-1.02	F*1
188	21	H	18	22	SAD	1BH	-1.16	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
189	21	H	19	22	MAD	1BH	-1.2	0	F*1
190	21	H	20	22	SAD	1BH	-0.88	0	F*1
191	21	H	21	22	MAD	1BH	-1.31	0	F*1
192	21	H	24	22	MAD	1BH	-0.85	0	F*1
193	21	H	26	22	MAD	1BH	-0.87	0	F*1
194	21	H	28	22	SAD	1BH	-1.28	0	F*1
195	21	H	32	22	SAD	1BH	-1.39	0	F*1
196	21	H	37	22	MAD	1BH	-1.49	0	F*1
197	21	H	1	23	MAD	1BH	-1	0	F*1
198	21	H	3	23	MAN	1BH	-1.17	-0.89	F*1
199	21	H	5	23	MAD	1BH	-1.4	0	F*1
200	21	H	6	23	MAN	1BH	-1.19	-1.08	F*1
201	21	H	8	23	MAD	1BH	-1.3	0	F*1
202	21	H	9	23	MAN	1BH	-0.44	-0.25	F*1
203	21	H	10	23	SAD	1BH	-0.87	0	F*1
204	21	H	12	23	MAD	1BH	-1.21	0	F*1
205	21	H	14	23	MAN	1BH	-1.2	-1.05	F*1
206	21	H	16	23	MAN	1BH	-1.22	-1.11	F*1
207	21	H	17	23	MAD	1BH	-1.3	0	F*1
208	21	H	19	23	MAN	1BH	-1.18	-1.07	F*1
209	21	H	23	23	MAD	1BH	-1.22	0	F*1
210	21	H	24	23	MAD	1BH	-0.83	0	F*1
211	21	H	25	23	MAD	1BH	-0.78	0	F*1
212	21	H	27	23	SAD	1BH	-1.17	0	F*1
213	21	H	30	23	MAD	1BH	-0.97	0	F*1
214	21	H	31	23	SAD	1BH	-1.23	0	F*1
215	21	H	34	23	SAD	1BH	-1.17	0	F*1
216	21	H	37	23	SAD	1BH	-1.38	0	F*1
217	21	H	38	23	MAD	1BH	-1.29	0	F*1
218	21	H	39	23	MAD	1BH	-1.38	0	F*1
219	21	H	2	24	SAD	1BH	-1.35	0	F*1
220	21	H	4	24	MAD	1BH	-1.23	0	F*1
221	21	H	5	24	MAN	1BH	-1.28	-1.11	F*1
222	21	H	7	24	SAD	1BH	-1.32	0	F*1
223	21	H	8	24	SAD	1BH	-1.26	0	F*1
224	21	H	9	24	SAN	1BH	-1.14	-1.04	F*1
225	21	H	11	24	MAD	1BH	-1.16	0	F*1
226	21	H	12	24	MAN	1BH	-1.24	-1.12	F*1
227	21	H	15	24	SAD	1BH	-0.89	0	F*1
228	21	H	16	24	MAD	1BH	-1.2	0	F*1
229	21	H	19	24	MAD	1BH	-0.82	0	F*1
230	21	H	20	24	MAD	1BH	-1.34	0	F*1
231	21	H	25	24	SAD	1BH	-1.25	0	F*1
232	21	H	28	24	SAD	1BH	-0.93	0	F*1
233	21	H	29	24	SAD	1BH	-1.14	0	F*1
234	21	H	30	24	MAD	1BH	-1.31	0	F*1
235	21	H	35	24	SAD	1BH	-0.83	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
236	21	H	37	24	SAD	1BH	-1.32	0	F*1
237	21	H	5	25	SAD	1BH	-1.17	0	F*1
238	21	H	6	25	MAD	1BH	-1.2	0	F*1
239	21	H	7	25	SAD	1BH	-1.3	0	F*1
240	21	H	8	25	SAD	1BH	-1.49	0	F*1
241	21	H	9	25	SAD	1BH	-0.82	0	F*1
242	21	H	10	25	SAD	1BH	-1.29	0	F*1
243	21	H	14	25	MAD	1BH	-1.29	0	F*1
244	21	H	16	25	SAN	1BH	-1.22	-1.12	F*1
245	21	H	17	25	SAD	1BH	-1.21	0	F*1
246	21	H	20	25	MAD	1BH	-1.26	0	F*1
247	21	H	23	25	SAD	1BH	-1.21	0	F*1
248	21	H	25	25	MAD	1BH	-1.25	0	F*1
249	21	H	28	25	SAD	1BH	-1.06	0	F*1
250	21	H	30	25	MAD	1BH	-1.39	0	F*1
251	21	H	38	25	MAD	1BH	-0.89	0	F*1
252	21	H	1	26	SAD	1BH	-0.95	0	F*1
253	21	H	5	26	SAD	1BH	-1.27	0	F*1
254	21	H	7	26	MAD	1BH	-1.32	0	F*1
255	21	H	8	26	SAD	1BH	-1.25	0	F*1
256	21	H	10	26	MAD	1BH	-0.91	0	F*1
257	21	H	13	26	MAD	1BH	-1.27	0	F*1
258	21	H	15	26	MAD	1BH	-0.85	0	F*1
259	21	H	16	26	SAD	1BH	-1.26	0	F*1
260	21	H	17	26	SAN	1BH	-0.99	-0.93	F*1
261	21	H	19	26	MAD	1BH	-1.27	0	F*1
262	21	H	22	26	SAD	1BH	-1.22	0	F*1
263	21	H	25	26	SAD	1BH	-1.13	0	F*1
264	21	H	28	26	SAD	1BH	-0.93	0	F*1
265	21	H	34	26	SAD	1BH	-1.1	0	F*1
266	21	H	2	27	SAD	1BH	-1.2	0	F*1
267	21	H	3	27	SAD	1BH	-1.46	0	F*1
268	21	H	4	27	MAN	1BH	-0.72	-0.29	F*1
269	21	H	5	27	SAN	1BH	-1.68	-1.51	F*1
270	21	H	6	27	SAD	1BH	-0.87	0	F*1
271	21	H	8	27	SAN	1BH	-1.09	-1.01	F*1
272	21	H	9	27	SAD	1BH	-1.23	0	F*1
273	21	H	13	27	SAD	1BH	-1.28	0	F*1
274	21	H	16	27	SAD	1BH	-1.21	0	F*1
275	21	H	17	27	MAN	1BH	-1.34	-0.98	F*1
276	21	H	18	27	SAD	1BH	-1.33	0	F*1
277	21	H	26	27	MAD	1BH	-1.27	0	F*1
278	21	H	27	27	MAD	1BH	-1.3	0	F*1
279	21	H	31	27	MAD	1BH	-0.79	0	F*1
280	21	H	32	27	SAN	1BH	-1.14	-1	F*1
281	21	H	35	27	SAD	1BH	-1.06	0	F*1
282	21	H	36	27	MAD	1BH	-1.18	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
283	21	H	37	27	MAD	1BH	-0.9	0	F*1
284	21	H	1	28	MAN	1BH	-1.17	-0.96	F*1
285	21	H	3	28	MAN	1BH	-1.24	-1.11	F*1
286	21	H	5	28	MAN	1BH	-1.21	-1.09	F*1
287	21	H	6	28	SAD	1BH	-1.3	0	F*1
288	21	H	7	28	MAD	1BH	-1.17	0	F*1
289	21	H	8	28	SAD	1BH	-1.2	0	F*1
290	21	H	10	28	SAN	1BH	-1.36	-1.25	F*1
291	21	H	11	28	SAD	1BH	-0.77	0	F*1
292	21	H	15	28	SAN	1BH	-1.19	-1.13	F*1
293	21	H	16	28	MAN	1BH	-1.28	-1.11	F*1
294	21	H	17	28	MAD	1BH	-1.17	0	F*1
295	21	H	18	28	MAD	1BH	-1.23	0	F*1
296	21	H	19	28	MAN	1BH	-1.29	-0.85	F*1
297	21	H	20	28	SAD	1BH	-1.25	0	F*1
298	21	H	21	28	MAN	1BH	-1.36	-0.97	F*1
299	21	H	23	28	MAN	1BH	-1.31	-0.94	F*1
300	21	H	28	28	SAD	1BH	-1.18	0	F*1
301	21	H	30	28	SAD	1BH	-1.15	0	F*1
302	21	H	31	28	MAD	1BH	-1.19	0	F*1
303	21	H	32	28	SAD	1BH	-0.96	0	F*1
304	21	H	39	28	SAD	1BH	-1.32	0	F*1
305	21	H	5	29	SAD	1BH	-0.89	0	F*1
306	21	H	7	29	MAN	1BH	-1.11	-0.98	F*1
307	21	H	8	29	MAD	1BH	-1.27	0	F*1
308	21	H	9	29	SAD	1BH	-0.9	0	F*1
309	21	H	10	29	MAD	1BH	-1.31	0	F*1
310	21	H	16	29	MAN	1BH	-1.03	-0.82	F*1
311	21	H	18	29	MAN	1BH	-1.38	-0.95	F*1
312	21	H	19	29	MAD	1BH	-1.3	0	F*1
313	21	H	22	29	MAD	1BH	-1.09	0	F*1
314	21	H	23	29	MAD	1BH	-1.26	0	F*1
315	21	H	25	29	SAD	1BH	-1.26	0	F*1
316	21	H	26	29	SAD	1BH	-1.22	0	F*1
317	21	H	27	29	MAD	1BH	-1.27	0	F*1
318	21	H	28	29	MAD	1BH	-1.16	0	F*1
319	21	H	31	29	MAD	1BH	-1.29	0	F*1
320	21	H	35	29	SAD	1BH	-0.86	0	F*1
321	21	H	1	30	MAD	1BH	-1.42	0	F*1
322	21	H	3	30	MAD	1BH	-1.26	0	F*1
323	21	H	4	30	MAN	1BH	-0.49	-0.32	F*1
324	21	H	6	30	MAN	1BH	-1.34	-0.98	F*1
325	21	H	8	30	SAN	1BH	-1.26	-1.15	F*1
326	21	H	10	30	SAD	1BH	-1.12	0	F*1
327	21	H	21	30	MAD	1BH	-1.25	0	F*1
328	21	H	22	30	MAD	1BH	-1.2	0	F*1
329	21	H	26	30	SAD	1BH	-0.79	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
330	21	H	29	30	MAD	1BH	-0.88	0	F*1
331	21	H	31	30	MAD	1BH	-1.38	0	F*1
332	21	H	38	30	SAD	1BH	-1.13	0	F*1
333	21	H	1	31	SAD	1BH	-1.21	0	F*1
334	21	H	2	31	MAD	1BH	-1	0	F*1
335	21	H	3	31	MAN	1BH	-1.08	-1.02	F*1
336	21	H	4	31	MAN	1BH	-1.35	-0.94	F*1
337	21	H	5	31	SAD	1BH	-1.08	0	F*1
338	21	H	6	31	SAN	1BH	-1.05	-0.81	F*1
339	21	H	7	31	MAD	1BH	-1.41	0	F*1
340	21	H	10	31	SAD	1BH	-1.26	0	F*1
341	21	H	22	31	SAD	1BH	-1.27	0	F*1
342	21	H	26	31	SAD	1BH	-0.84	0	F*1
343	21	H	27	31	SAD	1BH	-1.29	0	F*1
344	21	H	32	31	SAD	1BH	-1.36	0	F*1
345	21	H	34	31	MAD	1BH	-0.82	0	F*1
346	21	H	35	31	SAD	1BH	-0.9	0	F*1
347	21	H	37	31	MAD	1BH	-1.23	0	F*1
348	21	H	1	32	MAN	1BH	-1.31	-1.13	F*1
349	21	H	3	32	MAD	1BH	-1.5	0	F*1
350	21	H	5	32	SAD	1BH	-1.45	0	F*1
351	21	H	6	32	MAN	1BH	-1.47	-0.98	F*1
352	21	H	7	32	MAD	1BH	-1.07	-1.02	F*1
353	21	H	8	32	SAD	1BH	-0.97	0	F*1
354	21	H	24	32	MAD	1BH	-1.29	0	F*1
355	21	H	25	32	SAD	1BH	-1.26	0	F*1
356	21	H	26	32	SAD	1BH	-1.18	0	F*1
357	21	H	27	32	SAD	1BH	-1.27	0	F*1
358	21	H	30	32	SAN	1BH	-1.27	-1.1	F*1
359	21	H	32	32	MAN	1BH	-1.18	-1.1	F*1
360	21	H	33	32	SAD	1BH	-1.26	0	F*1
361	21	H	36	32	MAD	1BH	-0.9	0	F*1
362	21	H	3	33	MAN	1BH	-1.29	-1.09	F*1
363	21	H	4	33	SAD	1BH	-1.3	0	F*1
364	21	H	7	33	MAN	1BH	-1.2	-1.1	F*1
365	21	H	8	33	MAN	1BH	-1.2	-1.04	F*1
366	21	H	11	33	SAD	1BH	-1.24	0	F*1
367	21	H	21	33	MAN	1BH	-1.2	-1.06	F*1
368	21	H	22	33	SAD	1BH	-1.27	0	F*1
369	21	H	23	33	SAD	1BH	-0.88	0	F*1
370	21	H	24	33	SAD	1BH	-1.31	0	F*1
371	21	H	27	33	MAN	1BH	-1.25	-1.12	F*1
372	21	H	33	33	MAD	1BH	-1.26	0	F*1
373	21	H	37	33	MAD	1BH	-1.38	0	F*1
374	21	H	2	34	SAD	1BH	-1.24	0	F*1
375	21	H	3	34	SAN	1BH	-0.95	-0.81	F*1
376	21	H	4	34	SAD	1BH	-1.14	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
377	21	H	7	34	SAD	1BH	-1.42	0	F*1
378	21	H	8	34	MAN	1BH	-1.18	-1.03	F*1
379	21	H	10	34	MAN	1BH	-1.24	-0.96	F*1
380	21	H	27	34	SAD	1BH	-0.87	0	F*1
381	21	H	28	34	SAD	1BH	-0.88	0	F*1
382	21	H	29	34	MAD	1BH	-1.22	0	F*1
383	21	H	33	34	SAD	1BH	-1.26	0	F*1
384	21	H	34	34	MAN	1BH	-1.28	-1.13	F*1
385	21	H	36	34	SAD	1BH	-0.98	0	F*1
386	21	H	37	34	MAD	1BH	-1.38	0	F*1
387	21	H	41	34	MAD	1BH	-1.22	0	F*1
388	21	H	2	35	SAN	1BH	-1.28	-1.21	F*1
389	21	H	4	35	MAD	1BH	-0.95	0	F*1
390	21	H	5	35	MAD	1BH	-1.18	0	F*1
391	21	H	8	35	MAN	1BH	-1.18	-1.06	F*1
392	21	H	11	35	SAD	1BH	-1.28	0	F*1
393	21	H	12	35	SAD	1BH	-1.29	0	F*1
394	21	H	13	35	MAN	1BH	-1.14	-1.08	F*1
395	21	H	21	35	MAD	1BH	-1.21	0	F*1
396	21	H	24	35	SAD	1BH	-1.25	0	F*1
397	21	H	27	35	MAD	1BH	-1.2	0	F*1
398	21	H	29	35	SAD	1BH	-1.29	0	F*1
399	21	H	30	35	SAD	1BH	-1.31	0	F*1
400	21	H	31	35	SAD	1BH	-1.36	0	F*1
401	21	H	37	35	SAD	1BH	-1.45	0	F*1
402	21	H	3	36	SAD	1BH	-1.3	0	F*1
403	21	H	4	36	MAD	1BH	-1.27	0	F*1
404	21	H	6	36	MAN	1BH	-1.22	-1.04	F*1
405	21	H	9	36	SAD	1BH	-1.42	0	F*1
406	21	H	10	36	SAD	1BH	-1.35	0	F*1
407	21	H	12	36	SAD	1BH	-1.55	0	F*1
408	21	H	20	36	MAN	1BH	-1.16	-1.01	F*1
409	21	H	22	36	SAN	1BH	-1.18	-1.05	F*1
410	21	H	23	36	MAD	1BH	-1.3	0	F*1
411	21	H	25	36	SAD	1BH	-1.4	0	F*1
412	21	H	27	36	SAD	1BH	-1.26	0	F*1
413	21	H	29	36	SAD	1BH	-1.31	0	F*1
414	21	H	35	36	MAD	1BH	-0.86	0	F*1
415	21	H	36	36	SAD	1BH	-0.9	0	F*1
416	21	H	38	36	MAD	1BH	-1.22	0	F*1
417	21	H	4	37	SAD	1BH	-1.33	0	F*1
418	21	H	6	37	MAN	1BH	-1.13	-1	F*1
419	21	H	8	37	MAN	1BH	-0.94	-0.85	F*1
420	21	H	9	37	SAD	1BH	-0.9	0	F*1
421	21	H	10	37	SAD	1BH	-0.9	0	F*1
422	21	H	13	37	MAN	1BH	-1.16	-1.03	F*1
423	21	H	21	37	SAN	1BH	-1.12	-0.98	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
424	21	H	22	37	SAD	1BH	-0.8	0	F*1
425	21	H	25	37	SAD	1BH	-1.2	0	F*1
426	21	H	27	37	MAD	1BH	-1.25	0	F*1
427	21	H	28	37	MAD	1BH	-0.84	0	F*1
428	21	H	32	37	SAD	1BH	-1.2	0	F*1
429	21	H	33	37	SAD	1BH	-0.88	0	F*1
430	21	H	34	37	SAD	1BH	-1.24	0	F*1
431	21	H	36	37	MAD	1BH	-1.27	0	F*1
432	21	H	1	38	MAD	1BH	-1.25	0	F*1
433	21	H	3	38	MAN	1BH	-1.13	-1	F*1
434	21	H	5	38	SAD	1BH	-1.35	0	F*1
435	21	H	7	38	MAN	1BH	-1.16	-1.06	F*1
436	21	H	8	38	MAD	1BH	-0.93	0	F*1
437	21	H	9	38	MAN	1BH	-1.22	-1.04	F*1
438	21	H	12	38	SAD	1BH	-1.5	0	F*1
439	21	H	13	38	SAN	1BH	-1.15	-1	F*1
440	21	H	23	38	MAD	1BH	-0.91	0	F*1
441	21	H	24	38	SAD	1BH	-1.18	0	F*1
442	21	H	30	38	MAD	1BH	-1.11	0	F*1
443	21	H	31	38	SAD	1BH	-1.25	0	F*1
444	21	H	32	38	SAD	1BH	-1.4	0	F*1
445	21	H	35	38	MAD	1BH	-1.26	0	F*1
446	21	H	37	38	MAD	1BH	-1.22	0	F*1
447	21	H	2	39	SAD	1BH	-1.36	0	F*1
448	21	H	4	39	MAN	1BH	-1.33	-0.93	F*1
449	21	H	7	39	SAD	1BH	-1.35	0	F*1
450	21	H	9	39	SAD	1BH	-1.24	0	F*1
451	21	H	12	39	SAN	1BH	-1.13	-1.02	F*1
452	21	H	15	39	SAD	1BH	-0.91	0	F*1
453	21	H	19	39	SAD	1BH	-1.29	0	F*1
454	21	H	20	39	SAN	1BH	-1.27	-1.14	F*1
455	21	H	21	39	SAN	1BH	-1.2	-1.11	F*1
456	21	H	22	39	SAD	1BH	-1.28	0	F*1
457	21	H	24	39	SAD	1BH	-1.13	0	F*1
458	21	H	25	39	MAN	1BH	-1.17	-1.06	F*1
459	21	H	26	39	SAD	1BH	-1.22	0	F*1
460	21	H	30	39	MAD	1BH	-1.17	0	F*1
461	21	H	32	39	MAD	1BH	-1.23	0	F*1
462	21	H	33	39	SAD	1BH	-1.19	0	F*1
463	21	H	35	39	SAD	1BH	-1.13	0	F*1
464	21	H	36	39	SAD	1BH	-1.43	0	F*1
465	21	H	2	40	SAD	1BH	-1.36	0	F*1
466	21	H	3	40	MAD	1BH	-1.26	0	F*1
467	21	H	6	40	MAD	1BH	-1.3	0	F*1
468	21	H	9	40	SAD	1BH	-1.27	0	F*1
469	21	H	10	40	MAN	1BH	-1.26	-1.15	F*1
470	21	H	12	40	MAD	1BH	-1.3	0	F*1



2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
471	21	H	13	40	MAD	1BH	-1.56	0	F*1
472	21	H	21	40	MAD	1BH	-1.26	0	F*1
473	21	H	26	40	MAD	1BH	-1.28	0	F*1
474	21	H	29	40	SAD	1BH	-1.3	0	F*1
475	21	H	30	40	SAD	1BH	-0.8	0	F*1
476	21	H	32	40	MAD	1BH	-1.23	0	F*1
477	21	H	33	40	SAD	1BH	-1.2	0	F*1
478	21	H	37	40	MAD	1BH	-1.14	0	F*1
479	21	H	1	41	SAD	1BH	-1.3	0	F*1
480	21	H	2	41	SAD	1BH	-0.93	0	F*1
481	21	H	3	41	SAD	1BH	-1.31	0	F*1
482	21	H	4	41	MAN	1BH	-1.35	-0.91	F*1
483	21	H	5	41	MAN	1BH	-0.99	-0.9	F*1
484	21	H	7	41	MAN	1BH	-1.15	-1.06	F*1
485	21	H	8	41	MAD	1BH	-1.27	0	F*1
486	21	H	11	41	SAD	1BH	-1.37	0	F*1
487	21	H	12	41	MAN	1BH	-1.19	-1.06	F*1
488	21	H	14	41	MAN	1BH	-0.88	-0.1	F*1
489	21	H	23	41	SAD	1BH	-0.98	0	F*1
490	21	H	28	41	SAD	1BH	-1.29	0	F*1
491	21	H	1	42	SAD	1BH	-1.36	0	F*1
492	21	H	3	42	MAD	1BH	-1.22	0	F*1
493	21	H	4	42	SAD	1BH	-1.3	0	F*1
494	21	H	5	42	MAD	1BH	-0.92	0	F*1
495	21	H	8	42	MAD	1BH	-1.23	0	F*1
496	21	H	10	42	SAD	1BH	-1.28	0	F*1
497	21	H	12	42	MAD	1BH	-1.17	0	F*1
498	21	H	15	42	MAN	1BH	-1.11	-1.02	F*1
499	21	H	16	42	SAD	1BH	-1.31	0	F*1
500	21	H	17	42	SAD	1BH	-0.8	0	F*1
501	21	H	20	42	SAD	1BH	-1.3	0	F*1
502	21	H	21	42	SAN	1BH	-0.42	-0.26	F*1
503	21	H	24	42	SAD	1BH	-1.25	0	F*1
504	21	H	25	42	SAD	1BH	-0.85	0	F*1
505	21	H	28	42	SAD	1BH	-1.05	0	F*1
506	21	H	36	42	MAD	1BH	-1.37	0	F*1
507	21	H	5	43	SAN	1BH	-1.24	-1.18	F*1
508	21	H	7	43	MAN	1BH	-1.21	-1.09	F*1
509	21	H	8	43	SAN	1BH	-1.28	-1.15	F*1
510	21	H	9	43	MAN	1BH	-1.28	-1.05	F*1
511	21	H	12	43	SAN	1BH	-0.93	-0.89	F*1
512	21	H	21	43	SAD	1BH	-1.23	0	F*1
513	21	H	23	43	MAN	1BH	-1.24	-1.08	F*1
514	21	H	24	43	MAN	1BH	-1.5	-0.82	F*1
515	21	H	30	43	SAD	1BH	-0.8	0	F*1
516	21	H	32	43	SAD	1BH	-1.1	0	F*1
517	21	H	35	43	SAD	1BH	-1.18	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
518	21	H	1	44	MAD	1BH	-1.32	0	F*1
519	21	H	3	44	SAD	1BH	-1.3	0	F*1
520	21	H	4	44	MAD	1BH	-1.25	0	F*1
521	21	H	6	44	SAD	1BH	-1.3	0	F*1
522	21	H	8	44	SAD	1BH	-0.9	0	F*1
523	21	H	12	44	MAD	1BH	-0.95	0	F*1
524	21	H	13	44	SAD	1BH	-0.93	0	F*1
525	21	H	21	44	SAD	1BH	-1.3	0	F*1
526	21	H	22	44	SAD	1BH	-0.9	0	F*1
527	21	H	24	44	MAN	1BH	-1.34	-1.08	F*1
528	21	H	1	45	SAD	1BH	-1.36	0	F*1
529	21	H	3	45	MAN	1BH	-1.34	-0.83	F*1
530	21	H	6	45	SAD	1BH	-1.18	0	F*1
531	21	H	9	45	MAN	1BH	-1.06	-0.82	F*1
532	21	H	10	45	MAD	1BH	-0.89	0	F*1
533	21	H	13	45	MAN	1BH	-1.34	-0.75	F*1
534	21	H	14	45	SAN	1BH	-0.88	-0.82	F*1
535	21	H	16	45	SAD	1BH	-1.3	0	F*1
536	21	H	18	45	MAD	1BH	-1.23	0	F*1
537	21	H	21	45	MAD	1BH	-1.22	0	F*1
538	21	H	23	45	SAD	1BH	-1.33	0	F*1
539	21	H	32	45	MAD	1BH	-1.26	0	F*1
540	21	H	34	45	SAD	1BH	-1.07	0	F*1
541	21	H	4	46	MAN	1BH	-1.26	-1.17	F*1
542	21	H	5	46	SAD	1BH	-1.35	0	F*1
543	21	H	6	46	MAD	1BH	-1.55	0	F*1
544	21	H	7	46	SAD	1BH	-1.43	0	F*1
545	21	H	8	46	MAN	1BH	-1.32	-1.13	F*1
546	21	H	10	46	MAD	1BH	-1.49	0	F*1
547	21	H	14	46	MAN	1BH	-1.09	-0.86	F*1
548	21	H	15	46	SAD	1BH	-0.93	0	F*1
549	21	H	16	46	MAD	1BH	-1.36	0	F*1
550	21	H	17	46	SAD	1BH	-1.25	0	F*1
551	21	H	18	46	SAD	1BH	-1.24	0	F*1
552	21	H	19	46	SAD	1BH	-1.18	0	F*1
553	21	H	21	46	SAD	1BH	-1.25	0	F*1
554	21	H	22	46	MAN	1BH	-0.34	-0.04	F*1
555	21	H	24	46	MAN	1BH	-0.7	-0.13	F*1
556	21	H	27	46	SAD	1BH	-0.85	0	F*1
557	21	H	28	46	MAD	1BH	-1.28	0	F*1
558	21	H	34	46	MAD	1BH	-1.27	0	F*1
559	21	H	3	47	MAD	1BH	-1.41	0	F*1
560	21	H	4	47	MAN	1BH	-1.27	-1.1	F*1
561	21	H	8	47	SAN	1BH	-1.1	-1.03	F*1
562	21	H	9	47	SAD	1BH	-0.75	0	F*1
563	21	H	11	47	MAD	1BH	-1.18	0	F*1
564	21	H	12	47	SAN	1BH	-0.86	-0.73	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
565	21	H	13	47	MAN	1BH	-1.31	-1.01	F*1
566	21	H	19	47	MAD	1BH	-1.28	0	F*1
567	21	H	22	47	MAD	1BH	-1.27	0	F*1
568	21	H	23	47	MAD	1BH	-1.19	0	F*1
569	21	H	24	47	MAD	1BH	-1.32	0	F*1
570	21	H	26	47	SAD	1BH	-1.25	0	F*1
571	21	H	27	47	SAD	1BH	-1.47	0	F*1
572	21	H	31	47	SAD	1BH	-1.31	0	F*1
573	21	H	34	47	SAD	1BH	-1.2	0	F*1
574	21	H	36	47	MAD	1BH	-1.1	0	F*1
575	21	H	37	47	SAD	1BH	-1.6	0	F*1
576	21	H	1	48	SAD	1BH	-1.29	0	F*1
577	21	H	3	48	SAD	1BH	-1.34	0	F*1
578	21	H	4	48	MAN	1BH	-1.22	-0.9	F*1
579	21	H	5	48	SAD	1BH	-1.36	0	F*1
580	21	H	6	48	SAN	1BH	-1.07	-0.99	F*1
581	21	H	9	48	SAD	1BH	-1.36	0	F*1
582	21	H	11	48	MAD	1BH	-1.41	0	F*1
583	21	H	12	48	MAD	1BH	-1.31	0	F*1
584	21	H	16	48	SAD	1BH	-0.89	0	F*1
585	21	H	18	48	MAN	1BH	-0.45	-0.26	F*1
586	21	H	20	48	MAD	1BH	-1.24	0	F*1
587	21	H	22	48	MAD	1BH	-1.15	0	F*1
588	21	H	23	48	MAD	1BH	-1.31	0	F*1
589	21	H	30	48	MAD	1BH	-1.16	0	F*1
590	21	H	1	49	MAD	1BH	-0.91	0	F*1
591	21	H	3	49	SAD	1BH	-1.36	0	F*1
592	21	H	4	49	MAD	1BH	-1.39	0	F*1
593	21	H	7	49	MAD	1BH	-1.39	0	F*1
594	21	H	11	49	MAD	1BH	-1.36	0	F*1
595	21	H	12	49	MAN	1BH	-0.25	-0.16	F*1
596	21	H	13	49	MAN	1BH	-1.31	-1.01	F*1
597	21	H	14	49	SAN	1BH	-0.65	-0.49	F*1
598	21	H	23	49	SAD	1BH	-0.88	0	F*1
599	21	H	24	49	SAD	1BH	-0.87	0	F*1
600	21	H	28	49	SAD	1BH	-1.33	0	F*1
601	21	H	29	49	MAD	1BH	-1.26	0	F*1
602	21	H	31	49	SAD	1BH	-1.26	0	F*1
603	21	H	36	49	SAD	1BH	-1.26	0	F*1
604	21	H	2	50	MAN	1BH	-1.35	-0.88	F*1
605	21	H	3	50	SAD	1BH	-0.9	0	F*1
606	21	H	4	50	MAN	1BH	-1.34	-1.12	F*1
607	21	H	5	50	MAN	1BH	-1.31	-1.15	F*1
608	21	H	6	50	SAN	1BH	-1.41	-1.38	F*1
609	21	H	7	50	MAN	1BH	-0.98	-0.85	F*1
610	21	H	8	50	MAD	1BH	-0.93	0	F*1
611	21	H	10	50	MAN	1BH	-1.28	-1.15	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
612	21	H	12	50	MAN	1BH	-0.58	-0.38	F*1
613	21	H	18	50	MAD	1BH	-1.21	0	F*1
614	21	H	19	50	MAD	1BH	-0.9	0	F*1
615	21	H	20	50	SAD	1BH	-1.25	0	F*1
616	21	H	21	50	SAD	1BH	-1.3	0	F*1
617	21	H	22	50	SAD	1BH	-1.27	0	F*1
618	21	H	24	50	MAN	1BH	-0.62	-0.24	F*1
619	21	H	25	50	SAD	1BH	-1.26	0	F*1
620	21	H	28	50	SAD	1BH	-1.27	0	F*1
621	21	H	37	50	SAD	1BH	-0.9	0	F*1
622	21	H	1	51	SAN	1BH	-1.06	-0.97	F*1
623	21	H	2	51	SAD	1BH	-1.37	0	F*1
624	21	H	4	51	MAN	1BH	-1.15	-1.08	F*1
625	21	H	5	51	MAN	1BH	-1.2	-0.95	F*1
626	21	H	6	51	MAD	1BH	-1.27	0	F*1
627	21	H	8	51	MAN	1BH	-1.34	-0.86	F*1
628	21	H	11	51	SAD	1BH	-1.75	0	F*1
629	21	H	12	51	MAD	1BH	-1.3	0	F*1
630	21	H	13	51	SAD	1BH	-1.41	0	F*1
631	21	H	14	51	SAI	1BH	-0.37	-0.28	F*1
632	21	H	15	51	SAD	1BH	-1.28	0	F*1
633	21	H	16	51	MAD	1BH	-1.28	0	F*1
634	21	H	18	51	MAD	1BH	-1.3	0	F*1
635	21	H	19	51	SAD	1BH	-1.21	0	F*1
636	21	H	23	51	MAD	1BH	-0.88	0	F*1
637	21	H	26	51	SAD	1BH	-1.34	0	F*1
638	21	H	29	51	MAD	1BH	-1.3	0	F*1
639	21	H	32	51	MAD	1BH	-1.23	0	F*1
640	21	H	34	51	MAD	1BH	-0.84	0	F*1
641	21	H	35	51	SAD	1BH	-0.86	0	F*1
642	21	H	37	51	MAD	1BH	-1.31	0	F*1
643	21	H	38	51	SAN	1BH	-1.38	-1.27	F*1
644	21	H	1	52	SAN	1BH	-1.14	-1.11	F*1
645	21	H	2	52	MAN	1BH	-1.4	-0.96	F*1
646	21	H	3	52	MAN	1BH	-1.2	-1.11	F*1
647	21	H	4	52	MAN	1BH	-1.2	-1.07	F*1
648	21	H	5	52	MAD	1BH	-1.38	0	F*1
649	21	H	7	52	SAD	1BH	-1.31	0	F*1
650	21	H	9	52	SAD	1BH	-1.34	0	F*1
651	21	H	10	52	SAD	1BH	-1.36	0	F*1
652	21	H	11	52	SAD	1BH	-1.34	0	F*1
653	21	H	13	52	SAD	1BH	-1.65	0	F*1
654	21	H	15	52	MAD	1BH	-1.31	0	F*1
655	21	H	16	52	SAD	1BH	-0.88	0	F*1
656	21	H	18	52	SAD	1BH	-0.9	0	F*1
657	21	H	19	52	MAD	1BH	-1.33	0	F*1
658	21	H	20	52	MAD	1BH	-0.89	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
659	21	H	22	52	SAD	1BH	-1.27	0	F*1
660	21	H	25	52	SAD	1BH	-1.36	0	F*1
661	21	H	30	52	MAD	1BH	-1.34	0	F*1
662	21	H	33	52	SAD	1BH	-1.25	0	F*1
663	21	H	35	52	SAD	1BH	-0.9	0	F*1
664	21	H	1	53	MAN	1BH	-1.47	-1.43	F*1
665	21	H	2	53	SAD	1BH	-0.93	0	F*1
666	21	H	3	53	MAD	1BH	-1.4	0	F*1
667	21	H	4	53	SAN	1BH	-1.32	-1.19	F*1
668	21	H	7	53	MAN	1BH	-0.68	-0.38	F*1
669	21	H	10	53	SAN	1BH	-1.14	-1	F*1
670	21	H	11	53	SAD	1BH	-1.42	0	F*1
671	21	H	12	53	SAD	1BH	-1.23	0	F*1
672	21	H	13	53	MAD	1BH	-1.33	0	F*1
673	21	H	14	53	MAD	1BH	-1.5	0	F*1
674	21	H	18	53	SAD	1BH	-1.1	0	F*1
675	21	H	20	53	SAD	1BH	-1.3	0	F*1
676	21	H	21	53	SAD	1BH	-0.95	0	F*1
677	21	H	22	53	SAD	1BH	-0.85	0	F*1
678	21	H	27	53	MAD	1BH	-0.88	0	F*1
679	21	H	35	53	SAD	1BH	-0.84	0	F*1
680	21	H	1	54	SAN	1BH	-1.21	-1.14	F*1
681	21	H	2	54	SAD	1BH	-1.48	0	F*1
682	21	H	7	54	MAN	1BH	-1.26	-1.09	F*1
683	21	H	10	54	SAD	1BH	-0.92	0	F*1
684	21	H	13	54	MAD	1BH	-1.38	0	F*1
685	21	H	14	54	SAD	1BH	-1.37	0	F*1
686	21	H	17	54	MAD	1BH	-1.16	0	F*1
687	21	H	18	54	SAD	1BH	-1.21	0	F*1
688	21	H	19	54	MAN	1BH	-1.26	-1.13	F*1
689	21	H	20	54	SAD	1BH	-1.32	0	F*1
690	21	H	27	54	SAD	1BH	-1.31	0	F*1
691	21	H	29	54	MAD	1BH	-1.32	0	F*1
692	21	H	34	54	SAD	1BH	-1.29	0	F*1
693	21	H	7	55	SAD	1BH	-1.58	0	F*1
694	21	H	10	55	MAN	1BH	-1.29	-1.05	F*1
695	21	H	12	55	SAD	1BH	-1.4	0	F*1
696	21	H	15	55	MAD	1BH	-1.33	0	F*1
697	21	H	17	55	SAD	1BH	-1.23	0	F*1
698	21	H	18	55	MAD	1BH	-0.85	0	F*1
699	21	H	22	55	SAN	1BH	-1.26	-1.2	F*1
700	21	H	23	55	MAD	1BH	-1.19	0	F*1
701	21	H	27	55	SAD	1BH	-1.26	0	F*1
702	21	H	29	55	SAD	1BH	-1.3	0	F*1
703	21	H	31	55	SAD	1BH	-0.85	0	F*1
704	21	H	33	55	SAD	1BH	-0.9	0	F*1
705	21	H	2	56	MAN	1BH	-0.41	-0.24	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
706	21	H	4	56	MAD	1BH	-1.54	0	F*1
707	21	H	6	56	MAN	1BH	-1.16	-1.04	F*1
708	21	H	9	56	MAD	1BH	-1.27	0	F*1
709	21	H	10	56	MAN	1BH	-1.29	-0.91	F*1
710	21	H	13	56	SAD	1BH	-0.85	0	F*1
711	21	H	14	56	SAD	1BH	-1.46	0	F*1
712	21	H	18	56	SAD	1BH	-1.35	0	F*1
713	21	H	20	56	SAD	1BH	-1.28	0	F*1
714	21	H	22	56	SAD	1BH	-1.35	0	F*1
715	21	H	27	56	SAD	1BH	-0.88	0	F*1
716	21	H	29	56	SAD	1BH	-1.31	0	F*1
717	21	H	34	56	MAD	1BH	-0.85	0	F*1
718	21	H	2	57	MAD	1BH	-1.43	0	F*1
719	21	H	3	57	MAD	1BH	-1.29	0	F*1
720	21	H	4	57	SAD	1BH	-1.28	0	F*1
721	21	H	5	57	SAD	1BH	-1.5	0	F*1
722	21	H	6	57	MAN	1BH	-1.2	-1.01	F*1
723	21	H	7	57	MAD	1BH	-1.36	0	F*1
724	21	H	8	57	MAN	1BH	-0.72	-0.02	F*1
725	21	H	12	57	MAD	1BH	-1.38	0	F*1
726	21	H	13	57	MAN	1BH	-1.22	-0.76	F*1
727	21	H	14	57	SAD	1BH	-1.3	0	F*1
728	21	H	15	57	MAD	1BH	-1.37	0	F*1
729	21	H	17	57	SAD	1BH	-1.3	0	F*1
730	21	H	18	57	MAD	1BH	-1.3	0	F*1
731	21	H	19	57	SAD	1BH	-1.28	0	F*1
732	21	H	21	57	MAD	1BH	-0.87	0	F*1
733	21	H	23	57	MAN	1BH	-1.17	-0.96	F*1
734	21	H	25	57	SAD	1BH	-1.31	0	F*1
735	21	H	27	57	SAD	1BH	-1.11	0	F*1
736	21	H	2	58	SAD	1BH	-1.39	0	F*1
737	21	H	3	58	SAD	1BH	-1	0	F*1
738	21	H	4	58	MAD	1BH	-1.41	0	F*1
739	21	H	11	58	SAD	1BH	-1.2	0	F*1
740	21	H	14	58	MAN	1BH	-1.17	-1.1	F*1
741	21	H	16	58	MAN	1BH	-1.31	-0.85	F*1
742	21	H	17	58	SAD	1BH	-1.28	0	F*1
743	21	H	18	58	SAD	1BH	-1.32	0	F*1
744	21	H	21	58	MAN	1BH	-1.36	-1.02	F*1
745	21	H	23	58	SAD	1BH	-1.32	0	F*1
746	21	H	31	58	MAN	1BH	-1.44	-1.3	F*1
747	21	H	3	59	SAD	1BH	-1.29	0	F*1
748	21	H	6	59	MAD	1BH	-1.38	0	F*1
749	21	H	8	59	MAN	1BH	-1.35	-0.96	F*1
750	21	H	9	59	MAD	1BH	-1.39	0	F*1
751	21	H	10	59	MAN	1BH	-1.13	-1.01	F*1
752	21	H	11	59	MAN	1BH	-1.33	-1.01	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
753	21	H	12	59	MAD	1BH	-1.44	0	F*1
754	21	H	13	59	MAN	1BH	-1.28	-0.96	F*1
755	21	H	14	59	MAN	1BH	-1.39	-1.25	F*1
756	21	H	17	59	SAD	1BH	-1.32	0	F*1
757	21	H	19	59	MAN	1BH	-1.31	-1.24	F*1
758	21	H	21	59	SAD	1BH	-1.28	0	F*1
759	21	H	26	59	SAD	1BH	-1.23	0	F*1
760	21	H	27	59	SAD	1BH	-0.96	0	F*1
761	21	H	28	59	SAD	1BH	-1.2	0	F*1
762	21	H	31	59	MAD	1BH	-1.34	0	F*1
763	21	H	33	59	SAD	1BH	-1.39	0	F*1
764	21	H	3	60	MAN	1BH	-1.29	-1.18	F*1
765	21	H	7	60	SAN	1BH	-1.18	-0.99	F*1
766	21	H	9	60	MAD	1BH	-1.23	0	F*1
767	21	H	14	60	MAN	1BH	-1.19	-1.04	F*1
768	21	H	16	60	MAN	1BH	-1.15	-1	F*1
769	21	H	17	60	MAD	1BH	-1.34	0	F*1
770	21	H	18	60	SAN	1BH	-1.3	-1.21	F*1
771	21	H	19	60	SAD	1BH	-1.3	0	F*1
772	21	H	23	60	MAD	1BH	-1.29	0	F*1
773	21	H	24	60	SAD	1BH	-0.93	0	F*1
774	21	H	25	60	MAD	1BH	-0.98	0	F*1
775	21	H	29	60	MAD	1BH	-1.27	0	F*1
776	21	H	36	60	SAD	1BH	-1.3	0	F*1
777	21	H	37	60	SAD	1BH	-1.26	0	F*1
778	21	H	2	61	MAN	1BH	-1.32	-1.07	F*1
779	21	H	3	61	MAN	1BH	-1.39	-1.29	F*1
780	21	H	4	61	SAD	1BH	-1.26	0	F*1
781	21	H	5	61	MAN	1BH	-1.29	-1.14	F*1
782	21	H	6	61	MAD	1BH	-1.95	0	F*1
783	21	H	9	61	MAN	1BH	-1.2	-1.1	F*1
784	21	H	10	61	MAN	1BH	-1.21	-1.09	F*1
785	21	H	13	61	MAN	1BH	-0.55	-0.21	F*1
786	21	H	17	61	MAN	1BH	-1.23	-1.13	F*1
787	21	H	19	61	SAD	1BH	-1.32	0	F*1
788	21	H	23	61	SAD	1BH	-1.35	0	F*1
789	21	H	24	61	SAD	1BH	-1.32	0	F*1
790	21	H	31	61	SAD	1BH	-3.5	0	F*1
791	21	H	33	61	MAD	1BH	-1.42	0	F*1
792	21	H	34	61	MAD	1BH	-1.3	0	F*1
793	21	H	37	61	SAD	1BH	-1.33	0	F*1
794	21	H	1	62	SAD	1BH	-1.41	0	F*1
795	21	H	2	62	MAN	1BH	-1.12	-1.02	F*1
796	21	H	3	62	SAD	1BH	-1.36	0	F*1
797	21	H	5	62	MAN	1BH	-1.22	-1.11	F*1
798	21	H	6	62	SAD	1BH	-1.47	0	F*1
799	21	H	8	62	MAN	1BH	-1.24	-1.16	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
800	21	H	12	62	SAN	1BH	-1.25	-1.15	F*1
801	21	H	13	62	MAD	1BH	-1.34	0	F*1
802	21	H	14	62	MAN	1BH	-1.28	-1.06	F*1
803	21	H	17	62	MAD	1BH	-1.42	0	F*1
804	21	H	21	62	SAD	1BH	-1.1	0	F*1
805	21	H	27	62	MAD	1BH	-0.83	0	F*1
806	21	H	35	62	MAD	1BH	-1.35	0	F*1
807	21	H	36	62	SAD	1BH	-1.35	0	F*1
808	21	H	37	62	SAD	1BH	-0.9	0	F*1
809	21	H	38	62	SAD	1BH	-1.32	0	F*1
810	21	H	3	63	MAN	1BH	-1.17	-0.97	F*1
811	21	H	5	63	MAN	1BH	-1.22	-1.09	F*1
812	21	H	7	63	SAD	1BH	-1.4	0	F*1
813	21	H	9	63	SAD	1BH	-1.34	0	F*1
814	21	H	11	63	SAD	1BH	-1.39	0	F*1
815	21	H	14	63	MAD	1BH	-1.37	0	F*1
816	21	H	15	63	SAD	1BH	-1.21	0	F*1
817	21	H	16	63	SAD	1BH	-1.33	0	F*1
818	21	H	18	63	SAD	1BH	-0.89	0	F*1
819	21	H	19	63	MAN	1BH	-0.69	-0.16	F*1
820	21	H	25	63	MAD	1BH	-1.3	0	F*1
821	21	H	28	63	MAD	1BH	-1.3	0	F*1
822	21	H	34	63	MAI	1BH	-0.55	-0.18	F*1
823	21	H	36	63	SAD	1BH	-0.89	0	F*1
824	21	H	37	63	MAD	1BH	-1.38	0	F*1
825	21	H	1	64	SAD	1BH	-1.35	0	F*1
826	21	H	3	64	SAN	1BH	-1.18	-1.11	F*1
827	21	H	4	64	MAN	1BH	-1.19	-1.09	F*1
828	21	H	5	64	MAN	1BH	-1.49	-1.12	F*1
829	21	H	6	64	MAN	1BH	-1.05	-0.97	F*1
830	21	H	7	64	MAN	1BH	-1.2	-1.1	F*1
831	21	H	10	64	MAD	1BH	-1.28	0	F*1
832	21	H	11	64	MAD	1BH	-1.59	0	F*1
833	21	H	12	64	MAN	1BH	-1.12	-1	F*1
834	21	H	14	64	MAN	1BH	-1.21	-1.11	F*1
835	21	H	15	64	SAD	1BH	-1.25	0	F*1
836	21	H	19	64	MAD	1BH	-1.38	0	F*1
837	21	H	22	64	SAD	1BH	-1.35	0	F*1
838	21	H	29	64	SAD	1BH	-0.8	0	F*1
839	21	H	34	64	MAD	1BH	-1.22	0	F*1
840	21	H	35	64	SAD	1BH	-1.28	0	F*1
841	21	H	37	64	SAD	1BH	-1.34	0	F*1
842	21	H	1	65	MAD	1BH	-1.25	0	F*1
843	21	H	2	65	SAD	1BH	-1.42	0	F*1
844	21	H	4	65	SAI	1BH	-0.36	-0.23	F*1
845	21	H	5	65	MAN	1BH	-1.27	-1.13	F*1
846	21	H	8	65	SAN	1BH	-1.24	-1.13	F*1



2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
847	21	H	10	65	MAD	1BH	-1.24	0	F*1
848	21	H	13	65	MAI	1BH	-0.49	-0.28	F*1
849	21	H	14	65	SAD	1BH	-1.19	0	F*1
850	21	H	17	65	MAD	1BH	-1.33	0	F*1
851	21	H	18	65	SAD	1BH	-1.36	0	F*1
852	21	H	20	65	SAD	1BH	-1	0	F*1
853	21	H	25	65	SAD	1BH	-0.79	0	F*1
854	21	H	40	65	MAD	1BH	-1.32	0	F*1
855	21	H	3	66	MAD	1BH	-1.3	0	F*1
856	21	H	5	66	MAN	1BH	-1.15	-1.06	F*1
857	21	H	6	66	SAN	1BH	-1.27	-1.2	F*1
858	21	H	7	66	SAD	1BH	-1.27	0	F*1
859	21	H	12	66	MAD	1BH	-1.33	0	F*1
860	21	H	14	66	SAD	1BH	-1.29	0	F*1
861	21	H	15	66	MAD	1BH	-1.41	0	F*1
862	21	H	16	66	SAN	1BH	-2.03	-1.95	F*1
863	21	H	17	66	SAD	1BH	-1.4	0	F*1
864	21	H	18	66	SAD	1BH	-1.36	0	F*1
865	21	H	19	66	SAD	1BH	-0.82	0	F*1
866	21	H	21	66	SAD	1BH	-1.24	0	F*1
867	21	H	22	66	SAD	1BH	-1.23	0	F*1
868	21	H	24	66	MAD	1BH	-1.18	0	F*1
869	21	H	25	66	SAD	1BH	-1.26	0	F*1
870	21	H	35	66	SAD	1BH	-1.35	0	F*1
871	21	H	1	67	MAD	1BH	-1.31	0	F*1
872	21	H	2	67	SAD	1BH	-1.42	0	F*1
873	21	H	3	67	MAD	1BH	-1.36	0	F*1
874	21	H	4	67	SAD	1BH	-1.17	0	F*1
875	21	H	5	67	MAD	1BH	-1.35	0	F*1
876	21	H	6	67	SAD	1BH	-1.33	0	F*1
877	21	H	8	67	SAD	1BH	-0.86	0	F*1
878	21	H	11	67	SAD	1BH	-1.34	0	F*1
879	21	H	12	67	MAD	1BH	-1.36	0	F*1
880	21	H	16	67	SAN	1BH	-3.87	-3.76	F*1
881	21	H	19	67	SAD	1BH	-0.79	0	F*1
882	21	H	20	67	SAD	1BH	-0.92	0	F*1
883	21	H	21	67	MAD	1BH	-1.3	0	F*1
884	21	H	24	67	MAN	1BH	-1.27	-1.08	F*1
885	21	H	25	67	SAN	1BH	-3.88	-3.67	F*1
886	21	H	26	67	SAN	1BH	-1.26	-1.16	F*1
887	21	H	30	67	MAD	1BH	-1.25	0	F*1
888	21	H	34	67	MAD	1BH	-1.41	0	F*1
889	21	H	4	68	MAN	1BH	-1.35	-0.83	F*1
890	21	H	5	68	MAN	1BH	-1.17	-1.05	F*1
891	21	H	7	68	MAN	1BH	-1.18	-1.06	F*1
892	21	H	12	68	MAN	1BH	-0.46	-0.22	F*1
893	21	H	13	68	MAD	1BH	-1.39	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
894	21	H	14	68	MAD	1BH	-1.35	0	F*1
895	21	H	15	68	MAD	1BH	-1.44	0	F*1
896	21	H	17	68	MAD	1BH	-1.25	0	F*1
897	21	H	19	68	SAD	1BH	-0.85	0	F*1
898	21	H	20	68	SAD	1BH	-0.85	0	F*1
899	21	H	1	69	SAD	1BH	-1.3	0	F*1
900	21	H	4	69	MAD	1BH	-1.42	0	F*1
901	21	H	5	69	SAD	1BH	-1.35	0	F*1
902	21	H	6	69	SAD	1BH	-1.34	0	F*1
903	21	H	8	69	SAD	1BH	-1.4	0	F*1
904	21	H	11	69	SAN	1BH	-1.14	-1.05	F*1
905	21	H	12	69	MAD	1BH	-1.33	0	F*1
906	21	H	13	69	SAD	1BH	-1.34	0	F*1
907	21	H	14	69	SAD	1BH	-1.34	0	F*1
908	21	H	15	69	MAD	1BH	-1.47	0	F*1
909	21	H	16	69	SAD	1BH	-1.35	0	F*1
910	21	H	17	69	SAD	1BH	-1.3	0	F*1
911	21	H	20	69	MAD	1BH	-1.41	0	F*1
912	21	H	25	69	SAD	1BH	-1.42	0	F*1
913	21	H	26	69	SAD	1BH	-1.41	0	F*1
914	21	H	33	69	SAD	1BH	-1.48	0	F*1
915	21	H	35	69	SAD	1BH	-1.32	0	F*1
916	21	H	2	70	SAD	1BH	-1.23	0	F*1
917	21	H	4	70	SAD	1BH	-1.42	0	F*1
918	21	H	5	70	MAN	1BH	-1.17	-1.07	F*1
919	21	H	6	70	SAD	1BH	-1.41	0	F*1
920	21	H	7	70	SAD	1BH	-0.86	0	F*1
921	21	H	9	70	MAD	1BH	-1.2	0	F*1
922	21	H	11	70	MAD	1BH	-0.87	0	F*1
923	21	H	13	70	MAD	1BH	-1.4	0	F*1
924	21	H	16	70	MAD	1BH	-1.4	0	F*1
925	21	H	17	70	MAN	1BH	-0.52	-0.2	F*1
926	21	H	25	70	SAD	1BH	-1.49	0	F*1
927	21	H	2	71	MAD	1BH	-0.92	0	F*1
928	21	H	4	71	MAD	1BH	-0.96	0	F*1
929	21	H	5	71	MAD	1BH	-1.41	0	F*1
930	21	H	6	71	MAN	1BH	-1.36	-1.25	F*1
931	21	H	7	71	MAD	1BH	-1.55	0	F*1
932	21	H	8	71	MAD	1BH	-1.36	0	F*1
933	21	H	9	71	SAD	1BH	-1.46	0	F*1
934	21	H	10	71	MAN	1BH	-1.14	-1	F*1
935	21	H	11	71	MAN	1BH	-1.13	-1	F*1
936	21	H	12	71	SAD	1BH	-1.28	0	F*1
937	21	H	16	71	SAD	1BH	-0.87	0	F*1
938	21	H	17	71	MAD	1BH	-1.34	0	F*1
939	21	H	21	71	MAD	1BH	-1.42	0	F*1
940	21	H	22	71	MAD	1BH	-0.86	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
941	21	H	30	71	SAD	1BH	-1.3	0	F*1
942	21	H	31	71	SAD	1BH	-1.37	0	F*1
943	21	H	34	71	SAI	1BH	-0.52	-0.46	F*1
944	21	H	2	72	MAD	1BH	-1.37	0	F*1
945	21	H	4	72	SAD	1BH	-1	0	F*1
946	21	H	5	72	SAD	1BH	-1.41	0	F*1
947	21	H	6	72	SAD	1BH	-1.3	0	F*1
948	21	H	8	72	MAN	1BH	-1.09	-1.02	F*1
949	21	H	11	72	MAN	1BH	-1.16	-0.97	F*1
950	21	H	12	72	SAD	1BH	-1.46	0	F*1
951	21	H	15	72	SAD	1BH	-1.29	0	F*1
952	21	H	16	72	SAD	1BH	-1.42	0	F*1
953	21	H	17	72	SAD	1BH	-1.39	0	F*1
954	21	H	18	72	MAD	1BH	-1.48	0	F*1
955	21	H	23	72	SAD	1BH	-1.24	0	F*1
956	21	H	36	72	MAD	1BH	-1.46	0	F*1
957	21	H	38	72	SAD	1BH	-1.31	0	F*1
958	21	H	2	73	SAD	1BH	-0.95	0	F*1
959	21	H	3	73	MAN	1BH	-1.25	-1.12	F*1
960	21	H	5	73	MAN	1BH	-1.16	-1.06	F*1
961	21	H	11	73	MAN	1BH	-1.17	-1.07	F*1
962	21	H	12	73	MAD	1BH	-0.89	0	F*1
963	21	H	16	73	MAD	1BH	-0.86	0	F*1
964	21	H	17	73	MAD	1BH	-0.88	0	F*1
965	21	H	18	73	MAD	1BH	-1.45	0	F*1
966	21	H	23	73	SAD	1BH	-0.82	0	F*1
967	21	H	1	74	SAD	1BH	-1.41	0	F*1
968	21	H	2	74	SAD	1BH	-1.35	0	F*1
969	21	H	3	74	SAN	1BH	-1.26	-1.04	F*1
970	21	H	4	74	MAD	1BH	-1.43	0	F*1
971	21	H	5	74	MAN	1BH	-1.23	-1.12	F*1
972	21	H	6	74	SAD	1BH	-1.32	0	F*1
973	21	H	7	74	MAD	1BH	-1.34	0	F*1
974	21	H	11	74	MAN	1BH	-1.29	-1.14	F*1
975	21	H	13	74	SAD	1BH	-1.38	0	F*1
976	21	H	15	74	SAD	1BH	-1.37	0	F*1
977	21	H	19	74	SAD	1BH	-1.41	0	F*1
978	21	H	25	74	SAD	1BH	-0.85	0	F*1
979	21	H	28	74	SAD	1BH	-0.94	0	F*1
980	21	H	29	74	SAD	1BH	-1.49	0	F*1
981	21	H	37	74	SAD	1BH	-1.26	0	F*1
982	21	H	4	75	SAD	1BH	-1.34	0	F*1
983	21	H	5	75	MAN	1BH	-1.36	-1.26	F*1
984	21	H	8	75	MAD	1BH	-0.9	0	F*1
985	21	H	11	75	SAD	1BH	-1.36	0	F*1
986	21	H	17	75	MAD	1BH	-1.4	0	F*1
987	21	H	21	75	SAD	1BH	-1.47	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
988	21	H	22	75	SAD	1BH	-1.46	0	F*1
989	21	H	2	76	SAD	1BH	-1.38	0	F*1
990	21	H	3	76	SAD	1BH	-1.37	0	F*1
991	21	H	5	76	SAD	1BH	-1.31	0	F*1
992	21	H	7	76	MAD	1BH	-1.41	0	F*1
993	21	H	9	76	MAD	1BH	-1.39	0	F*1
994	21	H	10	76	MAD	1BH	-1.3	0	F*1
995	21	H	11	76	SAD	1BH	-1.38	0	F*1
996	21	H	18	76	SAD	1BH	-0.87	0	F*1
997	21	H	24	76	SAD	1BH	-1.33	0	F*1
998	21	H	28	76	SAN	1BH	-1.35	-1.28	F*1
999	21	H	3	77	MAD	1BH	-0.93	0	F*1
1000	21	H	4	77	SAD	1BH	-1.33	0	F*1
1001	21	H	5	77	SAD	1BH	-1.77	0	F*1
1002	21	H	6	77	MAD	1BH	-1.4	0	F*1
1003	21	H	7	77	SAN	1BH	-1.2	-1.07	F*1
1004	21	H	10	77	MAD	1BH	-1.33	0	F*1
1005	21	H	11	77	SAD	1BH	-1.44	0	F*1
1006	21	H	16	77	SAD	1BH	-0.87	0	F*1
1007	21	H	17	77	SAI	1BH	-0.63	-0.12	F*1
1008	21	H	20	77	SAD	1BH	-1.41	0	F*1
1009	21	H	22	77	SAD	1BH	-1.16	0	F*1
1010	21	H	3	78	MAD	1BH	-1.53	0	F*1
1011	21	H	4	78	MAD	1BH	-1.08	0	F*1
1012	21	H	5	78	MAD	1BH	-1.44	0	F*1
1013	21	H	7	78	MAN	1BH	-1.28	-1.15	F*1
1014	21	H	9	78	MAD	1BH	-1.39	0	F*1
1015	21	H	11	78	MAN	1BH	-1.15	-1.05	F*1
1016	21	H	2	79	MAD	1BH	-1.45	0	F*1
1017	21	H	4	79	SAD	1BH	-1.37	0	F*1
1018	21	H	5	79	MAD	1BH	-1.37	0	F*1
1019	21	H	7	79	MAN	1BH	-1.3	-1.18	F*1
1020	21	H	8	79	SAD	1BH	-0.93	0	F*1
1021	21	H	10	79	SAD	1BH	-1.39	0	F*1
1022	21	H	11	79	SAD	1BH	-1.47	0	F*1
1023	21	H	12	79	SAN	1BH	-1.48	-1.42	F*1
1024	21	H	17	79	MAI	1BH	-0.69	-0.14	F*1
1025	21	H	19	79	MAD	1BH	-1.52	0	F*1
1026	21	H	21	79	SAD	1BH	-1.29	0	F*1
1027	21	H	3	80	SAD	1BH	-1.31	0	F*1
1028	21	H	5	80	SAD	1BH	-1.56	0	F*1
1029	21	H	8	80	SAN	1BH	-1.31	-1.26	F*1
1030	21	H	9	80	SAD	1BH	-1.38	0	F*1
1031	21	H	11	80	MAD	1BH	-1.37	0	F*1
1032	21	H	12	80	SAD	1BH	-1.26	0	F*1
1033	21	H	28	80	SAN	1BH	-1.3	-1.24	F*1
1034	21	H	1	81	MAD	1BH	-0.9	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1035	21	H	8	81	SAD	1BH	-1.2	0	F*1
1036	21	H	11	81	SAD	1BH	-1.45	0	F*1
1037	21	H	19	81	SAD	1BH	-1.32	0	F*1
1038	21	H	21	81	SAD	1BH	-1.3	0	F*1
1039	21	H	1	82	SAD	1BH	-1.4	0	F*1
1040	21	H	7	82	SAD	1BH	-1.52	0	F*1
1041	21	H	9	82	MAD	1BH	-0.88	0	F*1
1042	21	H	11	82	SAD	1BH	-1.36	0	F*1
1043	21	H	12	82	SAD	1BH	-1.44	0	F*1
1044	21	H	26	82	SAD	1BH	-1.37	0	F*1
1045	21	H	2	83	SAD	1BH	-0.94	0	F*1
1046	21	H	4	83	SAD	1BH	-1.3	0	F*1
1047	21	H	9	83	MAD	1BH	-1.52	0	F*1
1048	21	H	4	84	SAD	1BH	-1.37	0	F*1
1049	21	H	5	84	MAD	1BH	-1	0	F*1
1050	21	H	9	84	SAD	1BH	-1.42	0	F*1
1051	21	H	11	84	MAD	1BH	-1.45	0	F*1
1052	21	H	12	84	MAD	1BH	-0.9	0	F*1
1053	21	H	7	85	SAD	1BH	-1.49	0	F*1
1054	21	H	9	85	MAD	1BH	-1.35	0	F*1
1055	21	H	11	85	SAD	1BH	-1.26	0	F*1
1056	21	H	13	85	MAD	1BH	-1.39	0	F*1
1057	21	H	18	86	SAN	1BH	-1.24	-1.12	F*1
1058	21	H	3	87	SAD	1BH	-1.31	0	F*1
1059	21	H	9	89	SAD	1BH	-1.23	0	F*1
1060	21	H	10	89	MAD	1BH	-1.25	0	F*1

21 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	21	H	6	14	SAN	2BH	-1.02	-0.9	F*2
2	21	H	4	17	SAD	2BH	-3.11	0	F*2
3	21	H	14	17	SAN	2BH	-1.14	-1.08	F*2
4	21	H	18	17	SAN	2BH	-0.82	-0.71	F*2
5	21	H	19	18	MAN	2BH	-0.89	-0.73	F*2
6	21	H	27	18	SAN	2BH	-0.97	-0.86	F*2
7	21	H	6	19	SAN	2BH	-0.97	-0.87	F*2
8	21	H	27	20	MAN	2BH	-1.05	-0.87	F*2
9	21	H	2	21	SAN	2BH	-1	-0.82	F*2
10	21	H	9	21	SAN	2BH	-1.03	-0.68	F*2
11	21	H	3	22	SAN	2BH	-0.65	-0.59	F*2
12	21	H	16	22	SAN	2BH	-1.02	-0.91	F*2
13	21	H	3	24	SAN	2BH	-1.02	-0.86	F*2
14	21	H	6	24	SAN	2BH	-0.89	-0.75	F*2
15	21	H	19	25	MAD	2BH	-3.03	0	F*2
16	21	H	4	26	SAN	2BH	-1.09	-0.8	F*2
17	21	H	18	26	SAN	2BH	-0.91	-0.74	F*2
18	21	H	12	27	SAN	2BH	-0.73	-0.64	F*2

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

21 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
19	21	H	28	27	SAN	2BH	-1.29	-0.75	F*2
20	21	H	9	28	MAN	2BH	-2.27	-1.97	F*2
21	21	H	38	28	SAN	2BH	-0.86	-0.72	F*2
22	21	H	4	29	MAN	2BH	-0.93	-0.82	F*2
23	21	H	13	29	SAN	2BH	-3.19	-3.12	F*2
24	21	H	9	30	SAN	2BH	-0.69	-0.32	F*2
25	21	H	18	30	SAN	2BH	-1.01	-0.86	F*2
26	21	H	23	34	SAN	2BH	-0.96	-0.81	F*2
27	21	H	5	36	MAN	2BH	-2.49	-1.88	F*2
28	21	H	7	36	SAN	2BH	-0.9	-0.72	F*2
29	21	H	8	36	SAN	2BH	-0.86	-0.72	F*2
30	21	H	14	36	MAD	2BH	-3	0	F*2
31	21	H	4	38	SAN	2BH	-0.86	-0.82	F*2
32	21	H	14	40	SAN	2BH	-2.88	-1.28	F*2
33	21	H	33	41	SAN	2BH	-0.85	-0.77	F*2
34	21	H	2	42	SAN	2BH	-0.99	-0.95	F*2
35	21	H	9	42	MAN	2BH	-0.74	-0.66	F*2
36	21	H	9	44	SAN	2BH	-0.78	-0.65	F*2
37	21	H	10	44	SAD	2BH	-2.9	0	F*2
38	21	H	19	44	SAN	2BH	-1.87	-1.71	F*2
39	21	H	30	45	SAN	2BH	-1.05	-0.99	F*2
40	21	H	3	46	SAN	2BH	-0.75	-0.62	F*2
41	21	H	9	46	SAN	2BH	-1.98	-1.32	F*2
42	21	H	12	46	MAN	2BH	-2.6	-1.82	F*2
43	21	H	20	46	SAD	2BH	-1.5	0	F*2
44	21	H	6	47	SAN	2BH	-2.84	-1.87	F*2
45	21	H	7	47	SAN	2BH	-0.77	-0.46	F*2
46	21	H	14	47	SAN	2BH	-2.86	-1.48	F*2
47	21	H	18	47	SAD	2BH	-4.53	0	F*2
48	21	H	10	48	MAN	2BH	-2.87	-2.75	F*2
49	21	H	8	49	MAN	2BH	-2.48	-1.63	F*2
50	21	H	15	49	MAD	2BH	-3.35	0	F*2
51	21	H	14	50	SAN	2BH	-2.16	-1.61	F*2
52	21	H	17	50	SAD	2BH	-3.58	0	F*2
53	21	H	12	52	SAD	2BH	-1.81	0	F*2
54	21	H	14	52	SAN	2BH	-0.97	-0.89	F*2
55	21	H	21	54	SAN	2BH	-0.81	-0.76	F*2
56	21	H	11	55	MAN	2BH	-0.63	-0.52	F*2
57	21	H	7	56	SAN	2BH	-0.59	-0.52	F*2
58	21	H	11	56	SAN	2BH	-0.75	-0.64	F*2
59	21	H	1	57	SAN	2BH	-0.81	-0.75	F*2
60	21	H	11	57	SAN	2BH	-1.18	-1.09	F*2
61	21	H	5	58	SAN	2BH	-0.86	-0.75	F*2
62	21	H	1	59	SAN	2BH	-0.91	-0.79	F*2
63	21	H	2	60	MAN	2BH	-0.68	-0.36	F*2
64	21	H	4	60	SAN	2BH	-0.61	-0.5	F*2
65	21	H	5	60	MAN	2BH	-0.83	-0.67	F*2

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

21 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
66	21	H	6	60	SAD	2BH	-1.11	0	F*2
67	21	H	4	62	SAN	2BH	-0.86	-0.71	F*2
68	21	H	10	62	SAN	2BH	-1.02	-0.85	F*2
69	21	H	25	62	MAI	2BH	-0.52	-0.08	F*2
70	21	H	8	63	MAN	2BH	-1.1	-0.88	F*2
71	21	H	8	64	SAN	2BH	-0.62	-0.5	F*2
72	21	H	17	64	MAN	2BH	-1.14	-1.03	F*2
73	21	H	12	65	MAN	2BH	-0.9	-0.78	F*2
74	21	H	16	65	SAN	2BH	-0.97	-0.83	F*2
75	21	H	10	66	SAN	2BH	-0.75	-0.63	F*2
76	21	H	14	67	SAD	2BH	-3.02	0	F*2
77	21	H	34	68	MAN	2BH	-1.1	-0.77	F*2
78	21	H	3	71	MAN	2BH	-0.94	-0.86	F*2
79	21	H	10	73	SAN	2BH	-0.87	-0.79	F*2
80	21	H	9	74	SAN	2BH	-0.99	-0.91	F*2

21 STEAM GENERATOR EF* TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	21	H	4	11	MAN	EBH	-10.61	-10.24	EF*
2	21	H	3	17	SAD	EBH	-13.35	0	EF*
3	21	H	9	18	SAI	EBH	-0.41	-0.35	EF*
4	21	H	30	27	SAN	EBH	-9.12	-9.04	EF*
5	21	H	13	30	SAD	EBH	-13.71	0	EF*
6	21	H	19	32	SAN	EBH	-12.22	-11.72	EF*
7	21	H	10	43	SAN	EBH	-13.25	-11.37	EF*
8	21	H	1	46	MAN	EBH	-12.87	-11.59	EF*
9	21	H	28	48	SAN	EBH	-13.31	-10.08	EF*
10	21	H	25	49	MAN	EBH	-13.03	-9.87	EF*
11	21	H	28	55	SAN	EBH	-13.45	-10.28	EF*
12	21	H	16	56	SAN	EBH	-9.3	-9.27	EF*
13	21	H	7	61	SAN	EBH	-9.16	-9.05	EF*
14	21	H	7	67	MAN	EBH	-9.63	-9.16	EF*

22 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	22	H	4	1	SAN	TRH	-2.54	-2.44	F*0
2	22	H	1	2	SAN	TRH	-2.02	-1.91	F*0
3	22	H	1	7	SAN	TRH	-2.81	-2.68	F*0
4	22	H	3	10	SAN	TRH	-2.37	-2.39	F*0
5	22	H	35	20	SAN	TRH	-2.34	-2.19	F*0
6	22	H	35	23	SAN	TRH	-2.29	-2.2	F*0
7	22	H	37	25	SAN	TRH	-2.26	-2.1	F*0
8	22	H	1	27	SAN	TRH	-2.54	-2.43	F*0
9	22	H	8	27	SAD	TRH	-2.57	0	F*0
10	22	H	1	28	SAN	TRH	-2.43	-2.3	F*0
11	22	H	3	28	SAN	TRH	-2.37	-2.23	F*0

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
12	22	H	2	29	SAN	TRH	-2.47	-2.33	F*0
13	22	H	3	29	SAN	TRH	-2.59	-2.48	F*0
14	22	H	2	30	SAN	TRH	-2.51	-2.48	F*0
15	22	H	1	33	MAN	TRH	-2.72	-2.5	F*0
16	22	H	1	34	SAN	TRH	-2.53	-2.34	F*0
17	22	H	42	35	SAN	TRH	-2.6	-2.5	F*0
18	22	H	1	37	MAN	TRH	-2.77	-2.6	F*0
19	22	H	2	45	SAN	TRH	-2.29	-2.16	F*0
20	22	H	1	46	SAN	TRH	-2.74	-2.57	F*0
21	22	H	7	48	SAN	TRH	-2.5	-2.4	F*0
22	22	H	9	48	SAN	TRH	-2.3	-2.06	F*0
23	22	H	10	48	SAN	TRH	-2.47	-2.35	F*0
24	22	H	5	49	SAN	TRH	-2.41	-2.34	F*0
25	22	H	7	49	SAN	TRH	-2.46	-2.24	F*0
26	22	H	8	49	SAI	TRH	-2.49	-2.3	F*0
27	22	H	3	50	SAN	TRH	-2.67	-2.58	F*0
28	22	H	4	50	SAN	TRH	-2.75	-2.66	F*0
29	22	H	6	50	SAN	TRH	-2.75	-2.66	F*0
30	22	H	7	50	SAN	TRH	-2.34	-2.23	F*0
31	22	H	10	50	SAN	TRH	-2.83	-2.74	F*0
32	22	H	37	50	SAI	TRH	-2.57	-2.42	F*0
33	22	H	4	51	MAN	TRH	-2.43	-2.35	F*0
34	22	H	7	51	SAN	TRH	-2.37	-2.27	F*0
35	22	H	1	52	MAN	TRH	-2.74	-2.4	F*0
36	22	H	10	52	SAN	TRH	-2.81	-2.71	F*0
37	22	H	1	53	MAN	TRH	-2.8	-2.52	F*0
38	22	H	6	53	SAN	TRH	-2.7	-2.6	F*0
39	22	H	7	53	SAN	TRH	-2.66	-2.55	F*0
40	22	H	34	53	MAN	TRH	-2.26	-2.2	F*0
41	22	H	5	54	MAN	TRH	-2.62	-2.5	F*0
42	22	H	7	55	SAI	TRH	-2.37	-2.33	F*0
43	22	H	34	55	MAN	TRH	-2.37	-2.19	F*0
44	22	H	1	56	MAN	TRH	-2.74	-2.5	F*0
45	22	H	2	56	SAN	TRH	-2.63	-2.53	F*0
46	22	H	34	56	MAN	TRH	-2.3	-2.09	F*0
47	22	H	37	57	MAN	TRH	-2.34	-2.2	F*0
48	22	H	9	58	SAN	TRH	-2.78	-2.63	F*0
49	22	H	34	58	MAN	TRH	-2.52	-2.36	F*0
50	22	H	7	59	SAN	TRH	-2.6	-2.56	F*0
51	22	H	26	59	MAN	TRH	-2.32	-2.24	F*0
52	22	H	37	59	MAN	TRH	-2.22	-2.12	F*0
53	22	H	34	60	MAN	TRH	-2.31	-2.14	F*0
54	22	H	11	61	SAN	TRH	-2.59	-2.49	F*0
55	22	H	1	62	MAN	TRH	-2.7	-2.44	F*0
56	22	H	8	63	SAN	TRH	-2.87	-2.74	F*0
57	22	H	17	63	MAN	TRH	-2.63	-2.57	F*0
58	22	H	34	63	MAN	TRH	-2.39	-2.25	F*0



2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*0 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
59	22	H	5	64	SAN	TRH	-2.31	-2.27	F*0
60	22	H	8	64	SAN	TRH	-2.39	-2.33	F*0
61	22	H	7	65	MAN	TRH	-2.48	-2.45	F*0
62	22	H	8	66	MAN	TRH	-2.37	-2.27	F*0
63	22	H	18	66	SAN	TRH	-1.44	-1.33	F*0
64	22	H	8	67	SAN	TRH	-2.41	-2.37	F*0
65	22	H	8	68	SAN	TRH	-2.36	-2.25	F*0
66	22	H	34	68	MAN	TRH	-2.32	-2.1	F*0
67	22	H	1	69	MAN	TRH	-2.78	-2.61	F*0
68	22	H	1	70	MAN	TRH	-2.74	-2.52	F*0
69	22	H	37	70	MAN	TRH	-2.2	-2.07	F*0
70	22	H	6	71	SAN	TRH	-2.45	-2.35	F*0
71	22	H	7	71	SAN	TRH	-2.4	-2.35	F*0
72	22	H	11	71	SAN	TRH	-2.54	-2.41	F*0
73	22	H	24	71	MAN	TRH	-2.31	-2.17	F*0
74	22	H	1	72	MAN	TRH	-2.73	-2.5	F*0
75	22	H	5	72	SAN	TRH	-2.82	-2.64	F*0
76	22	H	34	72	SAN	TRH	-2.13	-2.1	F*0
77	22	H	37	72	SAN	TRH	-2.2	-2.01	F*0
78	22	H	1	74	MAN	TRH	-2.73	-2.56	F*0
79	22	H	4	74	MAN	TRH	-2.25	-2.19	F*0
80	22	H	5	74	SAN	TRH	-2.42	-2.32	F*0
81	22	H	6	74	MAN	TRH	-2.2	-2.11	F*0
82	22	H	6	75	SAN	TRH	-2.46	-2.32	F*0
83	22	H	1	76	MAN	TRH	-2.77	-2.62	F*0
84	22	H	1	77	MAN	TRH	-2.65	-2.48	F*0
85	22	H	4	77	SAN	TRH	-2.52	-2.45	F*0
86	22	H	6	77	MAN	TRH	-2.38	-2.3	F*0
87	22	H	1	78	MAN	TRH	-2.7	-2.27	F*0
88	22	H	4	78	SAN	TRH	-2.61	-2.44	F*0
89	22	H	1	79	MAN	TRH	-2.68	-2.52	F*0
90	22	H	3	79	MAN	TRH	-2.51	-2.38	F*0
91	22	H	1	80	MAN	TRH	-2.66	-2.47	F*0
92	22	H	4	80	SAN	TRH	-2.56	-2.4	F*0
93	22	H	5	80	SAN	TRH	-2.52	-2.39	F*0
94	22	H	4	81	SAN	TRH	-2.44	-2.34	F*0
95	22	H	1	82	MAN	TRH	-2.66	-2.32	F*0
96	22	H	5	82	SAN	TRH	-2.53	-2.36	F*0
97	22	H	1	83	SAN	TRH	-2.72	-2.49	F*0
98	22	H	6	85	SAN	TRH	-2.43	-2.33	F*0
99	22	H	7	85	SAN	TRH	-2.55	-2.48	F*0
100	22	H	6	86	SAN	TRH	-2.43	-2.36	F*0
101	22	H	1	87	SAN	TRH	-2.62	-2.45	F*0
102	22	H	4	88	SAN	TRH	-2.46	-2.39	F*0
103	22	H	13	88	SAI	TRH	-1.59	-1.52	F*0
104	22	H	6	91	SAN	TRH	-2.54	-2.42	F*0
105	22	H	6	94	MAN	TRH	-2.54	-2.3	F*0

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	22	H	15	7	SAD	1BH	-1.05	0	F*1
2	22	H	4	8	SAD	1BH	-1.4	0	F*1
3	22	H	1	10	SAN	1BH	-2.17	-2.08	F*1
4	22	H	21	11	SAD	1BH	-1.42	0	F*1
5	22	H	15	13	SAD	1BH	-1.11	0	F*1
6	22	H	24	13	SAD	1BH	-1.46	0	F*1
7	22	H	4	14	SAN	1BH	-2.37	-2.2	F*1
8	22	H	17	14	MAD	1BH	-1.32	0	F*1
9	22	H	18	14	SAN	1BH	-1.39	-1.34	F*1
10	22	H	25	14	MAI	1BH	-0.65	-0.13	F*1
11	22	H	2	15	SAN	1BH	-2.3	-2.19	F*1
12	22	H	4	15	SAD	1BH	-1.25	0	F*1
13	22	H	9	15	SAD	1BH	-1.16	0	F*1
14	22	H	14	15	SAD	1BH	-1.06	0	F*1
15	22	H	24	15	MAN	1BH	-1.54	-1.29	F*1
16	22	H	25	15	SAD	1BH	-1.49	0	F*1
17	22	H	13	16	MAI	1BH	-0.6	-0.28	F*1
18	22	H	18	16	SAD	1BH	-1.34	0	F*1
19	22	H	25	16	SAD	1BH	-1.07	0	F*1
20	22	H	27	16	SAD	1BH	-1.17	0	F*1
21	22	H	1	17	MAN	1BH	-2.22	-2.01	F*1
22	22	H	4	17	MAD	1BH	-1.3	0	F*1
23	22	H	14	17	SAD	1BH	-1.32	0	F*1
24	22	H	25	17	SAD	1BH	-1.4	0	F*1
25	22	H	1	18	MAN	1BH	-2.16	-2.05	F*1
26	22	H	2	18	MAN	1BH	-2.1	-2.03	F*1
27	22	H	4	18	MAD	1BH	-1.19	0	F*1
28	22	H	9	18	SAD	1BH	-1.45	0	F*1
29	22	H	14	18	MAD	1BH	-1.37	0	F*1
30	22	H	4	19	SAN	1BH	-2.18	-2.09	F*1
31	22	H	15	19	MAD	1BH	-1.08	0	F*1
32	22	H	1	20	MAN	1BH	-2.21	-2.05	F*1
33	22	H	3	20	SAN	1BH	-2.18	-2.11	F*1
34	22	H	12	20	MAI	1BH	-0.87	-0.12	F*1
35	22	H	14	20	SAD	1BH	-0.91	0	F*1
36	22	H	20	20	MAD	1BH	-1.4	0	F*1
37	22	H	24	20	MAI	1BH	-0.91	-0.31	F*1
38	22	H	29	20	SAD	1BH	-1.47	0	F*1
39	22	H	1	21	MAN	1BH	-2.2	-2.07	F*1
40	22	H	4	21	MAN	1BH	-2.4	-2.3	F*1
41	22	H	10	21	SAD	1BH	-1.34	0	F*1
42	22	H	31	21	SAD	1BH	-1.4	0	F*1
43	22	H	7	22	SAD	1BH	-1.27	0	F*1
44	22	H	18	22	SAN	1BH	-1.55	-1.48	F*1
45	22	H	23	22	SAD	1BH	-1.31	0	F*1
46	22	H	25	22	MAD	1BH	-1.3	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
47	22	H	28	22	SAD	1BH	-1.47	0	F*1
48	22	H	32	22	MAI	1BH	-0.71	-0.14	F*1
49	22	H	33	22	SAD	1BH	-1.28	0	F*1
50	22	H	22	23	SAN	1BH	-1.55	-1.44	F*1
51	22	H	26	23	SAN	1BH	-1.53	-1.5	F*1
52	22	H	32	23	SAD	1BH	-1.24	0	F*1
53	22	H	1	24	SAD	1BH	-1.36	0	F*1
54	22	H	15	24	MAD	1BH	-0.9	0	F*1
55	22	H	21	24	SAI	1BH	-0.7	-0.44	F*1
56	22	H	25	24	MAD	1BH	-1.37	0	F*1
57	22	H	27	24	MAD	1BH	-1.57	0	F*1
58	22	H	28	24	SAN	1BH	-1.35	-1.24	F*1
59	22	H	34	24	SAD	1BH	-1.02	0	F*1
60	22	H	35	24	SAD	1BH	-1.32	0	F*1
61	22	H	7	25	SAD	1BH	-1.31	0	F*1
62	22	H	14	25	SAD	1BH	-1.33	0	F*1
63	22	H	16	25	SAD	1BH	-1.27	0	F*1
64	22	H	19	25	SAD	1BH	-1.24	0	F*1
65	22	H	20	25	MAD	1BH	-0.96	0	F*1
66	22	H	21	25	SAD	1BH	-1.51	0	F*1
67	22	H	23	25	MAN	1BH	-1.53	-1.37	F*1
68	22	H	26	25	SAN	1BH	-1.19	-1.12	F*1
69	22	H	28	25	MAI	1BH	-0.62	-0.3	F*1
70	22	H	31	25	SAD	1BH	-1	0	F*1
71	22	H	32	25	SAD	1BH	-1.4	0	F*1
72	22	H	33	25	SAD	1BH	-1	0	F*1
73	22	H	35	25	SAD	1BH	-1.56	0	F*1
74	22	H	1	26	SAN	1BH	-0.53	-0.34	F*1
75	22	H	18	26	SAD	1BH	-1.27	0	F*1
76	22	H	19	26	MAD	1BH	-1.67	0	F*1
77	22	H	21	26	SAD	1BH	-1.36	0	F*1
78	22	H	22	26	SAD	1BH	-1.56	0	F*1
79	22	H	24	26	MAD	1BH	-1.39	0	F*1
80	22	H	25	26	SAD	1BH	-1.31	0	F*1
81	22	H	27	26	SAD	1BH	-1.5	0	F*1
82	22	H	28	26	SAD	1BH	-0.96	0	F*1
83	22	H	32	26	SAD	1BH	-1.3	0	F*1
84	22	H	33	26	SAD	1BH	-1.33	0	F*1
85	22	H	13	27	MAD	1BH	-1.29	0	F*1
86	22	H	14	27	SAD	1BH	-0.95	0	F*1
87	22	H	15	27	SAD	1BH	-1.59	0	F*1
88	22	H	20	27	SAD	1BH	-1.52	0	F*1
89	22	H	24	27	SAD	1BH	-1.35	0	F*1
90	22	H	25	27	SAD	1BH	-1.22	0	F*1
91	22	H	28	27	MAD	1BH	-1.24	0	F*1
92	22	H	31	27	MAD	1BH	-1.29	0	F*1
93	22	H	7	28	MAD	1BH	-1.51	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
94	22	H	20	28	SAD	1BH	-1.21	0	F*1
95	22	H	23	28	SAD	1BH	-1.34	0	F*1
96	22	H	31	28	SAD	1BH	-1.34	0	F*1
97	22	H	1	29	MAD	1BH	-1.35	0	F*1
98	22	H	7	29	SAD	1BH	-1.18	0	F*1
99	22	H	19	29	SAD	1BH	-1.72	0	F*1
100	22	H	24	29	SAD	1BH	-1.57	0	F*1
101	22	H	26	29	MAD	1BH	-1.44	0	F*1
102	22	H	27	29	MAD	1BH	-1.23	0	F*1
103	22	H	29	29	MAN	1BH	-0.78	-0.04	F*1
104	22	H	32	29	SAD	1BH	-1.52	0	F*1
105	22	H	5	30	SAN	1BH	-0.35	-0.17	F*1
106	22	H	9	30	SAD	1BH	-1.61	0	F*1
107	22	H	21	30	SAD	1BH	-1.29	0	F*1
108	22	H	32	30	MAD	1BH	-1.4	0	F*1
109	22	H	35	30	SAD	1BH	-1.4	0	F*1
110	22	H	3	31	MAN	1BH	-1.67	-1.2	F*1
111	22	H	4	31	SAN	1BH	-1.69	-1.55	F*1
112	22	H	27	31	SAD	1BH	-1.25	0	F*1
113	22	H	28	31	SAD	1BH	-1.47	0	F*1
114	22	H	29	31	SAD	1BH	-1.25	0	F*1
115	22	H	32	31	SAD	1BH	-1.4	0	F*1
116	22	H	33	31	SAD	1BH	-1.32	0	F*1
117	22	H	35	31	SAD	1BH	-1.53	0	F*1
118	22	H	1	32	MAD	1BH	-1.34	0	F*1
119	22	H	9	32	MAD	1BH	-1.18	0	F*1
120	22	H	20	32	MAN	1BH	-1.36	-1.21	F*1
121	22	H	21	32	SAD	1BH	-1.36	0	F*1
122	22	H	28	32	SAD	1BH	-1.17	0	F*1
123	22	H	31	32	SAN	1BH	-1.49	-1.33	F*1
124	22	H	32	32	SAD	1BH	-1.44	0	F*1
125	22	H	33	32	MAD	1BH	-1.46	0	F*1
126	22	H	18	33	SAD	1BH	-1.41	0	F*1
127	22	H	23	33	SAD	1BH	-1.53	0	F*1
128	22	H	25	33	SAD	1BH	-0.9	0	F*1
129	22	H	32	33	MAD	1BH	-1.49	0	F*1
130	22	H	33	33	SAD	1BH	-1	0	F*1
131	22	H	7	34	SAD	1BH	-1.25	0	F*1
132	22	H	28	34	MAN	1BH	-1.52	-1.37	F*1
133	22	H	30	34	MAN	1BH	-1.61	-1.54	F*1
134	22	H	33	34	SAD	1BH	-0.97	0	F*1
135	22	H	3	35	SAD	1BH	-1.36	0	F*1
136	22	H	12	35	MAD	1BH	-1.21	0	F*1
137	22	H	13	35	MAN	1BH	-1.34	-1.12	F*1
138	22	H	22	35	SAD	1BH	-0.9	0	F*1
139	22	H	28	35	MAN	1BH	-1.58	-1.27	F*1
140	22	H	29	35	SAD	1BH	-1.27	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
141	22	H	30	35	SAN	1BH	-1.43	-1.37	F*1
142	22	H	1	36	SAD	1BH	-1.3	0	F*1
143	22	H	7	36	SAD	1BH	-1.35	0	F*1
144	22	H	20	36	MAD	1BH	-1.47	0	F*1
145	22	H	23	36	MAN	1BH	-1.47	-1.24	F*1
146	22	H	27	36	SAD	1BH	-1.48	0	F*1
147	22	H	29	36	SAD	1BH	-1.22	0	F*1
148	22	H	32	36	SAN	1BH	-0.99	-0.81	F*1
149	22	H	33	36	SAD	1BH	-1.23	0	F*1
150	22	H	35	36	SAD	1BH	-1.51	0	F*1
151	22	H	2	37	SAD	1BH	-1.25	0	F*1
152	22	H	20	37	SAD	1BH	-1.48	0	F*1
153	22	H	21	37	MAD	1BH	-1.23	0	F*1
154	22	H	23	37	SAD	1BH	-1.51	0	F*1
155	22	H	24	37	SAN	1BH	-1.55	-1.42	F*1
156	22	H	30	37	SAD	1BH	-1.29	0	F*1
157	22	H	33	37	MAN	1BH	-0.51	-0.03	F*1
158	22	H	37	37	SAD	1BH	-1.4	0	F*1
159	22	H	19	38	MAN	1BH	-1.34	-1.21	F*1
160	22	H	33	38	MAI	1BH	-0.75	-0.21	F*1
161	22	H	37	38	SAD	1BH	-1.37	0	F*1
162	22	H	1	39	MAI	1BH	-0.78	-0.15	F*1
163	22	H	3	39	SAD	1BH	-1.41	0	F*1
164	22	H	9	39	SAD	1BH	-1.5	0	F*1
165	22	H	20	39	SAD	1BH	-1.11	0	F*1
166	22	H	23	39	SAD	1BH	-1.5	0	F*1
167	22	H	33	39	SAD	1BH	-1.31	0	F*1
168	22	H	37	39	SAD	1BH	-1.33	0	F*1
169	22	H	1	40	MAD	1BH	-1.34	0	F*1
170	22	H	12	40	SAD	1BH	-1.03	0	F*1
171	22	H	20	40	SAD	1BH	-1.41	0	F*1
172	22	H	21	40	SAD	1BH	-1.36	0	F*1
173	22	H	22	40	MAD	1BH	-0.95	0	F*1
174	22	H	23	40	SAD	1BH	-1	0	F*1
175	22	H	32	40	SAD	1BH	-1.52	0	F*1
176	22	H	33	40	SAD	1BH	-1	0	F*1
177	22	H	1	41	MAD	1BH	-1.63	0	F*1
178	22	H	19	41	SAD	1BH	-1.54	0	F*1
179	22	H	21	41	SAD	1BH	-1.58	0	F*1
180	22	H	22	41	SAD	1BH	-1.47	0	F*1
181	22	H	27	41	MAN	1BH	-1.53	-1.4	F*1
182	22	H	28	41	SAD	1BH	-0.92	0	F*1
183	22	H	29	41	SAD	1BH	-1.28	0	F*1
184	22	H	33	41	MAD	1BH	-1.41	0	F*1
185	22	H	37	41	MAD	1BH	-1.45	0	F*1
186	22	H	1	42	SAD	1BH	-1.35	0	F*1
187	22	H	2	42	SAD	1BH	-1.32	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
188	22	H	13	42	SAD	1BH	-1.28	0	F*1
189	22	H	21	42	MAD	1BH	-0.95	0	F*1
190	22	H	22	42	SAD	1BH	-1.49	0	F*1
191	22	H	24	42	SAD	1BH	-1.71	0	F*1
192	22	H	29	42	SAD	1BH	-1.5	0	F*1
193	22	H	33	42	MAN	1BH	-1.49	-1.38	F*1
194	22	H	1	43	SAD	1BH	-1.63	0	F*1
195	22	H	3	43	SAD	1BH	-1.22	0	F*1
196	22	H	12	43	MAD	1BH	-1.17	0	F*1
197	22	H	13	43	SAD	1BH	-1.18	0	F*1
198	22	H	22	43	MAD	1BH	-1.44	0	F*1
199	22	H	33	43	MAN	1BH	-1.4	-1.27	F*1
200	22	H	37	43	SAN	1BH	-0.42	-0.26	F*1
201	22	H	13	44	MAN	1BH	-1.3	-1.17	F*1
202	22	H	14	44	SAD	1BH	-1.58	0	F*1
203	22	H	17	44	SAN	1BH	-1.2	-1.13	F*1
204	22	H	18	44	SAD	1BH	-0.93	0	F*1
205	22	H	23	44	MAD	1BH	-1.52	0	F*1
206	22	H	27	44	SAD	1BH	-1.55	0	F*1
207	22	H	30	44	SAD	1BH	-1.5	0	F*1
208	22	H	33	44	SAD	1BH	-1.36	0	F*1
209	22	H	37	44	SAD	1BH	-1.14	0	F*1
210	22	H	1	45	MAD	1BH	-0.75	0	F*1
211	22	H	6	45	SAD	1BH	-1.34	0	F*1
212	22	H	13	45	SAN	1BH	-1.36	-1.2	F*1
213	22	H	15	45	MAD	1BH	-1.52	0	F*1
214	22	H	19	45	MAD	1BH	-0.9	0	F*1
215	22	H	28	45	MAD	1BH	-1.57	0	F*1
216	22	H	29	45	SAD	1BH	-1.4	0	F*1
217	22	H	10	46	SAD	1BH	-1.18	0	F*1
218	22	H	12	46	SAD	1BH	-1.38	0	F*1
219	22	H	14	46	SAD	1BH	-1.2	0	F*1
220	22	H	16	46	MAD	1BH	-1.35	0	F*1
221	22	H	17	46	SAN	1BH	-1.02	-0.87	F*1
222	22	H	19	46	SAD	1BH	-1.47	0	F*1
223	22	H	26	46	MAN	1BH	-1.49	-1.29	F*1
224	22	H	1	47	SAD	1BH	-1.19	0	F*1
225	22	H	6	47	SAD	1BH	-1.29	0	F*1
226	22	H	12	47	SAD	1BH	-1.43	0	F*1
227	22	H	20	47	SAD	1BH	-0.93	0	F*1
228	22	H	28	47	SAD	1BH	-0.99	0	F*1
229	22	H	1	48	SAN	1BH	-1.15	-1.02	F*1
230	22	H	2	48	MAN	1BH	-1.14	-1.04	F*1
231	22	H	3	48	MAD	1BH	-1.17	0	F*1
232	22	H	21	48	SAD	1BH	-1	0	F*1
233	22	H	22	48	SAD	1BH	-1.52	0	F*1
234	22	H	23	48	MAN	1BH	-1.47	-1.19	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
235	22	H	28	48	MAN	1BH	-1.58	-1.23	F*1
236	22	H	29	48	SAD	1BH	-1.59	0	F*1
237	22	H	37	48	SAD	1BH	-1.43	0	F*1
238	22	H	1	49	SAN	1BH	-1.24	-1.17	F*1
239	22	H	4	49	SAD	1BH	-1.28	0	F*1
240	22	H	9	49	SAD	1BH	-1.32	0	F*1
241	22	H	10	49	SAD	1BH	-1.35	0	F*1
242	22	H	11	49	MAD	1BH	-1.36	0	F*1
243	22	H	12	49	SAN	1BH	-0.19	-0.01	F*1
244	22	H	13	49	SAD	1BH	-1.53	0	F*1
245	22	H	14	49	MAN	1BH	-1.27	-0.88	F*1
246	22	H	18	49	MAN	1BH	-1.35	-1.05	F*1
247	22	H	21	49	SAD	1BH	-0.86	0	F*1
248	22	H	23	49	MAN	1BH	-1.52	-1.17	F*1
249	22	H	27	49	SAD	1BH	-1.15	0	F*1
250	22	H	28	49	SAN	1BH	-1.48	-1.35	F*1
251	22	H	32	49	MAN	1BH	-1.65	-1.26	F*1
252	22	H	40	49	SAD	1BH	-1.19	0	F*1
253	22	H	41	49	SAN	1BH	-1.29	-1.18	F*1
254	22	H	1	50	SAD	1BH	-1.44	0	F*1
255	22	H	2	50	SAD	1BH	-1.15	0	F*1
256	22	H	9	50	MAN	1BH	-1.01	-0.99	F*1
257	22	H	11	50	SAD	1BH	-1.18	0	F*1
258	22	H	15	50	SAD	1BH	-1.2	0	F*1
259	22	H	18	50	MAD	1BH	-0.94	0	F*1
260	22	H	22	50	SAD	1BH	-0.99	0	F*1
261	22	H	23	50	MAD	1BH	-0.97	0	F*1
262	22	H	24	50	MAN	1BH	-1.52	-1.29	F*1
263	22	H	25	50	SAN	1BH	-2.35	-2.28	F*1
264	22	H	27	50	MAD	1BH	-1.51	0	F*1
265	22	H	28	50	SAN	1BH	-1.46	-1.38	F*1
266	22	H	29	50	SAD	1BH	-1.6	0	F*1
267	22	H	30	50	SAD	1BH	-1.22	0	F*1
268	22	H	31	50	SAN	1BH	-1.01	-0.93	F*1
269	22	H	32	50	MAN	1BH	-1.53	-1.19	F*1
270	22	H	33	50	SAN	1BH	-1.5	-1.34	F*1
271	22	H	34	50	SAD	1BH	-1.55	0	F*1
272	22	H	35	50	SAD	1BH	-1.56	0	F*1
273	22	H	1	51	SAD	1BH	-1.13	0	F*1
274	22	H	3	51	SAN	1BH	-1.36	-1.12	F*1
275	22	H	9	51	MAD	1BH	-1.22	0	F*1
276	22	H	10	51	SAD	1BH	-1.19	0	F*1
277	22	H	12	51	SAD	1BH	-1.17	0	F*1
278	22	H	13	51	MAD	1BH	-1.21	0	F*1
279	22	H	18	51	MAD	1BH	-1.37	0	F*1
280	22	H	21	51	SAD	1BH	-1.33	0	F*1
281	22	H	28	51	SAD	1BH	-1.47	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
282	22	H	32	51	SAN	1BH	-1.4	-1.3	F*1
283	22	H	37	51	SAD	1BH	-1.57	0	F*1
284	22	H	3	52	SAD	1BH	-1.35	0	F*1
285	22	H	7	52	SAD	1BH	-1.03	0	F*1
286	22	H	9	52	SAD	1BH	-1.15	0	F*1
287	22	H	20	52	SAD	1BH	-1.28	0	F*1
288	22	H	28	52	SAN	1BH	-1.37	-1.27	F*1
289	22	H	29	52	SAN	1BH	-1.46	-1.37	F*1
290	22	H	33	52	SAN	1BH	-1.44	-1.25	F*1
291	22	H	13	53	MAN	1BH	-1.37	-0.85	F*1
292	22	H	18	53	SAD	1BH	-1.33	0	F*1
293	22	H	24	53	SAD	1BH	-1.46	0	F*1
294	22	H	25	53	SAN	1BH	-1.54	-1.39	F*1
295	22	H	29	53	MAD	1BH	-1.53	0	F*1
296	22	H	30	53	MAI	1BH	-0.73	-0.12	F*1
297	22	H	32	53	SAD	1BH	-1.35	0	F*1
298	22	H	33	53	SAD	1BH	-1.34	0	F*1
299	22	H	37	53	MAD	1BH	-0.93	0	F*1
300	22	H	40	53	MAI	1BH	-0.89	-0.32	F*1
301	22	H	1	54	MAN	1BH	-1.16	-0.92	F*1
302	22	H	9	54	MAD	1BH	-1.18	0	F*1
303	22	H	10	54	SAD	1BH	-1.24	0	F*1
304	22	H	13	54	SAN	1BH	-1.35	-1.31	F*1
305	22	H	15	54	SAD	1BH	-1.07	0	F*1
306	22	H	16	54	MAN	1BH	-0.7	-0.15	F*1
307	22	H	18	54	MAD	1BH	-1.41	0	F*1
308	22	H	22	54	MAD	1BH	-1.28	0	F*1
309	22	H	23	54	SAN	1BH	-1.43	-1.27	F*1
310	22	H	24	54	SAD	1BH	-1.46	0	F*1
311	22	H	25	54	SAD	1BH	-1.33	0	F*1
312	22	H	27	54	SAD	1BH	-1.45	0	F*1
313	22	H	28	54	MAI	1BH	-0.55	-0.08	F*1
314	22	H	34	54	SAD	1BH	-0.93	0	F*1
315	22	H	37	54	SAD	1BH	-1.41	0	F*1
316	22	H	1	55	SAN	1BH	-1.13	-0.93	F*1
317	22	H	9	55	SAD	1BH	-1.36	0	F*1
318	22	H	10	55	MAN	1BH	-1.21	-1.14	F*1
319	22	H	13	55	MAN	1BH	-1.31	-0.75	F*1
320	22	H	14	55	SAD	1BH	-1.2	0	F*1
321	22	H	19	55	MAD	1BH	-1.25	0	F*1
322	22	H	20	55	SAD	1BH	-1.23	0	F*1
323	22	H	21	55	MAD	1BH	-1.41	0	F*1
324	22	H	22	55	SAN	1BH	-1.34	-1.21	F*1
325	22	H	23	55	SAN	1BH	-1.38	-1.27	F*1
326	22	H	24	55	SAD	1BH	-1.53	0	F*1
327	22	H	29	55	SAD	1BH	-1.39	0	F*1
328	22	H	32	55	SAD	1BH	-1.3	0	F*1



2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
329	22	H	33	55	SAN	1BH	-1.5	-1.27	F*1
330	22	H	37	55	MAD	1BH	-1.46	0	F*1
331	22	H	4	56	MAN	1BH	-1.25	-0.93	F*1
332	22	H	6	56	SAD	1BH	-1.26	0	F*1
333	22	H	7	56	SAD	1BH	-1.36	0	F*1
334	22	H	9	56	SAD	1BH	-1.28	0	F*1
335	22	H	10	56	MAD	1BH	-1.2	0	F*1
336	22	H	11	56	MAD	1BH	-1.19	0	F*1
337	22	H	12	56	MAD	1BH	-1.24	0	F*1
338	22	H	13	56	SAD	1BH	-1.41	0	F*1
339	22	H	16	56	SAD	1BH	-1.25	0	F*1
340	22	H	27	56	SAD	1BH	-1.6	0	F*1
341	22	H	28	56	SAD	1BH	-1.55	0	F*1
342	22	H	29	56	SAD	1BH	-1.5	0	F*1
343	22	H	32	56	SAD	1BH	-1.28	0	F*1
344	22	H	3	57	SAN	1BH	-1.32	-1.25	F*1
345	22	H	5	57	SAD	1BH	-1.37	0	F*1
346	22	H	7	57	SAN	1BH	-1.19	-1.09	F*1
347	22	H	10	57	SAD	1BH	-1.24	0	F*1
348	22	H	13	57	MAD	1BH	-1.31	0	F*1
349	22	H	15	57	SAD	1BH	-1.06	0	F*1
350	22	H	18	57	MAD	1BH	-0.92	0	F*1
351	22	H	23	57	SAD	1BH	-1.51	0	F*1
352	22	H	25	57	SAD	1BH	-1.44	0	F*1
353	22	H	27	57	SAD	1BH	-1.37	0	F*1
354	22	H	28	57	MAD	1BH	-1.41	0	F*1
355	22	H	32	57	SAD	1BH	-1.28	0	F*1
356	22	H	34	57	SAD	1BH	-1.45	0	F*1
357	22	H	1	58	SAD	1BH	-1.3	0	F*1
358	22	H	3	58	SAD	1BH	-1.27	0	F*1
359	22	H	7	58	MAN	1BH	-1.28	-1.21	F*1
360	22	H	14	58	SAD	1BH	-1.31	0	F*1
361	22	H	18	58	MAD	1BH	-1.31	0	F*1
362	22	H	20	58	SAD	1BH	-1.4	0	F*1
363	22	H	23	58	SAN	1BH	-1.42	-1.24	F*1
364	22	H	24	58	SAD	1BH	-1.51	0	F*1
365	22	H	37	58	SAN	1BH	-1.49	-1.34	F*1
366	22	H	4	59	SAD	1BH	-1.26	0	F*1
367	22	H	5	59	SAD	1BH	-1.42	0	F*1
368	22	H	9	59	SAD	1BH	-1.3	0	F*1
369	22	H	15	59	MAD	1BH	-1.34	0	F*1
370	22	H	16	59	MAD	1BH	-1.16	0	F*1
371	22	H	20	59	SAD	1BH	-1.43	0	F*1
372	22	H	22	59	SAN	1BH	-1.49	-1.41	F*1
373	22	H	23	59	SAN	1BH	-1.39	-1.31	F*1
374	22	H	24	59	SAD	1BH	-1.51	0	F*1
375	22	H	25	59	SAD	1BH	-1.4	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
376	22	H	27	59	SAD	1BH	-1.41	0	F*1
377	22	H	28	59	MAN	1BH	-1.48	-1.25	F*1
378	22	H	29	59	SAD	1BH	-1.51	0	F*1
379	22	H	30	59	MAN	1BH	-1.37	-1.3	F*1
380	22	H	34	59	SAD	1BH	-1.39	0	F*1
381	22	H	5	60	SAD	1BH	-1.35	0	F*1
382	22	H	6	60	SAD	1BH	-1.34	0	F*1
383	22	H	7	60	SAD	1BH	-1.35	0	F*1
384	22	H	13	60	SAD	1BH	-1.43	0	F*1
385	22	H	15	60	SAD	1BH	-1.26	0	F*1
386	22	H	18	60	SAD	1BH	-1.42	0	F*1
387	22	H	19	60	MAD	1BH	-1.41	0	F*1
388	22	H	23	60	SAD	1BH	-1.48	0	F*1
389	22	H	27	60	SAD	1BH	-1.26	0	F*1
390	22	H	32	60	SAN	1BH	-1.47	-1.3	F*1
391	22	H	37	60	SAD	1BH	-1.45	0	F*1
392	22	H	7	61	MAD	1BH	-1.26	0	F*1
393	22	H	12	61	SAD	1BH	-1.29	0	F*1
394	22	H	13	61	MAN	1BH	-1.54	-1.43	F*1
395	22	H	18	61	MAD	1BH	-1.43	0	F*1
396	22	H	20	61	SAD	1BH	-1.35	0	F*1
397	22	H	22	61	MAN	1BH	-1.37	-1.29	F*1
398	22	H	23	61	SAN	1BH	-1.44	-1.34	F*1
399	22	H	25	61	SAD	1BH	-1.5	0	F*1
400	22	H	26	61	SAD	1BH	-1.14	0	F*1
401	22	H	27	61	MAN	1BH	-0.58	-0.27	F*1
402	22	H	32	61	SAD	1BH	-1.47	0	F*1
403	22	H	5	62	MAD	1BH	-1.62	0	F*1
404	22	H	7	62	SAD	1BH	-1.23	0	F*1
405	22	H	10	62	SAD	1BH	-1.38	0	F*1
406	22	H	12	62	SAD	1BH	-1.42	0	F*1
407	22	H	13	62	MAD	1BH	-1.26	0	F*1
408	22	H	16	62	MAD	1BH	-1.17	0	F*1
409	22	H	18	62	SAD	1BH	-1.34	0	F*1
410	22	H	19	62	MAN	1BH	-1.28	-0.99	F*1
411	22	H	23	62	MAD	1BH	-1.55	0	F*1
412	22	H	24	62	SAD	1BH	-1.36	0	F*1
413	22	H	25	62	SAN	1BH	-0.7	-0.38	F*1
414	22	H	29	62	SAD	1BH	-1.16	0	F*1
415	22	H	34	62	SAD	1BH	-1.46	0	F*1
416	22	H	37	62	SAN	1BH	-1.44	-1.24	F*1
417	22	H	42	62	MAI	1BH	-0.73	-0.38	F*1
418	22	H	1	63	SAD	1BH	-1.24	0	F*1
419	22	H	7	63	SAD	1BH	-1.19	0	F*1
420	22	H	11	63	SAD	1BH	-1.3	0	F*1
421	22	H	12	63	SAD	1BH	-1.41	0	F*1
422	22	H	23	63	SAD	1BH	-1.16	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
423	22	H	24	63	SAD	1BH	-1.38	0	F*1
424	22	H	25	63	SAN	1BH	-1.59	-1.5	F*1
425	22	H	33	63	SAD	1BH	-1.52	0	F*1
426	22	H	37	63	SAN	1BH	-1.39	-1.36	F*1
427	22	H	1	64	SAD	1BH	-1.21	0	F*1
428	22	H	2	64	SAD	1BH	-1.26	0	F*1
429	22	H	4	64	SAD	1BH	-1.14	0	F*1
430	22	H	7	64	SAN	1BH	-1.62	-1.52	F*1
431	22	H	9	64	SAN	1BH	-1.23	-1.1	F*1
432	22	H	18	64	SAD	1BH	-1.3	0	F*1
433	22	H	19	64	MAD	1BH	-1.26	0	F*1
434	22	H	32	64	MAD	1BH	-1.5	0	F*1
435	22	H	34	64	MAN	1BH	-1.42	-1.29	F*1
436	22	H	37	64	SAD	1BH	-1.18	0	F*1
437	22	H	6	65	MAD	1BH	-1.27	0	F*1
438	22	H	8	65	SAD	1BH	-1.18	0	F*1
439	22	H	10	65	MAN	1BH	-1.22	-1.15	F*1
440	22	H	11	65	SAD	1BH	-1.33	0	F*1
441	22	H	12	65	MAN	1BH	-1.31	-1.22	F*1
442	22	H	15	65	MAN	1BH	-1.18	-1.08	F*1
443	22	H	19	65	SAD	1BH	-1.29	0	F*1
444	22	H	24	65	MAN	1BH	-1.38	-1.3	F*1
445	22	H	26	65	SAD	1BH	-1.26	0	F*1
446	22	H	27	65	SAN	1BH	-1.4	-1.36	F*1
447	22	H	33	65	SAD	1BH	-1.49	0	F*1
448	22	H	34	65	SAD	1BH	-1.23	0	F*1
449	22	H	36	65	SAD	1BH	-1.56	0	F*1
450	22	H	37	65	SAD	1BH	-1.28	0	F*1
451	22	H	9	66	SAD	1BH	-1.15	0	F*1
452	22	H	11	66	MAN	1BH	-1.29	-1.03	F*1
453	22	H	12	66	MAD	1BH	-1.5	0	F*1
454	22	H	13	66	SAD	1BH	-1.28	0	F*1
455	22	H	20	66	MAD	1BH	-1.27	0	F*1
456	22	H	21	66	MAD	1BH	-1.03	0	F*1
457	22	H	22	66	SAD	1BH	-1.47	0	F*1
458	22	H	24	66	SAN	1BH	-1.35	-1.28	F*1
459	22	H	31	66	SAD	1BH	-1.5	0	F*1
460	22	H	37	66	SAN	1BH	-1.37	-1.24	F*1
461	22	H	7	67	SAD	1BH	-1.31	0	F*1
462	22	H	9	67	MAN	1BH	-1.13	-1.03	F*1
463	22	H	16	67	SAN	1BH	-1.16	-1.09	F*1
464	22	H	17	67	SAD	1BH	-1.39	0	F*1
465	22	H	20	67	SAD	1BH	-1.27	0	F*1
466	22	H	24	67	MAN	1BH	-1.46	-1.33	F*1
467	22	H	27	67	MAN	1BH	-1.57	-1.32	F*1
468	22	H	30	67	SAN	1BH	-1.57	-1.54	F*1
469	22	H	31	67	SAD	1BH	-1	0	F*1

**2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT**

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
470	22	H	32	67	SAD	1BH	-1.22	0	F*1
471	22	H	34	67	SAD	1BH	-1.48	0	F*1
472	22	H	37	67	SAN	1BH	-1.56	-1.43	F*1
473	22	H	9	68	SAD	1BH	-1.59	0	F*1
474	22	H	10	68	SAD	1BH	-1.24	0	F*1
475	22	H	13	68	SAD	1BH	-1.17	0	F*1
476	22	H	21	68	MAD	1BH	-1.33	0	F*1
477	22	H	24	68	MAN	1BH	-1.36	-1.25	F*1
478	22	H	27	68	SAN	1BH	-1.48	-1.38	F*1
479	22	H	31	68	SAD	1BH	-0.9	0	F*1
480	22	H	32	68	SAD	1BH	-1.32	0	F*1
481	22	H	33	68	SAD	1BH	-1.27	0	F*1
482	22	H	37	68	MAN	1BH	-1.5	-1.37	F*1
483	22	H	9	69	SAD	1BH	-1.34	0	F*1
484	22	H	15	69	MAD	1BH	-0.94	0	F*1
485	22	H	16	69	MAD	1BH	-1.3	0	F*1
486	22	H	25	69	MAN	1BH	-1.32	-1.25	F*1
487	22	H	27	69	SAD	1BH	-1.51	0	F*1
488	22	H	31	69	SAD	1BH	-1.46	0	F*1
489	22	H	32	69	SAD	1BH	-1.15	0	F*1
490	22	H	37	69	SAD	1BH	-1.43	0	F*1
491	22	H	11	70	SAD	1BH	-0.95	0	F*1
492	22	H	21	70	SAD	1BH	-1.47	0	F*1
493	22	H	22	70	SAD	1BH	-1.19	0	F*1
494	22	H	23	70	SAD	1BH	-1.14	0	F*1
495	22	H	24	70	SAD	1BH	-1.57	0	F*1
496	22	H	27	70	SAN	1BH	-1.38	-1.29	F*1
497	22	H	31	70	MAN	1BH	-0.47	-0.34	F*1
498	22	H	12	71	MAD	1BH	-1.11	0	F*1
499	22	H	14	71	SAD	1BH	-1.36	0	F*1
500	22	H	17	71	MAD	1BH	-1.35	0	F*1
501	22	H	18	71	SAD	1BH	-1.28	0	F*1
502	22	H	20	71	SAD	1BH	-1.29	0	F*1
503	22	H	22	71	MAD	1BH	-1.24	0	F*1
504	22	H	23	71	MAD	1BH	-1.42	0	F*1
505	22	H	26	71	MAI	1BH	-0.46	-0.11	F*1
506	22	H	27	71	SAD	1BH	-0.9	0	F*1
507	22	H	32	71	SAD	1BH	-1.17	0	F*1
508	22	H	8	72	SAD	1BH	-1.28	0	F*1
509	22	H	9	72	MAD	1BH	-1.2	0	F*1
510	22	H	11	72	MAN	1BH	-1.41	-1.28	F*1
511	22	H	12	72	MAN	1BH	-1.22	-1.12	F*1
512	22	H	13	72	SAD	1BH	-1.37	0	F*1
513	22	H	16	72	SAD	1BH	-1.4	0	F*1
514	22	H	17	72	SAD	1BH	-1.26	0	F*1
515	22	H	24	72	SAN	1BH	-0.47	-0.15	F*1
516	22	H	27	72	MAD	1BH	-1.32	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
517	22	H	9	73	SAD	1BH	-1.27	0	F*1
518	22	H	12	73	MAN	1BH	-1.12	-1.04	F*1
519	22	H	13	73	MAN	1BH	-1.39	-1.3	F*1
520	22	H	14	73	MAD	1BH	-1.13	0	F*1
521	22	H	15	73	MAN	1BH	-1.16	-1.06	F*1
522	22	H	16	73	MAI	1BH	-0.48	-0.02	F*1
523	22	H	17	73	MAD	1BH	-1.3	0	F*1
524	22	H	18	73	SAD	1BH	-1.3	0	F*1
525	22	H	19	73	SAD	1BH	-1.22	0	F*1
526	22	H	25	73	SAD	1BH	-1.49	0	F*1
527	22	H	12	74	MAN	1BH	-0.56	-0.38	F*1
528	22	H	14	74	MAD	1BH	-1.34	0	F*1
529	22	H	15	74	MAD	1BH	-1.29	0	F*1
530	22	H	17	74	MAN	1BH	-0.75	-0.24	F*1
531	22	H	18	74	SAI	1BH	-0.62	-0.33	F*1
532	22	H	24	74	SAD	1BH	-1.54	0	F*1
533	22	H	4	75	SAD	1BH	-1.39	0	F*1
534	22	H	10	75	MAD	1BH	-1.24	0	F*1
535	22	H	12	75	MAD	1BH	-1.22	0	F*1
536	22	H	13	75	SAN	1BH	-1.2	-1.04	F*1
537	22	H	14	75	MAD	1BH	-1.33	0	F*1
538	22	H	15	75	MAD	1BH	-1.3	0	F*1
539	22	H	27	75	MAD	1BH	-0.9	0	F*1
540	22	H	8	76	SAD	1BH	-1.29	0	F*1
541	22	H	11	76	MAN	1BH	-1.09	-0.96	F*1
542	22	H	13	76	SAD	1BH	-1.48	0	F*1
543	22	H	17	76	MAD	1BH	-1.13	0	F*1
544	22	H	18	76	SAD	1BH	-1.42	0	F*1
545	22	H	20	76	SAD	1BH	-1.38	0	F*1
546	22	H	22	76	SAN	1BH	-0.71	-0.12	F*1
547	22	H	26	76	MAD	1BH	-1.5	0	F*1
548	22	H	8	77	SAD	1BH	-1.26	0	F*1
549	22	H	11	77	SAD	1BH	-1.39	0	F*1
550	22	H	12	77	MAD	1BH	-1.49	0	F*1
551	22	H	13	77	SAN	1BH	-1.23	-1.13	F*1
552	22	H	14	77	SAI	1BH	-0.45	-0.15	F*1
553	22	H	15	77	SAD	1BH	-1.33	0	F*1
554	22	H	16	77	MAD	1BH	-1.27	0	F*1
555	22	H	17	77	MAD	1BH	-1.1	0	F*1
556	22	H	18	77	MAD	1BH	-1.43	0	F*1
557	22	H	22	77	SAN	1BH	-1.31	-1.23	F*1
558	22	H	25	77	SAD	1BH	-0.94	0	F*1
559	22	H	11	78	SAD	1BH	-1.36	0	F*1
560	22	H	12	78	SAD	1BH	-0.95	0	F*1
561	22	H	17	78	SAD	1BH	-1.4	0	F*1
562	22	H	18	78	SAD	1BH	-1.38	0	F*1
563	22	H	22	78	SAD	1BH	-1.53	0	F*1

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*1 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
564	22	H	26	78	MAN	1BH	-1.13	-1.03	F*1
565	22	H	12	79	SAN	1BH	-0.53	-0.21	F*1
566	22	H	13	79	MAN	1BH	-1.22	-1.14	F*1
567	22	H	14	79	MAN	1BH	-1.11	-1	F*1
568	22	H	15	79	MAD	1BH	-1.29	0	F*1
569	22	H	17	79	MAD	1BH	-1.12	0	F*1
570	22	H	19	79	SAD	1BH	-1.2	0	F*1
571	22	H	22	79	SAD	1BH	-1.31	0	F*1
572	22	H	25	79	SAD	1BH	-1.36	0	F*1
573	22	H	26	79	SAD	1BH	-1.49	0	F*1
574	22	H	9	80	MAN	1BH	-1.31	-1.02	F*1
575	22	H	10	80	MAD	1BH	-1.36	0	F*1
576	22	H	12	80	MAD	1BH	-1.36	0	F*1
577	22	H	13	80	MAN	1BH	-1.22	-0.92	F*1
578	22	H	15	80	SAD	1BH	-1.32	0	F*1
579	22	H	23	80	SAD	1BH	-1.4	0	F*1
580	22	H	9	81	MAD	1BH	-1.3	0	F*1
581	22	H	12	81	SAD	1BH	-0.88	0	F*1
582	22	H	13	81	SAD	1BH	-1.38	0	F*1
583	22	H	15	81	MAD	1BH	-0.94	0	F*1
584	22	H	18	81	SAD	1BH	-1.26	0	F*1
585	22	H	22	81	SAN	1BH	-1.3	-1.23	F*1
586	22	H	12	82	SAD	1BH	-1.3	0	F*1
587	22	H	13	82	MAD	1BH	-1	0	F*1
588	22	H	17	82	MAD	1BH	-1.3	0	F*1
589	22	H	15	83	SAD	1BH	-0.9	0	F*1
590	22	H	17	83	SAD	1BH	-0.86	0	F*1
591	22	H	22	83	SAD	1BH	-1.44	0	F*1
592	22	H	10	84	SAD	1BH	-1.48	0	F*1
593	22	H	15	84	SAD	1BH	-1.48	0	F*1
594	22	H	18	84	MAD	1BH	-0.92	0	F*1
595	22	H	12	85	SAD	1BH	-1.45	0	F*1
596	22	H	15	85	SAD	1BH	-1.25	0	F*1
597	22	H	13	86	SAD	1BH	-1.32	0	F*1
598	22	H	17	87	SAD	1BH	-1.42	0	F*1

22 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
1	22	H	18	20	MAN	2BH	-2.47	-1.62	F*2
2	22	H	18	21	SAD	2BH	-2.71	0	F*2
3	22	H	21	22	SAD	2BH	-3.51	0	F*2
4	22	H	16	23	MAN	2BH	-2.34	-1.79	F*2
5	22	H	17	28	SAD	2BH	-2.12	0	F*2
6	22	H	20	29	SAD	2BH	-3.16	0	F*2
7	22	H	27	30	SAN	2BH	-1.93	-1.73	F*2
8	22	H	15	31	SAD	2BH	-0.31	0	F*2
9	22	H	22	34	MAN	2BH	-2.09	-1.52	F*2

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
10	22	H	14	35	SAN	2BH	-3.06	-2.99	F*2
11	22	H	19	35	SAD	2BH	-3.18	0	F*2
12	22	H	37	35	SAD	2BH	-0.88	0	F*2
13	22	H	19	36	SAD	2BH	-3.32	0	F*2
14	22	H	12	37	SAN	2BH	-3.33	-3.28	F*2
15	22	H	18	39	SAD	2BH	-3.16	0	F*2
16	22	H	19	39	SAD	2BH	-3.21	0	F*2
17	22	H	14	40	SAN	2BH	-1.1	-0.89	F*2
18	22	H	5	41	MAN	2BH	-2.35	-1.83	F*2
19	22	H	13	41	MAD	2BH	-3.52	0	F*2
20	22	H	12	42	SAN	2BH	-0.75	-0.64	F*2
21	22	H	15	43	SAN	2BH	-2.04	-1.96	F*2
22	22	H	1	44	MAD	2BH	-3.24	0	F*2
23	22	H	16	44	SAD	2BH	-3.4	0	F*2
24	22	H	17	45	MAN	2BH	-3.27	-2.85	F*2
25	22	H	37	45	SAD	2BH	-3.48	0	F*2
26	22	H	15	46	MAD	2BH	-3.28	0	F*2
27	22	H	23	46	SAD	2BH	-3.38	0	F*2
28	22	H	18	47	MAD	2BH	-3.37	0	F*2
29	22	H	21	47	SAD	2BH	-3.2	0	F*2
30	22	H	18	48	SAD	2BH	-2.96	0	F*2
31	22	H	27	48	SAD	2BH	-3.08	0	F*2
32	22	H	3	49	SAN	2BH	-0.74	-0.64	F*2
33	22	H	26	50	MAD	2BH	-3.14	0	F*2
34	22	H	11	51	SAD	2BH	-3.16	0	F*2
35	22	H	18	52	SAD	2BH	-3.1	0	F*2
36	22	H	24	52	MAN	2BH	-3.2	-3	F*2
37	22	H	10	53	MAD	2BH	-3.29	0	F*2
38	22	H	12	53	SAN	2BH	-2.99	-2.88	F*2
39	22	H	16	53	SAD	2BH	-3.48	0	F*2
40	22	H	17	53	MAN	2BH	-1.75	-1.65	F*2
41	22	H	20	53	MAD	2BH	-3.16	0	F*2
42	22	H	15	56	SAN	2BH	-0.47	-0.43	F*2
43	22	H	20	56	SAN	2BH	-3.3	-3.21	F*2
44	22	H	37	56	SAD	2BH	-3	0	F*2
45	22	H	21	57	MAN	2BH	-1.06	-0.99	F*2
46	22	H	2	58	SAN	2BH	-3.24	-3.2	F*2
47	22	H	13	58	SAN	2BH	-0.55	-0.43	F*2
48	22	H	9	60	SAN	2BH	-1.52	-1.25	F*2
49	22	H	20	60	SAD	2BH	-3.25	0	F*2
50	22	H	16	65	MAD	2BH	-3.04	0	F*2
51	22	H	24	69	SAN	2BH	-0.87	-0.81	F*2
52	22	H	32	70	MAN	2BH	-2.58	-1.94	F*2
53	22	H	19	74	SAN	2BH	-2.03	-1.87	F*2
54	22	H	22	75	MAN	2BH	-2.64	-1.81	F*2
55	22	H	23	78	MAN	2BH	-2.7	-2.11	F*2
56	22	H	17	80	SAN	2BH	-0.94	-0.62	F*2

2003 UNIT 2 STEAM GENERATOR INSPECTION RESULTS – 15 DAY REPORT

22 STEAM GENERATOR F*2 TUBES, BOC22, 2003									
No.	S/G	Leg	Row	Col	Indication	Location	Elev from	Elev to	Status
57	22	H	26	81	SAN	2BH	-2.36	-1.89	F*2
58	22	H	15	86	MAN	2BH	-2.57	-1.96	F*2
59	22	H	14	88	MAN	2BH	-2.64	-1.86	F*2