

November 3, 2003

MEMORANDUM TO: Stephen Dembek, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Brian Benney, Project Manager, Section 2 */RA/*
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF MEETING HELD ON OCTOBER 15, 2003, WITH
WESTINGHOUSE (TAC NO. MB1365)

On October 15, 2003, representatives of Westinghouse met with the NRC staff in a closed meeting to discuss "15 X 15 WH-177 Fuel Assembly Design." Members from Duke Energy also attended the meeting.

Westinghouse discussed fuel rod fretting as well as models developed and new testing tools. Westinghouse went on to discuss additional testing programs and measurements to confirm failure root causes. Westinghouse also discussed mechanical and plant compatibility. Westinghouse ended the meeting with a discussion of licensing. The staff recommended that Westinghouse clearly define lead test assembly, lead fuel assembly, and lead use assembly to prevent future issues. Following the meeting, the staff expressed its appreciation to Westinghouse for the presentation.

An attendance list is provided in the attachment. The non-proprietary slides used during the meeting are available in ADAMS under accession number ML032950540.

Project No. 700

Attachment: Meeting Attendees

cc w/att: See next page

November 3, 2003

MEMORANDUM TO: Stephen Dembek, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Brian Benney, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

/RA/

SUBJECT: SUMMARY OF MEETING HELD ON OCTOBER 15, 2003, WITH
WESTINGHOUSE (TAC NO. MB1365)

On October 15, 2003, representatives of Westinghouse met with the NRC staff in a closed meeting to discuss "15 X 15 WH-177 Fuel Assembly Design." Members from Duke Energy also attended the meeting.

Westinghouse discussed fuel rod fretting as well as models developed and new testing tools. Westinghouse went on to discuss additional testing programs and measurements to confirm failure root causes. Westinghouse also discussed mechanical and plant compatibility. Westinghouse ended the meeting with a discussion of licensing. The staff recommended that Westinghouse clearly define lead test assembly, lead fuel assembly, and lead use assembly to prevent future issues. Following the meeting, the staff expressed its appreciation to Westinghouse for the presentation.

An attendance list is provided in the attachment. The non-proprietary slides used during the meeting are available in ADAMS under accession number ML032950540.

Project No. 700

Attachment: Meeting Attendees

cc w/att: See next page

DISTRIBUTION:

PUBLIC	PClifford
PDIV-2 Reading	KErwin
RidsNrrDlpm (TMarsh/ELeeds)	SMiranda
RidsNrrDlpmLpdiv (HBerkow)	TAttard
RidsNrrPMBBenney	UShoop
RidsNrrLAEPeyton	RTaylor
RidsOgcRp	TMensha
RidsAcrsAcnwMailCenter	
FAkstulewicz	
SWu	
GThomas	

Package No.: ML03

Meeting Notice No.: ML032751423

ADAMS Accession No.: ML03

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	BBenney	EPeyton	SDembek
DATE	10/30/03	10/27/03	10/30/03

DOCUMENT NAME: G:\PDIV-2\Westinghouse (Vendor)\MTG summary 15 X 15.wpd
OFFICIAL RECORD COPY

Westinghouse Electric Company

Project No. 700

cc:

Mr. Gordon Bischoff, Manager
Owners Group Program Management Office
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp, Manager
Regulatory Compliance and Plant Licensing
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

MEETING ATTENDEES

MEETING WITH WESTINGHOUSE ELECTRIC COMPANY

OCTOBER 15, 2003

WESTINGHOUSE

R. Sisk
G. Settle
M. Goldfield

DUKE ENERGY

R. Gribble
C. Fago
R. St.Clair

NRC

B. Benney
F. Akstulewicz
S. L. Wu
P. Clifford
G. Thomas
K. Erwin
S. Miranda
T. Attard
U. Shoop
R. Taylor