



October 31, 2003  
L-2003-280  
EA-03-009(IV)(F)(2)

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Unit 4  
Docket No. 50-251  
Order (EA-03-009) Relaxation Request  
Examination Coverage of Reactor Pressure Vessel Head  
Penetration Nozzles - Supplement

On February 11, 2003 the NRC issued Order (EA-03-009) requiring specific inspections of the reactor pressure vessel (RPV) head and associated penetration nozzles at pressurized water reactors. By letters L-2003-272, dated October 21, 2003, and L-2003-277 dated October 23, 2003, and pursuant to the procedure specified in Section IV, paragraph F of the Order, Florida Power & Light (FPL) requested relaxation from the requirements specified in Section IV, paragraph C.(1)(b)(i) for Turkey Point Unit 4 for the Reactor Vessel Head (RPVH) penetration nozzles for which ultrasonic testing requirements could not be completed as required.

As discussed with NRC Staff on October 31, 2003, FPL is revising Section 5 of Attachment 1 to L-2003-272, Duration of Proposed Alternative. FPL requests the relaxation be applicable to the October 2003 refueling outage for PTN-4 and the next operating cycle. The PTN-4 RPV head is scheduled for replacement at the next refueling outage.

Please contact Walter Parker at (305) 246-6632 if there are any questions.

Very truly yours,

A handwritten signature in black ink that reads "Terry O. Jones".

Terry O. Jones  
Vice President  
Turkey Point Nuclear Plant

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant  
Florida Department of Health and Rehabilitative Services