

November 10, 2003

Mr. William R. Kanda, Vice President - Nuclear  
FirstEnergy Nuclear Operating Company  
10 Center Road  
P.O. Box 97  
Perry, OH 44081

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) FOR LICENSE  
AMENDMENT REQUEST (LAR), INCREASE IN MAIN STEAM LINE TURBINE  
BUILDING HIGH TEMPERATURE TRIP SETPOINT ALLOWABLE VALUE  
(TAC. NO. MC0342)

Dear Mr. Kanda:

By letter dated August 14, 2003, FirstEnergy Nuclear Operating Company (FENOC), requested approval of a license amendment request (LAR) for the Perry Nuclear Power Plant (PNPP). The proposed LAR increases the analytical limit and the resulting Technical Specification Allowable Value (AV) related to the setpoint for the main steam line turbine building temperature – high, system isolation function.

During the review, the NRC staff has identified that additional information is needed in order to complete the review. Specific questions are presented in the attached request for additional information (RAI).

The enclosed questions have already been discussed with your staff. In order to accommodate PNPP's needs, please respond to this RAI by December 15, 2003. If you have any questions concerning our review, or additional time is needed to respond to the RAI, please contact me at (301) 415-3154.

Sincerely,

*/RA/*

Stephen P. Sands, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure : Request for Additional Information

cc w/encl: See next page

November 10, 2003

Mr. William R. Kanda, Vice President - Nuclear  
FirstEnergy Nuclear Operating Company  
10 Center Road  
P.O. Box 97  
Perry, OH 44081

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) FOR LICENSE  
AMENDMENT REQUEST (LAR), INCREASE IN MAIN STEAM LINE TURBINE  
BUILDING HIGH TEMPERATURE TRIP SETPOINT ALLOWABLE VALUE  
(TAC. NO. MC0342)

Dear Mr. Kanda:

By letter dated August 14, 2003, FirstEnergy Nuclear Operating Company (FENOC), requested approval of a license amendment request (LAR) for the Perry Nuclear Power Plant (PNPP). The proposed LAR increases the analytical limit and the resulting Technical Specification Allowable Value (AV) related to the setpoint for the main steam line turbine building temperature – high, system isolation function.

During the review, the NRC staff has identified that additional information is needed in order to complete the review. Specific questions are presented in the attached request for additional information (RAI).

The enclosed questions have already been discussed with your staff. In order to accommodate PNPP's needs, please respond to this RAI by December 15, 2003. If you have any questions concerning our review, or additional time is needed to respond to the RAI, please contact me at (301) 415-3154.

Sincerely,

*/RA/*

Stephen P. Sands, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure: Request for Additional Information

cc w/encl: See next page

**DISTRIBUTION:**

PUBLIC	PDIII-2 r/f	AMendiola	THarris
SSands	OGC	ACRS	GGrant, RIII

**ADAMS Accession Number: ML033090400**

OFFICE	PM:LPD3-2	LA:LPD3-2	SC:LPD3-2
NAME	SSands	THarris	DPickett for AMendiola
DATE	11/07/03	11/07/03	11/10/03

OFFICIAL RECORD COPY

Perry Nuclear Power Plant, Unit 1

cc:

Mary E. O'Reilly  
FirstEnergy Corporation  
76 South Main St.  
Akron, OH 44308

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
P.O. Box 331  
Perry, OH 44081-0331

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4531

Sue Hiatt  
OCRE Interim Representative  
8275 Munson  
Mentor, OH 44060

Mr. Vernon K. Higaki  
Manager - Regulatory Affairs  
FirstEnergy Nuclear Operating Company  
Perry Nuclear Power Plant  
P.O. Box 97, A210  
10 Center Road  
Perry, OH 44081

Timothy Rausch, Plant Manager  
FirstEnergy Nuclear Operating Company  
Perry Nuclear Power Plant  
P.O. Box 97, SB306  
Perry, OH 44081

Mayor, Village of North Perry  
North Perry Village Hall  
4778 Lockwood Road  
North Perry Village, OH 44081

Donna Owens, Director  
Ohio Department of Commerce  
Division of Industrial Compliance  
Bureau of Operations & Maintenance  
6606 Tussing Road  
P. O. Box 4009  
Reynoldsburg, OH 43068-9009

Carol O'Claire, Chief, Radiological Branch  
Ohio Emergency Management Agency  
2855 West Dublin Granville Road  
Columbus, OH 43235-7150

Mayor, Village of Perry  
P.O. Box 100  
Perry, OH 44081-0100

Dennis Clum  
Radiological Assistance Section Supervisor  
Bureau of Radiation Protection  
Ohio Department of Health  
P.O. Box 118  
Columbus, OH 43266-0118

Zack A. Clayton  
DERR  
Ohio Environmental Protection Agency  
ATTN: Mr. Zack A. Clayton  
P.O. Box 1049  
Columbus, OH 43266-0149

Chairman  
Perry Township Board of Trustees  
3750 Center Road, Box 65  
Perry, OH 44081

Daniel Z. Fisher  
Transportation Department  
Public Utilities Commission  
180 East Broad Street  
Columbus, OH 43215-3793

Mr. William R. Kanda  
Vice President - Nuclear, Perry  
FirstEnergy Nuclear Operating Company  
Perry Nuclear Power Plant  
P.O. Box 97, A200  
10 Center Road  
Perry, OH 44081

## **REQUEST FOR ADDITIONAL INFORMATION**

### **PERRY NUCLEAR POWER PLANT (PNPP)**

#### **INCREASE IN MAIN STEAM LINE TURBINE BUILDING HIGH TEMPERATURE TRIP**

##### **SETPOINT ALLOWABLE VALUE**

The Nuclear Regulatory Commission (NRC) staff has reviewed the August 14, 2003, FENOC submittal regarding changes to the Perry Nuclear Power Plant license amendment request to increase the main steam line turbine building temperature – high, system isolation function, and has the following questions concerning the submittal:

- (1) Provide a description of the GOTHIC nodal model (include the GOTHIC version number) used to model the building (volumes, flow paths, active heat removal systems and heat structures, and their initial conditions). Identify the model used for the break flow, the model(s) used for heat transfer to structures, and the model used for flow between volumes. If the GOTHIC “jet breakup model” is used, provide justification to support its use for this application.
- (2) Provide a benchmark of the GOTHIC model to the current COMPARE model using GOTHIC models which closely resemble COMPARE.
- (3) Provide electronic copy(ies) of the GOTHIC input deck(s) (\*.GTH) for the model used for the LAR. The staff may perform independent, confirmatory analyses with the CONTAIN 2.0 code. In addition, the input deck should provide the full description of the nodal models and the GOTHIC models used for the LAR.