

---

**ISSUE RESOLUTION STATUS REPORT**

**KEY TECHNICAL ISSUE: REPOSITORY DESIGN AND  
THERMAL-MECHANICAL EFFECTS**

**Division of Waste Management  
Office of Nuclear Material Safety and Safeguards  
U.S. Nuclear Regulatory Commission**

**Revision 1**

**September 1998**

**Change History of "Issue Resolution Status Report, Key Technical Issue: Repository Design and Thermal-Mechanical Effects"**

<b>Revision</b>	<b>Section</b>	<b>Date</b>	<b>Modification</b>
Rev 0	All	September 1997	None. Initial issue
Rev 1	All	September 1998	General editorial and citation format changes
	3.1		Table 1 revised to be consistent with repository safety strategy
	3.3		Figure 1 replaces the four corresponding figures from Rev. 0 Text made consistent with Figure 1
	4.1.2		Review methods added
	4.1.5		Section added to include GROA design control process review
	4.2.2		Review methods added and subsection numbers revised
	4.2.3		Acceptance criteria reworded for clarity, and two previous criteria were combined
	4.3		Entire section expanded
	5.0		Section expanded and renumbered
6.0	References added and changed as necessary		

## TABLE OF CONTENTS

Section	Page
FIGURES .....	vi
TABLES .....	vii
ACKNOWLEDGMENTS .....	viii
1.0 INTRODUCTION .....	1
2.0 KEY TECHNICAL ISSUE AND SUBISSUES .....	3
2.1 PRIMARY ISSUE .....	3
2.2 SUBISSUES .....	3
3.0 IMPORTANCE OF ISSUE TO REPOSITORY PERFORMANCE ..	6
3.1 RELATIONSHIP OF THE ISSUE WITH U.S. DEPARTMENT OF ENERGY REPOSITORY SAFETY STRATEGY .....	6
3.2 IMPORTANCE TO PRECLOSURE PERFORMANCE .....	6
3.2.1 Design Control Process .....	6
3.2.2 Seismic Design Methodology .....	7
3.2.3 Thermal-Mechanical Effects .....	8
3.2.4 Design and Long-Term Contribution of Seals to Performance .....	8
3.3 IMPORTANCE TO POSTCLOSURE PERFORMANCE .....	8
3.3.1 Design Control Process .....	8
3.3.2 Seismic Design Methodology .....	10
3.3.3 Thermal-Mechanical Effects .....	10
3.3.4 Design and Long-Term Contribution of Seals to Performance .....	11
4.0 REVIEW METHODS, ACCEPTANCE CRITERIA, AND TECHNICAL BASES .....	12
4.1 IMPLEMENTATION OF AN EFFECTIVE DESIGN CONTROL PROCESS WITHIN THE OVERALL QUALITY ASSURANCE PROGRAM .....	12
4.1.1 Background .....	12
4.1.2 Review Methods .....	13
4.1.3 Acceptance Criteria .....	13
4.1.4 Technical Bases .....	14
4.1.4.1 Exploratory Studies Facility–Geologic Repository Operations Area Relationship .....	14
4.1.4.2 Regulatory Basis .....	14
4.1.4.3 Staff Technical Positions .....	15
4.1.4.4 Quality Assurance Audits and Surveillances .....	15
4.1.4.5 Site Characterization Review .....	15
4.1.4.6 Design Reviews .....	15
4.1.4.7 Meetings .....	16
4.1.4.8 On-Site Representatives' Inputs .....	16
4.1.4.9 Site Visits and In-Field Verification .....	16
4.1.4.10 Relevant U.S. Department of Energy–U.S. Nuclear Regulatory Commission Correspondence and Interactions ..	16
4.1.4.11 Summary of Technical Bases .....	16

## TABLE OF CONTENTS (cont'd)

Section	Page
4.1.5 U.S. Department of Energy's Design Control Process for the Geologic Repository Operations Area .....	17
4.1.5.1 Selective Review and Results .....	17
4.1.5.2 Comparison with Acceptance Criteria .....	18
4.2 DESIGN OF THE GEOLOGIC REPOSITORY OPERATIONS AREA FOR THE EFFECTS OF SEISMIC EVENTS AND DIRECT FAULT DISRUPTION .....	21
4.2.1 Background .....	21
4.2.2 Review Methods .....	21
4.2.3 Acceptance Criteria .....	21
4.2.4 Technical Bases .....	22
4.2.4.1 Seismic Design Topical Report Approach .....	22
4.2.4.2 U.S. Department of Energy-U.S. Nuclear Regulatory Commission Decision to Use the "Topical Report" Approach for Seismic Design .....	23
4.2.4.3 Preclosure Seismic Design Methodology Presented by the U.S. Department of Energy .....	23
4.2.4.4 Staff Review of Seismic Design Topical Report-2 .....	24
4.3 THERMAL-MECHANICAL EFFECTS ON UNDERGROUND FACILITY DESIGN AND PERFORMANCE .....	26
4.3.1 Background .....	26
4.3.2 Review Methods .....	26
4.3.3 Thermal-Mechanical Effects on Design of Underground Facility .....	27
4.3.3.1 Acceptance Criteria .....	27
4.3.3.2 Technical Bases .....	28
4.3.4 Effects of Seismically Induced Rockfall on Waste Package Performance .....	38
4.3.4.1 Acceptance Criteria .....	38
4.3.4.2 Technical Bases .....	39
4.3.5 Thermal-Mechanical Effects on Inputs to the Assessment of Flow into Emplacement Drifts .....	53
4.3.5.1 Acceptance Criteria .....	54
4.3.5.2 Technical Bases .....	54
4.4 DESIGN AND LONG-TERM CONTRIBUTION OF REPOSITORY SEALS IN MEETING POSTCLOSURE PERFORMANCE OBJECTIVES .....	55
4.4.1 Review Methods .....	55
4.4.2 Acceptance Criteria .....	55
4.4.3 Technical Bases .....	55

## TABLE OF CONTENTS (cont'd)

Section	Page
5.0 STATUS OF ISSUE RESOLUTION AT THE STAFF LEVEL .....	56
5.1 DESIGN CONTROL PROCESS .....	56
5.1.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans .....	56
5.1.2 Status of Open Items from U.S. Department of Energy—U.S. Nuclear Regulatory Commission Correspondence/Interactions .....	58
5.1.3 Status of Open Items from In-Field Verifications .....	58
5.2 SEISMIC DESIGN METHODOLOGY .....	59
5.2.1 Status of Topical Report-1 .....	59
5.2.2 Status of Topical Report-2 .....	59
5.2.3 Status of Topical Report-3 .....	59
5.3 THERMAL-MECHANICAL EFFECTS .....	60
5.3.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans .....	60
5.3.2 Other Related Items .....	60
5.4 DESIGN AND LONG-TERM CONTRIBUTION OF SEALS TO PERFORMANCE .....	60
5.4.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans .....	60
5.4.2 Other Related Items .....	61
5.5 OTHER OPEN ITEMS NOT COVERED UNDER THE FOUR SUBISSUES ..	61
5.5.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans .....	61
5.5.2 Status of Open Items from the Annotated Outline .....	61
6.0 LIST OF REFERENCES .....	63
APPENDIX .....	A-1

## LIST OF FIGURES

Figure		Page
1	Inputs from repository design thermal-mechanical engineering subissues to postclosure performance .....	9
2	Proposed repository subsurface layout [from CRWMS M&O (1997a)] .....	29
3	Rock-mass quality (Q) profile used in the analysis .....	31
4	Distribution of permanent (i.e., inelastic) strain intensity around emplacement drifts with degraded rock strength properties and nondegraded concrete lining .....	33
5	Distribution of permanent (i.e., inelastic) strain intensity around emplacement drifts with degraded rock strength properties and concrete lining .....	34
6	Normalized rock properties as a function of rock-mass quality (Q) .....	35
7	Distribution of principal stresses after drift excavation .....	41
8	Distribution of principal stresses after 100 years of heating .....	42
9	Distribution of yielding after drift excavation .....	44
10	Distribution of yielding after 100 years of heating .....	45
11	Rockfall simulated by dynamic analysis of a single drift in a rock-mass with irregular joint pattern after subjecting to 0.25 sec of dynamic load .....	46
12	Rockfall simulated by dynamic analysis of a single drift in a rock-mass with irregular joint pattern after subjecting to 1.0 sec of dynamic load .....	47
13	Flowchart highlight SEISMO calculation .....	48

**LIST OF TABLES**

<b>Table</b>		<b>Page</b>
<b>1</b>	<b>Relationship between repository design and thermal-mechanical effects on key technical issues and the U.S. Department of Energy repository safety strategy . . . . .</b>	<b>7</b>

### **ACKNOWLEDGMENTS FOR REVISION 0**

Revision 0 of the Issue Resolution Status Report (IRSR) was prepared by M.S. Nataraja, Senior Geotechnical Engineer, Division of Waste Management (DWM), Engineering and Geosciences Branch (ENGB). The author acknowledges the supervision provided by R. Weller (Section Leader), N.K. Stablein (Acting Branch Chief), and the guidance provided by the High-Level Waste (HLW) Review Board. E. Barbely provided her usual enthusiastic secretarial support. A number of key technical issue leads have provided inputs at various stages of completion of this IRSR. The Performance Assessment (PA) and Integration Section of the PA and HLW Integration Branch reviewed the drafts and assisted the author in making this IRSR uniform with the other current IRSRs. Lastly, C.W. Reamer, in the Office of the General Counsel, reviewed the draft for any legal objections.

### **ACKNOWLEDGMENTS FOR REVISION 1**

Revision 1 of the IRSR was prepared by U.S. Nuclear Regulatory Commission (NRC) staff M.S. Nataraja, DWM/ENGB, and S.M. Hsiung, G.I. Ofoegbu, R. Chen, A. Ghosh, and A.H. Chowdhury, Center for Nuclear Waste Regulatory Analyses. D. Rom, DWM, Uranium Recovery Branch, conducted the necessary NRC/U.S. Department of Energy (DOE) interactions and documented the progress made by the DOE under the subissue of design control process. P. Chaput, a summer intern with DWM, helped synthesize the inputs from several contributors. The authors thank W. Patrick for his technical review, B. Sagar for his programmatic review and N.K. Stablein and R. Weller for their management reviews. Inputs and review comments provided by various KTI teams are greatly appreciated. Thanks also go to J. Wike for assisting with the word processing and to B. Long and B. Ford, Southwest Research Institute, Publications Services, for editorial reviews.



## **1.0 INTRODUCTION**

One of the primary objectives of the U.S. Nuclear Regulatory Commission (NRC) refocused preclicensing program is to direct its activities toward resolving the 10 key technical issues (KTIs) it considers to be most important to repository performance. This approach is summarized in Chapter 1 of "NRC's High-Level Radioactive Waste Program Annual Progress Report: Fiscal Year 1996" (Center for Nuclear Waste Regulatory Analyses, 1997). Other chapters of this document address each of the 10 KTIs by describing the scope of the issue and subissues, path to resolution, and progress achieved during fiscal year (FY) 1996.

Consistent with existing regulatory requirements (RRs) and a 1992 agreement with the U.S. Department of Energy (DOE), staff-level issue resolution can be achieved during the preclicensing consultation period, however, such resolution at the staff level would not preclude the issue being raised and considered during the licensing proceedings. Issue resolution at the staff level during preclicensing is achieved when the staff has no further questions or comments (i.e., open items) at a point in time, regarding how DOE's program is addressing an issue. There may be some cases where resolution at the staff level may be limited to documenting a common understanding regarding differences in NRC's and DOE's points of view. Furthermore, pertinent additional information could raise new questions or comments regarding a previously resolved issue.

An important interim objective of the staff efforts toward issue resolution is to provide DOE with feedback regarding issue resolution, before the viability assessment (VA). Issue Resolution Status Reports (IRSRs) are the primary mechanism that the staff will use to provide feedback to DOE regarding progress toward resolving the subissues comprising the KTIs. IRSRs include: (i) acceptance criteria and review methods for use in issue resolution and regulatory review; (ii) technical bases for the acceptance criteria and review methods; and (iii) the status of resolution including where the staff currently has no comments or questions, as well as where it does. Additional information is also contained in the staff's annual/periodic progress reports, which summarize the significant technical work toward resolution of all KTIs during each reporting period. Finally, open meetings and technical exchanges with DOE provide opportunities to discuss issue resolution, identify areas of agreement and disagreement, and develop plans to resolve such disagreements.

In addition to providing feedback to DOE, the primary objective of the IRSRs is to serve as guidance to the staff for reviewing information in DOE's VA. The staff also plans to use the IRSRs in the future to develop the Yucca Mountain (YM) review plan (RP) for the repository license application (LA).

Each IRSR contains six sections, including this Introduction in Section 1.0. Section 2.0 defines the KTI, all the related subissues, and the scope of the particular subissue or subissues addressed in the IRSR. Section 3.0 discusses the importance of the subissue to repository performance, including: (i) qualitative descriptions; (ii) reference to a total system performance assessment (TSPA) flowdown diagram; (iii) results of available sensitivity analyses; and (iv) relationship to DOE's repository safety strategy (RSS) (i.e., DOE's approach to its safety case). Section 4.0 provides the review methods and acceptance criteria, which indicate the basis for resolution of the subissue and will be used by the staff in subsequent reviews of DOE's submittals. These

acceptance criteria are guidance for the staff and, indirectly, for DOE as well. The technical basis for the acceptance criteria are also included to further document the rationale for the staff decisions. Section 5.0 concludes the report with the status of resolution, indicating those items resolved at the staff level and those items remaining open. These open items will be tracked by the staff, and resolution will be documented in future revisions of the IRSR. Finally, Section 6.0 includes a list of pertinent references.

## **2.0 KEY TECHNICAL ISSUE AND SUBISSUES**

### **2.1 PRIMARY ISSUE**

The primary issue of the Repository Design and Thermal-Mechanical Effects (RDTME) KTI is the adequacy of design, construction, and operation of the geologic repository operations area (GROA)—including seals for the shafts and boreholes—to meet the preclosure and postclosure performance objectives, taking into consideration the long-term thermal-mechanical (TM) processes. Specific design requirements and performance objectives for the repository are currently provided in 10 CFR Part 60. The site-specific regulations for the proposed YM repository to be issued as 10 CFR Part 63, which are currently in preparation, will be performance based. Consequently, 10 CFR Part 63 is anticipated to introduce modifications to design requirements, which will be considered in future revisions of this IRSR.

Consideration of the time-dependent TM coupled response of a jointed rock mass is central to repository design and necessary for performance assessment (PA) at the YM site. Consequently, that is the focus of both the preclosure and postclosure elements of this KTI. Design for adequate postclosure performance requires an understanding of the TM response of the jointed rock mass over an anticipated compliance period of 10,000 years. Long-term TM response is anticipated to influence hydrological properties in the vicinity of the emplacement drifts, waste package (WP) degradation, radionuclide release within the engineered barrier system (EBS), performance of seals, and flow into and out of the emplacement drifts. Design for the preclosure operation period of approximately 100–150 years requires an understanding of TM response of the jointed rock mass as it influences drift, shaft, and ramp stability, and waste retrievability. In this regard, it should be noted that DOE recently announced that it may implement an extended monitored geologic disposition program that could result in continued underground access for up to 300 years (U.S. Department of Energy, 1998e). In such a case, the TM effects on the stability of emplacement drifts could potentially be more severe. Consequently, an understanding on the TM response of the jointed rock mass becomes more important.

### **2.2 SUBISSUES**

The RDTME KTI has been divided into subissues to facilitate addressing the breadth of technical concerns comprising the issue. It is expected that resolution of the subissues will lead to resolution of the primary issue. These subissues address topics that are of regulatory concern because they are, in general, at the limit of or beyond conventional engineering experience and may jeopardize the safe preclosure operations or effective postclosure performance of the GROA, or both. Although clearly interrelated, the subissues have been formulated to minimize redundancy. Alternatives, such as organizing the subissues by repository subsystem, would require, for example, seismic effects to be considered separately for the drifts, the seals, and the WPs, thus introducing extensive duplication. The four main subissues are stated in the next paragraph, with important considerations in each subissue noted parenthetically, as appropriate:

**Design Control Process—Implementation of an Effective Design Control Process Within the Overall Quality Assurance (QA) Program**

**Seismic Design Methodology**—Design of the GROA for the Effects of Seismic Events and Direct Fault Disruption (including implications for drift stability, key aspects of emplacement configuration (i.e., fault offset distance, retrievability, and WP damage))

**Thermal-Mechanical Effects**—Consideration of TM Effects on Underground Facility Design and Performance (including implications for drift stability, key aspects of emplacement configuration that may influence thermal loads and associated thermomechanical effects, retrievability, and flow into and out of emplacement drifts and fault setback distance)

**Design and Long-Term Contribution of Seals to Performance**—Design and Long-Term Contribution of Repository Seals in Meeting the Postclosure Performance Objectives (including implications for inflow of water and release of radionuclides to the environment)

Each of the four subissues may, in turn, be addressed in terms of its principal components. For example, although implementation of an effective design control process permeates the entire DOE's high-level waste (HLW) repository program, it may be addressed in two components: the design control process employed for the design, construction, and operation of the exploratory studies facility (ESF) and the design control process used for the design, construction, and operation of the GROA. Each component must be consistent with DOE's Quality Assurance Program (QAP). Furthermore, to the extent that the ESF is incorporated into the repository, its design must fulfill the requirements for preclosure safety and postclosure performance.

Similarly, the following three components have been identified for the second subissue: (i) DOE's methodology to assess seismic and fault displacement hazard; (ii) DOE's seismic design methodology; and (iii) seismic and fault displacement inputs to the design and PAs. Note that DOE has elected to consider preclosure aspects of seismic design separate from those for postclosure, although the repository design eventually must be shown to meet both sets of requirements. While this IRSR deals with the second component (i.e., design methodology) and parts of the third component (i.e., design inputs), a companion IRSR within the Structural Deformation and Seismicity KTI addresses the remaining components.

The third subissue—consideration of TM effects in design and PAs—has three important components: (i) stability of the underground excavations with regard to safety during the preclosure period, waste retrievability, and potential adverse effects on emplaced wastes; (ii) effect of seismically induced rockfall with respect to WP performance; and (iii) changes of emplacement drift geometries and hydrological properties surrounding emplacement drifts due to TM perturbation of the rock mass. All of these components have broad design and performance implications.

The fourth subissue deals primarily with postclosure performance. It is concerned with three main topics: (i) design and construction of seals (including material selection); (ii) long-term stability of seals and their components; and (iii) importance of seals in meeting the postclosure performance objectives. The RDTME and TSPA KTIs will jointly address these topics in the future. The status of this subissue may change depending on the approach taken by the new 10 CFR Part 63 which is currently under development.

Rev 0 of this IRSR addressed the specific questions related to the design control process employed by DOE for the ESF, and the (preclosure) seismic design methodology proposed by DOE

for the YM site. The staff found that the design control process employed by DOE for the ESF was acceptable and the GROA preclosure seismic design methodology proposed by DOE was likewise acceptable.

This version of the RDTME KTI IRSR (Revision 1) addresses the following topics: (i) the adequacy of the design control process employed by DOE for the GROA; (ii) the treatment of the potential for seismically induced rockfall in design and PA; and (iii) consideration of potential changes of emplacement drift geometries and hydrological properties surrounding emplacement drifts in design and PA. The development and documentation of acceptance criteria, review methods, and technical bases for the remaining components of the subissues will continue in subsequent revisions of this IRSR as information becomes available.

### **3.0 IMPORTANCE OF ISSUE TO REPOSITORY PERFORMANCE**

#### **3.1 RELATIONSHIP OF THE ISSUE WITH U.S. DEPARTMENT OF ENERGY REPOSITORY SAFETY STRATEGY**

DOE has formulated several hypotheses that, if confirmed, would demonstrate that waste can be contained and isolated at the proposed YM site for long periods of time [DOE's RSS, dated January 1998, (U.S. Department of Energy, 1998a)]. These hypotheses include:

- (1) Seepage into the emplacement drifts will be a fraction of the percolation flux;
- (2) Bounds can be placed on thermally induced changes in seepage rates;
- (3) The amount of seepage that contacts WPs can be limited;
- (4) Engineered enhancements can extend the long period of containment of the inner barrier;
- (5) The amount of water that contacts waste can be limited;
- (6) The amount of movement of faults through the repository horizon will be too small to bring waste to the surface, and too small and infrequent to significantly impact containment during the next few thousand years; and
- (7) The severity of ground motion expected in the repository horizon for tens of thousands of years will only slightly increase the amount of rockfall and drift collapse.

In addition to the above strategies, DOE has made an assumption that the preclosure facilities (both surface and underground) can be designed to withstand the effects of vibratory ground motion and fault displacements; and these facilities can be built and operated with minimal maintenance over a period of 150 years. It should be noted in this regard that DOE recently announced it may implement an extended monitored geologic disposition program that could result in continued underground access for up to 300 years (U.S. Department of Energy, 1998e).

Testing these hypotheses and design assumptions requires an understanding of DOE's design and the effects of time-dependent TM coupled processes taking place in the jointed rock mass on the GROA, including WPs and seals. The relationships between the RDTME subissues and DOE's RSS are indicated in Table 1.

#### **3.2 IMPORTANCE TO PRECLOSURE PERFORMANCE**

##### **3.2.1 Design Control Process**

The QA requirements for the GROA are specified in 10 CFR Part 60 (Subpart G); the YM specific regulation currently under development is anticipated to retain these or similar QA provisions. The

**Table 1. Relationship between repository design and thermal-mechanical effects on key technical issue and the U.S. Department of Energy repository safety strategy**

	Hypotheses from Repository Safety Strategy						
	Seepage Into Drifts	Changes In Seepage Rates	Limited Seepage to Waste Packages	Engineered Enhancements	Limited Water to Waste	Movement of Faults	Ground Motion
Design Control Process	X	X	X	X	X	X	X
Seismic Design Methodology					X	X	X
Thermal-Mechanical Effects	X	X	X				
Long-Term Performance of Seals	X		X			X	X

QA requirements are based on the criteria of Appendix B of 10 CFR Part 50, and are applied to activities such as site characterization and repository design, construction, operations, decommissioning, and closure. Appendix B includes 18 criteria that comprise an effective QAP. The application of criterion III for "design control" of repository structures, systems, and components (SSCs) is of particular interest here.

Design control is one of the most important of the 18 criteria because it defines the means by which the design organization will establish a design baseline, track changes with respect to the baseline, and document that RRs related to design have been fulfilled. Meeting the QA requirements is an important aspect of demonstrating compliance with preclosure design criteria during the licensing review. Prelicensing reviews by NRC staff have identified several weaknesses in DOE's QAP and design control process (Bernero, 1989). Therefore, the staff considers implementation of an effective design control process by DOE to be an important programmatic issue with major preclosure performance implications. These weaknesses have also led to further examination by the staff to determine if the shortfalls of the program have been and, are being addressed in a satisfactory manner for all repository design activities including the ESF design, construction and operation. Appropriate design control is considered important for the ESF because it is anticipated to eventually become a part of the GROA.

### 3.2.2 Seismic Design Methodology

There are two preclosure performance objectives in Part 60, namely, meeting 10 CFR Part 20 requirements [Section 60.111(a)] and meeting the retrievability requirements [Section 60.111(b)]. Similar provisions are anticipated to be retained in the YM specific regulation currently under development. DOE's designs for both the surface and underground facility SSCs must adequately

address seismic effects and direct fault disruption to demonstrate compliance with these two performance objectives. Failure of any of the structures, systems, and components important to safety (SSCIS), due to vibratory ground motion or direct fault displacement, could severely affect GROA performance during the preclosure period of 100 to 150 years, with a possible extension to 300 years. Because of this long operational period for which there is no regulatory experience for meeting public and worker radiation safety requirements and because of the unusual requirements associated with retrievability of HLW, the seismic design is considered one of the most important factors affecting preclosure performance.

### **3.2.3 Thermal-Mechanical Effects**

Consideration of TM effects is important in the design of an effective and efficient ventilation system, which in turn is very important to meeting radiological safety objectives during the operational period. Thermal loads also have considerable effects on the stability of underground openings (Ahola et al., 1996) which in turn affects ongoing access and monitoring, as well as waste retrievability, should that become necessary.

Furthermore, seismic effects will take place under the prolonged thermal environment. Depending on waste loading and other design features, the combined effect of thermal loads and seismic events may degrade the rock mass surrounding emplacement drifts. The rock mass may need to be reinforced with ground supports (e.g., concrete liners) to ensure operational and radiological safety of workers during the preclosure period. The condition of the rock mass will also influence retrievability, if liners or other support systems are not designed adequately to maintain stable openings. Consequently, the evaluation of TM effects is considered important to preclosure performance.

### **3.2.4 Design and Long-Term Contribution of Seals to Performance**

This subissue is of primary concern to postclosure performance and does not impact preclosure.

## **3.3 IMPORTANCE TO POSTCLOSURE PERFORMANCE**

Figure 1 highlights the inputs provided by the four subissues of RDTME KTI to postclosure PA. Subsections 3.3.1–3.3.4 describe the importance of the four subissues to postclosure performance.

### **3.3.1 Design Control Process**

DOE's design control process plays a major role in demonstrating compliance with the design requirements and performance objectives. Although the majority of the current design requirements in Part 60 are explicitly focused on preclosure performance, many (especially for the underground facility) play a significant role in meeting postclosure performance requirements as well. Thus, the design control subissue dealing with traceability of design changes and flowdown from RRs is equally important to postclosure performance. The design control process subissue directly or indirectly affects all the key elements of system abstraction under the engineered system shown in the flowdown diagram of TSPA (Figure 1).



**TOTAL SYSTEM**

**REPOSITORY PERFORMANCE**  
(Individual Dose)

**SUBSYSTEMS**

(Includes Defense-in-Depth Framework)

**ENGINEERED SYSTEM**

**GEOSPHERE**

**BIOSPHERE**

Components of Subsystem

**Engineered Barriers**

**UZ Flow & Transport**

**SZ Flow & Transport**

**Direct Release**

**Dose Calculation**

**KEY ELEMENTS OF SUBSYSTEM ABSTRACTION**

- WP Corrosion (Temperature, Humidity & Chemistry)
- Mechanical Disruption of WP (Seismicity, Faulting and Rockfall)
- Quantity & Chemistry of Water Collecting Waste Forms
- PPH Release Rates & Solubility Limits

- Fracture Vs Matrix Flow
- Spatial & Temporal Distribution of Flow
- Retardation in Fractures

- Volumetric Flow in Production Zones
- Retardation in Production Zones & Alluvium

- Probability of Volcanism
- Entrainment of Waste in Ash
- Airborne Transport of Ash

- Dilution of Plume in Groundwater (Well Pumping)
- Dilution of Plume in Soil (Plowing & Surface Processes)
- Location & Lifecycle of Critical Group

Figure 1. Inputs from repository design thermal-mechanical engineering subissues to postclosure performance

### **3.3.2 Seismic Design Methodology**

Design of the GROA for the effects of seismic events and direct fault disruption has several postclosure implications. The particular effects of seismic events and direct fault disruption, and consequently their importance to long-term performance, are design dependent. In general, the GROA design and the methodology used to develop that design must consider seismic effects on the WPs and other engineered barriers and key aspects of the emplacement configuration, particularly fault offset distance.

The WPs, backfill, drip shields, and other elements of the EBS that DOE may choose to deploy, as well as the surrounding rock mass, will all be subjected to repeated episodes of seismic loading during the postclosure period. The potential effects on these engineered and natural components are complex functions of the presence and properties of the various barriers. For example, degradation of rock mass strength and consequent rockfall could be quite important if backfill is absent, but have relatively little effect if backfill is present. In contrast, the absence of backfill could tend to mitigate the effects of direct fault displacement because of the large free space available around the WP. Backfill could act to more directly transfer load to the WPs, thus having a potentially detrimental effect with respect to direct fault disruption.

These examples highlight the complexity of design considerations related to seismic effects and direct fault disruption. Furthermore, they point to the need for the PA methodology to be sufficiently flexible to address the performance implications of a range of possible designs.

In subsequent revisions of the IRSR, sensitivity studies employing the Total Performance Assessment (TPA) code (Manteufel et al., 1997) will be used to evaluate the effects of these phenomena on repository performance. Processes, such as rockfall and mechanical disruptions to WPs and other EBS components, will be evaluated. The seismic design methodology subissue provides inputs to the "mechanical disruption of WP" key element of the flowdown diagram for TSPA (Figure 1).

### **3.3.3 Thermal-Mechanical Effects**

The potential influences of TM processes on underground design and performance during the postclosure period come into play beginning with the early stages of construction. The construction methods employed for the underground facility, the geometry of underground openings (shape, size, orientation, slopes, and waste emplacement configuration), the distribution of thermal load, presence or absence of backfill, and the quality and quantity of roof support are some of the parameters that may have a significant effect on the long-term performance of the repository (Ahola et al., 1996). As waste emplacement proceeds, TM effects begin to manifest in the EBS and surrounding rock mass. TM stresses resulting from excavation-induced changes and heat produced by the WPs will be superimposed on the existing *in situ* lithologic stresses throughout the postclosure period. TM effects combined with seismic loads may affect drift stability, particularly with unbackfilled designs. The effects may also cause rock to fall from the rock mass surrounding the emplacement drifts. Potential rockfall is a concern that could affect WP performance.

In addition, the effect of TM interactions on the hydrologic properties of the surrounding rock mass must be considered in design and PA, given that ground supports (including concrete liners) are currently designed to meet the requirements for only preclosure performance. In assessing the

postclosure total system performance, DOE made it clear that the effectiveness of the ground support system will not be considered in the assessment. In other words, the ground support system is assumed to lose its function after closure. This approach is clearly conservative. However, by taking this approach, the potential effects on postclosure performance of deterioration of the rock mass surrounding emplacement drifts will need to be evaluated.

It is the current understanding that after the emplacement of waste, the drifts will be subjected to a sustained high state of stress for a long time (Ahola et al., 1996). This high state of stress results mainly from thermal loading and may lead to significant deterioration of the rock mass surrounding the emplacement drifts. Subsequent collapse of the rock mass may eventually occur. Such collapse will obviously change the geometry of the emplacement drifts and consequently change the capture area for seepage in the vicinity of the emplacement drifts. The collapse will also affect the hydrologic properties in the vicinity, and the local changes in hydrologic properties are likely to be large. It is obvious that these changes will affect the WP environment. Accordingly, an understanding of TM effects is important to the staff's independent evaluation of DOE's PA. Thus, the TM effects subissue provides direct inputs to all key elements under the EBS (Figure 1).

#### **3.3.4 Design and Long-Term Contribution of Seals to Performance**

Section 60.134 provides a specific design requirement that calls for appropriate material selection and design methods for borehole and shaft seals so that they do not become preferential pathways during the postclosure period. At the present time, it is not certain how important the seals will be in meeting the postclosure performance objectives at the YM site. The staff has taken a position that until DOE demonstrates that seals are unimportant from a postclosure performance perspective, or the staff efforts on TSPA suggest that seals do not significantly contribute to meeting the performance objectives, this subissue will remain open. The seal design subissue is expected to provide inputs to the "quantity and chemistry of water contacting waste form" key element in the flowdown diagram of PA (Figure 1).

## **4.0 REVIEW METHODS, ACCEPTANCE CRITERIA, AND TECHNICAL BASES**

Review methods and acceptance criteria for each of the four main subissues are presented and discussed in Sections 4.1 through 4.4. These criteria will also be used in reviewing DOE's VA and in evaluating the LA to ensure that the methods proposed by DOE have been properly implemented and the resulting design meets the pertinent RRs. The last subsection of each section provides a discussion of the technical bases for the acceptance criteria and review methods. Included are descriptions of DOE's approach, summaries of staff evaluations of DOE's approach, and results of independent work conducted by the staff.

### **4.1 IMPLEMENTATION OF AN EFFECTIVE DESIGN CONTROL PROCESS WITHIN THE OVERALL QUALITY ASSURANCE PROGRAM**

#### **4.1.1 Background**

The focus of this component of the RDTME IRSR is on the staff evaluation of DOE's implementation of design control process for design, construction, and operation of the ESF. According to the current Part 60 (Subpart G) Quality Assurance Program Requirement, QA comprises all those planned and systematic actions necessary to provide adequate confidence that the geologic repository and its subsystems or components will perform satisfactorily in service. Section 60.152 requires DOE to implement a QAP based on the criteria of appendix B of Part 60. The YM specific regulation currently under development is anticipated to retain these or similar QA provisions. As a result of past DOE-NRC interactions in the area of ESF/GROA design and associated QA concerns, NRC had identified serious deficiencies in DOE's design control process (Bernero, 1989).

It has long been recognized by NRC that it is impractical for the staff to conduct a thorough review of all DOE's design documents given the limited resources at NRC's disposal. Consequently, NRC has utilized a "vertical slice" (audit) approach in which the staff selectively reviews some important aspects of DOE's ESF/GROA design packages and observes DOE's internal reviews, looking for trends that can be used as examples to provide feedback and guidance to DOE. NRC has paid particular attention to the design of the ESF because it will eventually become a part of the GROA if the YM site is found to be suitable. Therefore, many RRs applicable to GROA would also be applicable to the ESF. In the past, DOE found it difficult to demonstrate to NRC the traceability of RRs and to provide the necessary documentary evidence to clearly show that all applicable requirements were indeed being applied to various design components. In order to thoroughly examine this issue, NRC conducted a phased in-field verification in 1995 to evaluate DOE's design control process.

There were a number of open items that resulted from this in-field verification and the past NRC-DOE interactions and from NRC's review of ESF-GROA design documents related to this subissue. All these open items are being monitored under the RDTME KTi, and a number of them were closed during FY96 as a result of staff reviews and interactions with DOE. Some of the main FY96 activities conducted to help resolve the remaining open items and subissues were reported under Section 7.3.2 of the "NRC's High-Level Radioactive Waste Program Annual Progress Report for Fiscal Year 1996" (Center for Nuclear Waste Regulatory Analyses, 1997).

#### **4.1.2 Review Methods**

The review method for the design control process subissue during the precicensing consultations consists of a combination of staff activities and DOE/NRC interactions. These activities and interactions include: (i) selective "vertical slice" review of design documents; (ii) review of the site characterization plan (SCP) and any test data gathered; (iii) attending meetings with DOE's design teams; (iv) observing DOE's audits and surveillances or its contractors; and (v) conducting independent audits, surveillances, and in-field verifications on focused topics. In addition, appropriate sections of the VA and LA will be reviewed using the acceptance criteria developed in this section of the IRSR to document the acceptability of DOE's design control process on an ongoing basis. The staff review of DOE's design control process will continue during repository construction and operation until final decommissioning of the facilities.

#### **4.1.3 Acceptance Criteria**

The staff will find DOE's design control process to be acceptable if the following generic criteria are satisfied:

- (1) The applicable RRs are identified;
- (2) The design bases associated with the RRs are defined;
- (3) The RRs of (1) and the design bases of (2) are appropriately translated into specifications, drawings, procedures, and instructions;
- (4) Appropriate quality standards are specified in the design documents;
- (5) Any deviations from the standards specified under (4) are properly controlled;
- (6) Measures are established for selection of materials, parts, equipment, and processes that are essential to functions of SSCs that are important to safety and waste containment and isolation;
- (7) Design interfaces are identified and controlled and appropriately coordinated among participating design organizations;
- (8) Procedures are established for review, approval, release, distribution, and revision of documents involving design interfaces;
- (9) Measures are established for verifying or checking the accuracy of design calculations (e.g., performing design reviews using alternate or simplified calculational methods);
- (10) If testing is employed for verification of design adequacy, the testing is conducted under the most adverse conditions anticipated;
- (11) The design verification is done by independent and qualified professionals who did not participate in the original design efforts; and

- (12) In addition to being applied to the original design, the design control process is also applied to design changes and to field changes, and the changes are properly documented.

#### **4.1.4 Technical Bases**

The review of DOE's design control process has been molded by a number of past and continuing review activities, interactions, and correspondence on this subissue. It is important to keep in mind the historical background drawn from repository preclicensing interactions and regulations of similar nuclear facilities that has provided additional technical and review bases to the staff. Some of the important reviews, activities, interactions, and correspondence are described below.

##### **4.1.4.1 Exploratory Studies Facility-Geologic Repository Operations Area Relationship**

The overall premise of staff reviews of DOE's design control process for the ESF is that the ESF will eventually become a part of the GROA if the YM site is found to be suitable for the disposal of HLW. Therefore, it is important that all site characterization activities, including the design, construction, and operation of the ESF be carried out in such a way that all RRs applicable to the GROA be considered applicable to ESF, unless it can be shown to be otherwise. The staff has used two main bases for judging the ESF construction and other testing activities: (i) design, construction, and operation of the ESF should not result in unmitigable impacts adversely affecting long-term waste containment of the EBS and isolation capabilities of the site; and (ii) design, construction, and operation of the ESF should not preclude gathering necessary site characterization information. In addition, the staff specifically looks for site characterization activities that might have a potential for test-to-test, construction-to-test, or construction-to-construction interference and, thus, adversely affect containment and isolation or DOE's ability to gather crucial data.

The staff has effectively applied these criteria to judge the adequacy of DOE's SCP and various study plans (SPs) at different stages of the program and raised a number of objections, comments, and questions that have significantly affected DOE's program over the years. In response, DOE has developed a process that requires a "Determination-of-Importance-Evaluation" (DIE) at important stages of ESF construction and testing. Each DIE consists of a "Test-Interference-Evaluation" and a "Waste-Isolation-Evaluation," the results of which are used to make crucial decisions before major site activities are initiated. The staff may use the results of DIE reviews as bases for selecting certain design/site characterization activities for focused review.

##### **4.1.4.2 Regulatory Basis**

As mentioned earlier, Appendix B to Part 50 (Quality Assurance Criteria for Nuclear Power Plants adopted by Part 60 and expected to be adopted by Part 63) provides the underpinning technical/regulatory basis for the staff review methods and acceptance criteria. Specifically, criterion III of the 18 criteria described in Appendix B has been restructured into the specific criteria (listed under Section 4.1.3) for reviewing DOE's design control process. These criteria will continue to be used to review DOE's design control process employed during the GROA design, construction, and operation.

#### **4.1.4.3 Staff Technical Positions**

Additional bases are found in the staff technical positions (STPs) on: (i) Items and Activities in the "HLW Geologic Repository Program Subject to QA Requirements" (NUREG-1318, Duncan et al., 1988); and (ii) "Regulatory Considerations in the Design and Construction of the Exploratory Shaft Facility" (NUREG-1439, Gupta et al., 1991).

NUREG-1318 provides guidance on approaches acceptable to the staff for identifying items and activities subject to QA in the HLW repository program for preclosure and postclosure phases. NUREG-1439 provides guidance on identifying RRs applicable to the ESF and describes an approach acceptable to the staff for implementation of applicable Part 60 RRs. [Note: While NUREG-1318 needs updating, the underlying principles of the STP still apply. Also, these STPs will be reexamined in light of Part 63 requirements that are currently under development.]

#### **4.1.4.4 Quality Assurance Audits and Surveillances**

From time to time, DOE conducts QA audits and surveillance of its contractors and subcontractors. The staff is invited to observe such audits and provide feedback. Over the years, the staff has chosen to observe numerous DOE audits and written Audit Observation Reports in which the staff has documented either its satisfaction or concerns related to particular issues. The staff has also conducted a limited number of independent audits of DOE and/or its supporting organizations and documented the results of such audits in trip/audit reports. Such reports and reviews are used as the bases for making generalized observations on the overall effectiveness of DOE's QAP.

#### **4.1.4.5 Site Characterization Review**

The staff has conducted detailed technical and programmatic reviews of DOE's SCP and several associated SPs. Review comments have been documented in NRC's documents, such as the Site Characterization Analysis (SCA) and SP reviews. The results of such reviews have been used by the staff as bases for identifying concerns related to DOE's QA and technical programs.

#### **4.1.4.6 Design Reviews**

The staff has participated as observers during DOE's design reviews in which the participating design organizations coordinate their individual efforts and integrate different aspects of ESF and GROA design. Such design reviews used to take place at approximately the middle of a major effort (known as 50 percent design review) and towards the end (termed 90 percent design review). Depending on the design topic and the availability of resources, the staff has participated as observers and provided feedback to DOE on various aspects of ESF design. The staff has also, on a limited basis, conducted independent design reviews of specific design packages and documented the results of each review. For example, in accordance with NRC's "vertical slice approach," the staff has reviewed selected portions of ESF Design Requirements (ESFDRs), and various ESF Design Packages, such as Packages 2b and 2c, and DOE's Regulatory Compliance Review Report (RCRR). The results of the RCRR review were transmitted to DOE on December 14, 1995 (Nataraja et al., 1995). The results of such observations and limited independent reviews have been used as technical bases for staff conclusions on the effectiveness of DOE's designs and design control process.

#### **4.1.4.7 Meetings**

DOE and NRC conducts several technical meetings on topics of mutual interest under the existing precicensing agreement (Shelor, 1993). DOE makes presentations on several aspects of QA and design, and the staff provides feedback to DOE during or after such meetings. The meeting minutes document issues and concerns that are also used as bases for staff positions on the effectiveness of DOE's program. Appendix 7 meetings are effectively used by the staff to conduct free and open discussions on topics of mutual interest. Although no formal meeting minutes are kept of Appendix 7 meetings, the information is used as technical bases for staff conclusions regarding DOE's design control process.

#### **4.1.4.8 On-Site Representatives' Inputs**

NRC's on-site representatives (OSRs) attend a number of DOE's technical and management meetings and observe day-to-day proceedings at DOE and its Management and Operating (M&O) contractor offices. They also have access to site activities on a regular basis. They can acquire and review DOE's documents that are still under preparation and, thus, can provide feedback to DOE on a real-time basis. The OSR's reports are also used as bases for staff conclusions on DOE's design control process.

#### **4.1.4.9 Site Visits and In-Field Verification**

The staff visits the ESF periodically and observes construction and testing activities, reports on important matters, and provides written feedback in its trip reports. The staff has also developed a procedure for conducting in-field verification of DOE activities (such activities may include design, construction, or operation). These procedures are part of the HLW Division Manual, Chapter 0330 (U.S. Nuclear Regulatory Commission, 1995a). The primary objective of the in-field verification is to determine if DOE is acceptably implementing the site characterization program and constructing and operating the ESF. The first in-field verification of DOE's program was conducted in phases starting in April 1995, and the results were documented in the in-field verification report [NRC-VR-95-1, (U.S. Nuclear Regulatory Commission, 1995b)]. This report documents the objective evidence and technical bases for staff conclusions on the adequacy of ESF design and DOE's design control process.

#### **4.1.4.10 Relevant U.S. Department of Energy-U.S. Nuclear Regulatory Commission Correspondence and Interactions**

The staff has actively pursued the design control process subissue beginning with NRC's objection to DOE's SCP, specifically, the ESF Title-I design control process. The extensive correspondence and exchanges between NRC and DOE that have provided additional bases for the review methods and review criteria and positions taken by the staff on this subissue are listed in the appendix.

#### **4.1.4.11 Summary of Technical Bases**

The subissue regarding DOE's design control process is a very important and highly complex one that historically has played an important role in helping NRC staff monitor DOE's site characterization program. Staff activities at the management, programmatic, and technical levels have been used to evaluate the adequacy of the ESF design and the design control process in the



context of the overall GROA design and DOE's QAP. The staff will continue to monitor DOE's program by conducting focused reviews of selected vertical slices of GROA design documents prepared by DOE. The historical background that can be traced in the various DOE/NRC correspondences and interaction minutes will continue to serve as bases for future staff reviews.

#### **4.1.5 U.S. Department of Energy's Design Control Process for the Geologic Repository Operations Area**

##### **4.1.5.1 Selective Review and Results**

To evaluate DOE's progress in implementing the design control process for the GROA, an Appendix 7 meeting was held at the M&O Contractor's office during the week of June 8, 1998. The purposes of the meeting were to examine a number of design documents at different stages of preparation, and to select a limited number of them for comparison with the acceptance criteria listed in Section 4.1.3 of this IRSR.

Six documents considered to be both adequately developed and sufficiently representative of those describing underground facility systems and surface facility systems were identified for further review. The six documents reviewed in detail were: (i) Overall Development and Emplacement Ventilation System; (ii) Repository Subsurface Layout Configuration Analysis; (iii) Repository Ventilation System; (iv) Waste Handling Systems Configuration Analysis; (v) Site Gas/Liquid Systems Technical Report; and (vi) Surface Nuclear Facilities HVAC Analysis.

The M&O Contractor also provided the following additional documents to facilitate the review: (i) a current version of the Controlled Design Assumptions (CDA) Document; (ii) a matrix which interrelates VA Product documents with the CDA; (iii) Repository Design Requirements Document (U.S. Department of Energy, 1994c); and (iv) Engineered Barrier Design Requirements Document (U.S. Department of Energy, 1994d). These documents were used for comparison with design control process criteria.

For each of the six systems designated for review, the relevant technical documents were examined against the acceptance criteria of Section 4.1.3. Where specific design criteria and assumptions were cited, cross-checks between documents were made to verify source documentation. The document citations for sections dealing with design criteria and design assumptions were also verified to relate to the topic discussed therein. Each reference section was cross-checked for each individual use of a reference to verify that the appropriate document was cited.

Staff verified that the checking processes are autonomous, and that the individuals performing design system checks were both independent and technically qualified. The staff found and examined evidence that verification records were maintained by the M&O. As a result of the Appendix 7 meeting and the document review by staff, it was concluded that DOE is currently maintaining adequate oversight of the design control process. However, there is one area of concern, that being the control of changes to an original design and proper documentation of such changes.

#### 4.1.5.2 Comparison with Acceptance Criteria

During the June 1998 meeting, the 12 acceptance criteria discussed in Section 4.1.3 were used by NRC staff as the guide on which to base any conclusions. Each of the M&O sources was checked for discrepancies dealing with the 12 criteria. Results of comparison with each criterion are listed below to illustrate the review process used by the staff. The majority of the items reviewed showed general agreement with the review criteria. Total agreement with all the review criteria, however, could not be established because of the evolving nature of the GROA design.

- (1) The applicable RRs are identified: In every system document reviewed, the RRs were listed in Section 4.4 of the respective documents (CRWMS M&O, 1997a,b,e,g,h, 1998a).
- (2) The design bases associated with the RRs are defined: In Section 4.2.1 of the Surface Nuclear Facilities HVAC Analysis, "The WHB and WTB ventilation systems are to accomplish the following confinement functions in accordance with 10 CFR 60.131" [waste handling building (WHB); waste treatment building (WTB)]. The analysis then describes the functions the ventilation system will accomplish (e.g., minimizing the spread of radioactive material in the air) (CRWMS M&O, 1997g).
- (3) The RRs of (1) and the design bases of (2) are appropriately translated into specifications, drawings, procedures, and instructions: It should be noted that some of the data used in the design are yet to be confirmed, or are to be used only to determine space and size requirements. Some examples of what has been done to date for each category of interest include:
  - a. Specifications: Using the 85 MTU (metric ton of uranium) value for the spent nuclear fuel, the drift spacing value of 28 m was derived (CRWMS M&O, 1997b).
  - b. Drawings: In the Repository Subsurface Layout Configuration Analysis, Figure 7-2 shows the repository layout with respect to geological boundaries, and incorporates its Criterion 4.2.3 (Deleterious Rock Movement).
  - c. Procedures: Since the design is still in early stages, procedures are yet to be developed.
  - d. Instructions: Section 7.3 of the proposed wet waste handling system description of the Waste Handling Systems Configuration Analysis implements the need to minimize exposure to personnel which is a requirement of 10 CFR 60.131.
- (4) Appropriate quality standards are specified in the design documents: Every design/technical document reviewed has a QA Section (Section 2) that lists the governing QA documents. Section 4 of the system analyses lists the assumptions, criteria, design parameters, and codes and standards that will form the basis for the document (CRWMS M&O, 1997a,b,e,g,h, 1998a).
- (5) Any deviations from the standards specified under (4) are controlled properly: The use of the terms TBV (to be verified) and TBD (to be determined) is stated in Section 2 of all the technical documents; these are used when a specific value is unknown (i.e., cannot be measured at this time) or when the values are preliminary in nature (CRWMS M&O, 1997a,b,e,g,h 1998a). There are instances where the (assumed) values differ from those

listed in the standards, but this is because the current standards were revised after the design documents were finalized. The future revisions are expected to reconcile the differences.

(6) Measures are established for selection of materials, parts, equipment, and processes that are essential to functions of SSCs that are important to safety and waste containment and isolation: Section 4.2.9 in Overall Development and Emplacement Ventilation Systems states, "Subsurface repository operation involves continuous ventilation of repository airways until closure. To provide radiological protection to repository workers, and to have a positive control on potential radiological exposure to as low as is reasonably achievable, the subsurface repository ventilation design will include isolated return airways, isolation barriers and separate ventilation between emplacement and development." In Section 7.4.8 of the document, the general equipment and processes which achieve compliance with Section 4.2.9 are described, including the maintenance of a pressure differential, the use of ventilation barriers, and the standards for a primary ventilation fan. Materials and specific parts and equipment are not discussed due to the early stages of the design.

(7) Design interfaces are identified and controlled and appropriately coordinated among participating design organizations: DOE has developed Quality Administrative Procedures NLP-3-34, Mined Geological Disposal System (MGDS) Interface Control Documentation. DOE has defined four levels of MGDS interface, as described in its Configuration Management Plan. The four interface levels are designated A, B, C, and D. Levels A and B are *external* to a system, and levels C and D are *internal* (Ashlock, 1997):

Level A—Interfaces between the CRWMS and other external systems (e.g., waste producers).

Level B—Interfaces between the CRWMS elements (Repository, Transportation, Storage, and Waste Acceptance).

Level C—Interfaces within an element (MGDS) and between its systems (e.g., Surface Repository, Subsurface Repository, WP, and ESF configuration items).

Level D—Interfaces between subsystems internal to a MGDS system (Ashlock, 1997).

The interface control documents meet the standards of this criterion by maintaining guidelines for the interfacing organizations to follow.

(8) Procedures are established for review, approval, release, distribution, and revision of documents involving design interfaces: M&O's QAP NLP-3-34 provides instructions for the management of Level C interfaces on the MGDS. During the Appendix 7 meeting, NRC staff were informed of the following: until such time as formal guidelines for the management of Level A and B interfaces are approved by DOE, a procedure similar to that of NLP-3-34 is being used for Level A and B interfaces (it is expected that formal written procedures similar to NLP-3-34 will be in place in the near future for Level A and B interfaces); Level D interfaces, which do not follow management by procedure NLP-3-34, are controlled by a process which requires formal design review by the parties potentially affected by the design in question (Ashlock, 1997).

- (9) Measures are established for verifying or checking the accuracy of design calculations (e.g., performing design reviews using alternate or simplified calculational methods): The M&O established PCG verifies the design calculations through independent reviewers. The PCG is discussed in-depth under criterion 11.
- (10) If testing is employed for verification of design adequacy, the testing is conducted under the most adverse conditions anticipated: The application of this criterion cannot be verified at this time since the systems are in design stages only. Application of this criterion will be verified and documented in future revisions to this IRSR.
- (11) The design verification is done by independent and qualified professionals who are not among those who participated in the original design efforts: To address the issue of reviewer independence, the M&O established an independent Product Checking Group (PCG). The PCG verifies the independence of reviewers for: (i) drawings; (ii) specifications; (iii) analyses; (iv) system description documents; (v) interface documents; and (vi) reports. By maintaining a database for checking, confirmation of the independence of reviewers, receipt and return dates, and back check dates can now be confirmed with relative ease (CRWMS M&O, 1998c).

The product checking procedures are identified in the Design Guidelines Manual, (DGM) Section 10 (CRWMS M&O, 1997d). The DGM identifies the following topics:

1. Assembly of Engineering Documents for Discipline Check
2. Selection of a Checker
3. Tracking Checked Engineering Documents
4. Discipline Check of Input Lists and Engineering Documents
5. Final Check
6. Checking and Internal Processing of Engineering Change Requests
7. Checklists

- (12) In addition to being applied to the original design, the design control process is also applied to design changes and to field changes, and the changes are documented properly: In Section 4.3.6, Overall Development and Emplacement Ventilation Systems which was checked and approved on September 19, 1997, it is stated "Backfill in emplacement drifts is not required." Yet in the referenced CDA Key 046, dated May 8, 1997, this assumption has been withdrawn (CRWMS M&O, 1998b). This indication that the design uses the earlier assumption (CRWMS M&O, 1996) shows a potential loss of control with respect to changes in, and evaluation of, design inputs. Similar examples were found at least once in all of the design systems reviewed by the staff. The M&O staff explained that the lapse was due to revisions and Document Change Notices in the design input documents, specifically the CDA. The future revisions to GROA designs are expected to reconcile the differences.

## **4.2 DESIGN OF THE GEOLOGIC REPOSITORY OPERATIONS AREA FOR THE EFFECTS OF SEISMIC EVENTS AND DIRECT FAULT DISRUPTION**

### **4.2.1 Background**

This version of the RDTME IRSR focuses on design of the GROA for the effects of seismic events and direct fault disruption. To date, DOE has addressed the first two components of this subissue (i.e., hazard assessment methodology and seismic design methodology). Furthermore, DOE has limited the scope of its topical report (TR) on design methodology to preclosure aspects. Consequently, the following discussion is similarly limited to preclosure aspects. The third component of this subissue will be addressed in future revisions of the RDTME and other companion IRSRs.

### **4.2.2 Review Methods**

The review method for the seismic design methodology consists of reviewing DOE's TR on seismic design methodology and the associated references using the criteria developed in this IRSR. In addition, meetings are used to discuss and clarify various staff comments and DOE's responses. The adequacy of the inputs to design and performance assessments will be evaluated using appropriate acceptance criteria during the review of DOE's third and final TR. DOE's implementation of the design methodology will be monitored during the LA review.

### **4.2.3 Acceptance Criteria**

The staff will find the TR adequate for further review if, during an initial acceptance review of TR-2, the following acceptance criteria are satisfied:

- (1) The TR addresses all important-to-safety (or important-to-waste-isolation) issues pertaining to the scope of the TR.
- (2) The subject of the TR is currently undergoing pre-licensing evaluation.
- (3) NRC's acceptance of the TR would result in increased efficiencies in the staff review of DOE's LA.
- (4) The TR contains complete and detailed information on each element of the scope of the report.

The staff will find the methodology proposed in the TR adequate for use in ESF and repository design if the following criteria are satisfied:

- (1) Sufficient technical reasoning is provided for the proposed methodology.
- (2) If available, documented case histories of the performance of SSCIS designed using the proposed methodology are presented in the TR. In the absence of documented case histories, no serious problems have been identified that would impede applying the methodology.

- (3) The proposed methodology does not contradict established methodologies and principles tested and documented in the LAs for nuclear power plants and independent spent fuel storage installations.
- (4) Uncertainties associated with the proposed methodology that would significantly affect or impede the repository design process and development of inputs to PAs have been considered adequately.
- (5) The various steps involved in the proposed methodology are transparent.
- (6) To the extent that the proposed design methodology depends upon site-specific test data, such data are available now, are being gathered now, or there are plans for gathering such data during site characterization and before submittal of the LA.
- (7) To the extent that the proposed methodology depends on analytical/computer models, such models have been verified, calibrated, and validated to the extent practical, or there are plans for such activities prior to LA submittal or during the performance confirmation period, as appropriate.
- (8) Any major assumptions or limitations to the proposed methodology are identified, and the implications regarding design and performance are discussed in the TR.
- (9) The contents of TR-2 are consistent with the contents of TR-1 and, taken together, the two TRs support the development of inputs for design and PAs as described in TR-3.

#### **4.2.4 Technical Bases**

##### **4.2.4.1 Seismic Design Topical Report Approach**

Among several approaches to resolving potential licensing issues is the use of TRs. Historically, the purpose of NRC's TR program has been to provide a procedure whereby licensees may submit reports on specific important-to-safety subjects to NRC staff and have them reviewed independently of any construction permit or operating license review. The benefits resulting from this program are a minimization of duplication of time and effort that the applicants and NRC staff spend on these subjects and improved efficiencies in NRC's reviews.

NRC staff has documented in its TR RP (U.S. Nuclear Regulatory Commission, 1994) the conditions under which DOE can prepare a TR on a given issue (such as a design or analytical method) and submit it for staff review. Under this TR process, DOE submits an annotated outline (AO) of the proposed TR to get agreement of the staff on the scope and content of the report before spending significant resources. Subsequently, the completed TR is submitted for staff review that takes place in two stages, namely, an acceptance review and a detailed, independent technical review by the staff. The acceptance review in which the staff checks the general adequacy of the TR using the four criteria listed under Section 4.2.3 of this IRSR. The detailed technical review is conducted using the nine criteria listed in the same section. Considerable discussion with DOE may be required before the staff finally documents the status of the resolution of a particular issue or a subissue.

#### **4.2.4.2 U.S. Department of Energy—U.S. Nuclear Regulatory Commission Decision to Use the “Topical Report” Approach for Seismic Design**

DOE decided and the staff agreed that the issue of seismicity and fault displacement is an appropriate one to be dealt through the TR process. The issue of seismic design has a long history of potential for litigation and high public interest during licensing hearings of nuclear power plants. The TR approach is expected to facilitate efficient reviews during the limited licensing review period available under the Nuclear Waste Policy Act.

After discussions with the staff, DOE decided that the issue of seismicity and fault displacement is too unwieldy to be covered under one TR. Therefore, DOE developed a plan to address the issue using three TRs. The first TR (TR-1) deals with the proposed DOE's methodology to assess seismic hazards. The second TR (TR-2), which is one subject of this IRSR, deals with the proposed DOE's seismic design methodology. The third TR (TR-3), which is slated for completion during FY99, deals with vibratory ground motion and fault displacement inputs that will be used in repository design and PAs. Further details on these three TRs are discussed in following sections.

TR-1 Seismic Hazard. In its TR-1 (U.S. Department of Energy, 1994b), DOE has developed a five-step process for assessing the vibratory ground motion hazard at the YM site. First, the seismic sources are evaluated. Second, the maximum magnitude and rate of occurrence of each source are estimated. Third, ground motion/attenuation relationships are developed for the site region. Fourth, a probabilistic hazard curve for vibratory ground motion is generated. Finally, multiple seismic hazard curves are developed to incorporate the various uncertainties. After completing a detailed review of TR-1 in several stages, the staff documented the status of the resolution of the subissues covered under TR-1 in its letter to DOE (Bell, 1996b), which stated that the staff has no further questions on TR-1 at this time.

TR-2 Seismic Design Methodology. TR-2, already mentioned above, addresses preclosure seismic design methodology, keeping in mind that SSCIS must ultimately be built to a single design that meets all requirements, including those for postclosure performance. The seismic design methodology and criteria in Rev. 0 of TR-2 (U.S. Department of Energy, 1995) were based on DOE's safety performance goals found in DOE Standard 1020-94 (U.S. Department of Energy, 1994a). Upon staff review and recommendation, DOE revised TR-2 [Rev. 1, (U.S. Department of Energy, 1996)] substantially to make it compatible with NRC's NUREG-0800 (U.S. Nuclear Regulatory Commission, 1987) for the repository design (as applicable to surface facilities) and design basis events (DBEs) as clarified in a recent Part 60 rulemaking (U.S. Nuclear Regulatory Commission, 1996a).

TR-3 Design Inputs. TR-3, which will develop and document all the seismic and fault displacement inputs for repository design and PA, is scheduled for completion during FY99. A review process similar to the one adopted for TR-1 and TR-2 will be used for the review of TR-3. Only after the completion of the review of TR-3 can the staff resolve the seismic issue and potentially adopt the set of three TRs as an acceptable reference to the repository LA.

#### **4.2.4.3 Preclosure Seismic Design Methodology Presented by the U.S. Department of Energy**

DOE's preclosure seismic design methodology and criteria are described in TR-2. If implemented properly, this methodology is expected to provide reasonable assurance that vibratory ground motions and fault displacements will not compromise the preclosure safety functions of SSCIS.

The seismic design methodology and criteria implement the requirements of Part 60, including the latest amendments related to DBEs. Accordingly, the report summarizes DOE's approach to identifying categories-1 and -2 DBEs and establishes hazard probability levels that are appropriate for determining the two levels of design basis vibratory ground motions and the two levels of design basis fault displacements.

DOE intends to use mean annual probabilities of  $1 \times 10^{-3}$  and  $1 \times 10^{-4}$ , respectively, as reference values in determining the frequency of the above two design basis vibratory ground motions. Criteria for defining DBEs for both surface and underground facilities are provided for vibratory ground motion and fault displacement design. In addition, the report provides criteria for fault avoidance, which is DOE's preferred approach for mitigating fault displacement hazards. Seismic design considerations for WPs are also discussed in TR-2.

After reviewing NUREG-0800 for potential use in repository design, DOE considers that specific criteria and guidance contained therein are appropriate for use in surface facility preclosure seismic design. TR-2 identifies several NUREG-0800 RPs, such as Standard RPs 3.7.1-3.7.3 and 3.8-3.10, along with specific exceptions, as applicable to the surface facility design.

Many of the standard seismic design methods that are applicable to the surface SSCs are also applicable to SSCs underground except that the vibratory ground motions are appropriately attenuated to account for the depth below surface. Therefore, many of the RPs mentioned above for the surface facilities are also considered applicable at the repository level. However, the design of underground openings requires a combination of empirical and analytical approaches to account for the interaction of excavation-induced and thermally generated stresses superimposed on the *in situ* stresses. TR-2 describes the empirical methods, such as Dowding and Rozen's observational method (Dowding and Rozen, 1978), Rock Mass Quality Index Method (Barton et al., 1974), and analytical methods, including the Quasi Static Method and Dynamic Analysis Method (Hardy, 1992) that will be employed by DOE in the design of the underground facilities.

In general, the TR-2 approach to fault displacement design is to avoid major faults, and whenever possible, to provide sufficient standoff distance between SSCs and faults. TR-2 adopts the guidance provided in NUREG-1494 (McConnell and Lee, 1994) in establishing design criteria.

#### **4.2.4.4 Staff Review of Seismic Design Topical Report-2**

DOE requested a scoping review of the AO of TR-2 in August 1994 (Milner, 1994). The staff reviewed and transmitted its comments on the AO to DOE in November 1994 (Bell, 1994). DOE submitted a revised AO in January 1995 (Milner, 1995) that was considered acceptable. The staff notified its acceptance to DOE in its letter of February 14, 1995 (Bell, 1995a). DOE submitted Rev. 0 of TR-2 for NRC's review in October 1995 (U.S. Department of Energy, 1995).

Using the criteria given in Section 4.2.3, the staff concluded that the TR-2 contained sufficient information with sufficient detail to be considered for a detailed technical review. Staff acceptance of TR-2 for a detailed review was transmitted to DOE in their letter of December 1995 (Bell, 1995b).

A detailed technical review of Rev. 0 of TR-2 was conducted using the generic guidance available in the TR RP. In addition, the review criteria delineated in Section 4.2.3 were developed especially for this TR that deals with a specific design methodology.



After a detailed technical review of Rev. 0 of TR-2 and two appendix 7 meetings with DOE (March 13-14, 1996, in Las Vegas and April 23, 1996, in San Antonio), the staff concluded that the TR-2 (Rev. 0) would not meet most of the criteria stated in Section 4.2.3. In addition, there were other major concerns with TR-2, Rev. 0, such as:

- (1) A lack of adequate consideration of postclosure performance issues that might affect design;
- (2) Incompatibility of DOE's proposed design methodology based on its Standard 1020 with the DBE definition provided in the recent amendments to Part 60;
- (3) Inadequate consideration of existing models and codes for conducting dynamic analyses of jointed rock behavior for the design of underground facilities; and
- (4) Lack of a clear rationale for the choice of criteria that will be used to deal with uncertainties in the DBEs for ground motion and fault displacements.

These and other concerns were conveyed to DOE in the staff letter of May 1996 (Bell, 1996a).

As a result of the staff review and recommendations, DOE revised TR-2 and submitted the report to NRC in October 1996 (Brocoum, 1996). The most substantive change to the TR was that DOE dropped its proposed "performance-goal based design" approach (derived from DOE Standard 1020) and adopted an approach that: (i) complies with the new definition of DBE provided in Part 60; (ii) adopts the existing review criteria from NUREG-0800 for the design of surface facilities and some of the SSCs underground; and finally, (iii) addresses the significant concerns raised during the review of TR-2, Rev. 0.

The staff completed a detailed technical review of TR-2, Rev. 1 using the same criteria that were used for the review of Rev. 0 and found Rev. 1 to be a significant improvement. The staff transmitted its review results along with several recommendations for clarifications in a letter in March 1997 (Bell, 1997).

DOE finalized TR-2 in its third version (Rev. 2), and submitted the report for staff acceptance on August 27, 1997 (Brocoum, 1997). Based on a verification review to check if all clarifications sought in the March 21, 1997, letter were provided, the staff concluded that all concerns raised by the staff have been addressed satisfactorily by DOE. After a detailed technical review, the staff concluded that DOE's methodology was acceptable based on the following:

- (1) The methodology proposed by DOE utilizes the acceptance criteria found in NUREG-0800 that have been used repeatedly and tested many times during the licensing hearings for many nuclear power plants. The technical bases for the criteria in NUREG-0800 and its references have been clearly documented. TR-2 identifies the appropriate sections of the particular RPs that will be used as guides for the seismic design of surface facilities and certain SSCs of the underground facility.
- (2) TR-2 adopts staff guidance from appropriate STPs, namely NUREG-1451 (McConnell et al., 1992) and NUREG-1494 (McConnell and Lee, 1994). NUREG-1494 describes a methodology acceptable to the staff for investigating seismic and fault displacement hazards at the YM site. It also establishes criteria for defining the region of interest and the types of faults to be investigated. The STP emphasizes those faults that might have

an effect on design and performance. NUREG-1494 (McConnell and Lee, 1994) provides additional guidance and clarification on avoiding faults within the preclosure controlled area of the repository.

- (3) The empirical design methods and analytical/numerical methods that are proposed in TR-2 for the seismic design of the underground facility and the associated uncertainties are found acceptable to the staff.
- (4) The approach for the fault displacement design and the technical bases for the criteria chosen are acceptable to the staff.
- (5) Finally, all the comments made and concerns raised by the staff during appendix 7 meetings and several rounds of reviews have been addressed in the revisions to TR-2 including the final set of clarifications sought by the staff on Rev. 1.

In summary, the staff has accepted DOE's seismic design methodology proposed in TR-2, however, the final resolution of this subissue will be done after the review of DOE's TR-3 that is scheduled for completion in FY99.

#### **4.3 THERMAL-MECHANICAL EFFECTS ON UNDERGROUND FACILITY DESIGN AND PERFORMANCE**

##### **4.3.1 Background**

The subissue of the TM effects on underground facility design and performance consists of three major components. One is related to repository design while the other two areas focus on performance. More specifically, these three components include: (i) TM effects on underground facility design; (ii) effect of seismically induced rockfall on WP performance; and (iii) postclosure TM effects on inputs to hydrological flow into and out of the emplacement drifts. Review methods and acceptance criteria for each component are listed in separate subsections followed by a presentation of the technical bases to support these acceptance criteria and review methods. In this version of the IRSR, the technical bases presented for the TM effects are not complete. They will be updated in the future revision of this IRSR.

##### **4.3.2 Review Methods**

Review methods for the TM effects subissue consist of the following: (i) review of DOE's thermal strategy and its translation into design, construction and operation of the underground facility; (ii) review of DOE's TM models and associated TM analytical methodology; (iii) review of DOE's ground support designs; (iv) review of DOE's site characterization thermal testing and performance confirmation monitoring program; and (v) selective independent verification analyses. The staff will review DOE's documents related to TM analyses, and appropriate sections of VA and LA using the acceptance criteria developed in this section of the IRSR. The staff will also conduct site visits and audits to observe and document DOE's verification and validation of TM models used in repository design. (More detailed review methods will be developed in future revisions of this IRSR.)

### **4.3.3 Thermal-Mechanical Effects on Design of Underground Facility**

#### **4.3.3.1 Acceptance Criteria**

The TM design and analyses will be considered acceptable if:

- (1) Approved QA and control procedures and standards were applied to collection, development and documentation of data, methods, models and codes.
- (2) If used, expert elicitations are conducted and documented in accordance with the guidance in NUREG-1563 (U.S. Nuclear Regulatory Commission, 1996b) or other acceptable guidelines.
- (3) The TM design makes use of site-specific thermal and mechanical properties, and the spatial distribution of such properties is implemented in TM analyses for the design.
- (4) The process to develop inputs to TM design includes consideration of associated uncertainties and documents the potential impacts on design.
- (5) The seismic and fault-displacement data inputs for design are consistent with those established in seismic design TR-3.
- (6) The TM design and analyses make use of appropriate constitutive models that represent jointed rock mass behavior.
- (7) The analytical/numerical models used in the TM analyses are appropriately verified, validated, and calibrated before the submittal of the LA. (For those aspects of the models for which long-term experimental data are needed, continued verification and validation during performance confirmation are considered acceptable as long as detailed plans and procedures for such continued activities are found in the LA.)
- (8) Both drift- and repository-scale models of the underground facility are used in TM analyses to establish the intensity and distribution of ground movement (rock deformations, collapse, and other changes that may affect the integrity or geometrical configuration of openings within the underground facility).
- (9) The principles formulating the TM analytical methodology, underlying assumptions, resulting limitations, and the various steps involved in the design procedures are clearly explained and justified.
- (10) The analytical methodology considers plausible, potentially important TM processes appropriate to the design and YM site characteristics.
- (11) The TM design and analyses include a consideration of seismic effects relevant to the YM site and the methodologies are consistent with those established in DOE Seismic TR-2.
- (12) Time sequences of thermal loading used in TM design and analyses are clearly defined.

- (13) The TM design and analyses consider changes in thermal and mechanical properties due to rock-mass degradation caused by sustained TM loading and extended exposure to heat and moisture.
- (14) The TM design and analyses consider the potential effects of lithophysae for those areas of the emplacement drifts that are expected to cross lithophysae-rich strata.
- (15) The TM design and analyses consider the presence of roof supports (bolts, shotcrete, concrete, and steel liners, as applicable), consider the interaction between rock and roof supports, and address the degradation of supports with time under high temperature and moisture conditions, as they affect the maintainability of stable openings during the extended preclosure period.
- (16) The results of the TM analyses, including the consideration of ground support (e.g., liners), are accounted for in the determination of maintenance requirements for the underground facility.
- (17) The design discusses maintenance plans for keeping the underground openings stable with particular attention to retrieval operations. (If the details of retrieval operations/plans are found in other sections of the LA, a reference to such sections would be acceptable.)

#### 4.3.3.2 Technical Bases

The technical bases as currently provided address acceptance criteria 3, 8, 13, 15, and 16. In the future revision of this IRSR, technical bases for each of the acceptance criteria listed in Subsection 4.3.3.1 will be provided.

#### Thermally Induced Ground Movements in the Emplacement Drift Area of the Underground Facility

TM analyses of the emplacement-drift area of the proposed underground facility have been conducted by Center for Nuclear Waste Regulatory Analyses (CNWRA) to investigate the occurrence and distributions of thermally induced ground movement in the emplacement drift area of the underground facility. The effects of the following factors were investigated: (i) spatial variation of rock mass quality; (ii) rock mass degradation caused by sustained mechanical and thermally induced stresses and alteration of fracture wallrock resulting from extended exposure to heat and moisture; and (iii) degradation of ground support (concrete lining).

A two-dimensional, repository-scale, plane-strain finite element model of the emplacement drift area of the underground facility was used in the analysis. The model consists of a vertical, south-to-north section approximately through the proposed axis of the exhaust main as shown in Figure 2 (CRWMS M&O, 1997a). A total of 100 drifts were represented in the model (with drift #1 at the north end and drift #100 at the south end). Having set the drift spacing at 28 m center-to-center for the thermal-loading equivalent of 85 MTU/acre (cf. CRWMS M&O, 1997b), the total horizontal (north-south) extent of the model was 3,200 m (including 200-m extensions beyond the ends of drifts #1 and #100). The model extended 1,000 m vertically, with the emplacement drift axis at a depth of 302.5 m below the top of the model. Each emplacement drift was represented as a square opening, 5 m wide x 5 m high, and drifts were taken to be each 1,080 m long in the out-of-plane (east-west) direction (cf. CRWMS M&O, 1997b). Concrete lining on the drift walls was simulated using superimposed beam elements placed at the boundaries between each drift and the adjacent rock elements.





Figure 2. Proposed repository subsurface layout [from CRWMS M&O (1997a)]

Thermal loading was applied as a time-decaying volumetric heat flux distributed uniformly over each drift, the magnitude of which is equal to  $q/NV_d$ , where  $q$  is the total heat flux from the projected 10,938 WPs (CRWMS M&O, 1997b),  $N=100$  is the number of drifts, and  $V_d$  is the volume of each drift (equal to  $1,080 \times 25 \text{ m}^3$ ). The initial temperature distribution was calculated based on the geothermal gradient given in CRWMS M&O (1997b) and the thermal boundary conditions consisted of fixed temperature at all exterior boundaries. Mechanical boundary conditions consisted of no horizontal displacement at the vertical boundaries, no vertical displacement at the base, and free-surface conditions at the top, of the model. The temperature distribution calculated from the thermal analysis was used as input for each mechanical analysis.

Mechanical behavior was simulated using an elastic-plastic material model. Rock mass mechanical properties were determined from the ESF rock mass quality ( $Q$ ) profile, which gives values of  $Q$  at 5-m intervals over the entire 8-km length of the ESF based on the presentation of Use of Fracture Data in ESF Design, DOE/NRC Appendix 7 Discussions, October 6, 1997. Values of  $Q$  from the south end of the model to the boundary between drifts #33 and #32 were obtained from the ESF data, and  $Q$  was assumed constant from drift #32 to the north end of the model (Figure 3). Values of Young's modulus,  $E$ , and Mohr-Coulomb friction angle,  $\phi$ , and cohesion,  $c$ , for the rock mass were calculated from  $Q$  using empirical equations from Hoek (1994) and Hoek and Brown (1997). The empirical equations give each of the parameters ( $E$ ,  $\phi$ , and  $c$ ) as a monotonically increasing function of  $Q$ . As a result, each of the parameters varies with horizontal coordinate in the model following the same pattern shown for  $Q$  in Figure 3. Both rock mass Poisson's ratio and unconfined compressive strength of intact rock ( $\sigma_{ci}$ ) were kept constant at 0.21 and 180 MPa, respectively (cf. CRWMS M&O, 1997c; Brechtel et al., 1995). Material properties did not vary vertically because there is currently insufficient data to define vertical variation of rock mass quality at the YM site. The available data (e.g., Lin et al., 1993b) provide values of  $Q$  for five rock mass quality categories within each of the TM stratigraphic units but do not define the spatial distribution of the quality categories within each unit. Furthermore, compatibility of the Lin et al. (1993b) data with the ESF data needs to be established before using the two sets of data in one model. For example, Lin et al. (1993b) gives values of  $Q$  from about 0.2 to about 65 for the TSw2 unit, whereas the maximum  $Q$  value from the ESF data (Figure 3) is smaller than 15.

Two sets of mechanical analyses have been conducted, one with current values of rock mass strength parameters (as described in the foregoing paragraph) and the other with reduced values of the strength parameters to simulate rock mass degradation. The onset of significant degradation of rock mass mechanical properties is likely to be delayed such that degradation may not have any effect on mechanical response during the first 50 to 75 years. Consequently, TM response will likely consist of a period of thermal-stress buildup during which behavior will be governed by the current values of rock-mass properties followed by a period in which behavior may be governed by degraded rock-mass property values. Appropriate simulation of this evolution of TM response would require that the material parameters be prescribed as functions of time as well as space, but there is currently little quantitative information on the time rate of rock-mass degradation.

Material parameters were not specified as functions of time in the analyses conducted so far. Instead, the rock mass Young's modulus,  $E$ , Poisson's ratio,  $\nu$ , and thermal expansivity,  $\alpha$ , were assigned their current values in both analysis sets to simulate thermal stress buildup in essentially nondegraded rock mass. The rock-mass strength parameters [i.e., friction angle ( $\phi$ ), cohesion ( $c$ ), and intact-rock unconfined compressive strength ( $\sigma_{ci}$ )] were assigned their current values in analysis set 1 to simulate the response of nondegraded rock mass, whereas the same strength parameters were assigned reduced values, through a reduction of  $Q$  to  $0.1Q$  and  $\sigma_{ci}$  to  $0.5\sigma_{ci}$ , in analysis set 2 to simulate the response of degraded rock mass. The one-order-of-magnitude decrease in  $Q$  arises from an expectation that the ratio  $J/J_0$  ( $J$  is joint roughness number and  $J_0$



Note: South-to-north profile of rock-mass quality (Q) used in the model, shown in sev. 260-m long sections. Each section intersects 10 drifts, the numbers of which are given at the ends of the section. Drift #100 is at the south end (Exploratory Studies Facility Station 47+08) and drift #1 is at the north end. Because drifts #1 to #32 are outside the exploratory studies facility alignment, there is no Q data for these drifts.

Figure 3. Rock-mass quality (Q) profile used in the analysis

is joint alteration number) in the formula for  $Q$  (Barton et al., 1974) can decrease by one order of magnitude because of wallrock alteration caused by extended exposure to heat and moisture. The decrease of  $\sigma_c$  to  $0.5\sigma_c$  arises from published data on the behavior of intact hard rocks under sustained loading (e.g., Lajtai and Schmidtke, 1986).

Each analysis covered a period of 150 years from (instantaneous) waste emplacement. The beam elements, which represent concrete lining, were left in place (with no degradation) during the entire 150 years and were thereafter removed rapidly (without further change in temperature). Hence, each mechanical analysis sequence provides information to enable comparison of the states of ground movement with and without the lining.

The analysis results are presented in terms of contour plots of the magnitude of permanent (i.e., inelastic) strain (Figures 4 and 5). Inelastic strain in rock mass arises from processes such as fracture growth, re-opening and closure of existing fractures, and sliding on fracture surfaces, which, occurring individually or in combination, tends to cause loosening of the rock mass and, ultimately, the detachment of individual blocks (cf. Ofoegbu and Curran, 1992). Consequently, the intensity of inelastic strain may be used as an indicator of the occurrence of such failure processes and magnitude of the associated ground movement. Although the current state of knowledge does not permit associating a specific magnitude of inelastic strain with a specific intensity of failure-related ground movement, contour plots of inelastic strain intensity (e.g., Figures 4 and 5) may be used at least as a qualitative indicator of the potential for failure-related ground movement.


### ***Discussion of Results***

The distribution of permanent strain for the case of degraded rock mass and stiff tunnel liners (Figure 4), compared with  $Q$  profiles (Figure 3), indicates that thermally induced ground movement would be more intense around drifts located in higher  $Q$  areas. Occurrence of more intense deformation in areas of higher  $Q$  is explained by the fact that  $E$  increases monotonically with  $Q$ , and thermally induced stress is essentially proportional to  $E$ . As a result, higher stresses would develop in areas of higher  $Q$ . Because an increase in  $Q$  causes a much larger increase in  $E$  than the corresponding increase in either  $\phi$  or  $c$  (Figure 6), the strength difference between a given pair of  $Q$  values is smaller than the difference between their induced stresses. Consequently, the failure criterion is more likely to be satisfied first in areas of higher  $Q$  (because of their higher thermally induced stress) than in areas of lower  $Q$ . For example, between drifts #31 and #40 areas closer to drift #31 have lower  $Q$  values and experience lower intensity of permanent strain than areas closer to drift #40. Similarly, between drifts #51 and #60 areas closer to drift #60 have lower  $Q$  and experience lower permanent-strain intensity than areas closer to drift #51.


On the other hand, it does not always follow that decrease in  $Q$  would imply decrease in the intensity of ground movement. For example, compare the  $Q$  values and permanent-strain intensity values around drifts #33 and #83 [at horizontal coordinate ( $x$ ) of about 1,880 and 480 m, respectively]. The permanent-strain intensity around drift #33 is higher than around drift #83, notwithstanding that  $Q$  value is about 4.3 near  $x = 480$  (drift #83) and about 2.4 near  $x = 1,880$  m (drift #33). Similarly, the entire area from drifts #1 to #32 has the same  $Q$  value, but both the extent and intensity of permanent strain vary within the area because of temperature difference between drifts at the end and in the interior.

These results illustrate the effects of spatial distribution of rock-mass properties on ground movement within the underground facility area. The importance of a repository-scale model arises from the capability to implement within such a model measured or estimated spatial variations of material properties, such as the north-south variation of  $Q$  values applied in the current study.






Emplacement Drifts at 150 Years  
 Degraded Rock Mass  
 Stiff Tunnel Liners




Note: The rock material and strength properties used in the model are degraded values with the values of Young's modulus remaining the same. Result is presented in ten sections, each 280 m long (in north-south direction) by 35 m high (vertical dimension). Ten white squares within each section represent emplacement drifts, and the numbers for the end drifts of each section are shown. Drift #100 is at the south end of the figure and drift #1 is at the north end. White straight lines represent finite element edges. Values of rock-mass quality (Q) along the sections are shown in Figure 3.

Figure 4. Distribution of permanent (i.e., inelastic) strain intensity around emplacement drifts with degraded rock strength properties and nondegraded concrete lining




Emplacement Drifts at 150 Years  
Degraded Rock Mass  
Degraded Tunnel Liners



Note: The rock strength properties used in the model are degraded values. Result is presented in ten sections, each 280 m long (in north-south direction) by 35 m high (vertical dimension). Ten white squares within each section represent emplacement drifts, and the numbers for the end drifts of each section are shown. Drift #100 is at the south end of the figure and drift #1 is at the north end. White straight lines represent finite element edges. Values of rock-mass quality (Q) along the sections are shown in Figure 3.

Figure 5. Distribution of permanent (i.e., inelastic) strain intensity around emplacement drifts with degraded rock strength properties and concrete lining



Note: Values of ratios  $E/E_{\text{max}}$ ,  $\phi/\phi_{\text{max}}$ , and  $c/c_{\text{max}}$  are shown as a function of  $Q$  over the range of  $Q$  values encountered in the model. Parameters  $E_{\text{max}}$ ,  $\phi_{\text{max}}$ , and  $c_{\text{max}}$  are values of  $E$ ,  $\phi$ , and  $c$ , respectively, at  $Q = 15$ . Plots show that  $E$  is more sensitive than either  $\phi$  or  $c$  to changes in  $Q$ .

Figure 6. Normalized rock properties as a function of rock-mass quality ( $Q$ )

Such a model would permit determination of the areas of the underground facility that would be most likely to experience severe ground movement. In addition, both drift-scale models and models that are intermediate in scale between the drift and repository scales would be required to examine how such ground movement might affect the behavior of rock support (such as concrete liner) at a specific drift or small group of neighboring drifts.

The results for analysis set 1 (cases with the parameters  $E$ ,  $\phi$ ,  $c$ , and  $\sigma_{ci}$  assigned their current values) show zero inelastic strain everywhere. On the other hand, the results for Analysis Set 2 (cases with  $E$  set at its current values while  $\phi$ ,  $c$ , and  $\sigma_{ci}$  were assigned reduced values) show a considerable fraction of the emplacement area in which inelastic straining would occur (Figures 4 and 5). As explained earlier, the occurrence of inelastic straining indicates increased potential for occurrence of failure-related ground movement. Therefore, these results indicate that rock-mass degradation following thermal-stress buildup would result in increased potential for failure-related ground movement. It is necessary to incorporate material-property changes resulting from rock-mass degradation into TM analyses of the underground facility in order to evaluate the potential for such ground movement and incorporate the information into the ground support system design and maintenance plan.

### ***Summary of Findings***

The analysis results presented in the foregoing paragraphs lead to the following observations:

- (1) Degradation of rock-mass strength following the application of thermal load strongly increases the magnitude and extent of ground movements around the emplacement drifts.
- (2) The magnitude of ground movement resulting from rock-mass degradation is controlled by the spatial distribution of rock-mass mechanical properties, specifically, elastic stiffness and strength. Areas of largest ground movement may not necessarily coincide with areas of lowest rock-mass quality (Q or rock mass rating values).
- (3) Degradation of ground support (concrete lining) following the application of thermal loading strongly increases the magnitude and extent of ground movement around the emplacement drifts.
- (4) Collapse of unsupported rock within the zones of intense ground movement would cause considerable changes in the geometries of underground openings.

### **Thermal and Time Effects on Concrete**

The primary ground support system currently under consideration for the emplacement drifts is a concrete liner, although steel sets remain an option. A large amount of information regarding the behavior of concrete exposed to heat and moisture is available in the literature. Although this information is generally limited to short-term heating (mostly under transient conditions), certain observations/findings are expected to be relevant to the YM environment, irrespective of the design of the concrete liner and should be considered in the repository design. A summary of information gathered through literature search is presented in the following subsections.

### ***Thermal Properties at Elevated Temperature***

The thermal properties of concrete at elevated temperature are not constant since the concrete is physico-chemically unstable (Harmathy, 1970). Estimating the thermal properties at higher temperatures is even more complex due to the development of decomposition and transition reactions.

In general, concrete contains two or three components. The two-component concrete is a mixture of coarse aggregate and cement paste while the three-component concrete consists of coarse aggregate, fine aggregate, and cement paste. The specific heat for cement paste may experience a 100-percent increase as the temperature increases from 100 to 150 °C and starts to decrease gradually until about 400 °C. From 400 to 500 °C, specific heat increases sharply again and peaks at 500 °C and eventually returns to values equivalent to those between 25 to 100 °C (Harmathy, 1970). The volume-specific heat for concrete follows a similar trend. The maximum wall rock temperature in the repository is approximately 200 °C. Consequently, the temperature-dependent behavior of the specific heat is an important issue to be considered in repository design.

The thermal conductivity of cement paste is very low and not subject to large variations. The concrete thermal conductivity is primarily determined by that of the aggregates. Concrete with aggregates containing high-crystalline rocks has relatively high conductivity at room temperature, and the conductivity gradually decreases as temperature increases (Harmathy, 1970). Concrete containing amorphous rock aggregates exhibits low conductivity (Kingrey and McQuarrie, 1954) and is relatively insensitive to the chemical composition. The thermal conductivity of this type of concrete increases slightly with an increase in temperature. Concrete with common lightweight aggregates has also relatively low conductivity owing partly to the high porosities (low density) of the aggregates (Harmathy, 1970).

### ***Temperature Impact on Material Properties of Concrete***

A study has indicated that Young's modulus and Poisson's ratio of concrete increase slightly as the concrete is heated from room temperature to about 50 °C due to the release of the majority of evaporable water in the concrete during heating (Marechal, 1972). Young's modulus and Poisson's ratio decrease afterwards at a relatively constant rate as temperature continues to increase. The reduction in Young's modulus can be more than 40 percent if the temperature reaches 200 °C while the reduction could be as much as 36 percent for Poisson's ratio. This reduction is not reversible (Marechal, 1972). Bulk modulus decreases at a faster rate than Young's modulus due to the fact that Poisson's ratio decreases at a relatively slower rate than Young's modulus.

Compressive strength of concrete has been observed to decrease as temperature increases. Concrete strength at a temperature of 200 °C is about 70 to 75 percent of that at room temperature. Limestone-aggregate-based concrete experiences even faster strength reduction owing to destruction of bonds and an increase in plasticity affected by temperature. At 200 °C, this type of concrete has only about 57 percent of its original strength (Marechal, 1972).

### ***Degradation of Concrete***

Degradation of concrete could take place in several forms: creeping, chemical instability, and dehydration. Creep phenomenon is the focus of discussion in this section. Creep is a form of time-dependent degradation/damage through accumulation of micro-fractures (Baluch et al., 1989) formed in the concrete under load.

Concrete has been observed to experience a marked increase in creep when it is heated for the first time under load (Khoury et al., 1985; Baluch et al., 1989). Additional transient creep also originates in the cement paste and is restrained by the aggregate. This transient creep provides the heterogeneous concrete with some thermal stability for an applied constant stress level below 30 percent of the concrete strength. This phenomenon is due to the relaxation and redistribution of thermal stresses in the concrete. This relaxation process makes a stable structure possible (Khoury et al., 1985).

However, if the applied constant stress level is beyond 30 percent, the possibility for the concrete to fail during heating becomes greater. Experiments conducted by Khoury et al. (1985) have shown that concrete under heat may undergo creep failure at an applied constant stress level about 60 percent of the concrete compressive strength. The timing of the failure was not reported. It is suspected that the duration of creeping is short. This failure mechanism may be related to the differential thermal expansion coefficients between the aggregate and cement paste that lead to relaxation of stress. At a relatively lower stress level, this difference contributes to the stability of concrete structures. However, at a higher constant applied stress, microfractures in the concrete begin to accumulate and creep accelerates (Baluch et al., 1989). When the creep strain reaches a certain extent, the concrete may fail and stability of the concrete could be jeopardized. The amount of creep strain that is tolerable depends on materials involved.

As discussed earlier, concrete damage due to first-time heating could reduce concrete strength and make the concrete more susceptible to creep. In the emplacement area of the repository, the applied stress to the concrete liners from the thermal expansion and time-dependent degradation of the surrounding rock mass could be high. Subsequently, time-dependent degradation of concrete liner is possible. The extent of the degradation will depend upon the level of stresses applied. It should be noted that under certain combination of unfavorable conditions such degradation could take place at the early stage of the preclosure period.

The thermal expansion of the concrete could further jeopardize drift stability if the concrete structure is restricted from expanding, which may be the case for concrete liners for the emplacement drifts. Since the expansion capability is limited, the concrete tends to relax its excessive stresses through dislocations between aggregate and cement paste or even through the cement paste. This dislocation phenomenon leads to further degradation of the concrete structure and possible failure.

#### **4.3.4 Effects of Seismically Induced Rockfall on Waste Package Performance**

##### **4.3.4.1 Acceptance Criteria**

The staff will find DOE's consideration of seismically induced rockfall acceptable if:

- (1) Approved QA and control procedures and standards were applied to collection, development and documentation of data, methods, models and codes.
- (2) If used, expert elicitation is conducted and documented in accordance with the guidance in NUREG-1563 (U.S. Nuclear Regulatory Commission, 1996b) or other acceptable approaches.

- (3) The seismic hazard inputs used to estimate rockfall potential are consistent with the inputs used in the design and PAs as established in DOE's TR-3 that is reviewed and accepted by NRC.
- (4) Size distribution of rocks that may potentially fall on the WPs is estimated from site-specific data (such as, distribution of joint patterns, spacing, and orientation in three dimensions) with adequate consideration of associated uncertainties.
- (5) The analytical model used in the estimation of impact load due to rockfall on the WP is (a) based on reasonable assumptions and site data, (b) consistent with the emplacement drift and WP designs, and (c) defensible with respect to providing realistic or bounding estimates of impact loads and stresses.
- (6) The TM analyses that provide the background conditions upon which seismic loads are superimposed consider time-dependent jointed rock behavior.
- (7) Rockfall analyses consider, in a rational and realistic way through dynamic analyses, the possibility of multiple blocks falling onto a WP simultaneously, and the extent of potential rockfall area around an individual emplacement drift as well as over the entire repository as functions of ground motions.

#### **4.3.4.2 Technical Bases**

Seismicity is a disruptive event that needs adequate consideration in both repository design and PA. Seismicity could affect WP performance by producing rockfall that may damage WPs. The potential effects on the performance of WPs are twofold. The first possible effect of rockfall is to rupture WPs by the impact produced by the falling rock. The second aspect is that rockfall may cause damage to the container outer pack in a manner that corrosion of the WPs will accelerate and thus reduce the intended service life of WPs. In order to perform an adequate assessment of the effect of rockfall due to either thermomechanical load or seismicity, a number of factors will need to be understood better, such as the design of WPs, repository design (ground supports and backfills), and potential size of rockfall. Equally important is the availability of a reasonable model/approach that can be used to perform such an assessment.

The analyses of rockfall should explicitly account for four basic aspects: (i) size distribution of individual blocks that can potentially fall; (ii) possibility of multiple blocks falling onto a WP simultaneously; (iii) vertical and lateral extent of the region undergoing rockfall; and (iv) effects of repeated rockfall on the (corroded) canister due to repeated seismic events. These aspects of rockfall analyses are discussed in this section, with emphasis on specific needs for analyses, appropriateness of methodologies, and sufficiency of input considerations and associated uncertainties. The discussion is based mainly on data from YM site characterization activities, current DOE approaches, and ongoing modeling efforts at NRC/CNWRA. The ultimate goal of these analyses is to give technically adequate estimation of the volume range and quantity of rock blocks that have the potential to fall onto the WPs so as to evaluate the effects of such rockfall on the integrity of the WPs. Since characterizing rockfall is a recently initiated ongoing effort, the technical bases, provided in this section of the IRSR, are not completely developed and, therefore, should be considered preliminary. These technical bases address acceptance criteria 4, 5, 6, and 7. In the future revision of this IRSR, technical bases for each of the acceptance criteria listed in Subsection 4.3.4.1 will be provided.

### **Size Distribution of Individual Blocks**

The size distribution of individual rock blocks is controlled by geometrical characteristics of the joint network, including joint spacing, orientation, persistency, and trace length. Such data have been collected by DOE through various site characterization activities. These include data from North Ramp Geotechnical- (NRG) series core holes (Lin et al., 1993a) and ESF mapping (Fahy and Beason, 1995; Brechtel et al., 1995).

Schenker et al. (1995) performed statistical analyses for some of these individual parameters based on core hole and ESF data, including fracture frequency and orientation. They also derived some other basic parameters from measured parameters and certain assumptions, including joint spacing. Schenker et al. (1995) also derived distribution of joint spacing and assumed a parallel array of planar joints. In their rockfall analyses, Gauthier et al. (1995) estimated size distribution of individual rock blocks using a modified (log-space) version of the Topopah Spring fracture spacing distribution developed by Schenker et al. (1995), assuming cubic and parallelepiped blocks. Assumptions of cubic or parallelepiped block shape (Gauthier et al., 1995) may distort the estimation of size distribution of *in situ* blocks due to various assumptions with regard to the extent of joints in the third dimension.

Various methodologies and tools are available to estimate the size distribution of *in situ* rock blocks from joint geometrical characteristics. For example, the commercial code FRACMAN (Dershowitz et al., 1993) has the capability to estimate *in situ* block size distribution from joint geometry information. Alternatively, methodologies proposed by Hoek and Brown (1982), Goodman and Shi (1985), and Shi (1996) may be used to estimate the size distribution of *in situ* rock blocks. Generally, each method has some inherent assumptions. These assumptions need to be taken into account to develop the site-specific volume distribution curves for the *in situ* blocks.

There is a possibility of several blocks falling together on the WPs, which increases the impact load on the WPs. To determine the possibility of several rock blocks falling together during an earthquake and the vertical extent of rockfall, TM analysis coupled with dynamic effects need to be performed.

### **Possibility of Simultaneous Rockfall and Vertical Extent of Potential Rockfall**

In this section, the past and ongoing studies performed by NRC's RDTME team in an attempt to better understand the concerns discussed in the previous paragraph are summarized.

TM analyses at the drift scale up to 100 years (Ahola et al., 1996, Chen, et al., 1998) show that thermal loading causes significant stress redistribution around the drift. The study was for a single drift in a rock mass that had a regular joint pattern with two joint sets (subhorizontal and subvertical). The analyses were conducted using the computer code UDEC (Itasca Consulting Group, Inc., 1996). Figures 7 and 8 compare the distribution of principal stresses following drift excavation and after 100 years of heating under a 100 MTU/acre thermal loading density (which is somewhat higher than DOE is currently considering). The thermal load increased the maximum compressive stress, and rotated its direction from vertical to horizontal. The location of the highest compressive stress region shifted from the side walls to roof and floor areas of the drift. Failure along side walls due to concentration of compressive stresses and lack of lateral support in underground mines and tunnels is a frequently observed phenomenon. When such compressive stress is rotated and shifted to the roof area, a similar phenomenon could occur and thus cause rockfall.






Figure 7. Distribution of principal stresses after drift excavation




Figure 8. Distribution of principal stresses after 100 years of heating

This study also reveals that thermal load could increase failure of intact rock blocks. Other studies have also observed this phenomenon (Tsai, 1996 and CRWMS M&O, 1995). Although failure zones in most cases were localized to the immediate areas around the drift, in some cases they extended to the middle of the pillar in rock masses that are weaker and have a higher thermal expansion coefficient (Figures 9 and 10). Although failure of intact rock in discontinuum analysis may not be the direct evidence of explicit rockfall, it represents a failure or damage state and indicates the need to establish a criterion for mapping out the vertical extent of potential rockfall with appropriate modeling methodologies and input parameters (such as, joint patterns representative of the site).

A recent preliminary dynamic modeling study was carried out at the CNWRA on a single drift in a rock mass that has an irregular joint pattern as shown in Figure 11. This study used the computer code UDEC (Itasca Consulting Group, Inc., 1996). Preliminary results show that it is possible for multiple rock blocks to fall simultaneously under seismic ground motion. Figures 11 and 12 show blocks falling after being subjected to a sinusoidal dynamic load for about 2 seconds. [It should be noted that UDEC does not properly track a block once it is detached (i.e., the block has lost contact with neighboring blocks) from the remaining mass. Any calculations after the block is detached will not predict actual position of the block. Consequently, the blocks fallen into the drift from the roof region shown in Figure 12, are for illustration only.] Although preliminary, this modeling effort shows that there is a possibility of simultaneous rockfall.


It is desirable to establish a criterion that could be used to map out the maximum vertical extent of potential rockfall. The extent of rockfall will depend on factors such as level of ground motion, joint pattern, individual block sizes, thermal and mechanical properties of the rock mass, joint shear and normal displacements, joint shear and normal stresses, and joint strength.

### **Approach for Assessing Effects of Rockfall on WP Performance**

In the following, an approach implemented by the staff in the SEISMO module, a part of the TPA code, is discussed (Manteufel et al., 1997). This approach represents the first attempt of NRC to address rockfall and is used to assess the number of WPs ruptured due to rockfall induced by seismicity in the repository thermal environment. Rockfall due to instability of emplacement drifts caused by thermo-mechanical load can also be evaluated in a similar manner.


### ***Conceptual Model***

The SEISMO module adapted in NRC's TPA code (version 3.2) evaluates the potential for direct rupture of WPs due to rockfall induced by seismicity in the repository thermal environment. The code takes the volume of rockfall as input to perform impact analysis to determine integrity of WPs. The magnitude of the impact load is essentially a function of the size of the falling rock block and the distance of this rock block from the WPs. The volume of rockfall is in turn a function of rock conditions, *in situ* stress, thermal load, and magnitudes of seismic events. In the following paragraphs, discussions related to the conceptual model will be provided in the following sequence: (i) how variations of rock conditions are accounted for in the model; (ii) how falling rock size is related to the magnitude of seismicity; (iii) how the time dependency of the seismic events is accounted for, (iv) how impact load and impact stress are calculated; (v) how rupture of WPs is determined; and (vi) how the number of WPs ruptured is determined. A flowchart showing the steps of calculation in SEISMO is provided in Figure 13.




**Note: Dots represent elastic state. Crosses represent yield zones. Dash lines represent joints.**

**Figure 9. Distribution of yielding after drift excavation**




Note: Dots represent elastic state. Crosses represent yield zones, Dash lines represent joints.


Figure 10. Distribution of yielding after 100 years of heating



**Figure 11. Rockfall simulated by dynamic analysis of a single drift in a rock-mass with irregular joint pattern after subjecting to 0.25 sec of dynamic load**



**Figure 12. Rockfall simulated by dynamic analysis of a single drift in a rock-mass with irregular joint pattern after subjecting to 1.0 sec of dynamic load**



**Figure 13. Flowchart highlights SEISMO calculation**



### **Joint Spacing and Rock Conditions in TSw2 Unit**

It is recognized that not all rocks falling from the roof of the emplacement drifts will have an effect on WPs. The effective size of the rock falling on a WP is considered to be controlled by joint spacing (width and length) and height of the falling rock block and the falling distance of the rock block before it impacts the WPs. The falling distance is controlled by the diameters of emplacement drifts and WPs. Another factor that affects the falling distance is the number of rockfalls taking place at the same location.

The falling distance for the second rockfall is no doubt longer than that for the first rockfall at the same location. Consequently, the associated energy will apparently be higher and impact will be greater if the WP is not already covered by rock debris. The ability for assessing the effect of repeated rockfalls at the same area is not currently provided in the SEISMO module. One can indirectly evaluate the effects of repeated rockfalls by changing the baseline falling distance provided in the input file for the TPA code. In the future revision of the SEISMO module, the capability of evaluating the effect of repeated rockfalls on WPs will be included.

The joint spacing information provided in a Sandia report (Brechtel et al., 1995), which summarizes data collected from NRG holes, is used to bound the five rock conditions. A range of joint spacing is assigned to each rock condition. Since each rock condition represents a range of joint spacings, a uniform distribution function covering the range of joint spacings is assumed for each rock condition.

As discussed earlier, dividing the TSw2 unit into five rock conditions as implemented in the current version of SEISMO based on joint distribution information using NRG hole data is arbitrary. As more information regarding joint distribution in the TSw2 unit becomes available, it may be possible to develop a continuous function to describe the rock condition in the TSw2 unit such that the assumption of five rock conditions can be removed from the SEISMO module.

### **Determination of Size of Rockfall**

The size of a falling rock can be calculated by joint spacing (width)  $\times$  joint spacing (length)  $\times$  height of the rock block. At this time, the SEISMO module assumes, for simplicity, that the width of a falling rock is equal to its length, and the joint spacing is controlled by the rock condition. The maximum heights of the falling rock blocks are assumed to be equal to the heights of calculated yield zones induced by *in situ* stress, thermal load, and various levels of ground accelerations.

The height of the yield zone for each rock condition subjected to ground acceleration is estimated from the results of numerical modeling using the UDEC computer code (Ahola et al., 1996) based on three case studies. The height of the yield zone is a function of rock condition and magnitude of ground acceleration. Using the height of yield zone for calculation of the size of falling rock tends to give an upper bound value. Consequently, the determination of the vertical dimension of the rock that is falling in the SEISMO module is made through sampling a uniform function between the minimum vertical dimension and the maximum vertical dimension. The maximum vertical dimension is assumed to be equal to the height of yield zone while the minimum vertical dimension is assumed to be equal to the average joint spacing of a rock condition.

Investigation is currently underway to devise a more acceptable approach for determining the size of the falling rock using available joint information at the YM site.

### ***Fractional Coverage of Rock Conditions and Determination of Number of WPs Ruptured***

Based on the Sandia report (Brechtel et al., 1995), rock condition 4 appears to contain a larger portion of the TSw2 Unit. About 62.9 percent of the area can be characterized as rock condition 4 and rock condition 5 occupies roughly 35.6 percent of the area. Rock conditions 1, 2, and 3 take up only 1.5 percent of the area in total. Due to a lack of specific information, the 1.5 percent is equally divided into the three rock conditions.

If a seismic event triggers rockfall for a particular rock condition, rockfalls are not expected to take place in the entire area of that rock condition. In fact, only a small fraction of the rock under that rock condition will fall in response to a seismic event because of the inherent variation associated with the rocks. Another fraction of the rock may fall at a later time when a separate seismic event, having the same or greater intensity, takes place. Rockfall could also take place at a relatively smaller magnitude event if the rock has been sufficiently weakened due to repeated seismic events. The size of the fraction may be related to the event magnitude, joint dip angles, and incidence angle of incoming seismic waves, etc. At this time, there is little information available to determine such a relationship. Consequently, CNWRA experts developed a continuous function relating the fractional area of rockfall to the magnitude of seismic ground accelerations based on experience in the field. This function is implemented in the SEISMO module for TPA Version 3.2. As currently implemented, this function is rock-condition-independent, that is, the same fraction is applied to all rock conditions in estimating WPs affected by rockfall. This function represents our current thinking. Modification to the function may be necessary at a later date when more technical information becomes available. Also, this function should be made rock-condition-dependent. It is intuitive that, for a particular seismic event, weaker rock should experience relatively larger area of rockfall compared to stronger rock conditions.

### ***Seismic Hazard Parameters***

The SEISMO module requires a history of seismic events over the time period of interest. The history of seismic events is generated by the TPA executive SAMPLER utility module. The input required for generating event history includes ground acceleration sampling points and the corresponding recurrence times. These two pieces of information form a prescribed seismic hazard curve.

In determining the recurrence of seismic events, the horizontal acceleration hazard curve provided in DOE's Seismic Design Methodology for a Geologic Repository at YM report (U.S. Department of Energy, 1995) for surface facilities is used. The effect of surface/depth attenuation can be investigated using the SEISMO module. At the time of preparing this IRSR, new information generated through expert elicitation regarding potential seismic hazards at the YM site became available (U.S. Department of Energy, 1998b). This new information will be included as the base case in a subsequent version of the SEISMO module.

As noted earlier, the seismic recurrence sampling is handled by the SAMPLER utility module in the TPA code. Ten discrete sampling accelerations can be used to describe a seismic hazard and should provide a relatively good representation of that hazard curve. Evaluation of the sensitivity

of results to various hazard curves is possible using SEISMO by giving the ground acceleration sampling points and corresponding recurrence times representative of the seismic hazard curves to be analyzed.

### **Impact Load and Stress Calculations**

The approach used for dynamic or impact load determination in the SEISMO module is approximated based on the principle of conservation of energy. This approach assumes that the potential energy associated with freely falling rock is converted completely to strain energy imparted to the WPs during impact. Several other assumptions are also made: (i) a WP can be treated as an equivalent spring with a spring constant,  $k_{wp}$ ; (ii) the deformation of WPs is directly proportional to the magnitude of the dynamically applied force; (iii) no energy dissipation takes place at the point of impact due to local inelastic deformation of the WP material; and (iv) the inertia of the WP resisting an impact may be neglected.

Based on the above assumptions, the impact load can be approximated using the following equation (Popov, 1970):

$$P_{dyn} = W \left( 1 + \sqrt{1 + \frac{2hk_{wp}}{W}} \right) = W \left( 1 + \sqrt{1 + \frac{2h}{\Delta_{st}}} \right) \quad (1)$$

where

$P_{dyn}$ —impact load,  
 $W$ —weight of the rock falling,  
 $h$ —falling distance of rocks to WPs,  
 $\Delta_{st}$ —spring deformation, and  
 $k_{wp}$ —stiffness of the WPs.

$k_{wp}$  of a WP is defined as the load necessary to produce a unit deflection at the center of a simply supported beam.

The WP supports are considered to be flexible in the SEISMO module. In the current conceptual design, a WP will be sitting on four equally spaced v-shaped thin beams with one vertical cylindrical bar on either side of the v-shaped beam. However, only the two supports at the ends of a WP are considered. Originally,  $\Delta_{st}$  in Eq. (1) is the static deflection of the object impacted. In order to account for the deformability of WP support,  $\Delta_{st}$  is made to be equal to

$$\Delta_{st} = \frac{W}{k_{wp}} + \frac{W}{2N_s k_b} \quad (2)$$

where  $k_{wp}$ —stiffness of the WP,  $N_s = 2$ , which is the number of the supports at the end of a WP, and  $k_b$ —stiffness of the vertical bars.

$k_b$  can be calculated by

$$k_b = \frac{AE}{L} \quad (3)$$

and  $k_{wp}$  can be calculated by

$$k_{wp} = \frac{48EI}{L_{wp}^3} \quad (4)$$

where  $A$  and  $L$  are the cross-sectional area and height of the vertical bar, respectively.

$L_{wp}$ —length of the WP, and

$$I = \pi R_{avg}^3 t$$

$t$ —thickness of WP considering both inner and outer layers

$R_{avg}$ —average of the outer and inner wall radius of the WP

No information regarding the shape and dimension of the bar is currently available.

From the impact load, the equivalent static stress resulting from the impact can be calculated by adopting a simple concept of two spheres in contact and assuming that the pressure is distributed over a small circle of contact with the sphere representing rock has an infinite radius (Timoshenko and Goodier, 1987), the impact pressure,  $p$ , can be obtained by

$$p = \frac{3}{2\pi} \left( \frac{16P_{dyn}}{9\pi^2} \frac{1}{(c_{wp} + c_{rock})^2 R_{wp}^2} \right)^{\frac{1}{3}} \quad (5)$$

where

$R_{wp}$ —radius of lower sphere or WP

$c_{wp}$ —material constant for lower sphere or WP

$c_{rock}$ —material constant for upper sphere or rockfall, and

$$c_{wp} = \frac{1 - \mu_{wp}^2}{\pi E_{wp}} \quad (6)$$

$$c_{rock} = \frac{1 - \mu_{rock}^2}{\pi E_{rock}} \quad (7)$$

Where

$E_{wp}$ —modulus of elasticity of lower sphere or WP

$\mu_{wp}$ —Poisson's ratio of lower sphere or WP

$E_{rock}$ —modulus of elasticity of upper sphere or rockfall

$\mu_{rock}$ —Poisson's ratio of upper sphere or rockfall

The assumption made for the WPs, spherical in shape instead of a cylinder, is believed to give a conservative calculation of impact stress since the contact area calculated using this assumption is smaller than that from assuming a cylindrical shape.

### ***Failure Criterion***

To judge the failure of a WP, a maximum allowable strain failure criterion is adopted in the SEISMO module. If the impact stress calculated using Eq. (5) induces a plastic strain at the contact of impact exceeding 2-percent (Timoshenko, 1956), the WPs are assumed to be ruptured. This assumption should provide a conservative approach for estimating failure of WPs. The potential damage that rockfall can cause to the spent fuel cladding is currently not accounted for in the SEISMO module.

### ***Limitations of the SEISMO Approach***

Although the current SEISMO module does not link seismicity with corrosion, over time, corrosion could weaken WPs and make them more susceptible to failure by seismically induced rockfall. Conversely, the damage resulting from rockfall could weaken WPs and make them more susceptible to corrosion over time. In the current SEISMO module, these conditions are not included. These conditions may be considered in the future revision of the SEISMO module.

For calculation of the rockfall impact load, the falling rocks are assumed to remain intact (that is, all energy generated through dynamic impact is transferred to the WP). If rock is allowed to break, the effective impact stress on the WP should be smaller since some impact energy will be absorbed by breaking the rock. Consequently, assuming that the falling rock blocks remain intact is conservative in assessing integrity of WPs.

The SEISMO module in its current form does not take into consideration cumulative damage due to repeated rockfalls. Some work will need to be done to address this limitation.

### **4.3.5 Thermal-Mechanical Effects on Inputs to the Assessment of Flow into Emplacement Drifts**

It is DOE's position that ground supports (including concrete liners) are designed to meet only the requirements of preclosure performance. DOE made it clear that the effectiveness of the ground support system will not be considered in its postclosure assessments. In other words, the ground support system is assumed to lose its function after repository closure. This approach is clearly conservative. For consistency, however, the deterioration of rock mass surrounding emplacement drifts should also be factored into the PA code so that its effect can be evaluated. In order to conduct a reasonable evaluation, the extent of the deterioration of rock mass in the repository should be better understood.

The expected behavior of unsupported underground openings under sustained rock mass degradation includes cave-in of the roof and collapse of the sidewalls, leading to changes in geometry of the openings and consequently changes in porosity and permeability within the collapsed-rock zone. Immediately outside these caved zones, rock masses may be substantially loosened due to degradation of intact rock blocks and excessive joint displacements. It is clear that the hydrological properties in the area with rock mass disturbed will be different from those areas

that are undisturbed. The extent of this zone and the corresponding change in hydrological properties are not very well understood. The extent of disturbances for both caving and loosening due to TM effects and seismic shaking will be reduced if the emplacement drifts are backfilled.

#### **4.3.5.1 Acceptance Criteria**

The staff will find DOE's consideration of TM effects on input to hydrological flow assessment acceptable if:

- (1) Approved QA, control procedures, and standards were applied to collection, development and documentation of data, methods, models and codes.
- (2) If used, expert elicitation is conducted and documented in accordance with the guidance in NUREG-1563 (U.S. Nuclear Regulatory Commission, 1996b) or other acceptable approaches.
- (3) Time-dependent changes in size and shape of the emplacement drifts due to thermally induced ground movements (rock deformations, collapse, and other changes that may affect the integrity and geometrical configuration of underground openings) are clearly described, and the magnitudes and distributions of the changes provided are consistent with the results of TM analyses of the underground facility.
- (4) Changes in hydrological properties (e.g., fracture porosity and permeability) due to thermally induced ground movements are clearly described, and the magnitudes and distributions of the changes provided are consistent with the results of TM analyses of the underground facility.

#### **4.3.5.2 Technical Bases**

The focus of the technical bases provided in the following paragraphs is placed on acceptance criteria 3 and 4. Thermally induced ground movements (rock deformations, collapse, and other changes that may affect the integrity and geometrical configuration of underground openings) will affect inputs to hydrological flow assessment in two ways: changes in fracture permeability and porosity associated with rock deformation, and changes in geometry (size and shape) of underground openings. Both effects have been recognized within DOE's program. The assessment of the impact of thermal loading on the fracture porosity and permeability throughout the host rock, particularly near the emplacement drifts and within the intervening pillars is one of the issues that was presented to a panel of experts assembled by DOE to examine the role and assessment of near-field/altered zone coupled effects (Geomatrix Consultants, 1998). Also, the fraction of WPs exposed to seepage, referred to as seepage fraction,  $f_s$ , is a key input into the assessment of WP degradation and, ultimately, dose to individuals in DOE's TSPA-VA code (Wilson, 1998). The parameter  $f_s$  depends on the distribution of seepage on the drift wall, for which the size and shape of the drift are key inputs because of their effects on the capture area for drift seepage (Wilson, 1998; Birkholzer, 1998).

Changes in size and shape of emplacement drifts may result from drift-wall collapse and consequent enlargement of the roof area (e.g., Figures 5 and 12). Changes in fracture permeability and porosity may result from both elastic deformations (caused by reversible thermal

expansion of rock) and inelastic deformations (associated with failure in shear or tension). Adequate assessment of thermally induced changes in porosity and permeability requires consideration of both elastic and inelastic processes, because the magnitude of thermally induced elastic deformations may be small relative to the potential magnitude of inelastic deformations that may result due to failure caused by rock-mass degradation. For example, the assessment of permeability changes suggested by Elsworth (1998), which is based purely on consideration of elastic deformations, is likely to give only a lower-bound estimate of the potential permeability change.

It is DOE's decision to design the ground supports to maintain stability of the emplacement drifts for the preclosure period only, therefore, the continuing function of the ground supports beyond permanent closure cannot be assured. Consequently, the underground openings must be assumed to be unsupported during the postclosure period. Post-closure response within the underground facility will be controlled by thermal stresses imposed on a rock mass that may be experiencing progressive degradation of strength and elastic properties caused by sustained loading and extended exposure to heat and moisture. The expected behavior around unsupported underground openings under such conditions includes collapse of the surrounding rock into the openings and consequent cave-in of the roof area, leading to changes in geometry (size and shape) of the openings and changes in hydrological properties (such as fracture porosity and permeability) in the vicinity of the openings (see Figure 12).

An assessment of such potential changes in porosity and permeability as well as changes in emplacement-drift geometry will be considered by other KTIs as appropriate.

#### **4.4 DESIGN AND LONG-TERM CONTRIBUTION OF REPOSITORY SEALS IN MEETING POSTCLOSURE PERFORMANCE OBJECTIVES**

This subissue will be addressed in subsequent revisions of this IRSR.

##### **4.4.1 Review Methods**

The review methods will be developed in subsequent revisions to this IRSR.

##### **4.4.2 Acceptance Criteria**

The acceptance criteria will be developed in subsequent revisions to this IRSR.

##### **4.4.3 Technical Bases**

Technical bases will be described in future revisions to this IRSR.

## **5.0 STATUS OF ISSUE RESOLUTION AT THE STAFF LEVEL**

### **5.1 DESIGN CONTROL PROCESS**

#### **Exploratory Studies Facility**

The staff considers DOE's design control process implemented for the ESF to be acceptable. This conclusion is based on the reviews of DOE's responses to staff queries, QA audits, surveillances, review of DOE's RCRR, observation of design reviews, selective reviews of design packages, site visits, meetings, and in-field verification. The staff has no major concerns or questions related to the ESF design or the design control process employed for the ESF design, construction, or operation at this time. However, the following two items will continue to be under focused review by the staff: (i) quality classification for the concrete inverts used for the ESF construction; and (ii) hierarchy of documents that control site characterization, design, construction, and operations activities at the YM site (see item 24 of the appendix).

#### **Geologic Repository Operations Area**

During FY98, the staff conducted a limited evaluation of the effectiveness of DOE's implementation of the design control process as a generic matter for all the SSCs that comprise the GROA. Specifically, the staff selected six systems of the GROA (three surface and three subsurface systems) for a detailed assessment of DOE's compliance/noncompliance with the twelve acceptance criteria (Section 4.1.3) that the staff developed to measure the effectiveness of DOE's design control process. While the staff recognizes that the six systems represent only a small part of DOE's design activities for the entire GROA, the staff concludes that, with one exception, DOE has an effective design control program for the GROA, based on this limited review. The one area in this program in need of improvement is in relation to control of design changes relative to an original design and proper documentation of such changes (Section 4.1.5.2). As mentioned above, the staff will continue to monitor the effectiveness of DOE's design control process, including any identified areas of weakness.

#### **5.1.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans**

Item ID: OSC0000001347C121 Comment 121 SCA

Title: Seismic design criteria for ESF

Status: Closed

Basis: Staff review of revised ESFDR submitted by DOE (YMP/CM-0019, Rev. 2), appendix-A. Design input values are subject to verification under TR-3 review.

Item ID: OSC0000001347C130 Comment 130 SCA

Title: Part 60 design criteria applicable to ESF

Status: Closed

Basis: Staff review of RCRR submitted by DOE in response to NRC's letter of October 13, 1994.



Item ID: OSC0000001347Q003 Question 003 SCA  
Title: Rationale for selecting the total area for repository development  
Status: Closed  
Basis: Design concepts for the repository have changed. The question will be re-examined when DOE submits up-to-date design concepts.

Item ID: OSC0000001347Q020 Question 020 SCA  
Title: Vertical versus horizontal emplacement orientation decision  
Status: Closed  
Basis: Vertical emplacement is no longer an option.

Item ID: OSC0000001347Q021 Question 021 SCA  
Title: Radiation shielding of host rock  
Status: Closed  
Basis: Question based on outdated concepts of WP design and vertical emplacement that is no longer an option.

Item ID: OSC0000001347Q042 Question 041 SCA  
Title: Regulatory basis for Issue Resolution Strategy 2.4 on waste retrieval  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q042 Question 042 SCA  
Title: Stability of vertical emplacement holes  
Status: Closed  
Basis: Vertical emplacement hole is no longer an option.

Item ID: OSC0000001347Q056 Question 056 SCA  
Title: Fault displacement tolerance  
Status: Closed  
Basis: Question based on outdated vertical emplacement concept. Actual fault displacement design inputs are subject to verification during TR-3 review.

Item ID: OSC0000001347Q057 Question 057 SCA  
Title: Borehole drilling and design flexibility  
Status: Closed  
Basis: Question based on outdated ESF design

Item ID: OSC0000001347Q058 Question 058 SCA  
Title: Design to accommodate *in situ* WP testing  
Status: Closed  
Basis: Question based on two vertical shafts rather than the current ramps

Item ID: OSC0000001347Q062 Question 062 SCA  
Title: Separation distance between ESF and waste emplacement panels  
Status: Closed  
Basis: Question based on SCP conceptual design that is outdated.

### **5.1.2 Status of Open Items from U.S. Department of Energy—U.S. Nuclear Regulatory Commission Correspondence/Interactions**

**Item ID:** OQA013OCT1994C00 Comment 001

**Title:** The M&O QAP is not being effectively implemented in a manner that will assure acceptability of the ESF (includes flowdown of RRs)

**Status:** Closed

**Basis:** See OQA013OCT1994Q00 Question 003

**Item ID:** OQA013OCT1994Q00 Question 001

**Title:** Phases of proposed design and construction of ESF

**Status:** Closed

**Basis:** See OQA013OCT1994Q00 Question 003

**Item ID:** OQA013OCT1994Q00 Question 002

**Title:** Potential of construction work to impact site characterization or the waste isolation capability of the site

**Status:** Closed

**Basis:** See OQA013OCT1994Q00 Question 003

**Item ID:** OQA013OCT1994Q00 Question 003

**Title:** Current conceptual design, testing strategy, and control mechanism

**Status:** Closed

**Basis:** The previous four items are closed based on staff review of DOE's responses of October 17, 1994; November 14, 1994; January 27, 1995; March 14, 1995; May 1, 1995; staff observation of DOE's QA audit of January 9–13, 1995; and staff in-field verification of April 3–6, 1995 (see appendix for details).

### **5.1.3 Status of Open Items from In-Field Verifications**

**Item ID:** In-field Verification Recommendation-1

**Title:** Numerical modeling of rock bolts

**Status:** Closed

**Basis:** Review of Book #2, "Numerical Modeling of Rock Bolts," during appendix 7 meeting at M&O office, June 11–12, 1997.

**Item ID:** In-field Verification Recommendation-2

**Title:** Reportable geologic condition

**Status:** Closed

**Basis:** Staff review of revised procedure, "YAP-30.27" (which superseded AP-6.14).

**Item ID:** In-field Verification Recommendation-3

**Title:** Quality classification of precast concrete inverts

**Status:** Open

**Basis:** Staff review of DOE's response of September 25, 1995, and discussions during appendix 7 meeting at the M&O Office, June 11–12, 1997, including review of Book #5 "Invert Re-evaluation" and final draft of "White Paper on a Functional Reassessment of the ESF Inverts."

DOE continues to defend its decision to classify concrete inverts as temporary structures and considers that they can be removed and replaced by temporarily transferring the loads from the steel sets to another load-carrying frame while the "temporary" invert is removed and replaced by another qualified invert. The staff, however, believes that the concrete inverts are part of the roof support system and should be given the same QA classification as the rest of the roof support components, such as the steel sets and roof bolts. The staff also believes that the procedure of temporarily transferring the loads is not only cumbersome and complicated but also could potentially result in stressing the rocks and the steel sets in addition to posing increased worker-safety concerns.

The staff recommends that DOE take appropriate actions necessary to document the quality of concrete used and its characteristics, such as physical, chemical, and mechanical properties, and conduct the necessary analyses to study any long-term adverse impacts.

## **5.2 SEISMIC DESIGN METHODOLOGY**

### **5.2.1 Status of Topical Report-1**

The details of status of open items for TR-1 have been documented in the Structural Deformation and Seismicity KTI IRSR.

### **5.2.2 Status of Topical Report-2**

Based on the review of Rev. 2 of TR-2, the seismic design methodology presented by DOE is acceptable to the staff. The concerns related to repeated seismic loading for the preclosure design have been closed based on the rationale presented in TR-2. The staff has no further questions on this component of the subissue at the present time.

The staff will continue to be involved in observing DOE's expert elicitation during the preparation of final hazard curves for the YM site along with the identification of design basis accelerations and fault displacements. Although DOE's seismic design methodology is acceptable, it should be noted that the acceptability of DOE's seismic and fault displacement design of the GROA will be made during the LA review. Furthermore, this methodology is intended for a minimal maintenance for the preclosure facilities over a period of 150 years. In light of a possible implementation of an extended monitored geological disposition program that could result in continued underground access for up to 300 years (U.S. Department of Energy, 1998e), the applicability of the seismic design methodology may need to be revisited.

### **5.2.3 Status of Topical Report-3**

Consideration of repeated seismic loading for the (postclosure) design of WP and TSPAs is expected to be covered during the review of TR-3. (As stated earlier, the staff will review TR-3 on seismic and fault displacement inputs for design and PAs and consider the set of three TRs in the context of how the TRs together will help simplify the licensing review.) TR-3 will be reviewed during FY99 and review results will be documented in Rev. 2 of this IRSR.

### **5.1.2 Status of Open Items from U.S. Department of Energy—U.S. Nuclear Regulatory Commission Correspondence/Interactions**

Item ID: OQA013OCT1994C00 Comment 001

Title: The M&O QAP is not being effectively implemented in a manner that will assure acceptability of the ESF (includes flowdown of RRs)

Status: Closed

Basis: See OQA013OCT1994Q00 Question 003

Item ID: OQA013OCT1994Q00 Question 001

Title: Phases of proposed design and construction of ESF

Status: Closed

Basis: See OQA013OCT1994Q00 Question 003

Item ID: OQA013OCT1994Q00 Question 002

Title: Potential of construction work to impact site characterization or the waste isolation capability of the site

Status: Closed

Basis: See OQA013OCT1994Q00 Question 003

Item ID: OQA013OCT1994Q00 Question 003

Title: Current conceptual design, testing strategy, and control mechanism

Status: Closed

Basis: The previous four items are closed based on staff review of DOE's responses of October 17, 1994; November 14, 1994; January 27, 1995; March 14, 1995; May 1, 1995; staff observation of DOE's QA audit of January 9–13, 1995; and staff in-field verification of April 3–6, 1995 (see appendix for details).

### **5.1.3 Status of Open Items from In-Field Verifications**

Item ID: In-field Verification Recommendation-1

Title: Numerical modeling of rock bolts

Status: Closed

Basis: Review of Book #2, "Numerical Modeling of Rock Bolts," during appendix 7 meeting at M&O office, June 11–12, 1997.

Item ID: In-field Verification Recommendation-2

Title: Reportable geologic condition

Status: Closed

Basis: Staff review of revised procedure, "YAP-30.27" (which superseded AP-6.14).

Item ID: In-field Verification Recommendation-3

Title: Quality classification of precast concrete inverts

Status: Open

Basis: Staff review of DOE's response of September 25, 1995, and discussions during appendix 7 meeting at the M&O Office, June 11–12, 1997, including review of Book #5 "Invert Re-evaluation" and final draft of "White Paper on a Functional Reassessment of the ESF Inverts."

DOE continues to defend its decision to classify concrete inverts as temporary structures and considers that they can be removed and replaced by temporarily transferring the loads from the steel sets to another load-carrying frame while the "temporary" invert is removed and replaced by another qualified invert. The staff, however, believes that the concrete inverts are part of the roof support system and should be given the same QA classification as the rest of the roof support components, such as the steel sets and roof bolts. The staff also believes that the procedure of temporarily transferring the loads is not only cumbersome and complicated but also could potentially result in stressing the rocks and the steel sets in addition to posing increased worker-safety concerns.

The staff recommends that DOE take appropriate actions necessary to document the quality of concrete used and its characteristics, such as physical, chemical, and mechanical properties, and conduct the necessary analyses to study any long-term adverse impacts.

## **5.2 SEISMIC DESIGN METHODOLOGY**

### **5.2.1 Status of Topical Report-1**

The details of status of open items for TR-1 have been documented in the Structural Deformation and Seismicity KTI IRSR.

### **5.2.2 Status of Topical Report-2**

Based on the review of Rev. 2 of TR-2, the seismic design methodology presented by DOE is acceptable to the staff. The concerns related to repeated seismic loading for the preclosure design have been closed based on the rationale presented in TR-2. The staff has no further questions on this component of the subissue at the present time.

The staff will continue to be involved in observing DOE's expert elicitation during the preparation of final hazard curves for the YM site along with the identification of design basis accelerations and fault displacements. Although DOE's seismic design methodology is acceptable, it should be noted that the acceptability of DOE's seismic and fault displacement design of the GROA will be made during the LA review. Furthermore, this methodology is intended for a minimal maintenance for the preclosure facilities over a period of 150 years. In light of a possible implementation of an extended monitored geological disposition program that could result in continued underground access for up to 300 years (U.S. Department of Energy, 1998e), the applicability of the seismic design methodology may need to be revisited.

### **5.2.3 Status of Topical Report-3**

Consideration of repeated seismic loading for the (postclosure) design of WP and TSPAs is expected to be covered during the review of TR-3. (As stated earlier, the staff will review TR-3 on seismic and fault displacement inputs for design and PAs and consider the set of three TRs in the context of how the TRs together will help simplify the licensing review.) TR-3 will be reviewed during FY99 and review results will be documented in Rev. 2 of this IRSR.

### **5.3 THERMAL-MECHANICAL EFFECTS**

This subissue will be addressed in subsequent revisions of this IRSR. More work needs to be done to resolve this subissue (e.g., (i) determination of size of rock that will fail due to seismicity and its effect on performance assessment and (ii) detailed review of DOE's thermal testing data).

#### **5.3.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans**

Item ID: OSC0000001347C055 Comment 055 SCA  
Title: Use of statistics in TM properties  
Status: Open  
Basis: TBD

Item ID: OSC0000001346C056 Comment 056 SCA  
Title: Validation of models/TM properties  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q042 Question 009 SCA  
Title: Systematic drilling program implementation strategy  
Status: Open  
Basis: TBD

#### **5.3.2 Other Related Items**

TBD

### **5.4 DESIGN AND LONG-TERM CONTRIBUTION OF SEALS TO PERFORMANCE**

This subissue will be addressed in subsequent revisions of this IRSR as DOE and NRC begin to focus more attention on it.

#### **5.4.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans**

Item ID: OSC0000001347Q042 Comment 074 SCA  
Title: DOE's plan for *in-situ* testing of seal components  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q025 Question 025 SCA  
Title: Sealing program/gaseous transport  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q028 Question 028 SCA  
Title: Impacts on sealing program/calico hills penetration  
Status: Closed  
Basis: TBD

Item ID: OSP0000831421Q001 Question 001 SP831421  
Title: Status of borehole seal design  
Status: Open  
Basis: TBD

Item ID: OSP0000831421Q002 Question 002 SP831421  
Title: Specification for sealing boreholes  
Status: Open  
Basis: TBD

#### **5.4.2 Other Related Items**

TBD

### **5.5 OTHER OPEN ITEMS NOT COVERED UNDER THE FOUR SUBISSUES**

#### **5.5.1 Status of Open Items from Site Characterization Plan/Site Characterization Analysis, and Study Plans**

Item ID: OSC0000001347C077 Comment 077 SCA  
Title: Retrieval accidents/radiation exposure  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q012 Comment 120 SCA  
Title: Comprehensive, integrated and prioritized plan for model and code validation  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q042 Comment 122 SCA  
Title: Criteria for determining the acceptability of dry coring method  
Status: Open  
Basis: TBD

Item ID: OSC0000001347Q042 Question 055 SCA  
Title: Analysis of potential test interference from water storage facilities.  
Status: Open  
Basis: TBD

#### **5.5.2 Status of Open Items from the Annotated Outline**

Item ID: OAO030SEP1992C00 Comment 003 AO30SEP1992  
Title: Planned area/controlled area  
Status: Open  
Basis: TBD

Item ID: OAO030SEP1992C00 Comment 004 AO30SEP1992  
Title: Legal definition of controlled area  
Status: Open  
Basis: TBD

Item ID: OAO030SEP1992Q00 Question 001 AO30SEP1992  
Title: Figure reference/underground facility  
Status: Open  
Basis: TBD



## 6.0 LIST OF REFERENCES

- Ahola, M.P., R. Chen, H. Karimi, S. M. Hsiung, and A.H. Chowdhury, *A Parametric Study of Drift Stability in Jointed Rock Mass, Phase I: Discrete Element Thermal-Mechanical Analysis of Unbackfilled Drifts*, CNWRA 96-009, San Antonio, TX, Center for Nuclear Waste Regulatory Analyses, 1996.
- Ashlock, K.J., *MGDS Interface Control Document, Procedure Number NLP-3-34*, 1997.
- Baluch, M.H., L.A.R. Al-Nour, A.K. Azad, Y.M. Al-Mandil, A.M. Sharif, and D. Pearson-Kirk, *Concrete Degradation Due to Thermal Incompatibility of its Components*, Journal of Materials in Civil Engineering 1(3), 105-108, 1989.
- Barton, N., R. Lien, and J. Lunde, *Engineering Classification of Rock Masses for the Design of Tunnel Support*, Rock Mechanics 6, 189-236, 1974.
- Bell, M.J., Letter (November 3) to R.A. Milner, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1994.
- Bell, M.J., Letter (February 14) to R.A. Milner, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1995a.
- Bell, M.J., Letter (December 1) to S.J. Brocoum, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1995b.
- Bell, M.J., Letter (May 21) to S.J. Brocoum, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1996a.
- Bell, M.J., Letter (July 25) to S.J. Brocoum, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1996b.
- Bell, M.J., Letter (March 21) to S.J. Brocoum, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1997.
- Bernero, R.M., Letter (July 31) to S. Rousso, U.S. Department of Energy, Washington, DC, U.S. Nuclear Regulatory Commission, 1989.
- Birkholzer, J., *A Process Model for Seepage into Drifts at Yucca Mountain, Presentation at DOE/U.S. NRC Technical Exchange on Total System Performance Assessment, Viability Assessment, Berkeley, California, March 17-19*, Lawrence Berkeley National Laboratory, 1998.
- Brechtel, C.E., M. Lin, E. Martin, and D. S. Kessel, *Geotechnical Characterization of the North Ramp of the Exploratory Studies Facility*, Vol. 1-Data Summary, SAND95-0488/1, Albuquerque, Sandia National Laboratories, 1995.
- Brocoum, S.J., Letter (October 25) to M.J. Bell, U.S. Nuclear Regulatory Commission, Washington, DC, U.S. Department of Energy, 1996.

Brocoum, S.J. Letter (August 27) to M.J. Bell, U.S. Nuclear Regulatory Commission, Washington, DC, U.S. Department of Energy, 1997.

Center for Nuclear Waste Regulatory Analyses, *U.S. Nuclear Regulatory Commission High-Level Radioactive Program Annual Progress Report: Fiscal Year 1996*, NUREG/CR-6513, No. 1, Washington, DC, U.S. Nuclear Regulatory Commission, January 1997.

Chen, R., M.P. Ahola, S.M. Hsiung, and A.H. Chowdhury, *Thermal-Mechanical Stability of Emplacement Drifts for a Proposed Nuclear Waste Repository at Yucca Mountain*, San Antonio, TX, Center for Nuclear Waste Regulatory Analyses, 1998.

CRWMS M&O, *Thermomechanical Analyses*, Document Identifier Number BC0000000-01717-5705-00013, Rev. 00, Las Vegas, NV, Civilian Radioactive Waste Management System Management & Operating Contractor, 1995.

CRWMS M&O, *Controlled Design Assumptions Document*, Document Identifier Number BCA000000-01717-4600-00032, Rev. 04, ICN 4, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1996.

CRWMS M&O, *Repository Subsurface Layout Configuration Analysis*, Document Identifier Number BCA000000-01717-0200-00008, Rev. 00, Las Vegas, NV, Civilian Radioactive Waste Management System Management and Operations Contractor, 1997a.

CRWMS M&O, *Repository Thermal Loading Management Analysis*, Document Identifier Number B00000000-01717-0200-00135, Rev. 00, Las Vegas, NV, Civilian Radioactive Waste Management System Management and Operations Contractor, 1997b.

CRWMS M&O, *Repository Ground Support Analysis for Viability Assessment*, Document Identifier Number BCAA00000-01717-0200-00004, Rev. 00, Las Vegas, NV, Civilian Radioactive Waste Management System Management and Operations Contractor, 1997c.

CRWMS M&O, *Mined Geological Disposal System Design Guidelines Manual*, Document Identifier Number BCA000000-01717-3500-00001, Rev. 02, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1997d.

CRWMS M&O, *Overall Development and Emplacement Ventilation Systems*, Document Identifier Number BCA000000-01717-0200-00015, Rev. 00, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1997e.

CRWMS M&O, *Quality Administrative Procedure*, Volume 1 Rev. 03, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1997f.

CRWMS M&O, *Surface Nuclear Facilities HVAC Analysis*, Document Identifier Number BCA000000-01717-0200-00013, Rev. 00, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1997g.

CRWMS M&O, *Waste Handling Systems Configuration Analysis*, Document Identifier Number BCA000000-01717-0200-00001, Rev. 00, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1997h.

CRWMS M&O, *Site Gas/Liquid Systems Technical Report*, Document Identifier Number BCA000000-01717-5705-00001, Rev. 00, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1998a.

CRWMS M&O, *Controlled Design Assumptions Document*, Document Identifier Number BCA000000-01717-4600-00032, Rev. 04, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1998b.

CRWMS M&O, *Design Guidelines Manual*, Document Identifier Number BCA000000-01717-3500-00001, Rev. 03, Las Vegas, NV: Civilian Waste Management and Operations Contractor, 1998c.

Dershowitz, W., G. Lee, J. Geier, S. Hitchcock, and P. LaPointe, *Fracman—Interactive Discrete Feature Data Analysis, Geometric Modeling, Exploration Simulation*, Golder Associates, 1993.

Dowding, C.H., and A. Rozen, *Damage to rock tunnels from earthquake shaking*, Journal of Geotechnical Engineering, 104(GT2),175191, 1978.

Duncan, A.B., S.G. Bilhorn, and J.E. Kennedy, *Technical Position on Items and Activities in the High-Level Waste Geologic Repository Program Subject to Quality Assurance Requirements*, NUREG-1318, U.S. Nuclear Regulatory Commission, April 1988.

Elsworth, D., *TMH fracture porosity preliminary evaluation*, *Workshop on Preliminary Interpretations: Near Field/Altered Zone Coupled Processes Expert Elicitation Project*, Geomatrix Consultants, 1998.

Fahy, M.F., and F.C. Beason, *Geotechnical Analysis for the Exploratory Studies Facility North Ramp Boxcut and Starter Tunnel*, U.S. Geological Survey, Vols 1 & 2, 1995.

Gauthier, J.H., M.L. Wilson, D.J. Borns, and B.W. Arnold, *Impacts of Seismic Activity on Long-Term Repository Performance at Yucca Mountain*, *Proceedings Methods of Seismic Hazards Evaluation*, Focus '95, Albuquerque, NM, 159-168, 1995.

Geomatrix Consultants, *Workshop on Preliminary Interpretations: Near Field/Altered Zone Coupled Processes Expert Elicitation Project*, Geomatrix Consultants, 1998.

Goodman, R., and G.H. Shi, *Block Theory and Its Application to Rock Engineering*, Prentice Hall, 1985.

Gupta, D., J. Peshel, and J. Bunting, *Staff Technical Position on Regulatory Considerations of the Exploratory Shaft Facility*, NUREG-1439, U.S. Nuclear Regulatory Commission, July 1991.

Hardy, M.P., *Design of Underground Repository Openings in Hard Rock to Accommodate Vibratory Groundmotions*, *Dynamic Analysis and Design Considerations for High-Level Nuclear Waste Repositories*, American Society of Civil Engineers, 1992.

Harmathy, T.Z., *Thermal properties of concrete at elevated temperature*, Journal of Materials, 5(1), 47-74, 1970.

- Hoek, E., *Strength of rock and rock masses*, ISRM News Journal 2(2), 4–16, 1994.
- Hoek, E., and E.T. Brown, *Underground Excavations in Rock*, Institution of Mining and Metallurgy, London, England, 1982.
- Hoek, E., and E.T. Brown, *Practical estimates of rock mass strength*, International Journal of Rock Mechanics and Mining Sciences 34(8), 1165–1186, 1997.
- Itasca Consulting Group, Inc., *UDEC—Universal Distinct Element Code*, Ver. 3.0, Vol. I, User's Manual, Minneapolis, MN, Itasca Consulting Group, Inc., 1996.
- Khoury, G.A., B.N. Grainger, and P.J.E. Sullivan, *Strain of concrete during first heating to 600°C under load*, Magazine of Concrete Research 37(133), 195–215, 1985.
- Kingrey, W.D., and M.C. McQuarrie, *Thermal Conductivity: I, Concepts of measurement and factors affecting thermal conductivity of ceramic materials*, Journal of the American Ceramic Society 37, 1954.
- Lajtai, E.Z., and R.H. Schmidtke, *Delayed failure in rock loaded in uniaxial compression*, Rock Mechanics and Rock Engineering 19, 11–25, 1986.
- Lin, M., M.P. Hardy, and S.J. Bauer, *Fracture Analysis and Rock Quality Designation Estimation for the Yucca Mountain Site Characterization Project*, SAND92-0449, Albuquerque, NM, Sandia National Laboratories, 1993a.
- Lin, M., M.P. Hardy, J.F.T. Agapito & Associates, and S.J. Bauer, *Rock Mass Mechanical Property Estimations for the Yucca Mountain Site Characterization Project*, SAND92-0450, UC-814, Albuquerque, NM and Livermore, CA, Sandia National Laboratories, 1993b.
- Manteufel, R.D., R.G. Baca, S. Mohanty, M.S. Jarezemba, R.W. Janetzke, S.A. Stothoff, C.B. Connor, G.A. Cragolino, A.H. Chowdhury, J.T. McCartin, and T.M. Ahn, *Total system Performance Assessment (TPA) Version 3.0 Code: Module Description and User's Guide*, San Antonio, TX, Center for Nuclear Waste Regulatory Analyses, 1997.
- Marechal, J.C., *Variations in the Modulus of Elasticity and Poisson's Ratio with Temperature*, Concrete for Nuclear Reactors, ACI SP-34, 1, 495–503, 1972.
- McConnell, K.I., M.E. Blankford, and A.K. Ibrahim, *Staff Technical Position on Investigations to Identify Fault Displacement Hazards and Seismic Hazards at a Geologic Repository*, NUREG-1451, Washington, DC, U.S. Nuclear Regulatory Commission, July 1992.
- McConnell, K.I., and M.P. Lee, *Staff Technical Position on Consideration of Fault Displacement Hazards in Geologic Repository Design*, NUREG-1494, Washington, DC, U.S. Nuclear Regulatory Commission, September 1994.
- Milner, R.A., Letter (August 22) to J.J. Holonich, U.S. Nuclear Regulatory Commission, Washington, DC, U.S. Department of Energy, 1994.

Milner, R.A., Letter (January 26) to J.J. Holonich, U.S. Nuclear Regulatory Commission, Washington, DC, U.S. Department of Energy, 1995.

Nataraja, M.S., B.N. Jagannath, S.M. Hsiung, and A. Ghosh, *Review of Department of Energy Regulatory Compliance Review Report*, U.S. Nuclear Regulatory Commission and Center for Nuclear Waste Regulatory Analyses, November 1995.

Ofoegbu, G.I., and J.H. Curran, *Deformability of intact rock*, International Journal of Rock Mechanics and Mining Sciences 29(1), 35-48, 1992.

Popov, E.P., *Mechanics of Materials*, Prentice Hall, New York, NY, 1970.

Schenker, A.R., D.C. Guerin, T.H. Robey, C.A. Rautman, and R.W. Barnard, *Stochastic Hydrogeologic Units and Hydrogeologic Properties Development for Total-System Performance Assessments*, SAND94-0244, Albuquerque, NM, Sandia National Laboratories, 1995.

Shelor, D.E., Letter (June 7) to J.J. Holonich of U.S. Nuclear Regulatory Commission, Washington, DC, U.S. Department of Energy, 1993.

Shi, G.H., Simplex integration for manifold method, FEM, DDA and analytical analysis, *Proceedings of the 1<sup>st</sup> International Forum on Discontinuous Deformation Analysis*, Berkeley, CA, June 12-14, 205-265, 1996.

Timoshenko, S.P. *Strength of Materials: Part II Advanced Theory and Problems*, 3rd ed. D. Van Nostrand Co., Inc., Princeton, N.J., 1956

Timoshenko, S.P., and J.N. Goodier, *Theory of Elasticity*, McGraw-Hall, New York, NY, 1987.

Tsai, F.C., *Drift-Scale Thermomechanical Analysis for the Retrievability Systems Study*, Workshop on Rock Mechanics Issues in Repository Design and Performance Assessment, NUREG/CP-0150, Washington, DC, U.S. Nuclear Regulatory Commission, April 1996.

U.S. Department of Energy, *Natural Phenomena Hazards Design and Evaluation Criteria for Department of Energy Facilities*, DOE-STD-1020-94, Washington, DC, U.S. Department of Energy, 1994a.

U.S. Department of Energy, *Methodology to Assess Fault Displacement and Vibratory Groundmotion Hazards at Yucca Mountain*, YMP/TR-002-NP, Rev. 0, Washington, DC, U.S. Department of Energy, June 1994b.

U.S. Department of Energy, *Repository Design Requirements Document, Project Baseline Document*, YMP/CM-0023, Rev. 0, 1994c.

U.S. Department of Energy, *Engineered Barrier Design Requirements Document, Project Baseline Document*, YMP/CM-0024, Rev. 0, 1994d.

U.S. Department of Energy, *Seismic Design Methodology for a Geologic Repository at Yucca Mountain*, YMP/TR-003-NP, Rev. 0, Washington, DC: U.S. Department of Energy, October 1995.

U.S. Department of Energy, *Preclosure Seismic Design Methodology for a Geologic Repository at Yucca Mountain*, YMP/TR-003-NP, Rev. 01, Washington, DC: U.S. Department of Energy, October 1996.

U.S. Department of Energy, *Repository Safety Strategy: U.S. Department of Energy's Strategy to Protect Public Health and Safety After Closure of a Yucca Mountain Repository*, YMP/96-01, Rev. 01, Washington, DC, U.S. Department of Energy, January 1998a.

U.S. Department of Energy, *Probabilistic Seismic Hazard Analyses for Fault Displacement and Vibratory Ground Motion at Yucca Mountain, Nevada—Final Report*, Oakland, CA, U.S. Geological Survey, February 1998b.

U.S. Department of Energy, *Q-List*, YMP/90-55Q, Washington, DC: U.S. Department of Energy, 1998c.

U.S. Department of Energy, *Quality Assurance Requirements and Description*, DOE/RW-0333P, 1998d.

U.S. Department of Energy, *Repository Closure Policy*, Preliminary Draft Q, 1998e.

U.S. Nuclear Regulatory Commission, *Standard Review Plan for the Review of Safety Analyses for Nuclear Plants*, NUREG-0800, Washington, DC, U.S. Nuclear Regulatory Commission, 1987.

U.S. Nuclear Regulatory Commission, *Topical Report Review Plan*, Washington, DC, U.S. Nuclear Regulatory Commission, February 1994.

U.S. Nuclear Regulatory Commission, *In-Field Verification Activities*, Draft Manual Chapter 0330, Washington, DC, U.S. Nuclear Regulatory Commission, March 23, 1995a.

U.S. Nuclear Regulatory Commission, *Report of the In-Field Verification of the U.S. Department of Energy, Office of Civilian Radioactive Waste Management and its Management and Operating Contractor*, NRC-VR-95-01, Washington, DC, U.S. Nuclear Regulatory Commission, May 1995b.

U.S. Nuclear Regulatory Commission, *Disposal of High-Level Radioactive Waste in Geologic Repositories; Design Basis Events*, 61FR 64257, Washington, DC, U.S. Nuclear Regulatory Commission, December 4, 1996a.

U.S. Nuclear Regulatory Commission, *Branch Technical Position on the Use of Expert Elicitation in the High-Level Radioactive Waste Program*, NUREG-1563, Washington, D.C., U.S. Nuclear Regulatory Commission, 1996b.

Wilson, M.L., A Process Model for Seepage into Drifts at Yucca Mountain, *Presentation at DOE/U.S. NRC Technical Exchange on Total System Performance Assessment, Viability Assessment, March 17-19, Albuquerque, NM, Sandia National Laboratories*, 1998.

## APPENDIX

This appendix lists important correspondences and interactions between NRC and DOE related to the subissue of ESF design and design control process and briefly summarizes relevant details at the end of each item:

- (1) U.S. Nuclear Regulatory Commission letter from R.M. Bernero to S. Rousso of U.S. Department of Energy, (cover letter to NRC's SCA) dated July 31, 1989.  
  
[The letter and SCA raise two objections to DOE's continued deficiencies in its overall QAP and inadequacy of its ESF design and design control process.]
- (2) U.S. Nuclear Regulatory Commission letters from R.M. Bernero to J. Bartlett of U.S. Department of Energy, dated March 2, 1992, and November 2, 1992.  
  
[The letters lift NRC's objections 1 and 2 based in part, on DOE's demonstration that it had revised its process of controlling ESF design and implementation of such a process.]
- (3) U.S. Nuclear Regulatory Commission letters from J.J. Holonich to D. Shelor of U.S. Department of Energy, dated March 24, 1993, and May 5, 1993.  
  
[The letters express renewed concerns related to ESF design and design control process.]
- (4) U.S. Nuclear Regulatory Commission letter from B.J. Youngblood to D. Shelor of U.S. Department of Energy, dated August 20, 1993.  
  
[The letter requests specific information from DOE including an action plan for implementing an acceptable design control process before proceeding with further design activities.]
- (5) U.S. Department of Energy letter from D. Shelor to J.J. Holonich of U.S. Nuclear Regulatory Commission, dated November 1, 1993.  
  
[This letter provides details related to the technical and regulatory design requirements and document hierarchy.]
- (6) U.S. Department of Energy letter from D. Shelor to B.J. Youngblood of U.S. Nuclear Regulatory Commission, dated November 18, 1993.  
  
[This letter provides response to specific NRC requests made in (4) above.]
- (7) NRC-DOE interactions related to ESF design and design control process dated September 17, 1993, October 4-5, 1993, December 8, 1993, and January 5-7, 1994.  
  
[The discussions held during these interactions provide additional responses and clarifications to earlier staff requests.]

## APPENDIX (cont'd)

- (8) U.S. Nuclear Regulatory Commission letter from B.J. Youngblood to D. Shelor of U.S. Department of Energy, dated March 30, 1994.

[This letter expresses limited satisfaction at the progress made by DOE and recommends further follow-up, such as QA audits and surveillances for additional verification of DOE actions.]

- (9) U.S. Nuclear Regulatory Commission from R.M. Bernero to D. Dreyfus of U.S. Department of Energy, dated October 13, 1994.

[This letter notifies DOE of staff continued concerns with DOE and its M&O contractor QAP and transmits one major comment related to DOE and M&O QAP and three specific questions related to ESF design and its interface with GROA conceptual design.]

- (10) U.S. Department of Energy letter from D. Dreyfus to R.M. Bernero of U.S. Nuclear Regulatory Commission, dated October 17, 1994.

[This letter provides a quick initial response to staff letter of October 13, 1994, and proposes a set of actions and commitments.]

- (11) U.S. Department of Energy letter from D. Dreyfus to R.M. Bernero of U.S. Nuclear Regulatory Commission, dated November 14, 1994.

[This letter provides a detailed response to NRC's letter of October 13, 1994, and a series of actions and commitments. The staff uses this letter to develop a checklist of 51 items to be verified during an in-field verification.]

- (12) U.S. Department of Energy letter from R.A. Milner to J.J. Holonich of U.S. Nuclear Regulatory Commission, dated January 27, 1995.

[This letter provides a list of DOE's commitments in response to staff recommendations.]

- (13) U.S. Nuclear Regulatory Commission letter from J.J. Holonich to R.A. Milner of U.S. Department of Energy, dated March 9, 1995.

[This letter summarizes phase-1 staff review of DOE's detailed response of November 14, 1994, and concludes that the responses provided by DOE are acceptable and presents a schedule for phase-2 in-field verification.]

- (14) U.S. Department of Energy letter from D. Dreyfus to R.M. Bernero of U.S. Nuclear Regulatory Commission, dated March 14, 1995.

[This letter provides continued response to staff letter of October 13, 1994, and attaches the RCRR showing the allocation and traceability of Part 60 requirements to the ESF.]



## APPENDIX (cont'd)

- (15) U.S. Nuclear Regulatory Commission letter from J.J. Holonich to R.A. Milner of U.S. Department of Energy, dated March 16, 1995.
- [This letter summarizes staff observations of DOE's QA audit of M&O.]
- (16) U.S. Nuclear Regulatory Commission conducted in-field verification (phase-2) during April 3-6, 1995.
- [See NRC 1995b, for in-field verification procedures and NRC 1995c, for the summary of findings from 6.0 List of References.]
- (17) U.S. Department of Energy letter from R.A. Milner to J.J. Holonich of U.S. Nuclear Regulatory Commission, dated May 1, 1995.
- [This letter informs NRC of DOE's decision to lift a self-imposed "hold" on TBM progress beyond upper Paintbrush Tuff nonwelded (Ptn) contact.]
- (18) U.S. Nuclear Regulatory Commission letter from J.G. Greeves to R.A. Milner of U.S. Department of Energy, dated May 12, 1995.
- [This letter concludes that an "objection" level concern does not exist with respect to the "pneumatic pathway" issue and documents that establishing or lifting "hold points" for TBM progress was a matter left to DOE's discretion.]
- (19) U.S. Nuclear Regulatory Commission letter from J.J. Holonich to R.A. Milner of U.S. Department of Energy, dated June 16, 1995.
- [This letter transmits staff in-field verification report, along with a commendation, closing several open items from the 51 items of the checklist and making three specific recommendations and proposals for follow-up.]
- (20) U.S. Department of Energy letter from D. Dreyfus to C.J. Paperiello of U.S. Nuclear Regulatory Commission, dated August 3, 1995.
- [This letter provides the balance of responses to NRC's letter of October 13, 1994, and provides the supplement to RCRR.]
- (21) U.S. Department of Energy letter from S.J. Brocoum to J.J. Holonich of U.S. Nuclear Regulatory Commission, dated October 25, 1995.
- [This letter acknowledges the "cumbersome" nature of demonstrating regulatory flow-down and reports on two specific design process improvements: change to QA Procedure QAP-3-9 and modification to the structure and content of the Design Requirements Document.]

**APPENDIX (cont'd)**

- (22) U.S. Nuclear Regulatory Commission letter from M.J. Bell to S.J. Brocoum of U.S. Department of Energy, dated December 14, 1995.

[This letter transmits the staff review of DOE's RCRR and concludes that DOE made an acceptable demonstration of regulatory flowdown via the example of design package 2C and considered most of the applicable RRs from Part 60. In addition, the staff requests two specific items: a design example conducted under the new and improved design QA/design procedure and current versions of revised ESFDR Document along with DOE's latest description of "Document Hierarchy."]

- (23) U.S. Department of Energy letter from S.J. Brocoum to M.J. Bell of U.S. Nuclear Regulatory Commission, dated September 1996.

[This letter responds to staff requests made in December 14, 1995, letter and provides clarifications sought by the staff.]

- (24) U.S. Nuclear Regulatory Commission conducts an appendix 7 meeting on June 12-13, 1997, at DOE/M&O Offices and at the YM site to gather data, conduct onsite reviews, and complete activities intended to be covered under phase-3 of the in-field verification, which had to be canceled because of personnel and budgetary reasons.

[The staff concludes that most of the checklist items that were not verified during phase-2 of the in-field verification conducted on April 3-6, 1995, could be closed out based on interviews with DOE/M&O staff and onsite reviews. The staff also concludes to keep two items open: (i) quality classification for the concrete inverts used for the ESF construction; and (ii) hierarchy of documents that control site characterization, design, construction, and operations activities at the YM site.]