## JOB PERFORMANCE MEASURE APPROVAL SHEET

I JPM Title: Energize Bus 24C From the RSST (Alternate Path)

ID Number: JPM-01S

Revision: 0

II. Initiated:

R. J. Ashey Autorand Colleg Developer

6/16/03 Date

III. Reviewed:

R. Cimmino Abert Cumming Technical Reviewer

8

IV. Approved:

User Department Supervisor

Date

Nuclear Training Supervisor

Date

,-acility:MF	<u>-2</u> Ex	aminee:		
JPM Number:	JPM-01S		Rev	0
Task Title: En	ergize Bus 24C From the	RSST (Alternate Pa	ath)	
System:				
Time Critical Task:	Yes No <b>X</b>			
Validated Time (mi	nutes): <u> </u>			
Task No.(s): <u>NU</u>	FIMS #062-025-01-01		<del></del>	
Applicable To:	SRO X RO	X PEO		
K/A No0	62-A4.01 K/A Ratin	g <u>3.3/3.1</u>		
Method of Testing:				
Simulated Perform	ance: Ac	tual Performance:	<u> </u>	_
` <u>.ocation:</u>				
Classroom:	Simulato	r: <u>X</u>	In-Plant:	
Task Standards:	At the completion o 24C from Unit 3 pe	f this JPM, the exar r Appendix 23 of EC	ninee has )P 2541.	energized Bus
Required Materials (procedures, equipment):	EOP 2541, Append	ix 23		
General Reference	<u>s:</u> EOP 2541, Append	ix 23		

## \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JPM Number:	JPM-01S	Rev	0
Initiating Cues:	<ul> <li>You are the SPO.</li> <li>The Unit Supervisor has</li> </ul>	directed you to energ	ize Bus 24C from the RSST.
Initial Conditions:	<ul> <li>The plant was trippe</li> <li>EOP 2525, Standard crew has transitioned</li> <li>Bus 24C is de-energ RSST.</li> <li>"A" DG is out for PM</li> <li>There are NO faults</li> <li>There are NO faults</li> </ul>	d due to a LOCA. I Post Trip Actions hav d to EOP 2532, Loss o ized due to a failure to 's. indicated on bus 24C indicated on the RSST	re been completed and the of Coolant. automatically transfer to the
<u>Simulator Requirements</u> :	Initialize at any 100 Enter the following: - "A" DG OOS w racked out (EG - Reset "A" DG t - Place yellow ta	% power IC. / air starts closed (EG iR17). rouble alarm (EGR16) g on "A" DG breaker s	R12) and output breaker witch (A312) on C-08.
	Insert a large break Open breaker A302 Perform the actions Insert an I/O to prev ED, select ON for O Ensure Auto Aux Fe Place the simulator	LOCA (RC02A at 30% (RSST to Bus 24C) of EOP 2525, Standa vent breaker A302 fror S-2/22S3-24C2 TRP eed Override switches in FREEZE.	%) Ird Post Trip Actions n closing (Under the I/O for ). are in Pull-To-Lock.
	When examinee is	ready, place the simul	ator in RUN.

# \*\*\*\* NOTES TO EXAMINER \*\*\*\*

1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, **ALL** critical steps must be completed correctly.

2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".

- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 1. This JPM will be done in parallel with JPM-02S, Placing the Hydrogen Recombiner in Service.

$\smile$	JPM ID NUMBER: JPM-01S		TITLE: Energize Bus 24C From the RSST (Alternate Path)	
ST	ART TIME:			
	STEP <u>1</u>	Performance Steps:	Check the Unit 2 RSST energized.	
	GRADE	Standards: Ex	aminee determines the RSST is energized by observing the Itmeter on C-08 for the RSST reading approximately 4160V.	
		Cue: N	one	
	Comments:	If examinee does NOT sta	te this, question what they are observing.	
		~~~~~~~	~~~~~	
	STEP <u>2</u>	Performance Steps:	Check that NO fault indications are present for 4.16kv bus 24C.	
$\smile$	GRADE	Standards: Ex tha are	aminee checks lit annunciators on C-08 and determines at none of the RSST lockout or audio tone operation alarms e in alarm.	
		Cue: N	one	
	Comments:			
		~~~~~~~~~	~~~~~~	
	STEP <u>3</u>	Performance Steps:	<ul> <li>ENSURE all of the following breakers are open (C-08):</li> <li>A304, 24A/24C TIE BKR, 24C-1T-2</li> <li>A305, 24C/24E TIE BKR, 24C-2T-2</li> <li>A312, DG A FDR BKR, 15G-12U-2</li> </ul>	
	GRADE	Standards: Exactly ac	xaminee observes that the breakers are open OR takes tion to open them.	
		Cue: N	one	
	Comments:	Examinee may choose to t This is acceptable.	ake A304's hand switch to "TRIP" to clear the amber light.	
		~~~~~~~~~~	~~~~~	

$\smile$	JPM ID N	IUMB	ER: <u>JPM-01S</u>		TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>4</u>		Performance Ste	ps:	ENSURE A702 "RSS FDR BKR 24C/24D, 22S3-2-2 " is closed (C-08).
	GRADE		Standards:	Exam C-07.	inee verifies A702 is closed by its red light only lit on
			Cue:	Non	9
	Comments:				
			~~~~~~	~~~~~	~~~~~
	STEP <u>5</u>	<u>_X</u>	Performance Ste	ps:	Place "SYN SW, 22S3-24C-2 (A302)" to "ON" and check "Incoming" voltage indicated (C-08).
	GRADE	<u>_X</u>	Standards:	Exam synch and o voltme	inee observes note above step and places roscope switch in slot for 22S3-24C-2, turns it to "ON" bserves voltage reading of ~ 120 on the INCOMING eter.
$\bigcirc$					
			Cue:	None	e
	Comments:				
			~~~~~~	.~~~~	~~~~~~
	STEP <u>6</u>	<u>X</u>	Performance Ste	ps:	Place ALL four "UV BUS A3" ESAS channel bypass keyswitches to the "INHIBIT" position (Key26) (ESF Sensor Cabinets).
	GRADE	<u> </u>	Standards:	Exam A3" ke "INHII	inee places each of the 4 bypass keys into the "UV Bus eyholes for each channel of ESAS, and turns each to BIT."
			Cue:	Non	e
	Comments:				
			~~~~~~~	~~~~~	~~~~~~~~~~~~

$\smile$	JPM ID N	NUMBER: JPM-01S	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>7</u>	<u>X</u> Performance Steps:	PRESS facility 1 "UV RESET" button (ESAS Actuation Cabinet 5).
	GRADE	<u>X</u> Standards: Exa 5.	aminee pushes the "UV" button on ESAS Actuation Cabinet
		Cue: No	one
	Comments:	The examinee may use the TRIP), as verification that u	e resetting of annunciator C-33 on C-01 (ESAS UV CH 1 Indervoltage has reset.
	STEP <u>8</u>	Performance Steps:	<ul> <li>Place BOTH of the following control switches in "Pull to lock"</li> <li>Service Water Pump A</li> <li>RBCCW Pump A</li> </ul>
	GRADE	Standards: Exa	aminee places the control switches in Pull-to-Lock
$\smile$		Cue: No	one
	Comments:	~~~~~~~~~~~	~~~~~~
			Diago DOTU CO Auto Aury Food Overside Switches in
	SIEP <u>9</u>	Performance Steps:	"Pull To Lock"
	GRADE	Standards: Exa to le	aminee places both auto aux feed override switches in pull ock.
		Cue: No	one
	Comments:		

_	JPM ID N	NUMBER: JPM-01S	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>10</u>	Performance Steps:	Override all of the following control switches to prevent an inadvertent automatic start: • HPSI Pump A • LPSI Pump A • Containment Spray Pump A
	GRADE	Standards: Exan posit	ninee places the three pump hand switches to the START ion then to the OFF position.
		Cue: Nor	ne
	Comments:	~~~~~~~~~	~~~~~
	STEP <u>11</u>	X Performance Steps:	Close A302 "RSS SPLY BKR, 22S3-24C-2."
	GRADE	<u>X</u> Standards: Exam the C ■ E p 2	ninee attempts to close A302 by taking its hand switch to CLOSE position and observes the amber 'Trip' light lit. Examinee reports the failure to the US. Examinee recommends energizing bus 24E from Unit 3 er Attachment 23N, then energizing bus 24C from bus 4E per Attachment 23D.
		Cue: •	Ask the examinee for a recommendation for energizing bus 24C. <u>If asked</u> , report to the examinee as Unit 3 that bus 34A is available to power bus 24E. <i>J その Maric Pinnesscon</i>
	Comments:	The examinee may take a fe making a recommendation to	w minutes to determine the status of Unit 3 power before the US.

$\smile$	JPM ID NUMBER: <u>JPM-01S</u>		TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>12</u>	Performance Ste	eps: Check that NO fault indications are present for 4.16kV Bus 24E.
	GRADE	Standards:	<ul> <li>Examinee observes the following:</li> <li>DIESEL GEN 12U BKR TRIP annunciator NOT lit</li> <li>DIESEL GEN 12U BKR CLOSING CKT BLOCKED annunciator NOT lit.</li> <li>4KV BUS 24A/C TIE BKR A304 TRIP annunciator NOT lit.</li> <li>4KV BUS 24C/E TIE BKR A305 TRIP annunciator NOT lit.</li> </ul>
		Cue:	None
	Comments:		
		~~~~~~	
	STEP <u>13</u>	Performance Ste	eps: Ensure 4.16kV bus 24E "SPLY VOLTS" voltage is indicated.
	GRADE	Standards:	Examinee observes approximately 4160 Volts on "SPLY VOLTS" meter on C-08.
		Cue:	None
	Comments:		
		~~~~~~~	~~~~~~~~~~~~
	STEP <u>14</u>	Performance Ste	<ul> <li>Ensure all the following load breakers on 4.16kV bus 24E are open:</li> <li>A502, "SERVICE WTR PUMP B"</li> <li>A503, "HPSI PUMP B"</li> <li>A504, RBCCW PUMP B"</li> </ul>
	GRADE	Standards:	<ul> <li>Examinee ensures the following breakers are open:</li> <li>A502, "SERVICE WTR PUMP B"</li> <li>A503, "HPSI PUMP B"</li> <li>A504, RBCCW PUMP B"</li> </ul>
		Cue:	None
	Comments:		

$\smile$	JPM ID NUM	BER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>15</u> X	Performance Steps:	Ensure all the following breakers are open: • A305, "24C/24E TIE BKR, 24C-2T-2" • A408, "24D/24E TIE BKR, 24D-2T-2"
	GRADE <u>X</u>	Standards: Ex br Ex ob	xaminee ensures A408, "24D/24E TIE BKR, 24D-2T-2" reaker is open. xaminee opens A305, "24C/24E TIE BKR, 24C-2T-2" and oserves green light lit.
		Cue: N	lone
	Comments:	~~~~~~~	~~~~~
	STEP <u>16</u>	_ Performance Steps:	Request permission from Unit 3 SM or US to energize Unit 2 4.16kV Bus 24E.
$\smile$	GRADE	_ Standards: Ex cr	caminee contacts Unit 3 control room and asks permission to oss tie bus 24E to Unit 3.
		Cue: I	nform the examinee that cross tying bus 24E to Unit 3 s allowed.
	Comments:		
	STEP <u>17</u> <u>X</u>	Performance Steps:	Place "SYNC SEL SW, 34B-24E-2 (A505)" to ON and check "INCOMING voltage indicated.
	GRADE <u>X</u>	_ Standards: Ex O ap	xaminee places "SYNC SEL SW, 34B-24E-2 (A505)" to the N position and observes "INCOMING" voltage at oproximately 120 volts.
		Cue: N	lone
	Comments:	~~~~~~~~~~~	~~~~~

$\smile$	JPM ID NUMBI	ER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>18</u> X	Performance Step	os: Close A505, "24E/34B TIE BKR, 34B-24E-2.
	GRADE <u>X</u>	Standards:	Examinee places A505, "24E/34B TIE BKR, 34B-24E", switch in the CLOSE position and observes the red light is lit.
		Cue:	None
	Comments:		
		~~~~~~	~~~~~~
	STEP <u>19</u>	Performance Step	os: Check voltage indicated on "RUNNING" voltmeter.
	GRADE	Standards:	Examinee observes "RUNNING" voltmeter reads approximately 120 volts.
		Cue:	None
$\smile$	Comments:		
		~~~~~~~	~~~~~~
	STEP <u>20</u>	Performance Step	os: Place "SYNC SEL SW, 34B-24E-2 (A505)" to OFF.
	GRADE	Standards:	Examinee places "SYNC SEL SW, 34B-24E-2 (A505)" to the OFF position.
		Cue:	None
	Comments:		
		~~~~~~~	~~~~~

	JPM ID NUM	IBER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>21</u>	_ Performance Ste	os: Refer to Attachment 23-U and ensure the 3 MVA is NOT exceeded as loads are restored to service
	GRADE	Standards:	Examinee observes the current flow to bus 24E and determines that the limit is approximately 420 amps.
	,	Cue:	No other loads will be started until bus 24C energized. Continue actions to restore bus 24C.
	Comments: Ex	aminee must transfe	r to Attachment 23D
	STEP <u>22</u>	_ Performance Step	os: Check that fault indications are NOT present for 4.16kv bus 24C.
	GRADE	_ Standards:	<ul> <li>Examinee observes the following:</li> <li>DIESEL GEN 12U BKR TRIP annunciator NOT lit</li> <li>DIESEL GEN 12U BKR CLOSING CKT BLOCKED annunciator NOT lit.</li> <li>4KV BUS 24A/C TIE BKR A304 TRIP annunciator NOT lit.</li> <li>4KV BUS 24C/E TIE BKR A305 TRIP annunciator NOT lit.</li> </ul>
		Cue:	None
	Comments: Th	nis step was performe	ed during the initial assessment of Bus 24C.
	STEP <u>23</u>	Performance Step	DS: Check 4.15 kV bus 24E energized from Unit 3 is 4.16 kV bus 34A/34B.
	GRADE	_ Standards:	Examinee observes approximately 4160 Volts on 24E BUS VOTLS on C-08.
		Cue:	None
×	Comments:	~~~~~~~~	~~~~~

,	JPM ID NUMB	ER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>24</u>	Performance Ste	<ul> <li>Ensure the following breakers are open:</li> <li>A312, "DG A FDR BKR, 15G-12U-2"</li> <li>A302, "RSS SPLY BKR, 22S3-24C-2"</li> <li>A304, "24A/24C TIE BKR, 24C-1T-2"</li> <li>A408, "24D/24E TIE BKR, 24D-2T-2"</li> </ul>
	GRADE	Standards:	<ul> <li>Examinee ensures the following breakers are open:</li> <li>A312, "DG A FDR BKR, 15G-12U-2"</li> <li>A302, "RSS SPLY BKR, 22S3-24C-2"</li> <li>A304, "24A/24C TIE BKR, 24C-1T-2"</li> <li>A408, "24D/24E TIE BKR, 24D-2T-2"</li> </ul>
		Cue:	None
	Comments:	~~~~~~~~	~~~~~
	STEP <u>25</u>	Performance Ste	bs: Ensure A305, "24C/24E TIE BKR, 24C-2T-2", is open and racked up.
$\smile$	GRADE	Standards:	Examinee observes a green light on A305, "24C/24E TIE BKR, 24C-2T-2".
		Cue:	None
	Comments:	~~~~~~~	~~~~~
	STEP <u>26</u>	Performance Ste	ps: Notify Unit 3 that bus 24C is going to be energized via Unit 3 4.16 kV bus 34A/34B.
	GRADE	Standards:	Examinee contacts Unit 3 control room and states that bus 24C is going to be energized via Unit 3 4.16 kV bus 34A/34B.
		Cue:	Acknowledge the statement.
	Comments:	~~~~~~	~~~~~

$\smile$	JPM ID N	NUMBER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>27</u>	<u>X</u> Performance Step	s: Place ALL four "UV BUS A3" ESAS channel bypass keyswitches to the "INHIBIT" position (Key26) (ESF Sensor Cabinets).
	GRADE	<u>X</u> Standards:	Examinee places each of the 4 bypass keys into the "UV Bus A3" keyholes for each channel of ESAS, and turns each to "INHIBIT."
		Cue:	None
	Comments:	This action was accomp	lished earlier and will only require a verification.
		~~~~~~~~	~~~~~~~~~~~~~~~~~
	STEP <u>28</u>	X Performance Step	s: PRESS facility 1 "UV RESET" button (ESAS Actuation Cabinet 5).
	GRADE	<u>X</u> Standards:	Examinee pushes the "UV" button on ESAS Actuation Cabinet 5.
		Cue:	None
	Comments:	This action was accompl The examinee may use TRIP), as verification tha	lished earlier and will only require a verification. the absence of annunciator C-33 on C-01 (ESAS UV CH 1 at undervoltage has reset.
		~~~~~~~	~~~~~~
	STEP <u>29</u>	Performance Step	s: Check sequencer "0" light for DG A is NOT lit and sequencer 1, 2, 3, and 4 lights are lit.
	GRADE	Standards:	Examinee observes the sequence "0" light is NOT lit and the sequence 1, 2, 3, and 4 lights are lit on Actuation Cabinet 5.
		Cue:	None
	Comments:		
$\smile$		~~~~~~~	~~~~~~

	JPM ID NUMBER: JPM-01S	TITLE: Energize Bus 24C From the RSST (Alternate Path)					
	STEP <u>30</u> Performance Steps:	<ul> <li>Place BOTH of the following control switches in "Pull to lock"</li> <li>Service Water Pump A</li> <li>RBCCW Pump A</li> </ul>					
	GRADE Standards: Exa	ninee places the control switches in Pull-to-Lock					
	Cue: None						
	Comments: This action was accomplishe	ed earlier and will only require a verification.					
	STEP <u>31</u> Performance Steps:	Place BOTH SG Auto Aux Feed Override Switches in "Pull To Lock"					
$\smile$	GRADE Standards: Exam to lo	ninee places both auto aux feed override switches in pull ck.					
	Cue: No Comments: This action was accomplishe	ne ed earlier and will only require a verification.					
	STEP <u>32</u> Performance Steps:	Ensure AFW Pump A switch in Normal-After-Trip position.					
	GRADE Standards: Exar "Nor	ninee observes or places the AFW Pump A switch in mal-After-Trip" position.					
	Cue: No	ne					
	Comments:	~~~~~					

$\smile$	JPM ID NUMBER: <u>JPM-01S</u>	TITLE: Energize Bus 24C From the RSST (Alternate Path)
	STEP <u>33</u> Performance Steps	<ul> <li>Override all of the following control switches to prevent an inadvertent automatic start:</li> <li>HPSI Pump A</li> <li>LPSI Pump A</li> <li>Containment Spray Pump A</li> </ul>
	GRADE Standards: E	xaminee places the three pump hand switches to the START osition then to the OFF position.
	Cue:	None
	Comments: This action was accomplia	shed earlier and will only require a verification.
	STEP <u>34</u> X Performance Steps	Close A305, "24C/24E TIE BKR, 24C-2T-2, and observe bus 24C voltmeter indication increase.
$\bigcirc$	GRADE <u>X</u> Standards: <i>T</i> a 4	he examinee closes A305, "24C/24E TIE BKR, 24C-2T-2, nd observe bus 24C voltmeter indication at approximately 160 Volts.
	Cue:	None
	Comments: The JPM is complete whe	en bus 24C is energized from Unit 3.
	After this step is compl	eted, the JPM is considered complete.

STOP TIME: \_\_\_\_

## VERIFICATION OF JPM COMPLETION

~

Areas for Improvement:

Job Performance Measure No.	<u>JPM-01S</u>	Rev.	<u>0</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achiev If task is Time Critical, it <u>ML</u>	re a satisfactory grade, <u>ALL</u> critic J <u>ST</u> be completed within the spec	al steps n cified time	nust be completed correctly. to achieve a satisfactory grade.
Time Critical Task? Yes	NoX		
Validated Time (minutes):	30		
Actual Time to Complete (minut	es):		
Result of JPM: (Den	ote by an <u>S</u> for satisfactory or a <u>l</u>	<u>U</u> for unsa	atisfactory)

# JOB PERFORMANCE MEASURE APPROVAL SHEET

JPM Title: Containment Hydrogen Control – Alternate Path ١. Revision: 0 ID Number: JPM-02S Initiated: 11. Granni Ð 3 R. Cimmino, Jr. Developer Date III. Reviewed: Technical Reviewer IV. Approved: User Department Supervisor Date

Juail Hon

Nuclear Training Supervisor

8/6/03 Date

Facility: MP-2	Examinee:	
JPM Number:J	PM-02S	Rev. 0
Task Title: Containme	ent Hydrogen Control – Alternate Pa	<u>th</u>
System: Containment P	ost-Incident Hydrogen Control	
Time Critical Task: Yes	NoX	
Validated Time (minutes):	20	
Task No.(s): <u>NUTIMS# (</u>	028-01-025	
Applicable To: SRO	X RO X PEO	
K/A No.: 028-000-A4	.01 K/A Rating: 4.0/4.0	
Method of Testing:		
Simulated Performance:	Actual Performance:	X
Location:		
Classroom:	Simulator: X	In-Plant:
Task Standards:	At the completion of this JPM, the expurge of CTMT using the Hydrogen F	aminee will have established a <sup>ว</sup> urge System.
<u>Required Materials</u> (procedures, equipment):	<ul><li>As requested, EOP-2541, Append</li><li>EOP-2532</li></ul>	dix 20 and 21
General References:	EOP-2532, EOP-2541 (Appendix 20	and 21)

## \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JPM Number:	JP	M-02S	Rev.	0
Initiating Cues:	•	The Unit Supervisor has directed reduce containment hydrogen co	you, as the ncentratior	e Spare SRO, to per EOP-2532.
Initial Conditions:	• • •	A LOCA has occurred and EOP-2 Containment temperature has bee Average containment pressure has Containment H <sub>2</sub> concentration is 3 The pre-incident containment tem "A" Hydrogen Recombiner is "Out	2532 is bein en reduced as reduced 3.2%. aperature w c Of Service	ng utilized. I to 230°F. to 6 psig. vas 115°F. e".
<u>Simulator Requirements</u>	:	Initialize to any IC that is <b>post LB</b> I/O Override the following controls • "A" H <sub>2</sub> Recombiner Control • "B" H <sub>2</sub> Recombiner Control • "B" H <sub>2</sub> Recombiner Control • CTMT Temperature Indica I/O Override the following controls • "A" CTMT Pressure Indica • "B" CTMT Pressure Indica • "C" CTMT Pressure Indica • "D" CTMT Pressure Indica	<b>-LOCA</b> . Is and indic I Switch <u>H</u> I Light <u>HS</u> I Switch <u>H</u> Sand indic tion <u>PI-81</u> tion <u>PI-81</u> tion <u>PI-81</u>	ations under " <u>CH</u> " <u>S8387</u> to OFF <u>3387 G</u> to OFF <u>S8389</u> to OFF <u>96</u> to <b>230°F</b> ations under " <u>RP</u> " <u>13</u> to <b>6.2 psig</b> <u>14</u> to <b>5.9 psig</b> <u>15</u> to <b>6.0 psig</b> <u>16</u> to <b>5.9 psig</b>

Ensure CTMT Temperature Selecter Switch is set for point **#6** Place a YELLOW Tag on "A" H<sub>2</sub> Recombiner Control Switch

#### \* \* \* \* <u>NOTES TO EXAMINER</u> \* \* \* \*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

JPM ID NUMI	BER: <u>JPM-02S</u> TITLE: Containment Hydrogen Control – Alternate Path
START TIME:	
STEP 1	Performance Steps: To place the "B" hydrogen recombiner in service, go to Appendix 20, Attachment 20-C, "Hydrogen Recombiner 'B' Operation"
GRADE	Standards: <i>Examinee refers</i> Appendix 20, Attachment 20-C.
	Cue: <ul> <li>Provide Examinee with EOP-2532</li> <li>As requested, provide examinee with Appendix 20.</li> </ul>
Comments:	
STEP 2	Performance Steps: Ensure JC-8724, wattmeter potentiometer, is set at "000".
GRADE	Standards: Examinee observes that the "B" Hydrogen Recombiner potentiometer, JC-8724, on C-01 is set at zero.
	Cue:
Comments:	
STEP 3	X_Performance Steps: Place H-29B, hydrogen recombiner heater switch, to "ON".
GRADE	X Standards: Examinee locates and places the Hydrogen Recombiner Heater handswitch on C-01 to "ON" and observes that the Recombiner does NOT energize as expected and reports this to the US.
	Cue: The examinee may suggest to the US that the Recombiner breaker be investigated before proceeding, or may be confused as to how to proceed as the applicable procedure gives no direct guidance. In either of these instances, the Examiner should solicit from the examinee a recommendation on how to reduce containment hydrogen concentration.

JPM ID NUMBER: JPM-02S TITLE: Containment Hydrogen Control – Alternate Path

Comments:

JPM ID NUMI	BER: <u>JPM-02S</u> TI	TLE: Containment Hydrogen Control – Alternate Path
STEP 4	X Performance Steps	Examinee determines the alternate method of CTMT hydrogen control is via EOP-2532, step 56; "Operate Hydrogen Purge System".
GRADE	<u>X</u> Standards: E: pe St	caminee Refers to EOP-2532 and states the need to erform step 56, Appendix 21, requesting Technical upport Center (TSC) for concurrence.
	Cue: As the US ar CTMT via Ap	nd/or TSC, give concurrence to purge hydrogen from opendix 21, "Hydrogen Purge System Operation".
Comments:	Provide examinee with	Appendix 21 when requested.
	~~~~~~~~	~~~~~
STEP 5	_ Performance Steps	: Ensure EBFS is in operation on EBFS region.
GRADE	_ Standards: Ex	aminee verifies EBFS is operating per accident onditions.
	Cue:	
Comments:	~~~~~~~~~~	~~~~~~
STEP 6	Performance Steps	: Instruct US to have PEO open and RED tag both B5208 and B6216.
GRADE	Standards: Ex Be	caminee states the need to red tag open B5208 and 5216.
	Cue: Inform Exam open.	inee that the US has had both breakers red tagged
Comments:		

JPM ID NUM	BER: <u>JPM-02S</u> TITLE: Containment Hydrogen Control – Alternate Path
STEP 7	Performance Steps: Stop radiation monitor sample fans, F-39A and F-39B
GRADE	_ Standards: <i>Examinee goes to RC-14 and ensures fans</i> F-39A and F-39B are secured.
Comments:	
STEP 8	X_Performance Steps: Examinee notes from Initial Conditions that CTMT pressure is greater than 6 inches WG and requests TSC concurrence to close EITHER EB-194 (Facility 1) OR EB-193 (Facility 2).
GRADE	X Standards: Examinee proceeds to step 4 and requests permission of TSC to close ONE Hydrogen Purge 6 inch valve.
	Cue: Instruct examinee (as TSC) to utilize Facility 2 , and inform examinee that 2-EB-193 is closed.
Comments:	
STEP 9	X_Performance Steps: Examinee opens EB-91, "H2 PURGE INBD ISOL" and EB-92, "H2 PURGE OUTBD ISOL".
GRADE	X Standards: Examinee opens EB-91, "H2 PURGE INBD ISOL" and EB-92, "H2 PURGE OUTBD ISOL".
	Cue: Examinee may requests permission from TSC to perform step 5. If so, inform examinee that permission has been granted to utilize Facility 2 of Hydrogen Purge System to perform a Hydrogen purge of CTMT per Appendix 21.
Comments:	

JPM ID NUM	IBER: JPM-028	<u>S</u> TITLE:	Containment Hydrogen Control – Alternate Path
STEP <b>10</b>	<u>X</u> Performan	ce Steps: Exa to ( Sta	aminee notes the need to establish a purge supply CTMT and questions the US as to which method, ition Air or Instrument Air, should be used.
GRADE	X Standards	s: Examin method	ee requests guidance from US as to desired of CTMT purge supply
	Cue: Infor	m examinee t	he JPM is complete.
Comments:	After this step	is completed	, the JPM is considered complete.

STOP TIME:

## VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-02S	Rev.	<u>0</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achieve a satisfactory Time Critical, it <u>MUST</u> be completed w	/ grade, <u>ALL</u> critical steps must rithin the specified time to achie	be complete ve a satisfact	d correctly. If task is ory grade.
Time Critical Task? Yes	No <u>X</u>		
Validated Time (minutes):	20		
Actual Time to Complete (minutes	5):		
Result of JPM: (Denote	e by an <u>S</u> for satisfactory or a	a <u>U</u> for unsa	tisfactory)
Areas for Improvement:			

#### **EXAMINEE HANDOUT**

JPM ID Number: 02S

#### Initiating Cues:

• The Unit Supervisor has directed you, as the Spare SRO, to reduce containment hydrogen concentration per EOP-2532.

#### Initial Conditions:

- A LOCA has occurred and EOP-2532 is being utilized.
- Containment temperature has been reduced to 230°F.
- Average containment pressure has reduced to 6 psig.
- Containment H<sub>2</sub> concentration is 3.2%.
- The pre-incident containment temperature was 115°F.
- "A" Hydrogen Recombiner is "Out Of Service".

$\smile$		JOB PERFORMANCE MEASUR	RE APPROVAL SHEET
I	JPM Title:	Manual Operation of 2-SW-3.2A	
	ID Number:	JPM-124	Revision: <u>1, Ch. 1</u>
H.	Initiated:	M. Cote	<u>10/1/98</u>
111.	Reviewed:		
$\smile$		R. N. Spurr Technical Reviewer	10/6/98 Date
IV.	Approved:	J. M. Bergin User Department Supervisor	<u>10/17/98</u> Date
		<u>G. Bender</u> Nuclear Training Supervisor	<u>10/22/98</u>
		Hadiog. Haining ouportioor	24.0

. . .

Facility: MP-2	Examinee:		····		
JPM Number:	JPM-124	Rev.	1		
Task Title: Manual C	peration of 2-SW-3.2A				
System: Service Wate	۲ <u> </u>				
Time Critical Task: Yes	No				
Validated Time (minutes):	15				
Task No.(s): <u>NUTIMS #</u>	076-01-059 (076-025-01-04)				
Applicable To: SR	O X RO X PEO X	<u> </u>			
K/A No. 000-062-G	en. 6 K/A Rating <u>3.4/3.6</u>				
Method of Testing:         Simulated Performance:       X         Actual Performance:					
' <u>-ocation:</u>					
Classroom:	Simulator:	In-Pla	ant: <u>X</u>		
Task Standards:	At the completion of this JPM, examine SW-3.2A in manual and closing valve.	e has :	simulated placing	2-	
<u>Required Materials</u> (procedures, equipment):	OP 2326A				
General References:	OP 2326A, Section 4.26				

## \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

Initiating Cues:	<ul> <li>The Unit Supervisor has directed you, as the Turbine Building PEO, to place valve 2-SW-3.2A in manual and then close the valve.</li> </ul>
	- The examiner will act as the US as needed.
Initial Conditions:	- The plant has tripped due to a LOCA.
	- A SIAS actuation has occurred.
	<ul> <li>The "B" service water header supply to TBCCW heat exchangers, 2-SW-3.2A failed to close from the Control Room.</li> </ul>

Simulator Requirements: N/A

## \*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM.

JPM ID NUMBER:	JPM-124	TITLE: Manual Operation of 2-SW-3.2A
START TIME:	499-499-499-499-499-499-499-49-49-49-49-	
STEP <u>1</u>	X Performance Ste	ps: Close instrument air isolation valve to the air operator for 2-SW-3.2A.
GRADE	<u>X</u> Standards:	Examinee locates the I.A. isolation valve to 2-SW-3.2A and states they would close it (clockwise direction).
	Cue:	I.A. isolation to 2-SW-3.2A is closed.
Comments:	This is the black-handl	ed Whitey valve located in front of the operating cylinder.
STEP <u>2</u>	<u>X</u> Performance Ste	ps: Open the operating cylinder equalizing valve for 2-SW-3.2A.
GRADE	<u>X</u> Standards:	Examinee locates the equalizing valve for 2-SW-3.2A's operating cylinder and states they would open it (counterclockwise direction).
	Cue:	2-SW-3.2A equalizing valve is open.
Comments:	This is the yellow-hand	led valve located behind the operating cylinder.
	~~~~~~~	~~~~~
STEP <u>3</u>	X Performance Ste	os: Open the air operator flask drain valve for 2-SW-3.2A.
GRADE	<u>X</u> Standards:	Examinee locates the drain valve for 2-SW-3.2A's air operator flask and states they would open it (counterclockwise direction).
,	Cue:	The air operator flask drain valve is open; air is coming out; air noise has stopped.
Comments:	This valve is located at	the bottom of the air operator flask.

-

JPM ID NUMBER:	<u>JPM-124</u>	TITLE: Manual Operation of 2-SW-3.2A
STEP 4	X Performance Steps:	When the flask is depressurized, engage the handwheel for 2-SW-3.2A.
GRADE	<u>X</u> Standards: Exa turn not	aminee states they would engage the handwheel by ning it until the manual operator "key" is aligned with the ich in the collar and then pushing the "key" into the notch.
	Cue: T	ne key and notch are aligned; the key is in the notch.
Comments:		
	~~~~~~~~~	~~~~~~
STEP <u>5</u>	<u>X</u> Performance Steps:	Operate the handwheel and position the valve as directed by the Control Room.
GRADE	<u>X</u> Standards: Exa har rev	aminee states they would close the valve by turning ndwheel in the counterclockwise direction (valve is erse operating).
	Cue: Th	ne valve is going closed; the valve is closed.
Comments:	Both the collar and the ope After this step is complet	erator have position indication on them. and, the JPM is considered complete.
STOP TIME:		

## VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-124	Rev.	<u>1</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achiev If task is Time Critical, it <b>MU</b>	re a satisfactory grade, <u>ALL</u> critic JST be completed within the spe	al steps m	nust be completed correctly. to achieve a satisfactory grade.
· · · · · · · · · · · · · · · · · · ·			
Time Critical Task? Yes	NoX		
Validated Time (minutes):	15		
Actual Time to Complete (minut	es):		
Result of JPM: (Den	ote by an <u>S</u> for satisfactory or a <u>l</u>	<u>J</u> for unsa	tisfactory)
Areas for Improvement:			

## JOB PERFORMANCE MEASURE APPROVAL SHEET

Shift from "A" to "B" Waste Gas Decay Tank ١. JPM Title: ID Number: JPM-225 Revision: 0 11. Initiated: Rechard, alley R. J. Ashey 11/17/02 Developer Date III. Reviewed: R. N. Spurr 12/2/02 Technical Reviewer Date IV. Approved: N/A N/A User Department Supervisor Date M. Wilson 12/4/02

Nuclear Training Supervisor

Date

Facility: MP-2	Examinee:		
JPM Number: J	PM-225	Rev	0
Task Title: Shift From	n "A" to "B" Waste Gas Decay	(Tank	
System: Radioactivity R	elease		
Time Critical Task: Yes	No <u>X</u>		
Validated Time (minutes):	10		
Task No.(s): <u>NUTIMS #</u>	071-01-035		
Applicable To: SRC	X RO X PEC	D C	
K/A No.:071 A4.0	5 K/A Rating: 2.6*/2.6	6*	
Method of Testing:			
Simulated Performance:	X Actual Perform	ance:	_
Location:			
Classroom:	Simulator:	_ In-Plan	t: <u> </u>
<u>Task Standards:</u>	At the completion of this JPM to Waste Gas Decay Tank in serv Tank in service.	he examinee h vice to the "B" V	as shifted from the "A" Vaster Gas Decay
<u>Required Materials</u> (procedures,equipment):	OP 2337, Section 4.2		
General References:	OP 2337, Section 4.2, Rev. 01	6-03	

### \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JPM Number:	JPM-225	Rev. 0	)
Initiating Cues:	The US has directed you to remove the from service and place the "B" Waste G	"A" Waster ( as Decay Ta	Gas Decay Tank ank in service.
Initial Conditions:	The "A" Waste Gas Decay Tank pressu "B" Waste Gas Decay Tank pressure in	re indicates dicates 5 psi	137 psig. g

Simulator Requirements: N/A

#### \*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

JPM ID NUM	BER: JPM-225 TITLE: Shift From "A" to "B" Waste Gas Decay Tank
START TIME	
STEP 1	Performance Steps: Mark the boxes in steps 4.2.5, 4.2.9, and 4.2.10 with the letter "A" (for the "A" waste Gas Decay Tank).
GRADE	Standards: Examinee records the letter "A" in the boxes for steps 4.2.5, 4.2.9, and 4.2.10.
	Cue:
Comments:	
	~~~~~~
STEP 2	Performance Steps: Mark the boxes in step 4.2.6.with the letter "B" (for the "B" Waste Gas Decay Tank).
GRADE	Standards: Examinee records the letter "B" in the boxes for steps 4.2.6.
	Cue:
Comments:	
	~~~~~~
STEP 3	Performance Steps: Record position of Waste Gas Compressor hand switches.
GRADE	Standards: Examinee records the position of the "A" and "B" of Waste Gas Compressor hand switches.
Comments:	One compressor will be in AUTO, the other will be in STANDBY.

4

~~~~~~~~~~

~~~~~~~~~~~

JPM ID NUMBER: <u>JPM-225</u>	TITLE: Shift From "A" to "B" Waste Gas Decay Tank
STEP 4 <u>X</u> Performance S	Steps: Place both Waste Gas Compressor hand switches in OFF position.
GRADE <u>X</u> Standards:	Examinee states that they would place both Waste Gas Compressor hand switches on panel C-61 in the OFF position.
Cue:	
Comments:	
~~~~~~~	~~~~~
STEP <b>5</b> <u>X</u> Performance S	<ul> <li>Steps: Close the following valves:</li> <li>WASTE GAS DECAY TANK INLET VALVE, 2- GR-6.1A (C-61)</li> <li>Decay Tank Inlet Stop, 2-GR-6A (local)</li> <li>Pressure Control Valve Outlet Isolation, 2-GR-7A (local)</li> </ul>
GRADE <u>X</u> Standards:	<ul> <li>Examinee states that they would place the hand switch for the following valves in the CLOSE position and observe the only the green light is lit:</li> <li>WASTE GAS DECAY TANK INLET VALVE, 2-GR-6.1A, on C-61</li> <li>Decay Tank Inlet Stop, 2-GR-6A, in the -25'6"</li> <li>Pressure Control Valve Outlet Isolation, 2-GR-7A, in the -25'6"</li> </ul>
Cue: <b>The val</b> v	ves are closed and the green lights are lit.
Comments:	

5

~~~~~~~

.....

| TEP 6       _X_ Performance Steps: Ensure of Comparison of the following of the follo | e the following valves are closed:<br>ECAY TANK OUTLET CONTROL VALVE, 2<br>R-8.1B (C-61)<br>Ecay Tank Outlet Isolation, 2-GR-8B (local)<br>Ecay Tank Outlet Stop, 2-GR-9B (local)<br>States that they would ensure the hand switt<br>wing valves were in the CLOSE position are<br>at only the green light is lit:<br>E GAS DECAY TANK OUTLET VALVE, 2-G<br>In C-61<br>Tank Outlet Isolation, 2-GR-8B, in the -25'6 |
|--|---|
| RADE       X       Standards:       Examineer for the foll observe the observe t                   | states that they would ensure the hand swit<br>wing valves were in the CLOSE position an<br>at only the green light is lit:<br>E GAS DECAY TANK OUTLET VALVE, 2-G<br>n C-61<br>Tank Outlet Isolation, 2-GR-8B, in the -25'6   |
| Cue: The valves are close<br>comments:<br>TEP 7 <u>X</u> Performance Steps: Oper<br>• V<br>G<br>• D<br>• C<br>• C<br>• C<br>• C<br>• C<br>• C<br>• C<br>• C  | Tank Outlet Stop, 2-GR-9B, in the -25'6"  |
| TEP 7 <u>X</u> Performance Steps: Oper<br>• V<br>• C<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D   |   |
| TEP 7 <u>X</u> Performance Steps: Oper<br>• V<br>• C<br>• D<br>• P<br>(I<br>RADE <u>X</u> Standards: Examinee<br>for the foll<br>the only th   |   |
| TEP 7 <u>X</u> Performance Steps: Oper<br>• V<br>• C<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D<br>• D   |   |
| RADE <u>X</u> Standards: Examinee<br>for the fol<br>the only th  | the following valves:<br>ASTE GAS DECAY TANK INLET VALVE, 2<br>R-6.1B (C-61)<br>ecay Tank Inlet Stop, 2-GR-6B (local)   |
| <ul> <li>WAST</li> <li>6.1B,</li> <li>Decay</li> <li>Press</li> <li>the -2.</li> </ul>   | essure Control Valve Outlet Isolation, 2-GR<br>cal)   |
| Cue: The valves are oper   | essure Control Valve Outlet Isolation, 2-GR<br>cal)<br>states that they would place the hand switch<br>wing valves in the OPEN position and obse<br>e red light is lit:<br>E GAS DECAY TANK INLET VALVE, 2-GR-<br>Tank Inlet Stop, 2-GR-6B, in the -25'6"<br>re Control Valve Outlet Isolation, 2-GR-7B,<br>"6"   |

Comments:

~

~~~~~~

| JPM ID NUMBER: <u>JPM-225</u> TITLE: Shift From "A" to "B" Waste Gas Decay<br>Tank                                                                                        |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 8 <u>X</u> Performance Steps: Place Waste Gas Compressor switches back to the original position.                                                                     |
| GRADE <u>X</u> Standards: Examinee states that they would place both Waste Gas<br>Compressor hand switches on panel C-61 in the<br>previously recorded position.          |
| Cue: The compressor hand switches have been returned to their original position.                                                                                          |
| Comments:                                                                                                                                                                 |
| ~~~~~~                                                                                                                                                                    |
| STEP 9 Performance Steps: Record time and pressure of "A" and "B" Waste Gas Decay Tanks in the Rad Waste Log.                                                             |
| GRADE Standards: Examinee states that they would obtain the Rad Waste<br>Log and record the time and pressure when the "A" and<br>"B" Waste Gas Decay Tanks were swapped. |
| Cue: The information has been properly logged.                                                                                                                            |
| Comments:                                                                                                                                                                 |

~~~~~~~~~~~~~~~~~~~~~~~~~~~~~

STEP 10       X       Performance Steps: Open Decay Tank Sample Stop, 2-GR-17A, and request Chemistry to sample the "A" Waste Gas Decay Tank.         GRADE       X       Standards:       Examinee state that they would open Decay Tank Sa Stop, 2-GR-17A, and request Chemistry to sample th Waste Gas Decay Tank.         Cue:       The valve is open.         Comments:       Examinee may state that they would close Decay Tank Sample Stop, 2-GR 17A, when sampling is complete.	STEP 10       X       Performance Steps: Open Decay Tank Sample Stop, 2-GR-17A, and request Chemistry to sample the "A" Waste Gas Decay Tank.         GRADE       X       Standards:       Examinee state that they would open Decay Tank Sam Stop, 2-GR-17A, and request Chemistry to sample the Waste Gas Decay Tank.         Cue:       The valve is open.         Comments:       Examinee may state that they would close Decay Tank Sample Stop, 2-GR-17A, when sampling is complete.         Comments:       After this step is completed, the JPM is considered complete.	JPM ID NUN	BER: <u>JPM-225</u>	TITLE:	Shift From "A" to "B" Waste Gas Decay Tank
GRADE       X       Standards:       Examinee state that they would open Decay Tank San Stop, 2-GR-17A, and request Chemistry to sample the Waste Gas Decay Tank.         Cue:       The valve is open.         Comments:       Examinee may state that they would close Decay Tank Sample Stop, 2-GR 17A, when sampling is complete.	GRADEX       XStandards:       Examinee state that they would open Decay Tank San Stop, 2-GR-17A, and request Chemistry to sample the Waste Gas Decay Tank.         Cue:       The valve is open.         Comments:       Examinee may state that they would close Decay Tank Sample Stop, 2-GR-17A, when sampling is complete.         Comments:       After this step is completed, the JPM is considered complete.	STEP 10	<u>X</u> Performance S	Steps: Ope requ Deca	n Decay Tank Sample Stop, 2-GR-17A, and lest Chemistry to sample the "A" Waste Gas ay Tank.
Cue: <b>The valve is open.</b> Comments: Examinee may state that they would close Decay Tank Sample Stop, 2-GR 17A, when sampling is complete.	Cue: The valve is open. Comments: Examinee may state that they would close Decay Tank Sample Stop, 2-GR- 17A, when sampling is complete. Comments: After this step is completed, the JPM is considered complete.	GRADE	<u>X</u> Standards:	Examinee Stop, 2-G Waste Ga	e state that they would open Decay Tank Sam R-17A, and request Chemistry to sample the as Decay Tank.
Comments: Examinee may state that they would close Decay Tank Sample Stop, 2-GR 17A, when sampling is complete.	Comments: Examinee may state that they would close Decay Tank Sample Stop, 2-GR- 17A, when sampling is complete.		Cue: The valv	/e is open.	
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	Comments: After this step is completed, the JPM is considered complete.	Comments:	Examinee may state 17A, when sampling	e that they v g is complet	vould close Decay Tank Sample Stop, 2-GR- e.
Comments After this step is completed, the JPM is considered complete		Comments <sup>.</sup>	After this step is co	~~~~~	~~~~~~

/

## VERIFICATION OF JPM COMPLETION

Job Performanc	e Measure No.	<u>JPM-225</u>	Rev.	<u>0</u>	
Date Performed	:				
Operator:					
Evaluator(s):					
Ear avaminas to a	chieve a satisfactor	v grade ALL critical s	tens must be comple	ted correctly 1	f to all to
Time Critical, it <u>MU</u>	IST be completed w	vithin the specified tim	ne to achieve a satisfa	actory grade.	
Time Critical, it <u>MU</u>	I <u>ST</u> be completed w	vithin the specified tim	ne to achieve a satisfa	actory grade.	
Time Critical, it <u>MU</u> Time Critical Ta	sk? Yes	No X	ne to achieve a satisfa	actory grade.	
Time Critical, it <u>MU</u> Time Critical Ta Validated Time ( Actual Time to C	sk? Yes (minutes):	No <u>X</u> s): <u>10</u>	ne to achieve a satisfa	actory grade.	
Time Critical, it <u>MU</u> Time Critical Ta Validated Time of Actual Time to C Result of JPM:	I <u>ST</u> be completed with the second se	No <u>X</u> s): <u>10</u>	actory or a $\underline{U}$ for uns	satisfactory)	

Areas for Improvement:

#### **EXAMINEE HANDOUT**

JPM ID Number: JPM-225

Initiating Cues: The US has directed you to remove the "A" Waster Gas Decay Tank from service and place the "B" Waste Gas Decay Tank in service.

Initial Conditions:

The "A" Waste Gas Decay Tank pressure indicates 137 psig. "B" Waste Gas Decay Tank pressure indicates 5 psig

ADD PARCED WING TO CUE

## JOB PERFORMANCE MEASURE APPROVAL SHEET

Local Manual Operation of the Turbine Driven Auxiliary Feedwater 1. JPM Title: Pump ID Number: JPM-085 Revision: 9, Ch. 1 11. Initiated: Jim Barba 10/24/00 Developer Date III. Reviewed: John Hampton 10/24/00 Technical Reviewer Date IV. Approved: S. R. Myers 10/24/00 User Department Supervisor Date

M. C. Jensen Nuclear Training Supervisor 10/24/00 Date

Facility: MP-2	Examinee:			
JPM Number:	JPM-085 Rev. 9			
Task Title: Local Mar	nual Operation of the Turbine Driven Auxiliary Feedwater Pump	A Constant A Constant		
System: <u>Auxiliary Feed</u>	lwater			
Time Critical Task: Yes	NoX			
Validated Time (minutes):	15			
Task No.(s): <u>NUTIMS</u> #	000-05-150			
Applicable To: SRC	X RO X PEO X			
K/A No.: 054-EA1.	02 K/A Rating: <u>4.4/4.4</u>			
Method of Testing:				
Simulated Performance:	X Actual Performance:			
Location:				
Classroom:	Simulator: In-Plant:X			
Task Standards:	At the completion of this JPM, the examinee has simulated manually starting the turbine driven AFW pump.			
Required Materials (procedures,equipment):	<ul> <li>EOP 2541, Standard Appendix 7, TDAFW Pump Abnormal Startup</li> </ul>			
General References:	EOP 2541	l		

## \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JPM Number:	JPM-085	Rev. 9
Initiating Cues:	<ul> <li>The Unit Supervisor has d turbine per EOP 2541, Ap</li> </ul>	directed you to locally start the terry opendix 7.
Initial Conditions:	<ul> <li>The plant has been tripper subsequent loss of both S</li> <li>Vital D.C. Bus 201A and 2</li> <li>Due to a loss of <u>both</u> electric is in EOP 2540, "Function</li> <li>SG levels are at 220 inches</li> <li>Auxiliary feedwater piping</li> <li>TDAFW pump area temper</li> </ul>	d due to a lowering vacuum and a GGFPs. 201B have also been lost. tric auxiliary feedwater pumps, the shift al Recovery." es and lowering. integrity has been verified satisfactory. erature is less than 120°F

Simulator Requirements: N/A

## \*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM.

JPM ID NUM	IBER: <u>JPM-085</u>	TITLE:	Local Manual Operation of the Turbine Driven Auxiliary Feedwater Pump
START TIME			
STEP 1	<u>X</u> Performance	e Steps: Rei the	move four bolts connecting the governor motor to governor.
GRADE -	<u>X</u> Standards:	Examin locates they wc	ee proceeds to the terry-turbine AFP room, the wrench attached to the governor, and states ould remove the four bolts on the governor motor.
	Cue: The fo	ur bolts and	the governor motor are removed.
Comments:	Examinee may st headphones and The examinee ma operate the gear	ate the need jack in the r ay also state on the gove	d for establishing communications using the oom; if so, inform them to consider it done. that the motor needs to be removed in order to rnor.
STEP 2	X Performance	Steps: Slo PU	wly open MS-464, "TERRY TURBINE AUX FEED MP STEAM SUPPLY."
GRADE -	<u>X</u> Standards:	Examin down ol handwh	ee states they would open MS-464 by pushing In the manual clutch lever while rotating the leel in the counterclockwise direction.
	Cue: Manua passin	Il lever is pu g; sound of	shed down; valve stem is rising; sound of steam terry-turbine rotating; valve is fully open.
Comments:	Examinee may st the governor, whi Audible indication If SI-4194B, "SG available, TDAFP governor speed c attached).	ate that the ch can be do , when MS-4 AUXFEED F speed is be ontrol knob	pump should be running at a constant speed on etermined by using: 464 is fully open, OR PUMP TURBINE SPEED INDICATOR" is sing maintained at 1400 to 1600 rpm using the (i.e., the part where the governor motor was

JPM ID NUM	BER: <u>J</u>	P <u>M-085</u>	TITLE:	Local Manual Operation of the Turbine Driven Auxiliary Feedwater Pump
STEP 3	<u>X</u> Per	formance S	Steps: Rai	se turbine speed until feed flow is established.
GRADE	<u>X</u> Sta	andards:	Examin stabilize part of t attache "TERR" INDICA on the l SUPPL If comm until fee feed reg	ee states when TDAFW pump parameters have ed, they would turn the governor speed control (the the governor where the governor motor was d), until: discharge pressure on the local gage (PI-5284-1, Y TURBINE AUX F/P DISCH PRESSURE TOR") is 50 - 150 psi > steam generator pressure, ocal gage (PI-4190-1, "TERRY TURBINE STEAM Y PRESSURE INDICATOR"), OR nunications are established with the Control Room, ed flow is established to at least one SG using aux g valve.
	Cue	Steam ir and pur Feed flo	nlet pressu np discharg w to the S	ire gage indicating 890#; use pen, etc. to show this ge pressure rising until examinee stops adjusting. Gs is evident in control room.

Comments: After this step is completed, the JPM is considered complete.

STOP TIME:

### VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	<u>JPM-085</u>	Rev.	<u>9</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achieve a satis correctly. If task is Time Critica achieve a satisfactory grade.	sfactory grade, <u>ALL</u> critica I, it <u>MUST</u> be completed w	l steps mus <i>i</i> ithin the sp	t be completed ecified time to
Time Critical Task? Yes	No <u>X</u>		
Validated Time (minutes):	15		
Actual Time to Complete (minute	s):		
Result of JPM: (Denot	e by an <u>S</u> for satisfactory or a	a <u>U</u> for unsat	tisfactory)

Areas for Improvement:

#### **EXAMINEE HANDOUT**

JPM ID Number: 085

## Initiating Cues:

- The Unit Supervisor has directed you to locally start the terry turbine per EOP 2541, Appendix 7.
- Initial Conditions:
- The plant has been tripped due to a lowering vacuum and a subsequent loss of both SGFPs.
- Vital D.C. Bus 201A and 201B have also been lost.
- Due to a loss of <u>both</u> electric auxiliary feedwater pumps, the shift is in EOP 2540, "Functional Recovery."
- SG levels are at 220 inches and lowering.
- Auxiliary feedwater piping integrity has been verified satisfactory.
- TDAFW pump area temperature is less than 120°F.