MILLETON		
	NE FOWER STATION	
	\boldsymbol{V}	
	SIMULATOR EXAM GUIDE APPROVAL SHEE	ET
Lesson Title:	I OUT 2003 Simulator Fxam#1	
Revision [.]	1	
ID Number:		\backslash
ID Number.		
		1
	/	
This d	ocument is the property of the Millstone Power Station	which controls
This di its dist strictly	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of th prohibited without the written consent of the Millstone	which controls is document i Power Station
This dist its dist strictly	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of th prohibited without the written consent of the Millstone I	which controls is document i Power Station
This dist its dist strictly Submitted by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of th prohibited without the written consent of the Millstone I R. J. Ashey	which controls is document i Power Station 09/05/03
This districtly strictly Submitted by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey	which controls is document i Power Station 09/05/03 Date
This districtly Submitted by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey Developer	which controls is document i Power Station 09/05/03 Date
This districtly Submitted by: Reviewed by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey R. L. Cimmimo Multiple Millstone Millstone I Developer	which controls is document i Power Station 09/05/03 Date
This districtly Submitted by: Reviewed by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey R. L. Cimmimo Manuel Technical Reviewer	which controls is document i Power Station 09/05/03 Date
This districtly Submitted by: Reviewed by: Approved by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey R. L. Cimmimo Manuel R. L. Cimmimo Rawoit F. Paenettre RAWOIL F. Paenettre Developer	which controls is document i Power Station 09/05/03 Date 9/5 Date 9-17-
This dististing strictly Submitted by: Reviewed by: Approved by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey R. L. Cimmimo Multiple R. L. Cimmimo Manager, Operations (Optional)	which controls is document i Power Station 09/05/03 Date 9/5 Date 9-17-
This districtly Submitted by: Reviewed by: Approved by:	ocument is the property of the Millstone Power Station ribution. Further transfer, copying, or modification of the prohibited without the written consent of the Millstone I R. J. Ashey R. J. Ashey R. L. Cimmimo R. L. Cimmimo Technical Reviewer RANOIC F. Paenerre Manager, Operations (Optional)	which controls is document i Power Station 09/05/03 Date 9/5 Date 9-17- Date

,

SIMULATOR EXAM GUIDE SUMMARY OF CHANGES

1. Modified per NRC review comments. Removed the initial "Normal" action and replaced it with a "Component" malfunction.

•

SIMULATOR EXAM GUIDE TABLE OF CONTENTS

SECTIONS LISTED IN ORDER

1. Exam Overview

•

- 2. Scenario Initial Conditions Sheet
- 3. Exam Guide
- 4. Exam Guide Summary
- 5. STA Follow-up Questions
 - Attachments
- 1. Validation Checklists
- 2. Shift Turnover Sheet
- 3. Scenario Attribute Checklist

EXAM OVERVIEW

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Revision: 1

1. Purpose:

This examination is used to evaluate crew/individual performance in the simulator to satisfy the requirements of NUREG 1021 for SRO-U applicants. To meet these requirements, this exam is designed to:

- a. Evaluate the licensees' ability, as a team and individually, to respond to an emergency event.
- b. Evaluate licensees in the following areas:
 - 1) Ability of the crew to perform crew-dependent critical tasks.
 - 2) Ability of individuals to perform critical tasks.
 - 3) Ability of each applicant to:
 - a) Respond and correctly interpret annunciators
 - b) Correctly diagnose events
 - c) Properly interpret integrated system response
 - d) Comply with and use Technical Specifications
 - e) Comply with and use procedures
 - f) Demonstrate a responsible attitude
 - g) Properly communicate information and interact with the rest of the crew

EXAM OVERVIEW

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Revision: 1

2. Exam brief:

The simulator and room will be prepared for the exam.

- 1. The Simulator will be initialized at IC-98, 28% power, MOL, or an equivalent IC.
- 2. Power is being held constant for turnover. The unit was shut down three days ago to repair a small unisolable steam leak in the Turbine Building.
- 3. Bus 24E is aligned to bus 24D.
- 4. The Terry Turbine is tagged out for packing replacement.
- 5. TSAS 3.7.1.2b, Action a, and TRM Table 7.15-1, Items A, B, and C, Action a, have been logged into for about 6 hours.

Shortly after the Crew takes the watch, per the Examiners direction, initiate a slow failure of the Letdown Backpressure Controller. This will result in a slow oscillation of letdown pressure, which will become more divergent as time continues. Manual control of the Letdown Backpressure Controller will be required to stop the oscillation.

Approximately 3 minutes after the failure of the Backpressure Controller has been resolved, the Containment Sump level transmitter will fail low. The crew will respond to the failure and log into Tech Spec action statement 3.4.6.1b for Reactor Coolant Leakage Detection Systems, and 3.3.3.8, action 7, for Accident Monitoring.

Shortly after the Containment Sump level transmitter failure is resolved, an RCS leak on the RX Vessel Head Vent will develop. After the crew has identified that RCS leakage exists, and AOP 2568, Reactor Coolant System Leak, is used to respond to the leakage, the crew should continue the downpower using AOP 2575, Rapid Downpower. After the downpower is initiated, the "A" RCP will trip due to a loss of oil in the upper reservoir; however the automatic reactor trip will NOT be initiated. The US should direct a manual reactor trip. When the PPO attempts to trip the reactor, the trip pushbuttons do NOT operate. The PPO will open the CEDM MG set breakers, which will result in a reactor trip. When the reactor is tripped, the RCS leak will degrade to a small break LOCA. Additionally, a fault in the RSST will result in a Loss of Normal Power. Both D/G's will automatically start and energize their respective buses. The "A" AFW pump should be manually started but will be in a severely degraded condition. The SPO should attempt to start the 'B' AFW pump, but its breaker will NOT close. During the performance of EOP 2525, the "C" HPSI Pump will trip. The "A" HPSI Pump is degraded to the point that adequate SI flow CANNOT be achieved. The US will direct the PPO to start the "B" HPSI Pump.

The crew should diagnose a LOCA with a concurrent Loss of Feedwater and enter EOP 2540, Functional Recovery.

Using the Resource Assessment Trees, the US will complete the Safety Function Status Page. If the "B" HPSI Pump was NOT started prior to this, the US will determine that RCS Inventory Control is the first priority and direct the PPO to start the "B" HPSI Pump. Otherwise, the US will determine that RCS Heat Removal is the first priority, which will require the initiation of Once-Through-Cooling.

The scenario will be terminated when RCS Heat Removal (Once-Through-Cooling) and RCS Inventory Safety functions are satisfied. When the session is terminated, the examiners shall ask any questions of the licensees that require clarification of their actions.

 Plant/Simulator differences that may affect the scenario are: None

4. Duration of Exam: <u>1.5</u> hours.

SIMULATOR EXAM GUIDE SCENARIO INITIAL CONDITIONS

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Revision: 1

Out of Service Equipment

"B" Charging Pump Turbine Driven Auxiliary Feed Pump

Crew Instructions

After assuming the shift, hold power while placing "B" RBCCW Pump in operation and stopping "C" RBCCW Pump in preparation for performing maintenance on the "C" RBCCW Pump. Place a yellow caution tag on the "C" RBCCW Pump hand switch.

SIMULATOR EXAM GUIDE

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Revision: 1

All Control Room Conduct, Operations and Communications shall be in accordance applicable Unit Procedures.

"Review the Simulator Operating Limits (design limits of plant) and the Simulator Modeling Limitations and Anomalous Response List prior to performing this exam scenario on the simulator. The evaluators should be aware if any of these limitations may be exceeded." (NSEM 6.02)

(Simulat	tor Exam Guide			(•
Title:	LOUT 2003 Sim	nulator Exam #1		ID Number	<u>ES03LU1</u>	Revision:	<u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expe	cted Actions		Standard
To		Initial Conditions					
		Initialize the simulator to IC-98 (or equivalent), 28% power, MOL, Load Limit set to 1.39. RPS pot settings:					
		$\begin{array}{c c} \Delta T & Nuclear \\ A & 4.00 & 4.35 \\ B & 4.42 & 4.52 \\ C & 4.00 & 4.08 \\ D & 4.42 & 4.08 \end{array}$					
T ₀	EDR14 (RO)	Bus 24E is powered from bus 24D.					
	EDR15 (RI) SWR22 (22F)	Ensure all loads powered from bus 24E are properly aligned to Facility 2.					
Τo	FWR22 (LOCL) MSR13 (RI) MSR12 (RO) MSR13 (RO)	Insert remote functions to remove the terry turbine from service. Close MS-201 and 202. Place yellow tags on MS-201, 202 and steam supply valve.					
Τo	ED02 (BT1)	Insert malfunction to cause a loss of RSST when the reactor is tripped.					MA
To	FW30A (100%)	Insert malfunction to cause the 'A' AFW pump degraded performance.					TM EM
To	FW20B	'B' AFW pump trip.					MA
Τo	RC03A (0.2%) (BT1)	Insert a malfunction to cause a small break LOCA in the Loop 1A cold leg when the reactor is tripped.					MA
To	SI05A (75%)	"A" HPSI Pump degraded performance.					TM EM

-

×

Simulator Exam Guide

Title:	LOUT 2003 S	imulator Exam #1		ID Number	ES03LU1	Revision:	<u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expe	cted Actions		Standard
To	RP04A RP04B RP04C RP04D	Manual reactor trip failure					ТМ
	RP27B	Automatic reactor trip failure.					TM AE
To		Brief the "oncoming" SM. In addition to using the Turnover Sheet, provide the following information:					
		The plant is at 28% power and is holding for turnover. The unit was shut down to repair a small unisolable steam leak in the Turbine Building and is returning to 100%					
		RCS Boron concentration is 1175 ppm. The blend ratio is 3.5:1. Adding 20 gals of PMW every 15 minutes.					
		Bus 24E is being supplied by bus 24D in preparation for swapping RBCCW Pumps for scheduled maintenance. Vital Switchgear Room temperature is being logged once per shift. All switchgear room conditions are normal.					
		The Terry turbine is tagged out for packing replacement.					
		After you assume the shift, start the "B" RBCCW Pump on facility 2 and stop the "C" RBCCW Pump. Place a yellow caution tag on the hand switch and inform Work Control. When you are ready to take the shift, please inform me.					

.

.

(

ζ.	(Simulator, Fxam Guide						·
Title:	LOUT 2003 Sim	<u>ulator Exam #1</u>		ID Number	ES03LU1	Revision	(: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expe	cted Actions		Standard
T₀ + var.	CV06C (100%) 300 Sec.	Shortly after the Crew has taken the watch, insert malfunction to cause increasingly divergent oscillations of the Letdown Backpressure Controller	Inst.				ТМ
			PPO/US	Note oscillations in let letdown flow.	down backpressu	ure or	
			US	Direct the PPO to take Backpressure Control backpressure.	e MANUAL contro ller and stabilize I	ol of the etdown	
			US	The US may have a b reference the ARP (C Backpressure. This n the backpressure con	ooard operator, or 02/3-C8) for Hi/Lo nay be done befo troller is placed ir	^r himself, ow Letdown o re or after n manual.	
			US	Notify/direct I&C to inv	vestigate the mal	function.	
T₁ + 15 min.	WD03 (0%) Ramp = 150	After the crew has resolved the backpressure control problem, insert	SPO	Observe the "CTMT Norm Sump Level; Hi/Lo" annunciator and report that the CTMT Sump leve		; Hi/Lo" Sump level	MP-14-OPS- GDL02
	560.	Sump level transmitter to zero.		is trending to or readi	ng zero.		TM AE
			US	Direct the SPO to obta	ain the appropriat	te ARP	MP-14-OPS- GDL02
			US	Determine that the lev report failed CTMT Su I&C Department.	vel instrument has ump level indication	s failed and on to the	MP-14-OPS- GDL02
			US	Obtain Tech Specs ar and 3.3.3.8, Table 3.3	nd log into TSAS 8-11, Action 7.	3.4.6.1b	Tech Specs
T ₁ + 30 min.	RC04 (5%) Ramp = 200	Shortly after the crew resolves the level instrument failure, insert a malfunction to cause a 35 gpm leak	PPO	Observe and report in Rising CTMT press, ri	dications of RCS ising CTMT temp	leak: , rising gas	MP-14-OPS- GDL02
						~	

•

Page 11 of 26

(Simulat	Guide	· · ·	
Title:	LOUT 2003 Sir	nulator Exam #1		ID Number <u>ES03LU1</u> Revisio	n: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard
	sec.	on the Rx Vessel Head Vent.		and particulate RM readings.	TM AE
				Also report letdown lowering and backup charging pumps starting.	3
				Determines leak rate of greater than 10 gpm, but less than 50 gpm.	
			US	Enter AOP 2568, Reactor Coolant System Leak:	AOP2568
			US	 Ensure adequate SHUTDOWN MARGIN. Verify Pressurizer level 35 –70%. Maintain Pressurizer pressure 2225 to 2300 psia. Maintain SG level 55 – 75% Ensure RBCCW and Service Water are operating properly. Ensure at least 2 CARS operating with RBCCW flow to them. Direct PPO to obtain a leak rate from PPC or other indications. 	AOP 2568
		Event classification may be asked as a follow-up question after the exam is complete.	SM	When it is determined that the RCS leakage exceeds 10 gpm, then classify the event as a UE/D-1 (BU2).	MP-26-EPI- FAP06-002
			US	When leak rate is determined to be greater than Tech Spec allowed value, log into TSAS 3.4.6.2b Action b.	Tech Specs
			US	Determine that the plant shutdown must continue	. AOP 2568
		Because the crew will be able to determine the location of the leak from available indications and due to the limited resources, the remaining	US	Reference AOP 2575, Rapid Downpower, and coordinate a plant shutdown.	AOP 2575

÷

((Simulator Fxam Guide						
Title:	LOUT 2003 Sin	nulator Exam #1	× .	ID Number <u>ES03LU1</u> Revision:	<u>1</u>		
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard		
		actions for determining the leak location per AOP 2568 may be performed after commencing the down power.					
			US	Direct SPO to determine whether leakage in into a Steam Generator per step 5.1.	AOP 2568		
			US	Direct PPO to determine whether leakage in into Containment per step 5.2.	AOP 2568		
			US	Direct PPO to determine whether leakage is pasta PORVs of Pressurizer safeties per step 5.3.	AOP 2568		
			US	Direct SPO to determine whether leakage is into RBCCW per step 5.4.	AOP 2568		
			US	Direct SPO to determine whether leakage is into the Auxiliary Building per step 5.5.	AOP 2568		
			US	Direct PPO to determine whether leakage is into the Safety Injection system.	AOP 2568		
			US	Ensure board operators maintain parameters specified in Attachments 1, 5, and 6.	AOP 2575		
			US	Direct board operator to inform HP of the power change and rise in Letdown flow.	AOP 2575		
		The required notifications may be completed with one phone call.	US	 Direct or perform: Inform CONVEX and ISO New England or rapid down power. Refer to MP-01-SM-GDL01.01 and perform notifications as required. Notify Unit 3 of rapid down power. 	AOP 2575		

.

(Simulate	or ^F xam	Guide	•
Title:	LOUT 2003 Sim	ulator Exam #1	X	ID Number <u>ES03LU1</u> Revision:	1
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard
			US	Inform board operators of manual reactor trip requirements.	AOP 2575
			US	Direct the SPO to maintain SG levels 55 to 70% and FRV D/P greater than 20 psid.	AOP 2575
		The US may opt to borate directly from the RWST. Applicable steps are contained in AOP 2575.	US	Determine the appropriate down power rate and direct the PPO to confirm the corresponding Boric Acid addition rate.	AOP 2575
		to the charging pump suction would allow a blended make up to the VCT while maintaining a constant down power rate.		Direct the PPO to continue boration to the charging pump suction.	
				Direct SPO to maintain temperature control with the main turbine until the PPO is able to do so.	MP-14-OPS- GDL02
		This action was performed earlier to	PPO	Perform the following:	AOP 2575
		commence the down power; however, they may be verified by the PPO.		 Ensure the Makeup Mode Selector switch is in DILUTE and the Primary Makeup Water Flow controller is set to zero. 	
				2. Ensure CH 512 and CH-196 are closed.	
				 Ensure Boric Acid Flow controller is in AUTO. 	
				 Adjust Boric Acid Flow controller to the previously determined Boric Acid flow rate. 	
				5. Open CH-504.	
				 Place Makeup Mode Selector switch in MANUAL. 	
				Start a Boric Acid Pump and ensure discharge pressure is greater than 90 psig.	

- 8. When ready, open CH-196
- PPO When (If) required, raise Boration and dilution flow AOP 2575,

-

(

Simulator Fxam Guide

L			(0			C
Title:	LOUT 2003 Sim	ulator Exam #1		ID Number	<u>ES03LU1</u>	Revision	: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expec	Expected Actions		Standard
				and perform a blended maintaining the approposed power) rate.	d make up to the priate boration (do	VCT while own	Attachment 3
			US	Direct PPO to insert C ASI within 0.01 of ESI	EAs as required t	to maintain	AOP 2575
T₁ + 45 min.	RC12A (100%) Ramp = 180	Shortly after the crew initiates a down power, insert a malfunction for	Shortly after the crew initiates a PPO down power, insert a malfunction for		associated with I	oss of oil	MP-14-OPS- GDL02
	Sec.	an oil leak on "A" RCP		Obtain ARP 2590B			тм
T₁ + 47 min.	RC11A	This action must be performed prior to the US directing a manual Reactor trip. Approximately 1-2 minutes after the low oil level alarm, insert a malfunction to seize the "A" RCP. (This will result in an RPS trip signal, but the reactor will NOT automatically trip.)	US	Direct PPO to check ", level indication and de decrease.	A" RCP upper oil etermine the rate o	reservoir of level	ARP 2590B
			Crew	Observe the trip of the does NOT automatica	e "A" RCP, but the Ily trip.	ereactor	MP-14-OPS- GDL02
							AE
		SPTA-5: MANUALLY SHUT DOWN THE REACTOR.	US	Direct a manual reactor 2525, Standard Post 1	or trip and carry o Frip Actions.	ut EOP	MP-14-OPS- GDL02
							СТ
			PPO /	Push the 4 reactor trip	push buttons and	d observe	EOP 2525
			5P0	a failure to trip.			EC
		The PPO may open the CEDM MG output breakers <u>without</u> direction from the US.	US	Direct a manual reactor MG output breakers.	or trip by opening	the CEDM	EOP 2525

.

.

(Simulat	tor, T xam	Guide	· ·
Title:	LOUT 2003 Sim	ulator Exam #1	Υ,	ID Number <u>ES03LU1</u> Revision:	(<u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard
			US	Place Master Alarm Silence in SILENCE. Announce "Unit 2 trip" on the plant paging system.	OP 2260
			PPO	Complete and report SPTA for PPO per EOP 2525:	EOP 2525
				 Ensures Reactivity safety function is being met: Reactor is tripped All CEAs are inserted. Power is going down. SUR is negative. Manual reactor trip buttons failed to operate. Opened the CEDM MG set feeder breakers. Reports to US. 	
		PPO may report degradation of "A"		 Verifies RCS Inventory and Pressure safety functions are being met (Reports Letdown is isolated and all available Charging Pumps are running). 	
				 If Pressurizer pressure falls to less than 1800 psia, manually initiates SIAS. 	
				 Verifies Core Heat Removal established. NO RCPs are operating due to loss of RSST. 	
			 Verifies Containment Integrity safety function is being met by verifying CTMT pressure, temperature, and rad monitor readings. 		
				 Observes rad monitors in CTMT are in alarm and rising; all other rad monitors are normal. 	
				- Performs and reports subsequent actions.	
			SPO	Completes SPTA for SPO per EOP 2525 correctly:	EOP 2525
				- Vital Auxiliaries are satisfied:	

((Simulator ^F xam Guide (
Title:	LOUT 2003 Sim	ulator Exam #1		ID Number	<u>ES03LU1</u>	Revision:	<u>1</u>	
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Exped	cted Actions		Standard	
				 The Main Turbine All main stop valve Megawatts are zer 8T & 9T are open Reports to US Reports that a loss Buses 25A and B Buses 24A and B Buses 24C and 24 respective D/Gs VA-10 and 20 are Both DC busses a Both facilities of R Verifies RCS heat and RCS Tave). Verifies S/G feed 6 Starts the 'A' AFW degraded. (SPO n pump.) 'B' AFW pump bre Reports status of a 	is tripped es are closed ro s of RSST has occ are deenergized are deenergized D energized on th energized BCCW & SW are removal (S/G pre established: / pump, but perfor nay secure the 'A' eaker will NOT clos Aux Feedwater.	curred neir operating. essures mance is AFW se.		
T₁ + 55 min.	SI04C	SI04C Approximately 5 to 10 minutes after entry into EOP 2525, insert a	PPO	- Performs and report Observe and report th and that the "A" HPSI discharge pressure)	ne loss of the "C" H Pump is degrade	HPSI Pump d. (low	MP-14-OPS- GDL02	
	Pump.		Determine and report rate is less than requi	that the Safety In red.	jection flow			
		The direction to start the "B" HPSI Pump might not be given until	US	Direct the PPO to star	rt "B" HPSI		MP-14-OPS- GDL02	
		after entry into EOP 2540.				Daga 17 of 2	CT	
						rage 1 / of 2	O	

((Simulator Fxam Guide (
Title:	LOUT 2003 Sim	ulator Exam #1		ID Number <u>ES03LU1</u> Revision:	: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
		SPTA-4: Manually establish the minimum design Safety Injection System flow.						
			PPO	Start "B" HPSI and verify Safety Injection flow is adequate.	EOP 2525			
	EGR16 (RESET)	If directed, as a PEO to acknowledge D/G alarms then reset local trouble alarms.	SPO	Requests PEO to check out the D/Gs.	MP-14-OPS- GDL02			
	IAR10 (OPEN)	When directed, as a PEO to cross-tie Station Air with U-3, then perform actions to crosstie Station Air.	SPO	Requests PEO to cross-tie SA with U-1	EOP 2525			
		If directed to investigate the AFW Pumps, report:	US	Requests PEO/Electrician to check out the "A" and "B" AFW pumps.	MP-14-OPS- GDL02			
		"B" AFW Pump breaker is 'hung up' and cannot be racked down. Must deenergize the bus to troubleshoot.		Direct the SPO to stop the "A" Aux Feed Pump and place Auto Aux Feed hand switches in Pull- To-Lock.				
		"A" AFW Pump is making a grinding noise and is running very hot.						
		Need another day to complete repairs to the TDAFP.						
			US	Use the Diagnostic Flow Chart: Reactivity Safety Function is met. At least 1 vital AC bus and one DC are energized (same train) NO RCPs are operating (Consider EOP 2528) Inadequate flow to Steam Generators (Consider EOP 2537) Pressurizer pressure is less than 1850 and is lowering.	EOP 2525			

Page 18 of 26

(Simula	tor ^r xam	Guide	•
Title:	LOUT 2003 Sim	ulator Exam #1		ID Number <u>ES03LU1</u> Revisio	on: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard
				SG pressures are greater than 800 psia CTMT pressure is greater than 1 psig CTMT Rad monitors are going up (Consider EOP 2532)	
				Transition to EOP 2540, Functional Recovery	EU EC
		EAL classification may be asked as a follow-up question after the exam is complete.	SM	Classifies event as Alert/C-1, based on RCB2 (BA1) <u>or</u> EA1. If vessel level is observed to be less than 7%, then classification is a Site Area Emergency based on RCB2 <u>and</u> FCB4 (BS1).	MP-26-EPI- FAP06-002
			US	Place Master Alarm silence switch in NORMAL.	EOP 2540
			US	Enter the time on the Safety Function Tracking Page.	EOP 2540
			US	Ensure SIAS has been initiated and direct the following:	EOP 2540
				 Place both spray valve controllers in MANUAl and closed. 	L
				- Ensure HIC-4165 is in MANUAL and closed.	
			US	Direct the SPO to open the Steam Generator sample valves and direct Chemistry to sample both Steam Generators for Boron and activity.	EOP 2540
			SPO	Open both Steam Generator sample valves. Direct Chemistry to sample both Steam Generators for Boron and activity, frisk the samples and report the frisk results. When the frisk results are reported, obtain concurrence form the US and close the Steam Generator sample valves.	EOP 2540
			US	Direct the PPO to place both Hydrogen analyzers in operation per Appendix 19.	EOP 2540

Page 19 of 26

.

(Simulat	or Txam	Guide
Title:	LOUT 2003 Sim	ulator Exam #1	·	ID Number <u>ES03LU1</u> Revision: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions Standard
		 # If the "B" HPSI Pump is NOT started prior to this <u>or</u> if vessel level is less than 7%, then the first priority will be for Inventory Control, IC-2. When the "B" HPSI Pump is started and vessel level is 7% or greater, the Inventory Control safety function will be met and RCS Heat Removal, HR-3, will become the next priority. * If RCS pressure is less than 1200 psia, then the acceptance criteria for HR-3 will be met, resulting in a 'Y'. HR-3 will <u>still</u> be the first priority. 	US	With the assistance of the crew, identify and prioritize the success paths to be used:EOP 2540SAFETY FUNCTION NameEquip MetNameEquip MetNameEquipMetNameEquip MetM*RC-1YYHR-3YN*MVA-DC-1YYCI-1YYMVA-AC-2YYCTPC-3YYIC-2YY#CCGC-1YYPC-2YYHeat Removal, HR-3 will be the first priority.
		HR-1: Establish Once-Through- Cooling. The US should direct early initiation of Once-Through-Cooling due to the unlikelihood of establishing feed to the S/Gs and because only one HPSI Pump is running/available.	US PPO /	 Direct the crew to initiate Once-Through-Cooling: EOP 2540D 1. Ensure all proportional heaters are tripped and all backup heaters are in Pull-To-Lock. 2. Open both ADVs. 3. Ensure all RCPs are stopped. 4. Ensure SIAS is actuated. 5. Ensure HPSI Pumps have started. 6. Ensure all HPSI Injection Valves are open. 7. Ensure all available Charging Pumps are running. 8. Ensure both PORV Block Valves are open. 9. Open both PORVs. Perform the actions directed by the US as listed EOP 2540D CT
		If not performed earlier, the US	SPO US	above. Continue efforts to restore Auxiliary Feedwater. EOP 2540D
		should direct someone to investigate the status of the Aux Feed Pumps		

,

(Simula	tor ^E xam	Guide	
Title:	LOUT 2003 Si	mulator Exam #1	X	ID Number <u>ES03LU1</u> Revision:	(<u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard
		and/or their respective breakers.			
			US	Direct the PPO to ensure Safety Injection is optimized.	EOP 2540D
		The session may be terminated when the crew has verified that RCS Heat Removal is being satisfied and efforts are continuing to restore Auxiliary Feedwater.	PPO	 Perform the following: Check at least on train of SIAS, CIAS, and EBFAS has actuated on C-01X. Check Safety Injection Flow is adequate per Appendix 2 of EOP 2541. Ensure all available Charging Pumps are operating. Ensure Vital Switchgear Cooling is operating for each ECCS train. 	EOP 2540D

.

EXAM GUIDE SUMMARY

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Revision: 1

- I. Critical Tasks
 - 1. SPTA-5: Manually shutdown the reactor.
 - BASES: If the reactor is not shutdown all safety functions may be in jeopardy.
 - 2. SPTA-4: Manually establish the minimum design Safety Injection System flow.
 - BASES: Inadequate Safety Injection flow may result in loss of subcooled margin and core uncovery, and thus increase the risk of core damage.

3. HR-1: Establish Once-Through-Cooling.

BASES: If steam generator heat removal is inadequate, then another form of core and RCS heat removal must be implemented to prevent degradation of the fuel cladding barrier to fission product release. EXAM GUIDE SUMMARY - (Continued)

III. FOLLOW-UP QUESTIONS

1. What was the initial classification prior to the trip of the RCP?

Answer: Unsual Event/D-1 (BU2), RCS leakage > 10 gpm.

2. What was the classification at the completion of EOP 2525?

Answer: Classifies event as Alert/C-1 (BA1), RCB2, RCS subcooling < 30°F.

OR EA1, Failure of automatic trip and manual trip was successful.

If vessel level was less than 7%, then the classification is a Site Area Emergency/C-2 (BS1), RCB2, RCS subcooling < 30°F. <u>AND</u> FCB4, RVLMS reading = 0%.

SIMULATOR EXAM GUIDE VALIDATION CHECKLIST

Title: LOUT 2003 Simulator Exam #1

ID Number: ES03LU1

Initial Conditions:

The initial condition(s) contained in the guide are certified or have been developed from certified ICs.

Test Run:

The scenario contained in the guide has been test run on the simulator. Simulator response is reasonable and as expected.

Simulator Operating Limits:

The simulator guide has been evaluated for operating limits and/or anomalous response.

For Examination Scenario:

The Scenario Attributes Checklist is complete and attached. This is not required for Progress Review Exams

Verified By:

1

Revision:



Action/Complete

SIMULATOR GUIDE REUSE APPROVAL CHECKLIST

Title: LOUT 2003 Simulator Exam #1

÷

ID	Number:	ES03LU1	Revision	<u>1</u>
<u>Re</u>	eview of Sim	ulator Exam Guide		Verified (Initials)
•	The proced support the	lure references used in this guide are appropriate learning objectives.	te and -	NA
٠	There are r impact the	ely .	NA	
٠	There are r the reuse o	no simulator discrepancies that would negatively of this guide.	/ impact	NA
•	Validation,	if necessary, has been accomplished.	-	NA

Authorization for reusing this Simulator Exam Guide

NA		NA
	Operator Training Branch Supervisor	Date

Page 25 of 26

SIMULATOR EXAM GUIDE SCENARIO ATTRIBUTES CHECKLIST

ID Number: ES03LU1

Revision: <u>1</u>

Date:

Technical Reviewer:

SIMULATOR EXAM GUIDE SCENARIO ATTRIBUTES CHECKLIST

1. Total Malfunctions (TM) - Include EMs - 5 to 8 required	Total	7
2. Malfs after EOP entry (EMs) - 1 to 2 required	Total	4
3. Abnormal Events (AE) - 2 to 4 required	Total	4
4. Major Transients (MA) - 1 to 2 required	Total	3
5. EOPs Used (EU) beyond primary scram response - 1 to 2	Total	1
6. EOP Contingencies/Transitions (EC) - 0 to 3 required	Total	2
7. Crew Critical Task (CT)- 2 to 3 required	Total	3
8. Approximate Scenario Run Time: 60 to 90 min.	Total	90
9. EOP run time: 40 to 70 percent of scenario run time	Total	50
Technical Specifications are exercised during the scenario.	(Y/N)	Y

FOR TRAINING USE ONLY

DATE-TIME Today 0515		E-TIME y 0515	PREPARED BY Unit Supervisor /"NIGHT" Shift	SHIFT 18:00 - 06:00	
	PLANT STATUS:				
-	MODE:	1	RX POWER:	28%	
	MEGAWATTS:	Thermal: <u>770</u> MWTH	PZR PRESS:	<u>2250</u> psia	
		Electric: 257 MWe	RCS T-AVE:	545 degrees F	
İ.	RCS LEAKAGE:	Identified: 0.005 gpm	PROTECTED:	Train/Facility	
		Unidentified: 0.036 gpm		72 (VELLOW)	
		Date/Time: Today 0015		$\underline{L2}$ (IELLOW)	

TS LCO and TRM ACTION Statements Coming Due (if more than one ACTION requirement per LCO, list each separately)

Date	Time	LCO	Action	Action Requirement	Equipment	Reason
Today	1334	3.7.1.2	a	Restore within 72 hours or be in at least	TDAFP	Bearing replacement
				Hot Standby within the next 6 hours		
Today	1334	TRMAS 7.1.15,	a	Restore to Operable within 7 days or	TDAFP	Bearing replacement
		Item A, B, and C		perform actions b.1 and b.2 for fire area R-		
				1, R-2, R-3, R-11, R-13, R-16, and R-17		
3/20/03	0900	TRMAS 7.1.1,	c	With P18B inoperable for >60 days,	P18B,	Compliance with
		Item B		prepare an Engineering evaluation for	"B" Charging	Charging System OD
				continued operation. Engineering	Pump	
				assessment carried on OD No. MP2-043-		
				03 for 60 day TRM requirement.		

Continuous TS LCO and TRM ACTION Statements in effect (if more than one ACTION requirement per LCO, list each separately)

LCO	Action	Equipment	Reason
TSAS 3.4.11.b	a	Pzr Vent Solenoids	Manually isolated due to leakage (2-RC-440 is closed).
TRMAS 3.7.10	a	See AIL	See Active Impairment List.
TRM 7.1.1, Item	а	P18B	Compliance with Charging System
	LCO TSAS 3.4.11.b TRMAS 3.7.10 TRM 7.1.1, Item B	LCOActionTSAS 3.4.11.baTRMAS 3.7.10aTRM 7.1.1, ItemaBB	LCOActionEquipmentTSAS 3.4.11.baPzr Vent SolenoidsTRMAS 3.7.10aSee AlLTRM 7.1.1, ItemaP18B B

OD COMPENSATO	PRY ACTIONS / T	emp LOGS (Bold: Tecl	h Specs, Italics: TRM	1)	
None					

EVOLUTIONS IN PROGRESS & NOTES	Reference/Date
Holding power @ 28% for turnover. "A" MFW Pump operating, "A" Condensate Pump, GP 7 CEAs at	OPS/Today
152 steps. Xenon building in. Diluting 20 gals every 15 minutes.	
Bus 24E is aligned to Bus 24D to allow for planned maintenance on "C" RBCCW Pump	OPS/Today

Unit 2 Chemistry ON-LINE STATUS REPORT

REACTOR COOLAN	r	<u>Time 06:25</u>		
Parameter	Reading	Parameter	Reading	
Power	100 %	Fluoride	0.81 ppb	
Tave	545 deg F	Chloride	1.75 ppb	
Boron	1175 ppm	Oxygen	<5 ppb	



÷

SIMULATOR EXAM GUIDE SUMMARY OF CHANGES

1. Modified per NRC review comments. Removed the initial "Normal" action and replaced it with a "Component" malfunction.

Page 2 of 26

SIMULATOR EXAM GUIDE TABLE OF CONTENTS

SECTIONS LISTED IN ORDER

- 1. Exam Overview
- 2. Scenario Initial Conditions Sheet
- 3. Exam Guide
- 4. Exam Guide Summary
- 5. Follow-up Questions
 - Attachments
- 1. Validation Checklists
- 2. Shift Turnover Sheet
- 3. Scenario Attribute Checklist

EXAM OVERVIEW

Title: LOUT 2003 Simulator Exam #2

ID Number: ES03LU2

Revision: 1

1. Purpose:

,

This examination is used to evaluate crew/individual performance in the simulator to satisfy the requirements of NUREG 1021 for SRO-U applicants. To meet these requirements, this exam is designed to:

- a. Evaluate the licensees' ability, as a team and individually, to respond to an emergency event.
- b. Evaluate licensees in the following areas:
 - 1) Ability of the crew to perform crew-dependent critical tasks.
 - 2) Ability of individuals to perform critical tasks.
 - 3) Ability of each applicant to:
 - a) Respond and correctly interpret annunciators
 - b) Correctly diagnose events
 - c) Properly interpret integrated system response
 - d) Comply with and use Technical Specifications
 - e) Comply with and use procedures
 - f) Demonstrate a responsible attitude
 - g) Properly communicate information and interact with the rest of the crew

EXAM OVERVIEW

Title: LOUT 2003 Simulator Exam #2

ID Number: <u>ES03LU2</u>

Revision: 1

2. Exam brief:

The simulator and room will be prepared for the exam.

- 1. The Simulator will be initialized at IC-24, 100% power, MOL, or an equivalent IC.
- 2. "B" Charging Pump is tagged to prevent automatic start.
- 3. Bus 24E is aligned to bus 24D to allow for "C" HPSI Pump work later today.

Shortly after the Crew takes the watch, Main Feed Flow transmitter on #2 SG will begin to fail low. This will result in a slow rise in SG level requiring the selection of the Alternate Feed Flow transmitter to mitigate. Alternatively, the #2 SG Main FRV can be controlled in manual until level is stabilized at setpoint, at which time the Alternate Feed Flow transmitter can be selected and the system returned to auto.

Approximately 2 minutes after the SG level control failure has been mitigated, Channel 'Y' of Reactor Reg will fail. The crew will respond to the failure by entering the applicable ARPs for pressurizer level.

When the required actions to stabilize pressurizer level and pressure have been completed, the #1 SIT will develop a nitrogen leak requiring entry into Technical Specifications.

When the crew has completed logging TSAS 3.5.1, action b, the Main Control Valves will ramp close causing a rapid rise in RCS pressure and temperature. When the control valves close, the steam dump valves will NOT receive a 'quick open' signal (previous Reactor Reg. Failure) resulting in a continued rise in RCS temperature and pressure. The reactor will fail to automatically trip on high RCS pressure requiring a manual reactor trip.

As a result of the trip, a Steam Generator Tube Rupture will occur on #2 S/G. As a result of the high RCS pressure, a Pressurizer Safety will stick partially open. Additionally, the RSST will be lost and the "A" DG breaker will fail to close resulting in the need to emergency trip the "A" DG and the loss of vital bus 24C.

The crew should perform the actions of EOP 2525, Standard Post Trip Actions, and diagnose a LOCA with a SGTR on the #2 S/G. This will require entry in EOP 2540, Functional Recovery.

The crew will determine that Containment Integrity is NOT met and must implement EOP 2540E, Functional Recovery of Containment Isolation.

During the performance of EOP 2540E, The "C" Service Water Pump will trip, requiring the crew to start the "B" Service Water Pump on Facility 2.

The scenario may be terminated when #2 SG is isolated.

 Plant/Simulator differences that may affect the scenario are: None

4. Duration of Exam: <u>1.5</u> hours.

,

 \sim

SIMULATOR EXAM GUIDE SCENARIO INITIAL CONDITIONS

Title: LOUT 2003 Simulator Exam #2

ID Number: ES03LU2

,

Revision: 1

Out of Service Equipment

"B" Charging Pump

Crew Instructions

Maintain the plant at 100% power, steady state.

SIMULATOR EXAM GUIDE

Title: LOUT 2003 Simulator Exam #2

ID Number: ES03LU2

.

Revision: 1

All Control Room Conduct, Operations and Communications shall be in accordance applicable Unit Procedures.

"Review the Simulator Operating Limits (design limits of plant) and the Simulator Modeling Limitations and Anomalous Response List prior to performing this exam scenario on the simulator. The evaluators should be aware if any of these limitations may be exceeded." (NSEM 6.02)

1 [°]		Simula	tor Exam Guide				
($\langle \cdot \rangle$			<	
Title:	LOUT 2003 Sim	nulator Exam #2		ID Number	<u>ES03LU2</u>	Revision:	1
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expecte	ed Actions	S	tandard
To		Initial Conditions					
		Initialize the simulator to IC-24, 100% power, MOL, simulator in run.					
Γο	EDR14 (RO)	Bus 24E is powered from bus 24D.					
	EDR15 (RI) SWR22 (22F)	Ensure all loads powered from bus 24E are properly aligned to Facility 2.					
Γ _ο	ED02 BT 1	Insert malfunction to cause a loss of the RSST when the reactor is tripped.					
Fo	EG08A	"A" DG output breaker fails to close on the LNP.				ТМ	EM
Γo	RC05A (15%) BT 21	A Pressurizer Safety valve sticks partially open after the trip.				ТМ	EM MA
Гo	RP28D RP28E	Failure of RPS to automatically trip on low SG level or high RCS				ТМ	EM

 RP28E
 on low SG level or high RCS

 RP28H
 pressure.

 T₀
 SG02B (20%)

 SGTR in #2 SG on the trip.

 BT 1

Simulator Exam Guide							
({	
Title:	LOUT 2003 Sim	nulator Exam #2		ID Number	ES03LU2	Revision: <u>1</u>	
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expecte	ed Actions	Standard	
Τo		Using the turnover sheet, brief the "oncoming" US. In addition to the Turnover Sheet, provide the following:					
		The plant is at 100% power and has been at 100% power for the past 9 months.					
		RCS Boron concentration is 820 ppm with a blend ratio of 6.3:1.					
		Bus 24E is being supplied by bus 24D in preparation for removing "C" HPSI Pump from service for inspection later today. All other conditions are normal.					
		When you are ready to take the shift, please inform me.					
T ₁	RX10C (50%) 300 Sec.	Shortly after Crew takes the watch, insert a malfunction to slowly fail the Main Feed Flow Transmitter low.	Inst.			ТМ	
			US/SPO	Observe rising water le Note: The ARP for SG should be referenced a to verify actions taken a	vel in #2 SG. Level Hi/Lo (C05 A t some time by the are correct and com	8) Crew iplete.	
			US	Direct SPO to take MAI FRV and stabilize or se Transmitter.	NUAL control of #2 elect Alternate Feed	SG I Flow	
			SPO	Performs above actions	s as directed by US		

- 2

ſ	Simulator Exam Guide							
Title:	LOUT 2003 Sin	nulator Exam #2	λ	ID Number <u>ES03LU2</u> Revisi	on: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
			US	Note failure of Main Feed Flow Transmitter and (if not already done so) direct SPO to select Alternate Feed Flow Transmitter.				
			US	Once level is stabilized and failed transmitter is deselected, return FRV control to auto if required				
			US	Direct/Notify I&C of Feed Control System failure.				
T2	RX6B (0) Ramp = 180 sec.	Once FRV control failure is mitigated and system has been returned to automatic control, insert malfunction for a failure of channel 'Y' of Reactor Reg.	Crew	 Observe indications and diagnose a failure of the channel 'Y' Tave calculator. Lowering Tave reading on Channel 'Y'. Annunciators on C-02/3 to include: PRESSURIZER CH X LEVEL HI/LO (A38) PRESSURIZER CH Y LEVEL HI/LO (A39) PZR PRESSURE SELECTED CHANNEL DEVIATION HI/LO (D37) 	MP-14-OPS- GDL02 and various ARPs TM AE			
			US	Direct the PPO to take manual control of Letdown Flow Controller, HIC-110 and restore Letdown to 40 gpm.	ARP 2590B			
			PPO	Place HIC-110 in manual and lower Letdown flow to 40 gpm.	ARP 2590B			
			US	Direct the PPO to perform either of the following:1. Commence forcing sprays2. Place Backup heaters in Pull-To-Lock.	ARP 2590B			
			PPO	 Performs either: Places all Backup Heaters in Pull-To-Lock Lowers Pressurizer pressure controller to obtain a 50% output on the controller. 	ARP 2590B			

ſ	Simulator Exam Guide							
Title:	LOUT 2003 Sim	ulator Exam #2	X	ID Number <u>ES03LU2</u> Revisio	on: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
			US	Direct the PPO to shift Reactor Reg to Channel 'X'.	ARP 2590B			
			PPO	Places Reactor Reg switch in Channel 'X'.	ARP 2590B			
		The US may decide to continue forcing sprays.	US	When pressurizer level is restored to 65%, direct the PPO to return HIC-110 to automatic and to restore pressurizer pressure control to normal.	ARP 2590B			
			PPO	 Shifts HIC-110 to automatic and performs one of the following: Returns the pressurizer pressure controller to the previous set point and secures the backup heaters Removes backup heaters from Pull-To- 	AOP 2590B			
Τ ₃	SI03A (100%)	When pressurizer pressure and level are returned to normal, insert a malfunction for a Nitrogen leak on #1 SIT.	PPO	Lock. Observe and report value and trend of pressure on #1 SIT along with SAFETY INJECTION TANK 1 PRESS LO annunciator.	MP-14-OPS- GDL02 and various ARPs TM AE			
			US	Direct PPO to perform the following:	ARP 2590A			
				 Ensure level indicates between 55.2 and 59.7% Ensure Leakage Drain Stop, SI-618, closed. Attempt to determine the cause of the low pressure. 				

	Simulator Exam Guide							
(((
Title:	LOUT 2003 Sim	<u>ulator Exam #2</u>		ID Number <u>ES03LU2</u> Revisio	on: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
T4	TC06A-D (10%)	When the US has logged into TSAS 3.5.1, insert a malfunction to	PPO US Crew	 PPO reports: Ensure level indicates between 55.2 and 59.7% Ensure Leakage Drain Stop, SI-618, closed. Attempt to determine the cause of the low pressure. Request maintenance to investigate the cause of the low SIT pressure Log into TSAS 3.5.1. Observe rising RCS temperature, rising RCS pressure, and numerous annunciators. 	ARP 2590A ARP 2590A MP-14-OPS- GDL02			
	00 000. ramp	close.	Crew	Observe RCS pressure rising to the trip set point and a failure to automatically trip.	MA MP-14-OPS- GDL02			
		SPTA-5: Manually shutdown the reactor. This action may be performed by the PPO WITHOUT direction from the US.	US	Direct the PPO to manually trip the plant and the crew to perform EOP 2525, Standard Post Trip Actions.	MP-14-OPS- GDL02 CT			
			US	Place Master Alarm Silence in SILENCE. Announce "Unit 2 trip" on the plant paging system.	OP 2260			
			US	Begin querying board operators on the status of EOP 2525.	EOP 2525			

((Simulator Exam Guide						
Title:	LOUT 2003 Sim	ulator Exam #2		ID Number <u>ES03LU2</u> Revisio	on: <u>1</u>		
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard		
			PPO	Complete and report SPTA for PPO per EOP 2525:	EOP 2525		
				 Ensures Reactivity safety function is being met: Reactor is tripped All CEAs are inserted Power is going down. SUR is negative. 			
				 Verifies RCS Inventory and Pressure safety functions are being met (Reports Letdown is isolated, all available Charging Pumps are running, a Pressurizer Safety indicates open, and SIAS has actuated on Facility 2.) 			
				 Verifies Core Heat Removal established. NO RCPs are operating due to loss of RSST. 			
				 Verifies Containment Integrity safety function is being met by verifying CTMT pressure, temperature, and rad monitor readings. 			
				Observes CTMT temperature and pressure rising; rad monitors in CTMT are in alarm and rising; all other rad monitors are normal.	-		
				 Performs and reports completion of subsequent actions. 			

	Simulator Exam Guide							
(((
Title:	LOUT 2003 Sim	<u>ulator Exam #2</u>		ID Number <u>ES03LU2</u> Revisi	on: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
			SPO	Completes SPTA for SPO per EOP 2525 correctly:	EOP 2525			
				- Vital Auxiliaries are satisfied:				
				The Main Turbine is tripped All main stop valves are closed Megawatts are zero 8T & 9T are open				
				Reports that a loss of RSST has occurred Buses 25A and B are deenergized Buses 24A and B are deenergized "A" DG breaker failed to close, bus 24C is deenergized				
				 Bus 24D is energized by its respective diesel generator. 				
				- Buses 201A and B are energized.				
				- Buses VA-10 and VA-20 are energized.				
			SPO	 Verifies RCS heat removal (S/G pressures and RCS Tave). 	EOP 2525			
				 Verifies S/G feed established by starting Aux feedwater. 				
				 Reports unusual rise in #2 SG level with NO (or very little) feed flow. 				
	А.			 Performs and reports completion of subsequent actions. 				
	EGR16 (RESET)	If directed as a PEO, acknowledge D/G alarms, then reset local alarms.	SPO	Requests PEO to check out the D/Gs.	MP-14-OPS- GDL02			
	IAR10 (OPEN)	When directed as a PEO to cross-tie Station Air with U-3, then perform actions to crosstie Station Air.	SPO	Requests PEO to cross-tie SA with U-1	EOP 2525			

	Simulator Exam Guide							
(ζ				ζ.	
Title:	LOUT 2003 Sim	nulator Exam #2		ID Number	<u>ES03LU2</u>	Revisio	n: <u>1</u>	
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions			Standard	
		If the unusual rise in #2 SG is initially missed or determined to be 'not significant enough to warrant attention', the US may direct entry into EOP 2532, LOCA. When the unusual rise is determined to be indicative of a SGTR, the US will transition to EOP 2540.	US	Use the Diagnostic Flow Reactivity Safety Fur At least 1 vital AC bu energized (same trai NO RCPs are operat Adequate flow to Ste Pressurizer pressure lowering. SG pressures are gr lowering subcooling. CTMT pressure is gr rising. CTMT Rad monitors EOP 2532) Other SGTR indicati flow mismatch and u	w Chart: nction is met. is and one DC are n) ting (Consider EO eam Generators e is less than 1850 eater than 800 psi reater than 1 psig are going up (Con ons: feed flow – st inusual rise in #2 5 0, Functional Reco	P 2528) and is a with and nsider ieam SG level.	EOP 2525	
				based on LOCA and S	GTR.	ad in		
		EAL classification may be asked as a follow-up question after the exam is complete.	SM	RCB3, RCB4, or EA1			FAP06-002	
			US	Place Master Alarm sil	ence switch in NO	RMAL.	EOP 2540	
			US	Enter the time on the S Page.	Safety Function Tra	acking	EOP 2540	
			US	Ensure SIAS has been following:	i initiated and direct	ct the	EOP 2540	
				MANUAL and close	ed.			
				- Ensure HIC-4165 is	s in MANUAL and	closed.		

,

ĺ	Simulator Exam Guide						
Title:	LOUT 2003 Sir	nulator Exam #2	ч.	ID Number <u>ES03LU2</u> Revisio	n: <u>1</u>		
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard		
			US	Direct the SPO to open the Steam Generator sample valves and direct Chemistry to sample both Steam Generators for Boron and activity.	EOP 2540		
		Approximately 20-30 minutes after a request is made to sample both SGs for activity, report as Chemist:	SPO	 Open both Steam Generator sample valves. Direct Chemistry to sample both Steam Generators for Boron and activity, frisk the 	EOP 2540		
		#1 SG - <mda< td=""><td></td><td>samples and report the frisk results.</td><td></td></mda<>		samples and report the frisk results.			
Τ ₆		#2 SG – 250 cpm above background.		 When the frisk results are reported, obtain concurrence form the US and close the Steam Generator sample valves. 			
	SW01C	While the SPO is performing steps to obtain SG samples, insert a malfunction to trip the "C" Service Water Pump.	SPO	Observe indications of a loss of Facility 2 Service water.	MP-14-OPS- GDL02		
				- SW PUMP C OVERLOAD/TRIP annunciator.	TM EM		
				 "B" Service Water header low flow. Report loss of Service Water. 			
		MVA2: Energize at least one vital electrical AC bus.	US	Direct SPO to start "B" Service Water Pump on Facility 2.	MP-14-OPS- GDL02 AOP 2565		
					CT AE		
			SPO	Start "B" Service Water Pump on Facility 2, place "C' Service Water Pump hand switch in Stop, and report restoration of Service Water.	MP-14-OPS- GDL02 AOP 2565		
			US	Direct the PPO to place both Hydrogen analyzers in operation per Appendix 19.	EOP 2540		

(Simula	ator Exar	n Guide						, (
Title:	LOUT 2003 Sir	nulator Exam #2	λ,	ID	Numb	oer <u>E</u>	S03LU2	R	evisio	on: <u>1</u>
Time	IDA/Malf	Instructor Information / Activity	Task Assign		Ехр	ected	Actions			Standard
		The US will determine that Containment Integrity, CI-1, acceptance criteria are NOT met and immediately enter EOP 2540E.	US	With the assi prioritize the Name RC-1 MVA-DC-1 MVA-AC-2 IC-2 PC-2 Containmen priority.	stance succes SAFI Met Y Y Y Y t Integ	e of the ss path ETY FL Equip Y Y Y Y grity, C	crew, ident is to be use JNCTION Name HR-2 CI-1 CTPC-2 CCGC-1	tify and d: Met E Y <u>N</u> Y Y	Equip Y Y Y Y	EOP 2540
	CVR09 (RI)	When requested, rack in "B" Charging Pump breaker on Facility 2.	US	 Ensure SIAS, CIAS EBFAS, and MSI have actuated. Direct the following: Ensure all required Facility 2 components are in their accident condition. Ensure at least one train of Control Room Air Conditioning is in recirc. Ensure facility vital switchgear cooling is operating. 				s are n Air	EOP 2540E EC	

(Simulator Exam Guide							
				D Number 5000110 Devisio	· · · · · · · · · · · · · · · · · · ·			
l itle:	LOUT 2003 Sin	nulator Exam #2		ID Number <u>ES03L02</u> Revisio	n: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
			PPO / SPO	To ensure Facility 2 CRAC is in recirc, perform the following:	EOP 2540E			
				 F21B Exhaust Damper, HV 203B is open. CRACS Supply Fan, F21B is running. F31B Exhaust Damper, HV 206B, is open. CRACS Exhaust Fan, F31B, is running. F32B Exhaust Damper, HV 212B, is open. CRACS Filter Fan, F32B, is running. Fresh Air Makeup Damper, HV 495 is closed. Exhaust Air Damper, HV-496, is closed Cable Vault Exhaust Damper, HV-497 is closed. 				
		HR-7: Perform a plant cooldown.	US	Direct the SPO to initiate a cool down at the maximum controllable rate to a Th of <515°F using the ADVs.	EOP 2541, Appendix 12 CT EC			
			SPO	Commence a cool down by throttling open both ADVs.	EOP 2541, Appendix 12			
			US	 Direct the PPO to depressurize the RCS while maintaining the following parameters: RCS pressure less than 920 psia Within 50 psia of #2 S/G 	EOP 2541, Appendix 12			
			PPO	 vvitnin the contines of the P/T curve. Operate Pressurizer heaters and auxiliary spray to ensure RCS pressure is maintained within the directed parameters. 	EOP 2541, Appendix 12			

Ć	Simulator Exam Guide							
Title:	LOUT 2003 Sin	nulator Exam #2	X .	ID Number <u>ES03LU2</u> Revision	n: <u>1</u>			
Time	IDA/Malf	Instructor Information / Activity	Task Assign	Expected Actions	Standard			
		HR-6: Isolate the affected or most affected Steam Generator.	US	When both hot leg temperatures are less than 515°F, then direct the SPO to:	EOP 2541, Appendix 12			
				 Record the time and Tc in the operating loop. Isolate the #2 S/G per step 6 of EOP 2541, Appendix 12. 	СТ			
	MSR13 (RI)	When directed, close the disconnect for MS-202.	US/SPO	Direct a PEO to close the disconnect for Steam Supply to the Turbine Driven Aux Feed Pump, 2- MS-202.				
			SPO	 Ensure #2 ADV is in AUTO and closed with a set point of 920 psia. 	EOP 2541, Appendix 12			
				 Ensure #2 MSIV is closed. Ensure #2 MSIV Bypass Valve is closed. Close Main Feed Reg Valve Bypass Valve, 2- FW-41B. 				
				 Ensure Main Feedwater Block Valve, 2-FW- 42B, is closed. 				
				 Ensure Feedwater Reg Valve, 2-FW-51B is closed. 				
				 Place Main Feed Isolation Air Assist Check Valve, 2-FW-5B, in CLOSE. 				
				 Ensure SG Blowdown Isolation Valve, 2-MS- 220B, is closed. 				
				 Place both Aux Feed OVERRIDE/MAN/STRART/RESET hand switches are in Pull-To Lock. 				
				9. Close Aux Feed Reg Valve, 2-FW-43B.				
				10. Place Aux Feed Isolation Air Assist Check Valve, 2-FW-12B, to CLOSE.				
				11. Close the Steam Suppl;y Valve to the Turbine				
				Page 20 o	f26			

,

	<u>`</u>	n: <u>1</u>	Standard				EOP 2541, Appendix 12	
		Revisic		oi	'n	are closed.	herator	
		ES03LU2	d Actions	ump, 2-MS-20	ain, 2-MS-266	Safety Valves	#2 Steam Gei psia.	
		ID Number	Expecte	en Aux Feed Pu	e Low Point Dr	ck Main Steam	PO to maintain e less than 920	
am Guide			-	Drive	12. Clos	13. Cheo	Direct SI pressure	
ator Exa	\smile		Task Assigr				SN	
Simul		#2	Information / Activity					may be terminated ew has completed Steam Generator.
		Simulator Exam #	Instructor I					The session when the cre isolating #2
		LOUT 2003 (IDA/Malf					
	\rightarrow	Title:	Time					

Page 21 of 26

.

EXAM GUIDE SUMMARY

Title: LOUT 2003 Simulator Exam #2

ID Number: ES03LU2

Revision: 1

I. Critical Tasks

1. SPTA-5: Manually shutdown the reactor.

BASES: If the reactor is not shutdown all safety functions may be in jeopardy

2. MVA2: Energize at least one vital electrical AC bus

BASES: Loss of vital AC bus is a significant reduction in safety margin.

3. CI-1: Maintain Containment Isolation.

BASES: Failure to adequately isolate the containment in the event of a failure of the RCS and fuel cladding fission product barriers, may increase the potential for release to the environment.

4. HR-7: Perform a plant cooldown.

BASES: If steam generator heat removal is inadequate, then another form of core and RCS heat removal must be implemented to prevent degradation of the fuel cladding barrier to fission product release.

5. HR-6: Isolate the affected or most affected Steam Generator.

BASES: Isolation of the affected Steam Generator is assumed in the Safety Analysis. Failure to identify the most affected Steam Generator can result in the inability to isolate the most affected Steam Generator and reestablish the barrier to fission release.

EXAM GUIDE SUMMARY - (Continued)

III. FOLLOW-UP QUESTIONS

1. What was the classification for this event at the completion of EOP 2525?

Answer: Classify event as an Alert/C-1 based on BS1 RCB2 (or RCB4) or EA1.

RCB2 - RCS subcooling < 30°F.

RCB4 - Reactor coolant leak > CVCS capacity and entry into EOP 2525, Standard Post Trip Actions.

EA1 – Failure of automatic reactor trip and manual trip was successful.

SIMULATOR EXAM GUIDE VALIDATION CHECKLIST

Title: LOUT 2003 Simulator Exam #2

ID Number: ES03LU2

Initial Conditions:

The initial condition(s) contained in the guide are certified or have been developed from certified ICs.

Test Run:

The scenario contained in the guide has been test run on the simulator. Simulator response is reasonable and as expected.

Simulator Operating Limits:

The simulator guide has been evaluated for operating limits and/or anomalous response.

For Examination Scenario:

The Scenario Attributes Checklist is complete and attached. This is not required for Progress Review Exams

Action Complete

Verified By:

1

Revision:



SIMULATOR GUIDE REUSE APPROVAL CHECKLIST

Title: LOUT 2003 Simulator Exam #2

÷

ID	Number:	ES03LU2	Revision:	<u>1</u>
Re	eview of Sim	ulator Exam Guide		Verified (Initials)
•	The proced support the	lure references used in this guide are appropriat learning objectives.	te and -	NA
•	There are r impact the	no simulator model changes that would negative reuse of this guide.	ly _	NA
•	There are r the reuse o	no simulator discrepancies that would negatively of this guide.	r impact	NA
•	Validation,	if necessary, has been accomplished.	-	NA

Authorization for reusing this Simulator Exam Guide

NA		NA
	Operator Training Branch Supervisor	Date

Page 25 of 26

SIMULATOR EXAM GUIDE SCENARIO ATTRIBUTES CHECKLIST

ID Number: <u>ES03LU2</u>

Revision: <u>1</u>

Date:

Technical Reviewer:

SIMULATOR EXAM GUIDE SCENARIO ATTRIBUTES CHECKLIST

1. Total Malfunctions (TM) - Include EMs - 5 to 8 required	Total <u>9</u>
2. Malfs after EOP entry (EMs) - 1 to 4 required	Total <u>6</u>
3. Abnormal Events (AE) - 2 to 4 required	Total <u>4</u>
4. Major Transients (MA) - 1 to 2 required	Total <u>4</u>
5. EOPs Used (EU) beyond primary scram response - 1 to 2 required	Total1
6. EOP Contingencies/Transitions (EC) - 0 to 2 required	Total 2
7. Crew Critical Task (CT)- 2 to 3 required	Total <u>4</u>
8. Approximate Scenario Run Time: 60 to 90 min.	Total <u>90</u>
9. EOP run time: 40 to 70 percent of scenario run time	Total <u>60</u>
Technical Specifications are exercised during the scenario.	(Y/N) <u>Y</u>

FOR TRAINING USE ONLY

DATE Toda	E-TIME y 0515	PREPARED BY Unit Supervisor /"NIGHT" Shift	SHIFT 18:00 - 06:00	
PLANT STATUS:				
MODE:	1	RX POWER:	<u>100</u> %	
MEGAWATTS:	Thermal: <u>2699</u> MWTH	PZR PRESS:	<u>2250</u> psia	
	Electric: 903 MWe	RCS T-AVE:	572 degrees F	
RCS LEAKAGE:	Identified: 0.005 gpm	PROTECTED:	Train/Facility	
	Unidentified: 0.036 gpm		72 (VELLOW)	
	Date/Time: Today 0015		<u>L2 (IELLOW)</u>	

TS LCO and TRM ACTION Statements Coming Due (if more than one ACTION requirement per LCO, list each separately)

Date	Time	LCO	Action	Action Requirement	Equipment	Reason
3/20/03	0900	TRMAS 7.1.1,	С	With P18B inoperable for >60 days,	P18B,	Compliance with
		Item B		prepare an Engineering evaluation for	"B" Charging	Charging System OD
				continued operation. Engineering	Pump	
				assessment carried on OD No. MP2-043-		
				03 for 60 day TRM requirement.		

Continuous TS LCO and TRM ACTION Statements in effect (if more than one ACTION requirement per LCO, list each separately)

Action Requirement	LCO	Action	Equipment	Reason
Maintain the inoperable vent path closed with power removed from the valves. Maintain one PORV and block valve OPERABLE.	TSAS 3.4.11.b	a	Pzr Vent Solenoids	Manually isolated due to leakage (2-RC-440 is closed).
Infinite action: Establish hourly fire watch.	TRMAS 3.7.10	a	See AIL	See Active Impairment List.
Item B: Ensure P18C is operable from C10 and perform b.1 and b2 for Fire Area R-4	TRM 7.1.1, Item B	a	P18B	Compliance with Charging System OD

OD COMPENSATORY ACTIONS / Temp LOGS (Bold: Tech Specs, Italics: TRM)

None

EVOLUTIONS IN PROGRESS & NOTES	Reference/Date
None	

Unit 2 Chemistry ON-LINE STATUS REPORT

REACTOR COOLAN	Г	<u>Time_06:25</u>		
Parameter	Reading	Parameter	Reading	
Power	100 %	Fluoride	0.81 ppb	
Tave	545 deg F	Chloride	1.75 ppb	
Boron	821 ppm	Oxygen	<5 ppb	