

From: Rebecca Nease *RN*  
 To: ~~WPC~~ Alexion, Thomas; Bongarra, James; Bywater, Russ; Chamberlain, Dwight;  
 Dixon-Herrity, Jennifer; Eckenrode, Richard; Frumkin, Daniel; Gody, Tony; Gramm, Robert; Gwynn,  
 Pat; Hannon, John; Howell, Art; IQBAL, Naeem; Marschall, Charles; Parry, Gareth; Pruett, Troy;  
 Qualls, Phil; Reinhart, F. Mark; Salley, Mark; Sanborn, Gary; Smith, Karla; Smith, Linda; Tschiltz,  
 Michael; Wong, See-Meng  
 Date: 7/14/03 3:46PM  
 Subject: Add'l info from ANO

NRC Reg Conf Attendees,

Attached is a list of items we requested the licensee provide to us. I intend to include this with the meeting summary. Please review them to make sure I worded the requests as you meant them to be. If you have any questions or comments, you may respond to this e-mail, or call me at 817-860-8154.

*I/13*

ANO REGULATORY CONFERENCE QUESTIONS

The following are what, in the regulatory conference, we asked the licensee to provide. Please review and confirm:

EX 5



From: Thomas Alexion *NR-R*  
 To: Rebecca Nease *R-V*  
 Date: 7/14/03 4:33PM  
 Subject: Re: Add'l info from ANO

Rebecca,

My comments are as follows:

1. I had an addition subpart for the licensee to address the effect of thermoplastic cables to safely S/D Unit 2.
2. I had additional subparts to also provide the timeline for operator actions, and to provide the raw simulator data and evaluator sheets.
3. I thought the list was supposed to be for all cables in the area.
4. I had an additional subpart to address why the particular coating was chosen.

But I will defer to SPLB on these comments.

Tom

>>> Rebecca Nease 07/14/03 03:46PM >>>  
 NRC Reg Conf Attendees,

*R-V*

Attached is a list of items we requested the licensee provide to us. I intend to include this with the meeting summary. Please review them to make sure I worded the requests as you meant them to be. If you have any questions or comments, you may respond to this e-mail, or call me at 817-860-8154.

CC: Mark Salley