Mr. Michael A. Krupa, Director Nuclear Safety & Licensing Entergy Operations, Inc. 1340 Echelon Parkway Jackson, MS 39213-8298

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 (WATERFORD 3) -RELAXATION REQUEST FROM U.S. NUCLEAR REGULATORY COMMISSION (NRC) ORDER EA-03-009 FOR THE CONTROL ELEMENT DRIVE MECHANISM NOZZLES (TAC NO. MB9644)

Dear Mr. Krupa:

By letter dated September 15, 2003, as supplemented by letters dated September 26, October 2, October 8, and October 24, 2003, Entergy Operations, Inc. (Entergy, the licensee) requested relaxation to implement an alternative to the requirements of Section IV, Paragraph C.(1)(b)(i), of the Order for all control element drive mechanism (CEDM) nozzles at Waterford 3. The September 15, 2003, relaxation request superseded a request made on June 11, 2003.

Specifically, pursuant to the process specified in Section IV, Paragraph F of the Order, you requested relaxation from the requirement specified in Section IV, Paragraph C, Item (1)(b)(i), to instead perform inspections using a three-step alternative, which involves the use of an analysis technique, ultrasonic testing, and augmented surface examination.

The NRC staff has completed its review and concludes that the proposed alternative examination of the reactor pressure vessel (RPV) head provides reasonable assurance of structural integrity of the head. Further inspection of the head penetrations in accordance with Section IV.C.(1)(b)(i) of the Order would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. Thus, you have demonstrated good cause for the requested relaxation. Therefore, pursuant to Section IV, Paragraph F of the Order and 10 CFR 50.55a(a)(3)(ii), I authorize, for one operating cycle commencing with the startup from the fall 2003 refueling outage, the proposed alternative inspection for all CEDM head penetration nozzles at Waterford 3, subject to the following condition:

If the NRC staff finds that the crack-growth formula in MRP-55 is unacceptable, Entergy shall revise its analysis that justifies relaxation of the Order within 30 days after the NRC informs Entergy of an NRC-approved crack-growth formula. If Entergy's revised analysis shows that the crack growth acceptance criteria are exceeded prior to the end of the operating cycle [operating cycle 13], which follows the current refueling outage, this relaxation is rescinded and Entergy will, within 72 hours, submit to the NRC written justification for continued operation. If the revised analysis shows that the crack growth acceptance criteria growth acceptance criteria are exceeded during the subsequent operating cycle, Entergy shall, within 30 days, submit the revised analysis for NRC review. If the revised analysis shows that the crack growth acceptance criteria are not exceeded during either the

upcoming operating cycle or the subsequent operating cycle, Entergy shall, within 30 days, submit a letter to the NRC confirming that its analysis has been revised. Any future crack-growth analyses performed for the upcoming operating cycle and future cycles for RPV head penetrations will be based on an NRC-acceptable crack growth rate formula.

The staff's related Safety Evaluation (SE) is enclosed.

Pursuant to 10 CFR 2.790 as stated in the Title 10 of the *Code of Federal Regulations*, we have determined that the enclosed SE does not contain proprietary information. However, we will delay placing the SE in the public document room for 10 working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects only. If you believe that any information in the enclosure is proprietary, please identify such information line by line and define the basis pursuant to the criteria of 10 CFR 2.790.

Be aware that when vessel head inspections are performed using American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code) requirements, acceptance criteria, or qualified personnel, those activities and all related activities fall within the jurisdiction of the ASME Code. Therefore, Order-related inspection activities may be subject to third party review, including those by the Authorized Nuclear Inservice Inspector.

Sincerely,

/RA/

Herbert N. Berkow, Director Project Directorate IV Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Safety Evaluation

cc w/encl: See next page

upcoming operating cycle or the subsequent operating cycle, Entergy shall, within 30 days, submit a letter to the NRC confirming that its analysis has been revised. Any future crack-growth analyses performed for the upcoming operating cycle and future cycles for RPV head penetrations will be based on an NRC-acceptable crack growth rate formula.

The staff's related Safety Evaluation (SE) is enclosed.

Pursuant to 10 CFR 2.790 as stated in the Title 10 of the *Code of Federal Regulations*, we have determined that the enclosed SE does not contain proprietary information. However, we will delay placing the SE in the public document room for 10 working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects only. If you believe that any information in the enclosure is proprietary, please identify such information line by line and define the basis pursuant to the criteria of 10 CFR 2.790.

Be aware that when vessel head inspections are performed using American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code) requirements, acceptance criteria, or qualified personnel, those activities and all related activities fall within the jurisdiction of the ASME Code. Therefore, Order-related inspection activities may be subject to third party review, including those by the Authorized Nuclear Inservice Inspector.

Sincerely,

/RA/ Herbert N. Berkow, Director Project Directorate IV Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDIV-1 r/f RidsOgcRp RidsAcrsAcnwMailCenter RidsNrrLADJohnson (2) RidsRgn4MailCenter (AHowell) RidsNrrPMNKalyanam RidsNrrDlpmLpdiv1 (RGramm) SBloom

RDavis

Package: ML033160192 Accession No.: ML033160183 Safety Evaluation: ML033160198

*See previous concurrence

OFFICE	PDIV-1/PM	PDIV-1/LA	EMCB/SC*	OGC* (NLO with noted edits)	PDIV-1/SC	PDIV-1/D
NAME	NKalyanam	MMcAllister	TChan	MYoung	RGramm	HBerkow
DATE	11-12-03	11/12/03	11/10/03	11/10/03	11/12/03	11/12/03

OFFICIAL RECORD COPY

Waterford Steam Electric Station, Unit 3

cc:

Mr. Michael E. Henry, State Liaison Officer Department of Environmental Quality Permits Division P.O. Box 4313 Baton Rouge, Louisiana 70821-4313

Vice President, Operations Support Entergy Operations, Inc. P. O. Box 31995 Jackson, MS 39286-1995

Director Nuclear Safety Assurance Entergy Operations, Inc. 17265 River Road Killona, LA 70066-0751

Wise, Carter, Child & Caraway P. O. Box 651 Jackson, MS 39205

General Manager Plant Operations Waterford 3 SES Entergy Operations, Inc. 17265 River Road Killona, LA 70066-0751

Licensing Manager Entergy Operations, Inc. 17265 River Road Killona, LA 70066-0751

Winston & Strawn 1400 L Street, N.W. Washington, DC 20005-3502

Resident Inspector/Waterford NPS P. O. Box 822 Killona, LA 70066-0751 Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, TX 76011

Parish President Council St. Charles Parish P. O. Box 302 Hahnville, LA 70057

Executive Vice President & Chief Operating Officer Entergy Operations, Inc. P. O. Box 31995 Jackson, MS 39286-1995

Chairman Louisiana Public Services Commission P. O. Box 91154 Baton Rouge, LA 70825-1697

Joseph E. Venable Vice President Operations Entergy Operations, Inc. 17265 River Road Killona, LA 70066-0751