

Pamela F. Faggert Vice President and Chief Environmental Officer 5000 Dominion Boulevard, Glen Allen, VA 23060 Phone: 804-273-3467

<u>Certified Mail</u> <u>Return Receipt Requested</u>

November 7, 2003

Mr. Jeffrey S. Talbot DEQ – Northern Regional Office 13901 Crown Court Woodbridge, VA 22193-1453

RE: North Anna Power Station - VPDES Permit Exceedance

Dear Mr. Talbot:

This is to confirm our verbal report of an exceedance of the effluent limitations in our VPDES permit for North Anna Power Station.

The concentration of free available chlorine in the bearing cooling tower blowdown (Outfall 105) is limited to a maximum of 0.5 mg/l and a monthly average of 0.2 mg/l. The average concentration of free available chlorine for October 2003 was determined to be 0.36 mg/l. Only one sample was collected during the month. Station personnel did not run the test for manganese interference for this chlorine sample which, historical data indicate, would have lowered the actual chlorine value considerably.

An investigation by station personnel failed to reveal the cause of the high reading. Both the bearing cooling tower and chlorine feed system were being operated in accordance with established procedures. Once the exceedance was realized, a sample was taken to ensure the tower was in compliance at this time and the free available chlorine value was less than the QL.

The bearing cooling tower blowdown has a long history of compliance with the VPDES limitations. Since station personnel were not able to determine any irregularity in operations, this is believed to be an isolated incident. Procedures have been instituted to prevent a similar incident from occurring again.

If you have any questions or desire additional information, please contact Ron Birckhead at (804) 273-2992.

Sincerely,

Pamela F. Faggert

CODI

cc:

U. S. Nuclear Regulatory Commission Region II Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, GA 30303 RE: North Anna Units 1 and 2 Docket Nos. 50-338/50-339

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

License Nos. NPF-4/NPF-7

RE: North Anna Units 1 and 2 Docket Nos. 50-338/50-339 License Nos. NPF-4/NPF-7

Mr. M.J. Morgan NRC Senior Resident Inspector North Anna Power Station