

James R. Becker Vice President-Diablo Canyon Operations and Station Director Diablo Canyon Power Plant P.O. Box 56 Avila Beach, CA 93424

805.545.3462 Fax: 805.545.4234

November 5, 2003

PG&E Letter DCL-03-142

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80 Docket No. 50-323, OL-DPR-82 Diablo Canyon Units 1 and 2 <u>Response to NRC Request for Additional Information Regarding License</u> <u>Amendment Request 03-06, "Revision to Technical Specification 3.8.1,</u> <u>'AC Sources - Operating'"</u>

Dear Commissioners and Staff:

Pacific Gas and Electric (PG&E) Letter DCL-03-060, dated May 29, 2003, submitted License Amendment Request (LAR) 03-06, "Revision to Technical Specification 3.8.1, 'AC Sources - Operating,'" which would extend the completion time for restoring an inoperable diesel generator from 7 days to 14 days.

On August 25, 2003, the NRC staff requested additional information required to complete their review of LAR 03-06. PG&E's responses to the staff's questions are provided in Enclosures 1, 2, 3, and 4.

This additional information does not affect the results of the technical evaluation and no significant hazards consideration determination previously transmitted in PG&E Letter DCL-03-060.

If you have any questions or require additional information, please contact Stan Ketelsen at (805) 545-4720.

Sincerely, James R. Becker

jer/3664 Enclosures

PG&E Letter DCL-03-142



Document Control Desk November 5, 2003 Page 2

cc: Edgar Bailey, DHS Bruce S. Mallett David L. Proulx Diablo Distribution cc/enc: Girija S. Shukla

PG&E Letter DCL-03-142

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

In the Matter of) PACIFIC GAS AND ELECTRIC COMPANY)

Diablo Canyon Power Plant Units 1 and 2 Docket No. 50-275 Facility Operating License No. DPR-80

Docket No. 50-323 Facility Operating License No. DPR-82

<u>AFFIDAVIT</u>

James R. Becker, of lawful age, first being duly sworn upon oath states that he is Vice President Operations and Station Director - Diablo Canyon of Pacific Gas and Electric Company; that he has executed this supplement to License Amendment Request 03-06 on behalf of said company with full power and authority to do so; that he is familiar with the content thereof; and that the facts stated therein are true and correct to the best of his knowledge, information, and belief.

James R. Becker Vice President Operations and Station Director - Diablo Canyon

Subscribed and sworn to before me this 5th day of November 2003.

Notary Public

County of San Luis Obispø State of California



Enclosure 1 PG&E Letter DCL-03-142

PG&E Response to NRC Request for Additional Information Regarding License Amendment Request 03-06, "Revision to Technical Specification 3.8.1, 'AC Sources - Operating'"

NRC Question 1

Discuss and provide information on the reliability and availability of offsite power sources relating to the proposed change. The discussion should include duration, cause, date and time of each loss-of-offsite power (partial or complete) event. In addition, discuss the current reliability of all DGs at Diablo Canyon.

PG&E Response to Question 1 on Offsite Power Sources

Summary

Operating Procedure OP J-2:VIII, "Guidelines for Reliable Transmission Service for DCPP," includes the operating instructions for the transmission system contained in Pacific Gas and Electric (PG&E) Transmission System Operating Instruction O-23, "Operating Instructions for Reliable Transmission Service for Diablo Canyon P. P." The boundaries of jurisdiction and extent of control of these procedures are the same as listed in the Diablo Canyon Power Plant (DCPP) Final Safety Analysis Report Update (FSARU) Section 8.2, "Offsite Power System." See attached Figures 1 and 2. In the figures, the boundary of procedural control is at the Midway and Gates Substations and includes:

- 500 kV transmission lines from DCPP to Midway and Gates, and
- 230 kV transmission lines from DCPP to Midway and Gates. In the year 2000 the Morro Bay–Gates No. 1 Line was renamed Morro Bay-Templeton, and Templeton-Gates.

Table 1, "Availability History," summarizes the number of minutes and percentage of time that each line was available each year. Table 2, "Maintenance Outage History," provides the maintenance outage summary for October 2000 to September 9, 2003. Availability is not calculated for 1999 or January through August 2000 because of the lack of maintenance data in the PG&E Outage Coordination Database. Table 3, "Forced Outage History," lists the forced outage summary from January 1, 1999, through September 9, 2003.

For the period from January 1, 1999, through September 9, 2003, there have been no events that caused a complete loss of offsite power from the transmission systems supplying DCPP. During that period there was one incident on the 500 kV system and two incidents on the 230 kV system where power was interrupted from the transmission system. One event at DCPP Unit 1 on May 15, 2000, is characterized as a complete loss of offsite power to that unit. This event was due to an internal 12 kV bus fault that resulted in a loss of both offsite power connections to the 4 kV safety loads for

33.6 hours. During this time both the 500 kV and 230 kV transmission systems were available and Unit 2 remained in operation. (Reference PG&E Letter DCL-00-115, "Licensee Event Report 1-2000-004-01, Unit 1 Unusual Event Due to a 12kV Bus Fault," dated August 30, 2000).

500 kV System

On September 22, 1999, lightning struck the static ground wire protecting the tie line from Unit 1 to the 500 kV switchyard. No damage was sustained. The tie line remained deenergized for 8.2 hours. (Reference PG&E Letter DCL-99-118, "Licensee Event Report 1-1999-006-00, Reactor Trip Due to Lightning Strike," dated October 15, 1999). A follow-on event occurred on September 23, 1999, when the tie line was reenergized and tripped due to a cut-in 500 kV overvoltage protective relay with a trip signal picked up. (Reference PG&E Letter DCL-99-131, "Licensee Event Report 1-1999-008-00, Engineered Safety Feature Actuation - Auxiliary Feedwater Pump 1-1 Started on 12 kV Undervoltage Due to Personnel Error," dated October 22, 1999). The tie line remained deenergized for 6.1 hours while the event was analyzed. Unit 2 was not affected by this event.

230 kV System

On April 5, 2001, a prescribed burn in Diablo Canyon, east of the plant, generated heavy smoke that caused both 230 kV lines to trip. Offsite power from the 230 kV system was restored after 1.2 hours. Both units remained in operation during this event. (Reference PG&E Letter DCL-01-065, "Licensee Event Report 1-2001-001-00, Automatic Emergency Diesel Generator Start Upon Loss of Startup Power Due to 230 kV Line Arcing in Heavy Smoke from Escaped Fire Caused by Inadequate Administrative Controls," dated June 4, 2001).

On August 4, 2001, a fault on the grounding transformer fuse box for the 230/12 kV Startup Transformer 1-1 caused a loss of startup (230 kV) power to both units. Power was restored to the Unit 2 startup bus on August 5, 2001 (13.8 hour outage). Power was restored to the Unit 1 startup bus on August 6, 2001 by a crosstie to Unit 2 (44.0 hour outage). Full restoration was completed on August 22, 2001. Both units remained in operation during this event. (Reference PG&E Letter DCL-01-099, "Licensee Event Report 1-2001-002-00, System Actuation: Unplanned Diesel Start Due to Loss of Startup Power," dated October 4, 2001).

Discussion

Forced outage data for offsite power sources has been collected and reported for 5 years: 1999-2003. The five-year period is based on the following considerations.

In 1996 PG&E discovered that there were 47 past instances where the 230 kV system may have been degraded. (PG&E Letter DCL-96-158, "Licensee Event Report

1-95-007-01, 230 kV System May Not Be Able to Meet its Design Requirements for All Conditions Due to Personnel Error," dated August 6, 1996.) Corrective actions were taken over the next several years to improve the 230 kV system. On April 29, 1999, the NRC issued License Amendments No. 132 (Unit 1) and No. 130 (Unit 2) to incorporate modifications to the 230 kV offsite power system. The changes included installation of two new 230/12 kV startup transformers with automatic load tap changers, and capacitor banks at Diablo 230 kV and Mesa 115 kV switchyards. Figure 1 shows a single line diagram of the 230 kV system. The purpose of these changes was to improve the reliability of the 230 kV offsite power system and prepare for deregulation in California. By starting the reporting in 1999, this encompasses the period of implementation of the 230 kV system improvements, the California energy crisis years of 2000 and 2001, and the initial period of PG&E bankruptcy.

Table 4, "Transmission Forced Outage Data," lists the detailed outage data. Note that the reported forced outage data includes an entry for Outage Class = "N" (None) - "zero outage." This is an entry for a transmission line that had zero outages for that year. Table 5, "Primary and Secondary Outage Cause Codes, Outage Class Codes," lists the outage class and cause codes.

DCPP FSARU Section 8.2, "Offsite Power System," states that the minimum requirements for operable 500 kV and 230 kV offsite systems are:

- Either 230 kV circuit feeding DCPP, and
- One 500 kV circuit feeding DCPP.

In addition, the capacitors at DCPP and Mesa, along with the 230/12 kV startup transformers with automatic load tap changers enable the 230 kV transmission system to be independent of Morro Bay generation. FSARU Section 8.2.1.1, "230-kV System," identifies the occurrences that could result in a loss of power to the 230/12 kV startup transformers.

The only forced outage event related to the 230/12 kV startup transformers is discussed above under the 230 kV System. Routine maintenance of the transformers and their automatic load tap changers is performed during unit outages and controlled under the outage safety plan issued for each outage.

There were no forced outages of the capacitors at the Diablo 230 kV switchyard. There were two forced outage events involving the capacitors at the Mesa 115 kV substation.

• On September 16, 1999, at 13:20 PDT, a single capacitor faulted on a string of capacitors in C phase at Mesa. The single capacitor was replaced and returned to service in approximately 24 hours.

• On October 13, 1999, at 18:49 PDT, a fault in C phase caused severe damage to 3 capacitors (out of 20), a potential transformer, a resistor pack and collateral damage to bus and conductors. The capacitors were returned to service after a 36 day outage.

Both faults were limited to one-half of the installed 50 megavolt-ampere reactive (MVAR) capacity. Although 25 MVAR remained in service, procedurally the entire capacitor bank is considered out of service during this event. During these forced outages, the 230 kV supply to DCPP remained operable. Detailed data on the forced and maintenance outages of the capacitors at Mesa and Diablo are listed at the end of Tables 4 and 5.

The PG&E Transmission Operations Center in conjunction with the California Independent System Operator (CAISO) controls the operability of the transmission lines serving DCPP. The Diablo Canyon Control Center (Switchyard) personnel use common procedures with DCPP Operations to administer the operability of the transmission lines. PG&E and CAISO criteria control the periods for maintenance. Maintenance is typically performed when the system can allow the maintenance outage and the next contingency. Table 6, "Transmission Line Maintenance Outage Data," lists the maintenance outage data from November 1, 2000, through September 9, 2003. Maintenance data for 1999 and for January through October 2000 is not available in the PG&E Outage Coordination database.

It is important to note that during the "California energy crisis" of 2000 and 2001, the offsite power supplies into Diablo Canyon remained stable and reliable. Even when generation reserves dropped below the 7 percent level¹, the transmission systems serving DCPP remained stable due to system load control and selective load shedding. The CAISO did not allow elective maintenance during these years. Any transmission line maintenance was performed with the lines energized.

Since August of 1996, when problems in Oregon set off a chain of events that caused outages throughout California and other western states, PG&E has made many improvements to its electric transmission system. They include:

- Transmission substation equipment that boosts voltage and prevents oscillation,
- Sophisticated computer-based systems that sense abnormalities and disturbances and instantly correct for them,
- Major upgrades to and reinforcement of the transmission system PG&E has invested about \$1.4 billion since 1996 to expand capacity and improve reliability of the grid, and

¹ CAISO declares a Stage 1 Emergency when reserves drop to 7 percent, Stage 2 at 5 percent, and Stage 3 at 1.5 percent.

• Greater coordination of load shedding plans with the 14 western states, two Canadian provinces and the parts of northern Mexico under the Western Electricity Coordinating Council regional transmission umbrella.

The Oregon event discussed above occurred on August 10, 1996, and caused a 500 kV system transient that resulted in both DCPP units tripping off-line. However, the 230 kV system was available to safely shutdown the units. Subsequent to the 1996 event, PG&E installed generator out-of-step protection for each unit. The purpose is to protect the turbine-generator during severe grid transients. This protective function increases the likelihood of tripping the units and transferring to the 230 kV system during severe grid transients. However, the 230 kV and 500 kV switchyards are not inter-connected at DCPP. Consequently the loss of DCPP generation has negligible impact on the 230 kV voltage.

Enclosure 1 PG&E Letter DCL-03-142

Figure 1

Geographic Layout Of 500 And 230 kV Transmission Lines & Substations



6





7

Enclosure 1 PG&E Letter DCL-03-142

Table 1 Availability History

		199	1999 *		2000 *		2001		2002		2003**	
Voltage	Line_ID	minutes	% of yr	minutes	% of yr	minutes	% of yr	minutes	% of yr	minutes	% of yr	
500	Diablo-GatesNo1	N/A		N/A		525600	100.000%	525600	100.000%	525600	100.000%	
500	Diablo-MidwayNo2	N/A		N/A		525600	100.000%	524866	99.860%	525180	99.920%	
500	Diablo-MidwayNo3	N/A		N/A		525561	99.993%	524719	99.832%	524880	99.863%	
230	Diablo-Mesa	N/A		N/A		525554	99.991%	524773	99.843%	523380	99.578%	
230	MorroBay-Diablo	N/A		N/A		525555	99.991%	525600	100.000%	525600	100.000%	
230	MorroBay-GatesNo1	N/A		N/A		N/A	N/A	N/A	N/A	N/A	N/A	
230	MorroBay-GatesNo2	N/A		N/A		525600	100.000%	524027	99.701%	525360	99.954%	
230	MorroBay-Mesa	N/A		N/A		525600	100.000%	524700	99.829%	524099	99.714%	
230	MorroBay-MidwayNo1	N/A		N/A		525585	99.997%	523860	99.669%	524819	99.851%	
230	MorroBay-MidwayNo2	N/A		N/A		523925	99.681%	523019	99.509%	524879	99.863%	
230	MorroBay-Templeton	N/A		N/A		525600	100.000%	525600	100.000%	525600	100.000%	
230	Templeton-Gates	N/A		N/A		525600	100.000%	525600	100.000%	522599	99.429%	

* Availability History is not calculated for 1999 or 2000 because of the lack of maintenance data in the PG&E Outage Coordination Database ** For 2003, data covers the period through September 9, 2003.

Enclosure 1 PG&E Letter DCL-03-142

	1999 *		99 *	2000 *		2001		2002		2003**	
Voltage	Line_ID	minutes	% of yr								
500	Diablo-GatesNo1	N/A		0	0.0000%	0	0.0000%	0	0.0000%	0	0.0000%
500	Diablo-MidwayNo2	N/A		0	0.0000%	0	0.0000%	360	0.0685%	420	0.0799%
500	Diablo-MidwayNo3	N/A		0	0.0000%	0	0.0000%	0	0.0000%	720	0.1370%
230	Diablo-Mesa	N/A		0	0.0000%	0	0.0000%	660	0.1256%	2220	0.4224%
230	MorroBay-Diablo	N/A		0	0.0000%	0	0.0000%	0	0.0000%	0	0.0000%
230	MorroBay-GatesNo1	N/A		N/A							
230	MorroBay-GatesNo2	N/A		0	0.0000%	0	0.0000%	1320	0.2511%	240	0.0457%
230	MorroBay-Mesa	N/A		0	0.0000%	0	0.0000%	900	0.1712%	1500	0.2854%
230	MorroBay-MidwayNo1	N/A		0	0.0000%	0	0.0000%	1740	0.3311%	780	0.1484%
230	MorroBay-MidwayNo2	N/A		0	0.0000%	0	0.0000%	2580	0.4909%	720	0.1370%
230	MorroBay-Templeton	N/A		0	0.0000%	0	0.0000%	0	0.0000%	0	0.0000%
230	Templeton-Gates	N/A		0	0.0000%	0	0.0000%	0	0.0000%	3001	0.5710%

Table 2Maintenance Outage History

* Data for 1999 and January through August 2000 was not available in the PG&E Outage Coordination Database

** For 2003, data covers the period through September 9, 2003.

Į

Table 3 Forced Outage History

{	1	19	1999		00	2001		2002		2003*	
Voltage	Line_ID	minutes	% of yr								
500	Diablo-GatesNo1	48	0.0091%	429	0.0814%	0	0.0000%	0	0.0000%	0	0.0000%
500	Diablo-MidwayNo2	43	0.0082%	0	0.0000%	0	0.0000%	374	0.0712%	0	0.0000%
500	Diablo-MidwayNo3	161	0.0306%	160	0.0304%	39	0.0074%	881	0.1676%	0	0.0000%
230	Diablo-Mesa	0	0.0000%	29	0.0055%	46	0.0088%	167	0.0318%	0	0.0000%
230	MorroBay-Diablo	144	0.0274%	0	0.0000%	45	0.0086%	0	0.0000%	0	0.0000%
230	MorroBay-GatesNo1	0	0.0000%	N/A	_N/A	N/A	N/A	N/A	N/A	N/A	N/A
230	MorroBay-GatesNo2	0	0.0000%	0	0.0000%	0	0.0000%	253	0.0481%	0	0.0000%
230	MorroBay-Mesa	360	0.0685%	1	0.0002%	0	0.0000%	0	0.0000%	1	0.0002%
230	MorroBay-MidwayNo1	359	0.0683%	58	0.0110%	15	0.0029%	0	0.0000%	1	0.0002%
230	MorroBay-MidwayNo2	0	0.0000%	805	0.1527%	1675	0.3187%	1	0.0002%	1	0.0002%
230	MorroBay-Templeton	N/A	N/A	303	0.0575%	0	0.0000%	0	0.0000%	0	0.0000%
230	Templeton-Gates	N/A	N/A	0	0.0000%	0	0.0000%	0	0.0000%	0	0.0000%

* For 2003, data covers the period through September 9, 2003.

ĺ

Voltage Class	Line_ID	Outage Start Date	Outage Start Time	DUR (Min)	Outage End Date	Outage End Time	Outage Class	Primary Cause	Secondary Cause	Comments
500	Diablo-GatesNo1	1/13/1999	23:35	46	1/14/1999	0:21	F	PROT	NONE	Diablo CBs 622 & 722 relayed by transfer trip - cutout channel "C" transfer trip relays.
500	Diablo-GatesNo1	9/22/1999	12:41	2	9/22/1999	12:43	F	LIGT	NONE	Unknown - lightning.
500	Diablo-GatesNo1	1/15/2000	9:39	429	1/15/2000	16:48	귀	CNTM	INSL	De-energized wash of contaminated "V" string insulators on towers 67/176 to 72/297.
500	Diablo-GatesNo1	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
500	Diablo-GatesNo1	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage
500	Diablo-MidwayNo2	1/7/1999	9:53	43	1/7/1999	10:36	न	OPER	NONE	Relay test error while working on Midway CB 912 breaker failure relay.
500	Diablo-MidwayNo2	1/1/2000	0:00	0	1/1/2000	0:00	N	NONE	NONE	zero outage
500	Diablo-MidwayNo2	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
500	Diablo-MidwayNo2	2/9/2002	3:37	374	2/9/2002	9:51	F	SEQP	NONE	Open ended when feed pump regulator valve unexpectedly closed.
500	Diablo-MidwayNo3	8/19/1999	13:44	161	8/19/1999	16:25	F	FIRE	COND	Structure fire started grass fire that burned through conductor between 17/66 and 17/67 - CDF delayed restoration.
500	Diablo-MidwayNo3	1/13/2000	5:23	98	1/13/2000	7:01	F	СВ	NONE	To remove Midway CB 802 from service due to loss of all air pressure.
500	Diablo-MidwayNo3	11/25/2000	6:38	62	11/25/2000	7:40	F	DIST	NONE	Out of section trip (Midway- Vincent #3-500kV line trouble).

.

ł.

Voltage Class	Line_ID	Outage Start Date	Outage Start Time	DUR (Min)	Outage End Date	Outage End Time	Outage Class	Primary Cause	Secondary Cause	Comments
500	Diablo-MidwayNo3	5/31/2001	20:48	39	5/31/2001	21:27	F	SEQP	ARRS	Trip occurred when Midway #11- 500/230 kV bank failed.
500	Diablo-MidwayNo3	7/24/2002	14:48	97	7/24/2002	! 16:25	F	СВ	NONE	Open ended when Midway CB 902 was forced out to repair the compressor regulator.
500	Diablo-MidwayNo3	11/15/2002	10:10	784	11/15/2002	23:14	F	LEQP	NONE	Forced out due to failure of PT insulator column.
230	Diablo-Mesa	1/1/1999	0:00	0	1/1/1999	0:00	N	NONE	NONE	ZERO OUTAGE
230	Diablo-Mesa	3/24/2000	12:22	1	3/24/2000	12:23	F	СВ	NONE	Mesa CB 212 forced out of service to adjust hydraulic pump control governor.
230	Diablo-Mesa	3/24/2000	13:07	28	3/24/2000	13:35	F	СВ	NONE	Mesa 212 out of service to adjust hydraulic pump control governor
230	Diablo-Mesa	4/5/2001	15:10	46	4/5/2001	15:56	F	FIRE	NONE	Control burn under line.
230	Diablo-Mesa	12/16/2002	9:36	1	12/16/2002	9:37	F	OPER	NONE	Relayed when conductor came out of fitting, contacted CT cover on CB 212 "A" Phase.
230	Diablo-Mesa	12/16/2002	12:37	166	12/16/2002	15:23	F	OPER	NONE	Forced out to repair conductor that came out of fitting, contacted CT cover on CB 212 "A" Phase.
230	MorroBay-Diablo	5/3/1999	22:49	143	5/4/1999	1:12	F	LATE	INSL	Applied additional silicone to CB 612 at MB, washing and replace support insulators.
230	MorroBay-Diablo	9/22/1999	12:41	1	9/22/1999	12:42	F	PROT	RELY	Diablo Canyon CB 262 relayed and reclosed OK with power remaining on line.
230	MorroBay-Diablo	1/1/2000	0:00	0	1/1/2000	0:00	N	NONE	NONE	zero outage

•

Voltage	Line_ID	Outage	Outage	DUR (Min)	Outage End	Outage	Outage	Primary	Secondary	Comments
Class		Start Date	Time	()	Date	Time	Class	Cause	Cause	
230	MorroBay-Diablo	4/5/2001	15:10	45	4/5/2001	15:55	F	FIRE	NONE	Control burn under line.
230	MorroBay-Diablo	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage
230	MorroBay-GatesNo1	1/1/1999	0:00	0	1/1/1999	0:00	N	NONE	NONE	zero outage
230	MorroBay-GatesNo2	1/1/1999	0:00	0	1/1/1999	0:00	N	NONE	NONE	zero outage
230	MorroBay-GatesNo2	1/1/2000	0:00	0	1/1/2000	0:00	N	NONE	NONE	zero outage
230	MorroBay-GatesNo2	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
230	MorroBay-GatesNo2	1/24/2002	7:03	253	1/24/2002	11:16	F	LEQP	NONE	Forced out to permanently jumper out Sw 247 that was burning
230	MorroBay-Mesa	5/1/1999	6:19	41	5/1/1999	7:00	F	UNKN	NONE	Line relayed, 0700 started pre- scheduled line work. 1512 tested OK (temp jumpers at MB).
230	MorroBay-Mesa	5/7/1999	7:48	318	5/7/1999	13:06	F	UNKN	INSL	Replaced flashed and broken insulators due to trouble 5/1/99 - Temp Jumpers MB.
230	MorroBay-Mesa	12/4/1999	11:17	1	12/4/1999	11:18	F	OPER	NONE	Mesa CB's 172, 182, 202, 222 relayed, reclosed OK by breaker failure during work on CB 212.
230	MorroBay-Mesa	2/11/2000	22:12	1	2/11/2000	22:13	F	PROT	RELY	Mesa CB 222 relayed due to out of section fault.
230	MorroBay-Mesa	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
230	MorroBay-Mesa	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage
230	MorroBay-Mesa	7/30/2003	5:45	1	7/30/2003	5:46	F	LIGT	NONE	Relayed, tested OK; no interruptions, lightning in area.
230	MorroBay-MidwayNo1	5/1/1999	6:19	41	5/1/1999	7:00	F	UNKN	NONE	Line relayed, 0700 started pre- scheduled line work. 1512 tested OK temp jumpers at MB.

Table 4 Transmission Forced Outage Data 1/1/1999 through 9/9/2003

2

Voltage Class	Line_ID	Outage Start Date	Outage Start Time	DUR (Min)	Outage End Date	Outage End Time	Outage Class	Primary Cause	Secondary Cause	Comments
230	MorroBay-MidwayNo1	5/7/1999	7:48	318	5/7/1999	13:06	F	UNKN	INSL	Replaced flashed and broken insulators due to trouble of 5/1/99 - temp. jumper MB.
230	MorroBay-MidwayNo1	11/26/2000	7:57	58	11/26/2000	8:55	F	PROT	NONE	Open ended at Midway due to CB 572 breaker failure relay misoperation.
230	MorroBay-MidwayNo1	1/11/2001	10:12	1	1/11/2001	10:13	F	LIGT	NONE	Unknown - lightning.
230	MorroBay-MidwayNo1	2/13/2001	9:32	14	2/13/2001	9:46	F	СВ	NONE	Unusual snow & Morro Bay CB 522 failed to close by autos
230	MorroBay-MidwayNo1	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage
230	MorroBay-MidwayNo1	7/30/2003	5:17	1	7/30/2003	5:18	F	LIGT+J2	None	Relayed, tested OK; no interruptions, lightning in area
230	MorroBay-MidwayNo2	1/1/1999	0:00	0	1/1/1999	0:00	N	NONE	NONE	zero outage
230	MorroBay-MidwayNo2	12/21/2000	19:02	805	12/22/2000	8:27	F	СВ	RELY	Open ended at Morro Bay to repair hydraulic leak on CB 522.
230	MorroBay-MidwayNo2	2/13/2001	9:40	237	2/13/2001	13:37	F	СВ	СВ	Snow; repaired Morro Bay CB 522.
230	MorroBay-MidwayNo2	10/23/2001	19:56	1438	10/24/2001	19:54	F	SEQP	INSL	Cleaned flashed insulators and adjusted Midway switch 545.
230	MorroBay-MidwayNo2	2/11/2002	16:42	1	2/11/2002	16:43	F	СВ	NONE	Momentarily open ended at Morro Bay when Midway #11-500/230 Bk relayed, did not test.
230	MorroBay-MidwayNo2	7/30/2003	5:17	1	7/30/2003	5:18	F	LIGT	None	Relayed, tested OK; no interruptions, lightning in area.
230	MorroBay-Templeton	2/11/2000	22:12	117	2/12/2000	0:09	F	WEAT	COND	Patrol found 115 kV undercrossing top phase conductor contacted bottom phase 230 kV.

.

Voltage Class	Line_ID	Outage Start Date	Outage Start Time	DUR (Min)	Outage End Date	Outage End Time	Outage Class	Primary Cause	Secondary Cause	Comments
230	MorroBay-Templeton	6/14/2000	9:26	186	6/14/2000	12:32	F	LEQP	HDWR	Cleared to replace compression sleeve at tower 0/1.
230	MorroBay-Templeton	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
230	MorroBay-Templeton	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage
230	Templeton-Gates	1/1/2000	0:00	0	1/1/2000	0:00	N	NONE	NONE	zero outage
230	Templeton-Gates	1/1/2001	0:00	0	1/1/2001	0:00	N	NONE	NONE	zero outage
230	Templeton-Gates	1/1/2002	0:00	0	1/1/2002	0:00	N	NONE	NONE	zero outage

•		anif eninge enabe een	oo, oalage elace couc.	
PRIMARY CAUSE TRANSLATION TABLE	E		SECONDARY CAUSE	
PG&E Outage	CAISO Outage	CAISO Outage	CAISO & PG&E Outage	CAISO & PG&E Outage
Root Cause Detail	Primary Cause	Primary Cause Code	Secondary Cause	Secondary Cause Code Description
	Code*	Description	Code*	
Animal-bird	ANIM	Animal Contact	ARRS	Arrestor
Animal-ground	ANIM	Animal Contact	AUX	Station auxiliary equip (e.g., CT, PT, CCVT)
Contamination-agriculture	CNTM	Contamination	BATT	Battery system
Contamination-animal waste	CNTM	Contamination	BUSH	Bushing
Contamination-environmental	CNTM	Contamination	СВ	Circuit breaker/Circuit switch
Contamination-industrial waste	CNTM	Contamination	COMM	Communication facility (no relay)
Disaster-earthquake	ND	Natural Disasters	COND	Conductor/shield wire/splice
Disaster-fire	FIRE	Fire	DISC	Disconnect
Disaster-flood	ND	Natural Disasters	ENCR	Encroachment
Disaster-other	ND	Natural Disasters	GUYS	Guy/anchor
Equipment Failure-arrestor	SEQP	Other Substation Equip	HDWR	Hardware, fittings, accessories
Equipment Failure-bus	SEQP	Other Substation Equip Trouble	INSL	Insulator (station/line)
Equipment Failure-bushing	SEQP	Other Substation Equip Trouble	LS	Line switch
Equipment Failure-ccvt	SEQP	Other Substation Equip Trouble	NONE	None
Equipment Failure-circuit breaker	СВ	Circuit Breaker Trouble	REAC	Reactive device (e.g., capacitors, condensers)
Equipment Failure-conductor	LEQP	Line Equipment Failure	REG	Regulator
Equipment Failure-connector/hardware	LEQP	Line Equipment Failure	RELY	Relay/communications for relay
Equipment Failure-CT	SEQP	Other Substation Equip Trouble	STRU	Structure/foundation
Equipment Failure-insulator-line	LEQP	Line Equipment Failure	XFRM	Transformer/LTC
Equipment Failure-insulator-station	SEQP	Other Substation Equip Trouble	UG	Underground transmission component
Equipment Failure-other-line	LEQP	Line Equipment Failure	PROC	Work Procedure/Human error
Equipment Failure-other-station	SEQP	Other Substation Equip		
Equipment Failure-PT	SEQP	Other Substation Equip	*NOTE: Reference is the No. 2 entitled "Outage	California ISO Maintenance Procedure
Equipment Failure-reactive equipment	SEQP	Other Substation Equip	Performance Monitoring	System", effective date 5/27/99, pages 2-8
Equipment Failure-regulator/LTC	SEQP	Other Substation Equip		
Equipment Failure-relay	PROT	Protection	— I	

Table 5Primary and Secondary Outage Cause Codes, Outage Class Codes

ĺ

•

FIIII	ary and Second	lary Oulage Gause Coues,	Outage Glass Goues)			
PRIMARY CAUSE TRANSLATION TABLE			SECONDARY CAUSE				
PG&E Outage	CAISO Outage	CAISO Outage	CAISO & PG&E Outage	CAISO & PG&E Outage			
Root Cause Detail	Primary Cause	Primary Cause Code	Secondary Cause	Secondary Cause Code Description			
	Code*	Description	Code*				
Equipment Failure-structure-line	LEQP	Line Equipment Failure	I				
Equipment Failure-structure-station	SEQP	Other Substation Equip	OUTAGE CLASS	3			
Equipment Failure-switch-line	LEQP	Line Equipment Failure	C Capped (at a 72 ho	ur outage)			
Equipment Failure-switch-station	SEQP	Other Substation Equip	Forced Outage				
Equipment Failure-transformer	SEQP	Other Substation Equip					
External Contact-aircraft	AIR	Aircraft					
External Contact-car pole	VEH	Vehicles					
External Contact-foreign object	OTHR	Other					
External Contact-system disturbance	DIST	System Disturbance		· · · · · · · · · · · · · · · · · · ·			
External Contact-vandalism	OTHR	Other					
Other-customer/IPP caused	OTHR	Other					
Other-distribution caused	UC	Utility Contact	1				
Other-generation caused	GEN	Generation Trouble					
Other-overload situation	DIST	System Disturbance					
Other-safety clearance	OTHR	Other					
Scheduled-approved	SCHD	Scheduled Outage					
Scheduled-disapproved	LATE	Late Notification					
Scheduled-extended	LATE	Late Notification		· · · · · · · · · · · · · · · · · · ·			
Tree-3rd party	OTHR	Other					
Tree-failure	VEGA	Vegetation					
Tree-tree contact	VEGA	Vegetation					
Unknown-no patrol conducted	UNKN	Unknown					
Unknown-patrol found nothing	UNKN	Unknown					
Weather-lightning	LIGT	Lightning					
Weather-rain	WEAT	Weather		·····			
Weather-snow/ice	WEAT	Weather					
Weather-wind	WEAT	Weather					
Work Procedure-design error	OPER	Operation Error	· · · · · · · · · · · · · · · · · · ·	l			
Work Procedure-equipment incorrectly set	OPER	Operation Error		· · · · · · · · · · · · · · · · · · ·			
Work Procedure-inattention or carelessness	OPER	Operation Error					
Work Procedure-miscommunications or unclear	OPER	Operation Error		l			
expectations							
Work Procedure-not following prescribed procedures	OPER	Operation Error					

 Table 5

 Primary and Secondary Outage Cause Codes, Outage Class Codes

1

Table 6 Transmission Line Maintenance Outage Data 11/1/2000 through 9/9/2003

Line Name	Voltage	Clearance Boundary	Actual Out Time	Actual Return Time	Duration (minutes)
Diablo-Midway #2	500	Midway 813, 913; Diablo 643, 741	03/14/2002 04:03	03/14/2002 10:03	360
Diablo-Midway #2	500	911, 913	06/03/2003 08:06	06/03/2003 15:06	420
Diablo-Midway #3	500	Midway 801, 901; Diablo 633, 733	03/06/2003 06:03	03/06/2003 18:03	720
Morro Bay-Gates #2	230	Morro Bay 483, 485; Gates 223, 225	05/15/2002 07:05	05/15/2002 12:05	300
Morro Bay-Gates #2	230	Morro Bay 483, 485; Gates 223, 225	07/23/2002 07:07	07/23/2002 16:07	540
Morro Bay-Gates #2	230	Morro Bay 483, 485; Gates 223, 225	07/24/2002 07:07	07/24/2002 15:07	480
Morro Bay-Gates #2	230	Morro Bay 483, 485; Gates 223, 225	06/11/2003 09:06	06/11/2003 13:06	240
Morro Bay-Mesa	230	Morro Bay 543, 545; Mesa 223, 225	05/22/2002 07:05	05/22/2002 15:05	480
Morro Bay-Mesa	230	Morro Bay 543, 545; Mesa 223, 225.	12/03/2002 07:12	12/03/2002 14:12	420
Morro Bay-Mesa	230	Mesa 223, 225; Morro Bay 543, 545	05/21/2003 08:05	05/21/2003 17:05	540
Morro Bay-Mesa	230	Mesa 223, 225; Morro Bay 543, 545	05/22/2003 08:05	05/22/2003 16:05	480
Morro Bay-Mesa	230	Morro Bay 223, 225; Mesa 543, 545	06/03/2003 07:06	06/03/2003 15:06	480
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 533, 535	06/24/2002 07:06	06/24/2002 17:06	600
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 533, 535	06/25/2002 07:06	06/25/2002 16:06	540
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 533, 535	06/26/2002 10:06	06/26/2002 14:06	240
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 533, 535	11/18/2002 08:11	11/18/2002 14:11	360
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 537, 539	07/15/2003 00:07	07/15/2003 07:07	420
Morro Bay-Midway #1	230	Morro Bay 513, 515; Midway 537, 539	07/15/2003 23:07	07/16/2003 05:07	360
Morro Bay-Midway #2	230	Morro Bay 525, 523; Midway 543, 545	03/18/2002 07:03	03/18/2002 15:03	480
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549, CB 542 and T-Tap	06/18/2002 07:06	06/18/2002 16:06	540
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549, CB 542 and T-Tap	06/19/2002 07:06	06/19/2002 16:06	540
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549, CB 542 and T-Tap	06/20/2002 07:06	06/20/2002 16:06	540
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549, CB 542 and T-Tap	06/21/2002 07:06	06/21/2002 15:06	480
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549	07/15/2003 00:07	07/15/2003 07:07	420
Morro Bay-Midway #2	230	Morro Bay 523, 525; Midway 547, 549	07/16/2003 00:07	07/16/2003 05:07	300

Table 6 Transmission Line Maintenance Outage Data 11/1/2000 through 9/9/2003

Line Name	Voltage	Clearance Boundary	Actual Out Time	Actual Return Time	Duration (minutes)
Diablo-Mesa	230	Diablo 283, 285; Mesa 213, 215	10/17/2002 07:10	10/17/2002 15:10	480
Diablo-Mesa	230	Diablo 283, 285; Mesa 277, 201, 287	12/16/2002 12:12	12/16/2002 15:12	180
Diablo-Mesa	230	Diablo 283, 285; Mesa 213, 215.	08/26/2003 09:08	08/27/2003 15:08	1800
Diablo-Mesa	230	Diablo 283, 285; Mesa 213, 215	09/19/2003 08:09	09/19/2003 15:09	420
Templeton-Gates	230	Gates 217, 219; Templeton 293	03/25/2003 08:03	03/25/2003 20:03	720
Templeton-Gates	230	Gates 217, 219; Templeton 293	04/30/2003 11:04	05/01/2003 16:05	1741
Templeton-Gates	230	Templeton 293; Gates 213, 215	06/12/2003 08:06	06/12/2003 17:06	540

PG&E Response to Question 1 on Diesel Generator Reliability

Reliability of the DCPP diesel generator (DGs) can be addressed in three ways; (1) DG hours unavailable due to planned and unplanned events, (2) DG failures to meet starting requirements on demand, and (3) maintenance related failures requiring a DG or related system to be placed in 10 CFR 50.65(a)(1) (Maintenance rule goal setting) status. DG hours unavailable is addressed in the regulatory assessment performance indicator (PI) data reported guarterly to the NRC in accordance with NEI 99-02, "Regulatory Assessment Performance Indicator Guideline," Revision 2, dated November 2001. The PI values for the DCPP DGs for the period from the third quarter, 2001 through the second quarter, 2003 range from 0.7 percent to 0.9 percent for Unit 1 and from 0.5 percent to 0.6 percent for Unit 2. Actual planned and unplanned unavailable hours and PI values for the last eight guarters are shown in Table 7, "Unit 1 Safety System Unavailability, Emergency AC Power," and Table 8, "Unit 2 Safety System Unavailability, Emergency AC Power." The PI values are well below "Increased Regulatory Response Band" threshold of 2.5 percent specified by NEI 99-02. The DG PI values are calculated each guarter based on data from the previous 12 guarters. They reflect system unavailability due to both planned and unplanned unavailability and are calculated for each unit by summing the guarterly unavailability for all three trains and dividing by three, the number of trains in each unit.

	30/01	40/01	10/02	20/02	30/02	40/02	10/03	20/03
	30/01	40/01	10/02	20/02	30/02	40/02	10/03	20/03
Train 1								
Planned unavailable hours	16.90	0.10	0	4.40	0	13.20	0	0
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00
Train 2					[]			
Planned unavailable hours	32.20	0.10	0.10	2.20	0	18.00	0	0
Unplanned unavailable hours	0	0	0	11.90	0.10	0	0	0.20
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00
Train 3								
Planned unavailable hours	0.10	0.20	19.90	5.20	0	0	0	0
Unplanned unavailable hours	0	0	0	2.40	79.00	0	120.30	28.90
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2160.00	2183.00	2208.00	2209.00	2160.00	2183.00
								<u>.</u>
Indicator value	0.9%	0.8%	0.8%	0.7%	0.7%	0.7%	0.8%	0.8%

 Table 7

 Unit 1 Safety System Unavailability, Emergency AC Power

Enclosure 1 PG&E Letter DCL-03-142

	· · · · · · · · · · · · · · · · · · ·		r			<u></u>		
	3Q/01	4Q/01	1Q/02	2Q/02	3Q/02	4Q/02	1Q/03	2Q/03
Train 1	[[]	· · · · · ·	:		[[
Planned unavailable hours	0.10	0.10	29.90	6.80	0	6.90	0	0
Unplanned unavailable hours	0	0	0	0	5.50	2.00	0	0.10
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	. 0	0	0	0	0
Required hours	2208.0 0	2209.0 0	2160.0 0	2183.0 0	2208.0 0	2209.0 0	2160.0 0	2183.0 0
Train 2	·····	[]					[]	
Planned unavailable hours	0.30	0.10	29.00	1.90	0	0	0	0
Unplanned unavailable hours	0	0	0	3.10	0	0	0	52.30
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.0 0	2209.0 0	2160.0 0	2183.0 0	2208.0 0	2209.0 0	2160.0 0	2183.0 0
Train 3								;
Planned unavailable hours	0.10	0.10	29.90	5.70	0	0	0	0
Unplanned unavailable hours	0	0	0		Q	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.0 0	2209.0 0	2160.0 0	2183.0 0	2208.0 0	2209.0 0	2160.0 0	2183.0 0
	[
Indicator value	0.6%	0.6%	0.6%	0.6%	0.6%	0.6%	0.5%	0.5%

 Table 8

 Unit 2 Safety System Unavailability, Emergency AC Power

DG failures to meet starting or surveillance test requirements is tracked by PG&E for each DG start. Such requirements include accelerating to 900 rpm within 10 seconds or less, reaching rated voltage and frequency in 13 seconds or less, and maintaining rated voltage and loading for the duration of the test or event. Provided below is a table showing DG failures for the last 20, 50, and 100 starts for each DG.

	Failure to meet starting or loading requirements in last number of starts (reliability* shown in parentheses)				
DG	Last 20 starts	Last 50 starts	Last 100 starts		
1-1	0 (1.00)	0 (1.00)	2 (0.980)		
1-2	0 (1.00)	1 (0.980)	1 (0.990)		
1-3	2 (0.909)	3 (0.943)	4 (0.962)		
2-1	0 (1.00)	1 (0.980)	2 (0.980)		
2-2	1 (0.952)	1 (0.980)	1 (0.990)		
2-3	0 (1.00)	0 (1.00)	0 (1.00)		

The DG failure data presented above is consistent with the DG target reliability of 0.950 assumed for the DCPP station blackout (SBO) analysis submitted by PG&E Letter DCL-92-084, dated April 13, 1992, and approved by the NRC in a supplemental safety evaluation dated May 29, 1992. The DCPP SBO analysis was performed in accordance with NUMARC 87-00, Revision 1, "Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors," dated August 1991. NUMARC 87-00 prescribes allowed target reliabilities to be:

Evaluation Criteria

Last 20 demands	>	0.90 reliability
Last 50 demands	>	0.94 reliability
Last 100 demands	>	0.95 reliability

*Where total reliability = <u>total valid tests</u>

total valid tests + total valid failures

(This reliability equation is used in PG&E Letter DCL-85-375, "License Amendment Request 85-15, Technical Specification 3.8.1.1, Electrical Power Systems, A.C. Sources," dated December 26, 1985, approved by License Amendments No. 9 (Unit 1) and No. 7 (Unit 2), dated June 20, 1986.)

NUMARC 87-00 further prescribes that for the class of plants to which DCPP is assigned, if any of the above three criteria are met; the unit may select a DG reliability target of 0.95 for determining the required SBO coping period. Therefore the current DG reliability status is consistent with previous analyses.

Finally, since 2001, there have been two DG or related systems placed in 10 CFR 50.65(a)(1) status. On March 28, 2001, Diesel Fuel Oil Transfer Pump No. 1 was placed in 10 CFR 50.65(a)(1) status due to age related degradation of the motor thermal overload relay. It was removed from 10 CFR 50.65(a)(1) status on October 1, 2002, following revision of the preventive maintenance procedure and successful testing for three quarters. On April 17, 2003, DG 1-2 was placed in 10 CFR 50.65(a)(1) status due to maintenance activities that allowed the lubricating oil to cool to an unacceptably low temperature.

NRC Question 2

It is the staff's understanding that the purpose of the requested amendment is to allow an increased outage time during plant power operation for performing DG inspection, maintenance, and overhaul, which would include disassembly of the DG. DG operability verification after a major maintenance or overhaul may require a full load rejection test. If a full load rejection test is performed at power, please address the following:

- (a) What would be the typical and worse-case voltage transients on the 4160-V safety buses as a result of a full-load rejection?
- (b) If a full-load rejection test is used to test the DG governor after maintenance, what assurance would there be that an unsafe transient condition on the safety bus (i.e., load swing or voltage transient) due to improperly performed maintenance or repair of a governor would not occur?
- (c) Using maintenance and testing experience on the DG, identify possible transient conditions caused by improperly performed maintenance on the DG governor and voltage regulator. Discuss the electrical system response to these transients.
- (d) Provide the tests to be performed after the overhaul to declare the DG operable and provide justification for performing those tests at power.

PG&E Response

- 2(a) The typical voltage response recorded on the 4 kV busses during full load rejection testing in accordance with Surveillance Test Procedure (STP) M-9D1, "Diesel Generator Load Rejection Test," is a small drop from the DG supported voltage to the off-site power source voltage. The largest drop yet recorded is 54 volts.
- 2(b) Maintenance testing that PG&E performs following any DG governor or voltage regulator maintenance is designed to preclude creating any transient conditions that would challenge a safety bus with the DG loaded. Normally, maintenance is not performed on the DG governors that would necessitate full load rejection testing. In cases where full load rejection testing is necessary, such as following replacement or tune-up of the governor, the governor's response is first verified during an idle run prior to paralleling the DG to the bus. This is performed by "bumping" the fuel rack and causing a speed transient. The transient is observed both visually using attached instruments and physically by observing the fuel rack's return to a stable state. This ensures that prior to paralleling, the governor is working correctly. Electrical Maintenance Procedure MP E-21.6. "Diesel Generator Governor and Voltage Regulator Adjustment," is used for governor tune-up. It directs the technician to ask the operator in the control room to raise the DG frequency to 61 Hz, then to lower it to 59 Hz and then to raise it back to 60 Hz to ensure proper operation of the motor-operated potentiometer. This procedure also verifies proper null voltage, stability and gain of the electronic governor with the engine idling. Each of these items could cause load swings during parallel operation and therefore they are set and verified prior to parallel operation.

2(c) Except for tune-up maintenance per MP E-21.6, there is no maintenance performed on the DG electronic governors. Unless governor replacement is required due to failure, usually no adjustments are necessary and MP E-21.6 is followed to verify proper governor response (stability, amplifier gain) and proper set-up values for droop and load gain. Based on experience, once the values of droop and load gain are set, no adjustments are needed unless the governor is replaced.

The only maintenance performed on the mechanical governor is oil change-out. This maintenance does not affect the performance of the mechanical governor. If the mechanical governor is replaced, then set-up of governor linkages and electronic governor null voltage is performed in accordance with MP E-21.6. Proper operation of the governor is verified prior to paralleling the DG to the bus.

Except for periodic inspection of the solder joints on the automatic voltage regulator card there is no maintenance involved on the voltage regulator. After the voltage regulator is initially set for stability and voltage range, it does not require any adjustments.

Since proper operation of the governors is verified prior to paralleling the DG to the bus, no electrical transients are expected, nor have been experienced, as a result of maintenance.

2(d) Normally, after maintenance is completed, the DG is started manually and is run to ensure proper operation and control of the voltage regulator and the governor. During this run, voltage regulator and governor tune-up verification is performed. Post maintenance testing to determine DG operability is performed using monthly test STP M-9A, "Diesel Engine Generator Routine Surveillance Test." The DG is paralleled and loaded to 2600 kW and run for one hour. If the governor or voltage regulator was replaced, or tune-up was required, then full load rejection testing would be performed at the end of the STP M-9A test by opening of the emergency diesel generator (EDG) output breaker in accordance with STP M-9D1. Historically, no problems have been encountered resulting in unacceptable plant transients due to DG full load rejection testing, including performance of the test at power.

Copies of STP M-9A and STP M-9D1 are provided in Enclosure 4.

NRC Question 3

What type of communication has been established between the control room operator at Diablo Canyon Plant and the System Load Dispatcher? Is the System Load Dispatcher notified in advance that the DG is going to be out for extended period of time?

PG&E Response

DCPP Operating Procedure OP J-6B:VII, "Diesel Generator - Clearing," Prerequisite 4.2 provides the following guidance:

"The potential for a loss of off-site power should be minimized during a Diesel Generator out-of-service time. The Diablo Switchyard Operator should be notified as far in advance as reasonable prior to clearing a Diesel Generator for planned maintenance work and again when a Diesel Generator has been made available. This will limit the instances of simultaneous maintenance on off-site transmission equipment and the diesel generators."

NRC Question 4

Other licensees who requested for DG AOT extension provided the following Regulatory Commitments in their requests:

- A. Weather conditions will be evaluated prior to entering the extended DG AOT for voluntary planned maintenance. An extended DG AOT will not be entered for voluntary planned maintenance purposes if official weather forecasts are predicting severe conditions (tornado or thunderstorm warnings).
- B. The condition of the offsite power supply and switchyard will be evaluated prior to entering the extended AOT.
- C. No discretionary switchyard maintenance will be allowed. In addition, no discretionary maintenance will be allowed on the main, auxiliary or startup transformers associated with the unit.
- D. No maintenance or testing that affects the reliability of the train associated with the OPERABLE DG will be scheduled during the extended AOT. If any testing and maintenance activities must be performed while the extended AOT is in effect, a 10CFR50.65 (a)(4) evaluation will be performed.
- *E.* The steam driven emergency feedwater pump will not be taken out of service for planned maintenance activities and will be treated as protected equipment.
- *F* The system dispatcher will be contacted once per day and informed of the DG status along with the power needs of the facility.
- G. The on-shift Operations crews will discuss and review appropriate normal and emergency operating procedures upon or prior to assuming the Watch for the first time after having scheduled days off while the AOT is in effect.

H. The Operations crews will be briefed concerning the unit activities, including compensatory measures established and the importance of the alternate ac source following instruction of the Shift Manager upon the loss of power event. This briefing will be performed upon or prior to assuming the Watch for the first time after having scheduled days off while the AOT is in effect.

Please provide the provisions, limitations and compensatory actions that you will be committing to implement to assure adequate defense in depth, during the extended DG AOT.

PG&E Response

On-line DG maintenance utilizing the extended completion time proposed by LAR 03-06 will be controlled in accordance DCPP Administrative Procedure AD7.DC6, "On-Line Maintenance Risk Management." AD7.DC6 guidance includes evaluating risk in accordance with 10 CFR 50.65(a)(4) (maintenance rule), establishing compensatory measures, and assuring the work is scheduled in the appropriate train/bus/set workweek. A copy of AD7.DC6 is provided in Enclosure 2.

In addition, as has been done for past for major DG on-line maintenance, operational instructions and contingency plans will be provided by a temporary procedure (TP) or other appropriate procedure. The procedure will include prerequisites, precautions and limitations, and compensatory measures similar in scope to the examples provided in the NRC question above. An example TP is provided in Enclosure 3 (TP TO-0105, "Diesel Generator 2-1 On-Line Maintenance").

Rather than prescribing a specific set of provisions, limitations, and compensatory measures in advance for future extended DG maintenance periods, such limitations will be evaluated based on the plant and grid conditions present at the time of each extended DG maintenance period, and will comply with AD7.DC6 and will be similar in scope to those identified in TP TO-0105.

NRC Question 5

On Page 22, Item 3, it is stated that only one major overhaul (in excess of 7 days) will be performed per DG per refueling. It is also stated that the increase in "at-power" DG unavailability given the extension in completion time is 2.2 days per year. It is not clear to the staff how with the performance of one major overhaul per DG, per refueling (which takes in excess of seven days), the increase in unavailability will only be 2.2 days. Please explain.

PG&E Response

The discussion of the approach for calculating the change in the annual average core damage frequency due to the change in the DG completion time starts on page 19 of

PG&E Letter DCL-03-060, dated May 29, 2003. On page 20 of DCL-03-060, the following definition is provided for T_{x-x} (e.g. T_{1-1}):

"Additional time per year (T_{YEAR}) that DG 1-1 is out of service (OOS) as a result of extending the completion time."

The important word in the definition is "additional."

Starting on page 21 and continuing on page 22, DCL-03-060 addresses the predicted additional time, not the total time, due to the proposed change in the DG completion time. For example, on page 21 (bottom of the page), it is stated that:

"The amount of time to be added to future on-line unavailability due to moving preventative maintenance work out of refueling outages is approximately 29 hours per year. Currently, a significant portion of the DG preventative maintenance is already performed on-line."

Therefore, 2.2 days is PG&E's prediction of the average additional unavailability time per year (note that one major overhaul will be per refueling outage (i.e. once per 18-21 months). Currently, on average, a DG OOS time is 5 days annually (under the current 7-day Technical Specification completion time). With the proposed 14-day completion time, PG&E expects this yearly average OOS time to increase to 7.2 days.

It is also noted that the incremental conditional core damage probability, which is the incremental probability of a core damage event over a period of time equal to the proposed extended completion time (14 days), is discussed on pages 23-25 of DCL-03-060.

NRC Question 6

Page 8 of your submittal provides a discussion of SBO. Please provide additional information as to what is considered a SBO and how SBO is modeled.

PG&E Response

Page 8 of DCL-03-060, under "Station Blackout Capacity," presents the prescriptive definition of SBO at DCPP, and the prescriptive basis for being able to cope with such a SBO condition.

In the DCPP probabilistic risk assessment (PRA) model, consistent with the industry PRA practices, SBO is treated as the loss of all onsite and offsite AC power. In a SBO sequence, the operators are instructed to depressurize the steam generators using the 10 percent steam dump valves or the 40 percent steam dump valves to limit reactor coolant pump (RCP) seal leakage. The turbine-driven auxiliary feedwater pump is credited to cool the reactor coolant system (RCS). These actions reduce RCS

temperatures and pressures sufficiently to allow the accumulators to inject their contents into the RCS. The accumulator inventories provide additional RCS inventory, which must also leak out if the core is to be uncovered. The reduced RCS temperatures and pressures limit the rate of seal degradation and minimize the rate of subsequent leakage. Failure of these actions reduce the time available for recovery of electric power because the RCP seal leak rate would be higher. These actions are all considered in the determination of success criteria for the electric power recovery factors.

During SBO scenarios, the PRA assumes that operators take action to (1) restore AC power to at least two vital buses by restoring offsite power, recovering DGs, or cross-tying vital buses, (2) maintain and control auxiliary feedwater flow from an auxiliary feedwater pump, (3) monitor core subcooling and reactor coolant inventory, and (4) monitor DC power availability and take action to extend battery life.

The following should be noted relative to SBO scenarios:

- No electric power recovery action is credited for the SBO scenarios in which a pressurizer power operated relief valve or safety valve fails to reseat, resulting in a loss-of-coolant accident path.
- Following recovery of a DG during a SBO, operator action is credited to cross-tie two vital buses.

Enclosure 2 PG&E Letter DCL-03-142

Diablo Canyon Power Plant Administrative Procedure AD7.DC6, "On-Line Maintenance Risk Management"

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

PACIFIC GAS AND ELECTRIC COMPANY NUCLEAR POWER GENERATION DIABLO CANYON POWER PLANT ADMINISTRATIVE PROCEDURE

NUMBERAD7.DC6REVISION7PAGE1 OF 15

TITLE: On-Line Maintenance Risk Management

10/24/02

EFFECTIVE DATE

PROCEDURE CLASSIFICATION: QUALITY RELATED SPONSORING ORGANIZATION: OPERATIONS REVIEW LEVEL: "A"

TABLE OF CONTENTS

SECTION		:		<u>PAGE</u>
SCOPE				1
DISCUSSION				2
RESPONSIBILITIES		•••••••••••		3
DEFINITIONS				4
Compensatory Measures				4
Core Damage Frequency (CDF)				4
Core Damage Probability (CDP)	•••••		•••••••••••••••••••••••••	5
Degraded			••••••	5
External Risk		•••••	••••••	5
Internal Risk			•••••••	6
Key Safety Function (KSF)				6
Large Early Release Frequency (LERF)			••••••	7
Probabilistic Risk Assessment Allowable Outage	e Time (PRA	A AOT)	••••••••••••	7
Risk Significant				7
Threshold PRA AOT		•••••		7
Train Level SSC		••••••		8
Trip Mitigation SSC		••••••	••••••	8
Trip Risk			••••••	8
PRECAUTIONS AND LIMITATIONS		••••••••	•••••	8
INSTRUCTIONS	****		******	8
Developing the 12 Week Rolling Matrix	· · · · · · · · · · · · · · · · · · ·	• • • • • • • • • • • • • • • • • • • •	· · · · · · · · · · · · · · · · · · ·	8
Managing Risk in the Maintenance Planning Pha	ise	••••••••••••••••••••••	•••••	10
Managing Risk in the Maintenance Execution Ph	nase (Real T	'ime)	••••••	11
Plant Trip Risk Assessment		••••••	•••••••••••••••••••••••••••••••••••••••	11
Probabilistic Risk Assessment	t · · ·	•••••	· .	12
Safety Function Degradation Assessment	-	••••••	· · · ·	13
REFERENCES			••••••••••••••••••••••	14
RECORDS			••••••	
ATTACHMENTS			•••••	15
SPONSOR			******	15

- 1. <u>SCOPE</u>
 - 1.1 This procedure provides guidance for managing plant trip, probabilistic, and safety function degradation risk from on-line maintenance, external or internal conditions, as required by 10 CFR 50.65(a)(4) of the Maintenance Rule.

DIABI	FIC GAS LO CAN	AND EL YON PO	NUMBER AD7.DC6 REVISION 7 PAGE 2 OF 15	
TTLE	E: On-	Line Mai	ntenance Risk Management	
	1.2	These in and 4. 1 AD8.D0	nstructions shall be used for risk managemen Risk management in MODES 5 and 6 is add C55.	t when the unit is in MODES 1, 2, 3 ressed in AD8.DC50 through
	1.3	Risk in	the transitional MODE 4 will be controlled a	s follows:
		1.3.1	Any maintenance on risk significant Syste (SSCs) in MODE 4 will require specific a manager.	ems, Structures, or Components uthorization of the operations
		1.3.2	Risk significant equipment removed from Spec requirements (e.g., isolating a CCP a SR 3.4.12.2) does not require special auth	service in accordance with Tech and the SIPs per SR 3.4.12.1 and orization.
		1.3.3	Qualitative evaluation based on Key Safe performed for risk significant equipment a No quantitative core damage frequency va probabilistic risk analysis is based on a fu	ty Function degradation should be removed from service in MODE 4. alues should be used since the Il power model.
	1.4	Certain mainten insights probabil also refe	risk significant components cannot be taken ance or result in very short Tech Spec action provide limited value. Therefore, this proce listic and safety function degradation risk on crence 7.7 for bases.	out of service for on-line statements. In these cases, risk dure will limit itself to assessing SSCs listed in Attachment 9.1. See
	<u>DISCUS</u>	SION		
	2.1	Risk fro	m performing maintenance on-line is minim	ized by:
	·	2.1.1	Performing only those preventative and correquired to maintain the reliability of the solution (SSC).	prrective maintenance items on-line tructure, system, or component
		2.1.2	Minimizing cumulative unavailability of s SSCs by limiting the number of at-power (MOW) per cycle per train/component. R	afety-related and risk significant maintenance outage windows efer to AD7.ID4.
		2.1.3	Minimizing the total number of SSCs out	of-service (OOS) at the same time.
		2.1.4	Minimizing the risk of initiating plant trar safety systems by implementing compens	sients (trips) that could challenge atory measures.
		2.1.5	Avoiding higher risk combinations of OO Assessment (PRA) insights.	S SSCs using Probabilistic Risk
			Maintaining Hilafanas in Joseph Hilas and di	a combinations of 0.00 SSCs that

•

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE *** PACIFIC GAS AND ELECTRIC COMPANY NUMBER AD7.DC6 REVISION 7 **DIABLO CANYON POWER PLANT** PAGE 3 OF 15 118 8 **On-Line Maintenance Risk Management** TITLE: Scheduling the SSCs in the 12 week rolling matrix according to their Train/Bus/Set 2.2 relationship minimizes a large part of the Tech Spec conflict and risk factor. Refer also to AD7.ID4. Risk is managed as follows: 2.3 、 Plant trip risk activities or conditions are evaluated qualitatively and mitigated 2.3.1 1. . . . <u>.</u> by: . :

- Taking appropriate compensatory measures; and/or a. b. Ensuring defense-in-depth for safety systems that are challenged by a plant trip. Risk significant equipment OOS configurations (singles and pairs of 2.3.2 components) affecting Core Damage Frequency (CDF) have been quantitatively pre-analyzed by probabilistic risk methods. 2.3.3 The ability of SSCs to support Key Safety Functions (KSFs) that protect the fission product barriers (clad, RCS, and containment) is evaluated • qualitatively. ¥. . .. Compensatory measures and management authorization may be required to و به تابغ ا 2.3.4 allow higher risk configurations for planned maintenance. Management notification may be required for emergent higher risk situations. RESPONSIBILITIES 3.1 The engineering director is responsible for overall administration of the Maintenance Rule per MA1.ID17. 3.2 The scheduling supervisor is responsible for overall coordination of scheduling on-line maintenance in accordance with this instruction and AD7.ID4. 3.3 The cognizant manager is responsible for identifying and proposing compensatory measures for HIGH or VERY HIGH risk activities performed by their groups per MA1.DC10 and MA1.DC11. 3.4 The operations manager is responsible for approving higher risk OOS configurations as identified by this instruction. · . . The operations work control supervisor and the daily scheduling supervisor are 3.5 responsible for overall implementation of the on-line risk management program. 3.6 The operations work week manager (or, in his absence, an OPS Shift Manager) is responsible for ensuring risk assessments for planned maintenance are completed in accordance with this instruction and AD7.ID4.
 - 3.7 The operations shift foreman is responsible for:

3.

- Verifying risk assessments for planned activities are valid; and for
- Performing risk assessments for emergent conditions affecting the plant in accordance with this instruction and AD7.ID4.

100	UNC	CONTROLLED H	PROCEDURE - DO NOT USE TO PERFORM W	ORK or ISSUE FOR	USE •••
PAC	IFIC GAS BLO CAN LE: On	S AND ELECT YON POWEI -Line Mainter	TRIC COMPANY R PLANT nance Risk Management	NUMBER REVISION PAGE	AD7.DC6 7 4 OF 15
			<u> </u>		
					1
	3.8	The PRA su	pervisor is responsible for:		
		Providin	ng the risk insights and numerical risk values f	for this procedure; a	and for
		 Maintai 	ning the ORAM-Sentinel software.		
4.	DEFIN	TIONS			
	4.1	Compensat plant equipr	ory Measures - Actions taken to mitigate the nent conditions or external or internal condition	risk from planned ons. Examples incl	or emergent ude:
		<u>NOTE</u> : De	ferral of elective work to avoid unacceptable r	risk is an assumed o	ption.
		4.1.1 R	isk Awareness		
		•	Tailboards, PA announcements, Plan of the Direct supervisory oversight.	Day, special notice	es, etc.
		•	Upper Management authorization.		
		•	Abnormal or infrequent evolution briefings	5.	
		4.1.2 N	finimize duration of the activity or condition		
		•	Pre-planning - Tailboards, pre-job walkdov supplies, mock-up training.	vns, pre-staging equ	ipment and
		•	Contingency planning - Canned tailboards, temporary procedures, call-out lists, back-o failure).	JIT simulator train out criteria, etc. (pla	ing, n for
		•	Augmented coverage - Working two (2) sh coverage.	ifts/day, around-the	e-clock
		4.1.3 N	fitigate Consequences		
		•	Protect redundant equipment - barricading redundant DEG MOWs, offsite power outa restricting activities in the 500kV and 230k service.	OPERABLE DEGs ges, or grid instabil V yards when DEC	during ity; is are out of
	4.2	Core Dama occurrence o	ge Frequency (CDF) - The instantaneous risl expressed as occurrences per year.	k of a core damagin	g accident's
		4.2.1 T	he plant specific Probabilistic Risk Analysis (arious plant configurations and accident scena	PRA) calculates CI rios.	OF for
		a.	For example, the CDF for operating the p available (no maintenance case) is about accident might be expected to occur abou	lant with all safety 1E-5/yr; that is, a co t once every 100,00	systems ore damaging 00 years.
		b	If startup power were to be removed from CDF would increase by about a factor of every 10,000 years	a service for the who 10 to about 1E-4/yr	ole year, the , or once

I

ļ

•

ł
PACIFIC GA DIABLO CAN	<i>CONTROLL</i> S AND EL NYON PO'	<i>ED PROCEDURE <u>DO NOT USE TO</u></i> ECTRIC COMPANY WER PLANT	PERFORM WOR	<i>K or ISSUE FOR</i> NUMBER REVISION PAGE	USE **** AD7.DC6 7 5 OF 15	;
TITLE: Or	n-Line Mai	ntenance Risk Management	· ·	· .		
مي مور منطقة مي	4.2.2	Because the PRA model evaluate Train Level SSCs in this procedure representative of the train vice sp	es individual com are are sometimes becific component	ponent failures, composite valu ts.	the CDF for es	
4.3	Core D	amage Probability (CDP) - The pr	oduct of the CDF	and the out-of-	service	

duration. This represents the actual risk of a core damaging event occurring during a given period of time.

4.3.1 From the above example, if startup power was to be out-of-service for six (6) hours, the core damage probability would be:

 $\frac{(1E - 4/yr)(6 \text{ hrs})}{8760 \text{ hrs/yr}} = 6.9E-8$

3...

4.4

·· ·· ·

۰**.**

Degraded - SSC condition or performance is below nominal. May still be considered OPERABLE, but operation may be curtailed or under increased monitoring. Examples include:

- SSCs in Maintenance Rule (a)(1) (goal setting) status or approaching performance criteria limits.
- SSCs on the Predictive Maintenance "Equipment Watch List."
- SSCs on alert frequency Surveillance Testing (PX ALRT ARs).
- SSCs requiring compensatory measures per Prompt Operability Assessments or Operability Evaluations (refer to OM7.ID8 and OM7.ID12).
- SSCs with other significant existing deficiencies (CM or AT EQPR or EVAL ARs, operator workarounds, etc.).

4.5 External Risk - Trip Risks from factors originating outside the plant boundaries. Severity of trip risk will be evaluated qualitatively on a case-by-case basis. The following examples should be classified as High Trip Risks:

4.5.1 Offsite power system induced trip risks:

<u>NOTE</u>: External risks affecting offsite power may also affect plant trip mitigation SSCs.

- Peak power demand (i.e., CAISO stage 3 or higher grid emergencies).
- Fires threatening offsite power source lines.
- Storms (wind, rain, etc.).
- 4.5.2 Direct trip risk from storms:
 - High ocean swell warning. (Refer to OP O-28, "Intake Management.")
 - Lightning strikes, etc.
- 4.5.3 Seismic risk factors.
 - Parkfield Level A earthquake prediction. (Refer to CP M-4, "Earthquake.")
 - Tsunami warning. (Refer to CP M-5, "Tsunami Warning.")

	UNCONTROLL	ED PROCEDURE	DO NOT USE	TO PERFORM WORK o	ir ISSUE FOR	USE ***						
PACIFIC DIABLO C	GAS AND EL CANYON POV	ECTRIC COM	PANY		NUMBER REVISION PAGE	AD7.DC6 7 6 OF 15						
TITLE:	On-Line Mai	ntenance Risk N	lanagement									
4.6	Interna the plan	Internal Risk - Risks from operations, maintenance, and environment originating inside the plant boundaries.										
	4.6.1	Examples of e energy line br	nvironmental e eaks.	ffects include fire, flood	ling, high and	l medium						
	4.6.2	So long as compensatory measures are put in place per the Equipment Control Guideline actions for degraded engineered features, risk to adjacent components is considered insignificant.										
	4.6.3	Failure to implement ECG actions within the required time limits should require an after the fact risk assessment by the PRA Group. This includes:										
		• Fire protec	tion - Barriers,	doors, detection, suppre	ession, etc. (E	CG 18).						
		• Flooding -	Doors, barriers	, drains, etc. (ECG 80).								
		• High and N (ECG 80).	fedium Energy	Line Breaks - Doors, b	low-out pane	ls, etc.						
4.7	Key Sat Degrada of logic assessm	fety Function (K ation of "defense trees when remo ent is independer	SF) - A function in depth," the a ving Risk Signi at of the PRA A	on required to protect the bility to maintain the K ificant SSCs from service OT method.	e fission prod SF, is evaluat ce for mainter	uct barriers. ed by the use nance. This						
	4.7.1	These KSFs correspond to the critical safety functions in the Emergency Operating Procedures (EOP) Function Restoration Guidelines (FRGs) that mitigate extreme - RED, or severe - MAGENTA, challenges to the barriers.										
		NOTE: The RCS inventory critical safety function in the FRGs was not included because there are no RED or MAGENTA paths in that series of procedures.										
	4.7.2	Two additional support functions, Component Cooling and Vital Electric Power, were created in addition to those in the FRGs. Many individual components can be affected by a degradation of these support systems. For ease of use, rather than evaluate the affect on each supported component, the new KSFs were created.										
	4.7.3	Similar to the color.	FRGs, KSF def	ense in depth degradation	on is represer	ited by a						
		a.	GREEN	KSF fully satisfied								
		b.	YELLOW	Moderate degradation								
		c.	ORANGE	Significant degradatio	n							
		d.	RED	Severe degradation								

PACIFIC DIABLO	<i>UNU</i> GAS CAN	ONTROLL AND EL YON PO	ED PR ECTR WER	OCEDURE DO A	NOT USE TO	PERFORM V	NORK ÖI N H	<i>ISSUE FOR</i> NUMBER REVISION PAGE	USE **** AD7.DC6 7 7 OF 15
TITLE:	On	Line Mai	intena	nce Risk Manag	ement	· "	,		r
4.8 	- - 	Large l releases emerge pathwa contain	Early I s via pe ncy res y this I ment p	Release Frequent netration failures ponse plan has b arge that could be urge and exhaust	icy (LERF) s three (3) in een impleme e affected by valves.	- The instanta ch diameter a ented in an ac maintenance	aneous r and large ccident s e is the v	isk to the pul r before the cenario. The racuum/press	blic from plant's e only release sure relief or
188 - 	10 10 10	4.8.1	LEI Fun	RF risk is evaluat	ed qualitativ	ely under the	e Contain	nment Key S	afety
	·		a.	For example, v avoided if a Tr Core Cooling o give yellow for	venting of co ain Level SS or Containmo r both).	ntainment for C affecting (ent Key Safet	r pressur CDF was ty Funct	re relief shou s OOS giving ion color (e.g	ld be g a yellow g., RHRP
			b.	Alternatively, t measures to mi awareness tailt	the example itigate the ris coards, conti	above would k were imple ngency plann	be acce emented ing in th	ptable if con such as incre ne event of a	npensatory eased risk leak, etc.
			с.	If an inoperabl	e penetration	is isolated to	o comply	y with Tech	Spec 3.6.3

actions, those compensatory measures are sufficient to mitigate the LERF risk. No other risk management actions would be required.

Probabilistic Risk Assessment Allowable Outage Time (PRA AOT) - The number of hours a single or combination of Risk Significant Train Level SSCs may be OOS before the time-integrated risk addition to the "no maintenance case" Core Damage Probability (CDP) exceeds 1E-6. Industry PRA guidelines define a change of less than 1E-6 as "insignificant risk increase." The PRA AOT is used as a "ruler" to compare the relative risk of removing Risk Significant Train Level SSCs from service.

- Risk Significant As defined by MA1.ID17, a SSC is deemed to be risk significant if: 4.10
 - 4.10.1 It is a significant contributor to the plant specific PRA:
 - 4.10.2 If it provides or supports a Key Safety Function; or

5

1. 4.9

÷

4.10.3 It has been judged to be risk significant by the Maintenance Rule expert panel.

> NOTE: Certain risk significant components cannot be taken out of service for on-line maintenance or result in very short Tech Spec action statements. In these cases, risk insights provide limited value. Therefore, this procedure will limit itself to assessing probabilistic and safety function degradation risk on SSCs listed in Attachment 9.1. See also reference 7.7 for bases.

Threshold PRA AOT - The PRA AOT of the riskiest single Risk Significant Train Level 4.11 SSC normally allowed to be removed from service for on-line maintenance. It is reasoned that any combination of Risk Significant Train Level SSCs may be removed from service as long as it is allowed by Tech Specs, OP1.DC17, and the combination is no riskier than the riskiest single Risk Significant Train Level SSC.

UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK	or ISSUE FOR	USE, •••
PACIFIC GAS AND ELECTRIC COMPANY	NUMBER	AD7.DC6
DIABLO CANYON POWER PLANT	REVISION	7
	PAGE	8 OF 15

TITLE: On-Line Maintenance Risk Management

4.12 **Train Level SSC (TLS)** - Equipment name that represents the train affected by individual component maintenance or failure. For example:

OOS Component	TLSSC
FCV-95	AFWP1
8803A	CCP1
8807B	SIP2
Opposite Unit ASW pp	FCV-601

- 4.13 **Trip Mitigation SSC** The primary SSCs that are immediately challenged during a normal plant trip (no safety injection). Loss of redundancy for these SSCs present significant complications in the event of a plant trip:
 - Offsite power sources (230kV initially, 500kV with delayed access)
 - Emergency Diesel Generators (backup to 230kV startup)
 - Auxiliary Feedwater trains
 - Auxiliary Saltwater trains
- 4.14 **Trip Risk -** Any activity that could lead to a reactor or turbine trip. Turbine and reactor trips represent the most likely transient initiators leading to core damaging and large early release events.
 - 4.14.1 HIGH risk activities evaluated per MA1.DC10 or MA1.DC11 are considered Trip Risks by this procedure *only* if they might lead to a transient having a significant effect on reactor power (>2%RTP). See Reference 7.9.

5. PRECAUTIONS AND LIMITATIONS

- 5.1 The 12 week rolling matrices shown in Attachment 9.2 are FOR INFORMATION ONLY. The Daily Work Coordination Group (DWC) keeps current versions of the matrices for each unit.
- 5.2 Current PRA AOT values are found using the on-line risk assessment computer program ORAM-Sentinel. PRA AOT values for single configurations are documented on Attachment 9.1.
- 5.3 The SFATs are based on the equipment importance in accident mitigation as described in the EOP background documents. SFATs are displayed using ORAM-Sentinel software.

6. <u>INSTRUCTIONS</u>

- 6.1 Developing the 12 Week Rolling Matrix
 - 6.1.1 The 12 Week Rolling Matrix (Matrix) is based on the STPs performed in MODE 1 for all the major risk significant SSCs. (Refer to Attachment 9.1, List of Risk Significant Systems.)

DIABLO	GAS AND EL CANYON PO	WER PLANT REVISION 7 Big PAGE 9 OF 15
TITLE:	On-Line Mai	intenance Risk Management
	6.1.2	The weeks are categorized by 3 methods.
	' ^	a. SSPS Train relation - A, B, or A/B
		b. Vital bus relation - F, G, H, or Non-bus
- .		c. Protection Set relation - I, II, III, IV
		d. Thus, the 4 week sub-cycle within the 12 week cycle is:
		1. Train A/B Bus H
•		2. Train B Bus G
		3. Train A Bus F
		4. Train A/B Non-bus
		e. Protection set weeks are spread over the full 12 week cycle.
р. 134	6.1.3	Each week is further subdivided into two work windows; Tuesday-Wednesday, Thursday-Friday - each 48 hours long.
		a. This is consistent with the AD7.ID4 requirement that T.S. SSCs out-of-service (OOS) duration be scheduled not to exceed 1/2 the Tech Spec Action Allowable Outage Time (AOT). For most ESF components.
.	. ,	this is 1/2 of 72 hours: 36 hours.
		b. This also provides time separation for working two safety related SSCs in the same week.
	6.1.4	Compile a listing of the quarterly and monthly STPs for the major SSCs.
	6.1.5	Classify the SSCs by SSPS train, vital bus and protection set as described above and spread out the STPs through the 12 week cycle in their appropriate train/bus/set weeks (refer to Attachment 9.2, Sample 12 Week Rolling Matrix).
		a. Group the STPs at the train level if possible, for example slave relay test with pump test and associated valve tests.
		b. Levelize for daily work loading, cross-discipline support required for test performance, opposite unit testing schedule, test instrumentation requirements. etc.
	6.1.6	Analyze weeks for possible trip risks, train level probabilistic risk, and safety function degradation conflicts as described below and correct as required.
	6.1.7	Revisions to the matrix should be minimized.
		a. If changes are found to be necessary, follow above guidance and analyze for risk similarly.
		b. STP performance should be short cycled as required to avoid use of surveillance interval grace period during transition to the revised matrix. (Refer to AD13.DC1.)

TITLE: On-Line Maintenance Risk Management

	6.1.8	The Matrix Coordinator should mark up a long-term matrix spreadsheet (example: Attachment 9.3) or schedule with planned MOWs from the PIMS PM RTS due dates and other Daily Work Coordination (DWC) reports.							
		a. Identify all MOWs on the spreadsheet to help visualize the SSCs OOS at the same time for risk assessment and workload levelization.							
		b. Verify Risk Significant SSC MOWs are correctly scheduled in their train/bus/set week to align with the component STP. Correct the PIMS/P3 schedule if necessary or obtain Work Week Manager (WWM) approval for deviation.							
		c. Schedule so that the STP provides the PMT for the maintenance on the SSC.							
6.2	Managir	g Risk in the Maintenance Planning Phase							
	6.2.1	The OPS work week managers shall ensure risk management actions are completed for planned work considering:							
		a. Expected plant conditions during the week.							
		b. Expected external conditions due to seasonal effects (e.g., storm or fire season, summer peak loads, etc.).							
	6.2.2	Determine the activities scheduled for the week that are Trip Risks.							
	6.2.3	Determine the Risk Significant SSCs that are scheduled to be OOS. Classify them at the train level (TLS). Refer to Attachment 9.1.							
		a. For each TLS, determine its current unavailability and health of its redundant train.							
		1. The cognizant system engineer and/or maintenance manager should give concurrence to schedule or consider deferral of maintenance.							
		a) If the TLS is approaching or will exceed 75% of its Maintenance Rule Availability Performance Criteria; or							
		b) If the TLS's redundant train is Degraded.							
	6.2.4	If a Trip Risk is scheduled concurrently with OOS or degraded trip mitigation TLSs, attempt to separate the activities.							
	6.2.5	If two or more TLSs are scheduled to be OOS in the same week, attempt to separate the work to avoid overlap.							
	6.2.6	Determine the risk configurations during the week (unique plant states where one or a combination of trip risks or TLSs will be OOS).							
	6.2.7	Manage the trip risk, probabilistic risk, and/or safety function degradation associated with each configuration as described in Steps 6.4, 6.5 and 6.6.							

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT NUMBER DIABLO CANYON POWER PLANT PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT DIABLO CANYON POWER PLANT DIABLO CANYON POWER PLANT

			PAGE 11 OF 1				
TITLE: O	n-Line Ma	intenance Risk Management	· · ·				
			<u> </u>	· · · · · · · · · · · · · · · · · · ·			
	6.2.8	Propose risk mitigation compensato	ry measures, as approp	riate.			
	6.2.9	Document risk management actions OP1.DC17.	for each configuration	on a TS sheet per			
-6.3	Managi	ng Risk in the Maintenance Execution	Phase (Real Time)				
ان میکند در این	6.3.1	The SFM shall evaluate and manage based on the current plant state:	e the risk of all activitie	s or conditions			
· •		a. Before any planned OR emerg	ent maintenance is to b	e performed.			
		b. As soon as possible when an e	mergent plant condition	n is discovered.			
		c. As soon as possible when an e recognized.	external or internal even	t or condition is			
	6.3.2	Verify if the activity or condition is	a Trip Risk and manag	e per step 6.4.			
•	6.3.3	Determine if the activity removes a	TLS from service, and				
· ·	1	a. Manage probabilistic risk per	step 6.5.				
1947 - Ja		b. Manage safety function degrad	lation per step 6.6.				
	6.3.4	If the redundant train remaining in s compensatory measures.	ervice is degraded, imp	lement additional			
. .	6.3.5	If the evaluation reveals unacceptab restoration of safety function first, F	le risk, determine cours RA aspects second.	e of action based on			
	6.3.6	Document risk management actions OP1.DC17.	for each configuration	on a TS sheet per			
6.4	Plant T	rip Risk Assessment					
· .	6.4.1	For pre-planned trip risk activities:					
		a. Ensure the work group propos appropriate authorization form	ing Trip Risk activities from MA1.DC10 or M	completes the IA1.DC11.			
		b. Concur with or propose comportant as appropriate.	ensatory measures to m	itigate the trip risk,			
		c. Check for concurrent OOS or ORAM-Sentinel or TS Sheet r ASW). If present:	degraded plant trip miti eview (offsite power, I	gation TLSs using)EGs, AFW, or			
		1. Obtain OPS manager au	horization for concurre	nt performance.			
		2. Implement additional co	mpensatory actions, as	appropriate			
		 Document condition and TS Sheet. 	basis for approval on t	he appropriate			
		1					

TITLE: On-Line Maintenance Risk Management

6.4.2 For <u>emergent</u> plant trip risk activities or conditions:

NOTE: Emergent External Conditions should be treated as Trip Risks.

- a. Implement immediate compensatory measures, as appropriate.
- b. Check for concurrent OOS or degraded plant trip mitigation TLSs using ORAM-Sentinel or TS Sheet review. If present:
 - 1. Implement <u>additional</u> compensatory measures to mitigate risk, as appropriate.
 - 2. Notify the operations manager.
 - 3. Document condition in an Action Request.
- 6.5 Probabilistic Risk Assessment

NOTE: If the OOS TLS is a Trip Mitigation TLS, also check for concurrent Trip Risk using ORAM-Sentinel or TS sheet review and evaluate per step 6.4.

- 6.5.1 Determine the PRA AOT for the single or combination of TLSs OOS by using ORAM-Sentinel. If ORAM-Sentinel is not available, determine PRA AOT as follows:
 - a. Use Attachment 9.1 to obtain PRA AOT values for a single TLS OOS.
 - b. Contact the PRA group for any multiple TLSs OOS.
- 6.5.2 If the scheduled duration of work is <u>less</u> than the PRA AOT, determine and implement appropriate compensatory measures.
- 6.5.3 If the PRA AOT is <u>less</u> than the threshold PRA AOT:
 - a. Verify operations manager approval (or notification for emergent conditions) regardless of the scheduled duration. Scheduled duration is a factor that will be of importance in the decision process.
 - b. Basis for approval should be documented.
 - c. Determine and implement additional compensatory measures, as appropriate
 - d. Document the higher risk configuration in on the TS sheet.
- 6.5.4 If the scheduled duration of work is greater than the PRA AOT, then:

<u>NOTE</u>: If the duration of work exceeds the PRA AOT then, by definition, the risk increase is no longer insignificant.

- a. Verify operations manager approval (or notification for emergent conditions).
- b. Document basis for approval.

*** UNCONTROLLED PROCEDURE - DO NOT USE TO PERFORM WORK or ISSUE FOR USE *** NUMBER AD7.DC6 PACIFIC GAS AND ELECTRIC COMPANY : **DIABLO CANYON POWER PLANT REVISION** ...7 No. PAGE 13 OF 15 ; ·;: •

2 2 ••

•

		<u></u>	
		c.	Determine and implement additional compensatory measures, as appropriate.
		d.	Document the higher risk configuration in an action request.
6.6	Safety I assess a	Function of the second se	on Degradation Assessment - For each configuration determined above, nage the degradation of Key Safety Functions.
	6.6.1	Det usir use the	termine the Key Safety Functions that are affected by the OOS TLS(s) by ing the PC program ORAM-Sentinel. If ORAM-Sentinel is not available, Attachment 9.1 to determine KSF score for a single SSC TLS, or contact PRA group.
	6.6.2	Det Fun	ermine the degree of degradation (color) of each affected Key Safety action by selecting the affected TLS in ORAM-Sentinel.
	6.6.3	Ifa	ny TLS OOS combination results in a RED terminus.
		a.	The condition is not normally allowed and may be a Tech Spec violation
		b.	Prior PSRC approval (operations manager notification for emergent conditions) is required.
s: 1		c.	Document the RED KSF configuration in an Action Request.
Ś.A.	6.6.4	Ifa	ny TLS OOS combination results in an ORANGE terminus:
		а.	Verify operations manager approval (or notification for emergent conditions).
		b.	Document basis for approval.
		c.	Determine and implement additional compensatory measures, as appropriate.
		d.	Document emergent ORANGE configuration in an Action Request.
•	,		en e

*** UNCONTROLLED PROCEDURE DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***PACIFIC GAS AND ELECTRIC COMPANYNUMBERAD7.DC6DIABLO CANYON POWER PLANTREVISION7PAGE14 OF 15

TITLE: On-Line Maintenance Risk Management

- 6.6.5 If an OOS TLS or combination results in one or more YELLOW terminuses, evaluate as follows:
 - a. The Key Safety Functions yellow terminuses are assigned weighting factors in accordance with their importance IAW EOP FR F-0:

1.	Subcriticality	=5
2.	Core Cooling	=4
3.	Heat Sink	=3
4.	RCS Integrity	=2
5.	Containment	=1
6.	Vital Power	=5
7.	Component Clg	=5

- b. If the sum of the weighting factors for the YELLOW terminuses is 8 or greater, then:
 - 1. Verify operations manager approval (or notification for emergent conditions).
 - 2. Document basis for approval.
 - 3. Determine and implement additional compensatory measures, as appropriate.
 - 4. Document emergent configurations with $KSF \ge 8$ in an Action Request.
- c. If the sum of the weighting factors for the YELLOW terminuses is less than 8, determine and implement compensatory measures, as appropriate.

7. <u>REFERENCES</u>

- 7.1 10 CFR 50.65 "The Maintenance Rule."
- 7.2 ERIN Engineering, "Equipment Out -of -Service Monitoring for the Maintenance Rule at Diablo Canyon Technical Basis Document," dated 10/95.
- 7.3 NUMARC 93-01, "Industry Guideline for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," dated 7/2000.
- 7.4 NRC Inspection Manual, Inspection Procedure 62706, "Maintenance Rule," dated 8/31/95.
- 7.5 AD7.ID4, "On-Line Maintenance Scheduling."
- 7.6 OP1.DC17, "Control of Plant Equipment Required by the Technical Specifications or Other Designate Programs."

TITLE: On-Line Maintenance Risk Management

7.7 Procedure History Sheet for AD7.DC6 Rev 1, "Bases For Attachment 9.1, "Risk Significant Train Level SSCs." 2.7.8 PG&E PRA Calculation File C13, Revision 1, "PRA Evaluation of Various Maintenance Configuration to Support the On-Line Maintenance Risk Assessment Procedure ÷., (AD7.DC6)," 08/31/01. 7.9 Action Request A0551882, "AD7.DC6, RISK MANAGEMENT VS. MA1.DC11, WORK RISK ASSESSMENT". 8. RECORDS None 9. **ATTACHMENTS** 9.1 "Risk Significant Train Level SSCs," 11/08/01 9.2 "Sample 12 Week Rolling Matrix," 05/23/96 · 9.3 "Sample MOW Planning Spreadsheet," 05/23/96 ^{2.}9.4 "On-Line Risk Management Summary," 11/08/01 SPONSOR 10. A.J. Chitwood

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

Page 1 of 1

11/08/01

DIABLO CANYON POWER PLANT AD7.DC6 ATTACHMENT 9.1

TITLE: Risk Significant Train Level SSCs

Sys	Trn	Bus	Train Level	Risk	PC1	SFAT	PRA	PRA	Sub	Core	Heat	RCS	Ċtmt	Vital	Comp	SF	Train Level
			SSC	Signif-				AOT	critical	Cool	Sink	Integ-		Power	Cool	Score	SSC
			(See Notes)	icant					ity	ing		rity			ing		(See Notes)
3	A/B	Non	AFWP 1	Y I	<u>y</u>	Y	Y	993			3				i	3	AFWP 1
3	8	Н	AFWP 2	Y Y	Y	Y	y_	3432			3					3	AFWP 2
3	A	F	AFWP 3	y	Y	y	Y	2559			3					3	AFWP 3
7			PCV-455C	Y	y	Y	y y	> 8760			3	2				5	PCV-455C
7			PCV-456	Y.	y y	, y	Y.	> 8760			3	2				5	PCV-456
8	A	F	CCP 1	y y	Y	y y	y	2770	5	4	3	2				14	CCP 1
8	В	G	CCP 2	Y	y	Y	y	2459	5	4	3	2				14	CCP 2
9	A	F	SIP 1	Y.	Y .	, y	y	> 8760		4	3					7	SIP 1
9	В	Н	SIP 2	Ϋ́	y	Ŷ	<u>y</u>	8656		4	3					7	SIP 2
10	8	G	RHRP 1	у	Y	Y	у.	4704		4			1			5	RHRP 1
10	A	H	RHRP 2	Y	Y	Y	у	4755		4			1			5	RHRP 2
12	В	G	CSP 1	Y	y	Y	Y	> 8760					1			1	CSP 1
12	A	H	CSP 2	Y	Ŷ	Y	Y	> 8760					1			1	CSP 2
14			CCWHE1	Y	<u>y</u>	Y	Υ	336							5	5	CCWHE 1
14			CCWHE2	Y	<u> </u>	Y	Y	370							5	5	CCWHE 2
14	A	F	CCWP 1	Υ	Y	<u>y</u>	<u> </u>	1144							5	5	CCWP 1
14	B	_ G	CCWP 2	Y	_у_	Y	Y	1609							5	5	CCWP 2
14	A/B	H	CCWP 3	Y	у	Ϋ́	Y	689							5	5	CCWP 3
17	<u>A</u>	F	ASP 1	y	у	Y	Y	336							5	5	ASP 1
17	В	G	ASP 2	Y	<u>y</u>	_ Y	Y	370							5	5	ASP 2
17			FCV-601	Ŷ	y	γ	Y	502							5	5	FCV-601
21	A/B	H	DEG 1 (2)	Y	Y	Y	<u> </u>	823						5		5	DEG 1
21	B	G	DEG 2 (1)	Y	<u> </u>	y y	Y	457						5		5	DEG 2
21	<u>A</u>	_ F_	DEG 3	Y	Y	Ŷ	Y	408						5		5	DEG 3
21		H•	DFOTP1	Y	<u> </u>	y	Y	1150						5		5	DFOTP1
21		_G•	DFOTP2	y y	Y	y y	<u> </u>	1023						5		5	DFOTP2
23			CFCU X	n	n	Y	y	> 8760					1			1	CFCU X
23			CRVS S-35	Y	Y	n	y	> 8760								0	CRVS S-35
_23			CRVS S-36	Y	_ Y	л	y	> 8760								0	CRVS S-36
38	A		SSPS A	y	Y	Y	Y	759	Orange							NA	SSPS A
38	В		SSPS B	y I	Y	Y	y	728	Orange							NA	SSPS B
67		F	BTC_1	Y I	Y	Y	Y	5000						5		5	BTC_1
67		G	BTC 2	Y	y	Y	Y	1398						5		5	BTC 2
67		H	BTC_32	Y	y	Y	γ	1541						5		5	BTC_32
69			S/U Pwr	Y	y	Y	Y	119						5	•	5	S/U Pwr
70			500kV OSP	л	n	Y	Y	990						5		5	500kV OSP

RS - Risk significant per Maintenance Rule AND can be worked On Line

PC1 - Unavailability hours tracked as performance criteria

SFAT - Included in Safety Function logic trees

PRA - Modeled in PRA AOT spreadsheet

PRA AOT - Single component AOT to 1E-6 additional CDF

NOTES: Only those Risk Significant SSC's that are modeled in the DCPP PRA, have PC1 availability AOT's assigned, AND can be removed from service for maintenance on-line are included in this table. Examples of Risk Significant SSC's not in the table include RCS, Pzr safeties, MSIV's, S/G's, RWST, CST, etc. See reference 7.7 for bases.

*** UNCONTROLLED PROCEDURE - DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

05/23/96

DIABLO CANYON POWER PLANT

Page 1 of 1

AD7.DC6 ATTACHMENT 9.2

TITLE: Sample 12 Week Rolling Matrix

UNIT ONE TWELVE WEEK ROLLING MATRIX

	MONDAY	TUESDAY `	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
WEEK 1 TRAIN A/B BUS H	DAYSHIFT: M-67A FIRE VALVES	•	M-9A (CG11	P-138 FIRE PP 02	DAYSHIFT: OP C-1 SEC. PLANT M-69C F IRE EXT	P-AFW-12V-3P6 LC V110-113	M-51 ALL CFCUs P-1281 DF0 PP 01 <u>DAYSHIFT:</u> P-24 LTCW PP 01
WEEK 2 TRAIN B BUS G	V-3H12 RCV16 DAYSHIFT- M-67A FIRE VALVES V-3H11 LCV69 & 70	M-26 CCW HX 12	P-CCP-12	M-1688 *M-9A DG 12 *V-9E11 8803A&B DAYSHIFT: CATINAT ENTRY *SEAL TABLE INSP.	M-16HB *P-CSP-11 *V-313 9001A DAYSMIFT: SP 5-3125 SEC DG M-69B CO 2	P-MUW-02	P-1282 DF0 PP 02 <u>DAYSHIFT:</u> P-24 LTCW PP 02
WEEK 3 TRAIN A BUS F	<u>DAYSHIFT:</u> W3R1 10% DUMPS M-67A F IRE VALVES	M-9A DG 13	M-54 SEAL FLOW <u>DAYS</u> <u>HIFT:</u> M-89 ECCS VENTING	P-SIP-11 V-3L10 8923A&B V-3L2 8821A&B V-3L3 8807A&B M-26 CCW HX 11	P-13B FIRE PP 01 DAVSHIFT: m-69A FIRE EXT	P- AFW-13	P-CCW-11 M-16K *V-354 *V-353 DAYSHIFT: P-24 LTCW PP 03
WEEK 4 TRAIN A/B BUS NON	M-21A <u>Davshift:</u> M-67A FIRE VALVES	P-SIP-12 DAYSHIFT: R-1A ROOS	M-16J BLDN VLVS M-16N BLDN/AFW *V-3S2 BLDN 0C *P-AFW-11 *V-3P5 LCV 106-109 *V-3R5 FCV 95 * V-3R6 FCV-37838	M-16P2 PAINTIWELD RESTRICTION S FOR WEEKEND TESTING <u>DAYSHIFT</u> : CNTNMTENTRY * STP I-1D	DAYSMIFT: M-67C MOSE REELS M-10A DFOST	M-4 ABVS M-5 FHBVS M-6A CRVS	
WEEK 5 TRAIN A/B BUS H	DAYSHIFT: M-67A FIRE VALVES	M-9A DG 11		P-13B FIRE PP 02	DAYSHIFT: DP C-1 SEC, PLANT M-69C FIRE EXT M-16HA *P-CSP-12 *V-313 90018	P-AFW-12	M-51 ALL CFCUS DAYSHIFT: P-24 LTCW PP 01
WEEK 6 TRAIN B BUS G	V-3K5 8140,8147 V-3K6 8166,8167 DATSHIFT: M-67A FIRE VALVES	P-78 ASW PP 12 M-25 CCW HX 12	PAINTWELD RESTRICTS ONS FOR M-160	M-9A DG 12 V-3SB FCV3B1 V-3JI BLOCK VLVS <u>DAYSHIFI</u> : CNTMNT ENTRY *SEAL TAB LE INSP.	M-18D *P-RIR-11 <u>DAYSHIFT:</u> SP S-312S SEC DG M-69B CO 2	P- CCW-12	P-BAT-12 A+16I *V-3S1 PH. A VLVS *V-3S7 PH. A VLVS *V-3S8 PH. A VLVS <u>DAYSHIFT:</u> P-24 LTCW PP 02
WEEK 7 TRAIN A BUS F	V-3P4 AFW VLVS <u>DAYSHIFT:</u> M-67A FIRE VALVES	V-3G1 6DTs M-9A DG 13	M-54 SEAL FLOW P-CCP-11 <u>DAYSHIFT:</u> M-89 ECCS VENTING	M-28 CCW HX 11 P-78 ASW PP11 V-3F1 FCV 495 V-3F2 FCV 498 V-3F2 FCV 601 V-3F4 FCV 602 V-3F5 FCV 603	P-13B FERE PP 01 DAYSHIFT; m-69A FERE EXT	M-16E *P-AFW-13	<u>DAYSHIFT:</u> P-24 LTCW PP 03
WEEK 8 TRAIN AIB BUS NON	M-21A <u>DAYSHIFT</u> M-67A FIRE VALVES	M-16P4 V-303 DF0 VLVS <u>DAYSHIFT:</u> R-1A RODS	P-AFW-11	PAINTMELD RESTRICTIONS FOR TESTIN G DAYSHIFT: CNTMNT ENTRY *STP 1-10	<u>DAYSHIFT:</u> M-10A DFOST M-67C HOSE REELS	M-4 ABVS "M-5 FHBVS M-6A CRVS	<u>DAYSHIFT:</u> P-1283 PORT.DFO PP D1
WEEK 9 TRAIN A/B BUS H	PAINTWELD RESTRICTIONS FOR TESTING FOR STP M-18 U DAYSHIFT: M-67A FIRE VALVES		M-16A *M-9A DG11 *V-369 8801A&B M-16U *V-355 PH.A VLVS PAINTMELD RESTRICTI ONS FOR M-18C	P-138 FIRE PP 02	M-18C *P-RHR-12 <u>DAYSHIFT:</u> DP C-1 SEC PLANT M-69C FIRE EXT	M-16F "P- AF W -12	M-51 ALL CFCUs <u>DAYSHIFT</u> : P-24 LTCW PP 01
WEEK 10 TRAI N B BUS G	<u>DAYSHIFT:</u> M-67A FIRE VALVES	M-26 CCW HX 12	STP P-MUW-01 *V-3U1 WTR VLVS *V-3U2 WTR VLVS	M-9A DG 12 <u>DAYSHIFT:</u> CNTMNT ENTRY *SEAL TAB LE INSP.	M-16M Y-3T1 CV1 VLVS P-SFP-12 DAYSHIFT: SF S-312S SEC DG M-698 CO 2	P-178 CP 13 -	V-3E1 FCV 110A V-3E2 FCV 110B V-3E5 8104,8445 V-3E6 FCV 128 DAYSHIFT: P-24 LTCW PP 02
WEEK 11 TRAI N A BUS F	<u>DAYSHIFT:</u> M-67A FIRE VALVES	M-168A *M-9A DG 13	M-54 SEAL FLOW <u>DAYSHIFT:</u> M-89 ECCS VENTING	M-26 CCW HX 11	M-166 DUMP INTRLK P-138 FIRE PP 01 <u>DAYSHIFT:</u> m-69A FIRE EXT	P- AFW-13	P-BAT-11 <u>DAYSHIFT:</u> P-24 LTCW PP 03
WEEK 12 TRAI N A/B BUS NO N	M-21A <u>DAYSHIFT:</u> M-67A FIRE VALVES	<u>Dayshift:</u> R-1A RODS	P-AFW-11	V-3H7&8 CCW VLVS V-3M1,2.4 RHR VLVS PAINTWELD RESTRICTION S DAYSHIFT: CATMINT ENTRY 'STP 1-10	P-SFP-11 M-16P3 *V-3R3 BLDN 1C *V-3R4 MSIV BYP DAYSHIFT: M-10A DF0ST M-70C HOSE REELS	M-4 ABVS M-5 FHBVS M-6A CRVS	P-CCW-13 P-1284 PORT DFD PP D2

ł

*** UNCONTROLLED PROCEDURE - DO NOT USE TO PERFORM WORK or ISSUE FOR USE *** 05/23/96 Page 1 of 1

DIABLO CANYON POWER PLANT AD7.DC6 ATTACHMENT 9.3

TITLE: Sample MOW Planning Spreadsheet

Date	10/29/95	11/5/95	11/12/95	11/19/95	11/26/95	12/3/95	12/10/95	12/17/95	12/24/95	12/31/95	1/7/96	1/14/96
Events	187 11/1	1		Thksava			1	1	Chrstms	New Yrs	1	1
DWC Week	9544	9545	9546	9547	9548	9549	9550	9551	9552	9601	9602	9603
12WMtxWk	1	2	3	4	5	6	7	8	9	10	11	12
Train	A/B	B	A	A/B	A/B	В	A	A/B	A/B	B	A	A/B
Bus	Н	G	F	Non	н	G	F	Non	Н	G	F	Non
System	1	1	1				1	1				
00				I-10				I-10				I-1D
02		1					1					1
03A		T					AFWP3			·		<u> </u>
03B	AFWP2	1					1					1
03A/B		1		AFWP1			1	AFWP1				AFWP1
04		·					1					1
07	i		M-54	R-1A			M-54	R-1A			M-54	R-1A
08										PDP3		
08A		[CCP1				BATPI	
088		CCP2				BATP2						
09			M89				M-89				M-89	
09A			SIP1									
09B				SIP2								
10A									RHRP2			
108						RHR1						
11												
12A					CSP2							
12B		CSP1										
13	·						l			SFP2		SFP1
14A			CCWP1									
14B						CCWP2						
14A/B							L					CCWP3
<u>14HEA</u>			CCWHE1				CCWHE1				CCWHE1	
14HEB		CCWHE2				CCWHE2	L		·	CCWHE2		
15												
16		MUWTP2								MUWTP1		
16	LTCWP1	LTCWP2	LTCWP3		LTCWP1	LTCWP2	LTCWP3		LTCWP1	LTCWP2	LTCWP3	
17												
17A							ASP1					
17B		CCWHX2				ASP2						
18	FP2		FP1		FP2		FP1		FP2		FP1	
19					ł			~ł				
20				M-21A				M-21A				M-21A
21	DFOTP1	DF0TP2			SACIB			PDF0P1				PDF0P2
21A			DEG3				DEG3				OEG3	
21B		DEG2	ŀ			DEG2	<u> </u>			DEG2		
2TA/B	DEGI		ł		DEG1				DEG1			
22		ł	<u></u>									
23	Crus	ł			CECS				CFCS			
23	·							<u> </u>				
ZJABV				M-4				M-4				M-4
23588	ł	{		M-5				M-5				M-5
ZJCHV				M-6A				M-6A				M-6A
24												
25					ł							
26												
27			OWS1		ļ							
28												
45		CTMT		CTMT		CTMT		CTMT		CTMT		CTMT
66		SECDEG				SECOEG				SECDEG		
67]			1		<u> </u>							

UNCONTROLLED PROCEDURE DO NOT USE TO PERFORM WORK or ISSUE FOR USE

11/08/01

. . .

Page 1 of 1

DIABLO CANYON POWER PLANT AD7.DC6

ATTACHMENT 9.4

TITLE: On-Line Risk Management Summary

Evaluate risk for all planned or emergent activities, equipment OOS, or external conditions as follows:

NOTE 1: For all steps below, deferring elective activities to avoid unacceptable risk is an assumed option.

NOTE 2: If all steps are answered "NO," risk evaluation documentation is not required.

Step 1. Is the activity or condition a Trip Risk?					
	Emergent Trip Risk - implement compensatory measures;				
YES	• Planned Trip Risk - concur with comp measures per MA1.DC10 or 11;				
	AND GO TO Step 2.				
NO	GO TO Step 3				

Step 2. Is there a Trip Risk concurrent with degraded or out of service Trip Mitigation SSCs?						
	• Verify OPS manager concurrence or notification to allow 1 and 2 concurrently;					
YES	• AND implement compensatory measures;					
	- AND GO TO Step 3.					
NO	GO TO Step 3					
N/A	GO TO Step 3					

Step 3. Is the SSC out of service Risk Significant for CDF or LERF?					
	• Evaluate PRA and KSF;				
YES	Implement compensatory measures;				
	• If the OOS SSC is a Trip Mitigation SSC, THEN verify Step 2 is complete;				
	• AND GO TO Step 4.				
NO	GO TO Step 4				

Step 4. Is the remaining in-service redundant train Degraded?						
YES		Implement additional compensatory measures.				
NO		Risk evaluation complete.				

This checklist may be summarized as a lamicoid at the SFM desk for reference.

Enclosure 3 PG&E Letter DCL-03-xxx

Diablo Canyon Power Plant Temporary Procedure TP TO-0105, "Diesel Generator 2-1 On-Line Maintenance

••• <i>·</i> U	NCONTROLLED PROCEDURE _ DO NOT USE TO	PERFORM WOR	K or ISSUE FO	RUSE-***
PACIFIC	GAS AND ELECTRIC COMPANY		NUMBER	TP TO-0105
NUCLEA	R POWER GENERATION		REVISION	0
DIABLO	CANYON POWER PLANT		PAGE	1 OF 5
TEMPOR	ARY PROCEDURE		UNIT	
TITLE:	Diesel Generator 2-1 On-Line Maintenance		2	
		· . 	03/09 EFFECTI	0/01 VE DATE
	PROCEDURE CLASSIFICATION	: QUALITY RE	LATED	

1. <u>SCOPE</u>

- 1.1 This procedure is intended to provide operational guidance and contingency actions during the Diesel Generator (DG) 2-1 on line maintenance.
- 1.2 This procedure outlines various aspects of the project including the following:
 - 1.2.1 Prerequisite checklist should be completed prior to clearing DG 2-1 from service (see Attachment 9.1).
 - 1.2.2 Initial plant conditions for the start and duration of the MOW.
- 1.3 This procedures expires March 29, 2001 or upon completion of the DG 2-1 MOW.

2. DISCUSSION

- 2.1 The DG 2-1 routine maintenance is scheduled between March 20 and March 23, 2001. The duration of the MOW is scheduled for approximately 61 hours.
- 2.2 This procedure has been written to expect success while planning for failures. Specific initial plant operating conditions and restrictions should be in effect for the duration of the project.
- 2.3 This procedure will address those conditions that require backing out of the maintenance window and are listed in Attachment 9.2. Once inside the maintenance window the back out time should be limited to 1 shift.

. 11

3. **RESPONSIBILITIES**

- 3.1 The Turbine Building Asset ATL for all work associated with DG 2-1 MOW.
- 3.2 Operations Section for ensuring this procedure is performed, including shiftly checks and compensatory measures.
- 3.3 Turbine Building Assistant Team Leader and DG system engineer will give daily updates to the Operations Section management on project status.
- 3.4 The In Service Inspection Team for ensuring availability of inspection equipment prior to and throughout the DG 2-1 maintenance window.
- 3.5 Diesel Generator engineer and Assistant Team Leader to inform the Unit 2 SFM in the event a required prerequisite is not being met.

PAC DIAI	*** UNCONTROLLED PROCEDUREDO NOT USE TO PERFORM WORK or ISSUE FOR USE ***PACIFIC GAS AND ELECTRIC COMPANYNUMBERDIABLO CANYON POWER PLANTREVISION 0PAGE2 OF 5						
TITI	LE: Die	UNIT	2.				
4.	PRERE	QUISITES	INIT	<u>/DATE</u>			
	4.1	Prerequisites checklist (Attachment 9.1) is complete.		_/			
	4.2	The following organizations have been tailboarded, discussin work scope activities and contingency plans:	ng	_/			
		4.2.1 Operations					
		4.2.2 Turbine Asset Team					
		4.2.3 Engineering					
		4.2.4 In Service Inspection					
		4.2.5 Security					
		4.2.6 Safety					
		4.2.7 Warehouse					
	4.3	Maintenance Services has agreed to support the DG 2-1 maintenance window on a 24 hour a day (two, 12 hour shifts day) schedule.	s per	_/			
	4.4	A clearance has been approved to support removal of DG 2- from service.	1	_/			
5.	PRECA	UTIONS AND LIMITATIONS					
	5.1	Ensure proper compensatory measures are in effect for the observed on Attachment 9.1 and 9.2, as well as guidelines throuprocedure.	current projec ughout the bo	t period, dy of the			
	5.2	If, during the course of the project, a condition changes such the initial condition requirements or project restrictions, and performed by Engineering and Operations, with a determina Manager of Operations as to the proper course of action.	n that it no lo evaluation sho tion being ma	nger meets buld be ade by the			
	5.3	No maintenance, other than that agreed upon prior to this M without Engineering and Operations review for PMT require require no more than an STP M-9A.	OW will be p ements. All w -	performed ork must			

- - --- - -

PACIFIC GA DIABLO CA	AS AND ELECTRIC COMPANY NYON POWER PLANT	NUMBER REVISION	TP TO-0105
TITLE: Di	iesel Generator 2-1 On-Line Maintenance	PAGE UNIT	3 OF 5 2
5. INSTR	UCTIONS	· .	
*****	********	*****	*****
CAUTION: S	STP I-1C, Attachment 11.4 will be required to be performed in a n of the DG 2-1 maintenance window.	accordance wi	th TS 3.8.1
	· · · · · · · · · · · · · · · · · · ·	T	
6.1	Notify the DCPP Switching Center at extension 3519 to info them of project start. (reference OP J-6B:VII)	rm	/ <u>DATE</u>
<u>NOTE</u> perforr conside DGs (2 determ	Some of the routine maintenance on DG 2-1 is normally ned during refueling outages. None of the corrective maintenance ered a common cause failure. Hence starting of the remaining 2-3 and 2-2) following removal of DG 2-1 from service has been ined to be not required.	æ is	
6.2 ÷	Verify redundant safety related systems, subsystems, trains, components and devices for DG 2-3 operable within 24 hour declaring DG 2-1 inoperable.	s of	_/
6.3	Verify DG 2-3 Operable.		_/
6.4	Verify redundant safety related systems, subsystems, trains, components and devices for DG 2-2 operable within 24 hour declaring DG 2-1 inoperable.	s of	_/
6.5	Verify DG 2-2 Operable.		<u> </u>
NOTE other to	: Ensure that steps 6.6 and 6.7 are performed within 1 hour of e o satisfy TS.	each	
6.6	Declare DG 2-1 Inoperable and enter TS 3.8.1. Time TS entered:	<u></u>	_/
6.7	Perform STP I-1C, Attachment 11.4, "Modes 1, 2 and 3 "As Required" Operability Checks of Independent Circuits."		_/
	, · ·		
		-	
•	· · · ·		
		·. ·.	
		J	
	-		

PACIFIC GA DIABLO CAI	IMBER EVISION GE	TP TO-010 0 4 OF 5		
TITLE: Di	esel Genera	ator 2-1 On-Line Maintenance UN	IT	2
**************************************	********** Performance measures sh *********	of the following step places the project in the inoperable ould be addressed in accordance with Attachment 9.2.	******** e status. A *******	**************************************
			INIT	<u>/ DATE</u>
6.8	Hang clo (reference)	earance to support removing DG 2-1 from service. ce OP J-6B:VII)	<u>-</u>	/
6.9	Turbine mainten	Asset Team reports on DG 2-1 clearance to begin ance.	<u></u>	/
6.10	Turbine post mai	Asset Team has completed work on DG 2-1 to support intenance testing.		/
6.11	Operatio	on removes clearance on DG 2-1.		./
6.12	Enginee: testing o	ring and Turbine Asset Team begin post maintenance on DG 2-1.		/
6.13	Enginee: Operatio	ring and Turbine Asset Team turn DG 2-1 over to ons and have reported OFF of the DG 2-1 clearance.		/
6.14	Operation testing of the other of the other of the other oth	ons and Engineering has completed post maintenance on DG 2-1 to support returning DG 2-1 to service.		/
<u>NOTE</u> "NORM comper	: Completion MAL" completions AL" complete compl	on of the following step returns the project to the bensatory measure level. This means there are no sures in effect for the DG 2-1 maintenance.		
6.15	Exit T.S	. 3.8.1 Time TS exited:		/
6.16	Notify tl project c	he DCPP Switchyard Center at 3519 to inform them of completion. (reference OP J-6B:VII)		/
6.17	Remove	CAUTION signs from the following locations;		
	6.17.1	DG 2-3 and 2-2		_/
	6.17.2	Vital 4KV bus F, G and H	<u></u>	_/
	6.17.3	Vital 480 V bus F, G and H	-	_/
	6.17.4	Motor driven and turbine driven AFW Pp rooms.	<u></u>	_/
6.18	Return t	he following equipment to SFM desired configuration;		
	6.18.1	Aux building ventilation supply/exhaust fans		_/
	6.18.2	Overall Aux building ventilation control room select		_/
	6.18.3	Fuel handling ventilation control room select		_/
	6.18.4	BA Transfer Pump and Primary Water Make-Up Pumps		1

.

PAC DIA	UNCO CIFIC GA BLO CAN	DNTROLLED PROCEDURE DO NOT USE TO PERFORM WOR S AND ELECTRIC COMPANY NYON POWER PLANT	<i>K or ISSUE FO</i> NUMBER REVISION PAGE	DR USE **** TP TO-0105 0 5 OF 5
TIT	LE: Di	esel Generator 2-1 On-Line Maintenance	UNIT	2
7.	REFER	RENCES		
	7.1	EOP ECA-0.3, " Restore 4KV Busses."		
	7.2	AD7.ID4, " On-Line Maintenance Scheduling."		
	7.3	OP O-13, "Transferring Equipment To/From Alternate Pow	ver Sources."	
	7.4	AR PK 17-17 " 4Kv Bus G or SU FDR UV"		
	7.5	AD7.ID6, " On-Line Maintenance Risk Management"		
8.	<u>RECO</u>	<u>RDS</u>		
	None			
9.	ATTA	CHMENTS		
	9.1	"Prerequisite Checklist," 03/02/01		
	9.2	"Compensatory Measures," 03/02/01		
	9.3	"Support Information," 03/02/01		

، ، ۰

. .

•

,

- **f** -

.

11.

-

.

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

03/02/01

DIABLO CANYON POWER PLANT TP TO-0105 ATTACHMENT 9.1 Page 1 of 3

2

TITLE: Prerequisite Checklist

1.1 * A walkdown has been performed by DG system engineer or designee	
verifying DG 2-3 and associated area is clean and in good material condition with no work being performed which could jeopardize operation.	/
1.2 * A walkdown has been performed by DG system engineer or designee verifying DG 2-2 and associated area is clean and in good material condition with no work being performed which could jeopardize operation.	
1.3 * Diablo Canyon Switching Center has been contacted to verify offsite power sources are not in danger of being lost due to wild land fires, other grid related transients, or scheduled work activities.	/
 1.4 * No elective maintenance or testing to be performed on Unit 1 or Unit 2 components required to crosstie vital 4kV bus' as required by DCPP Emergency Operating Procedures, Appendix X, "Crosstie of Vital Bus." See Attachment 9.3 for the list of effected Appendix X breakers. 	/
 1.5 * No elective maintenance or testing to be performed on either unit 12kV startup bus. 	/

* These items are to be maintained current for the duration of the DG 2-1 maintenance project.

UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE

03/02/01

Page 2 of 3

TP TO-0105 (UNIT 2)

TITLE: Prerequisite Checklist

i

. ·		<u>INIT_/ DATE</u>
1.6	Contact Security to ensure adequate security support for DG 2-1 maintenance window.	/
1. 7 . 30	Place 480 V equipment on alternate power supplies or select alternate equipment as described by Attachment 9.3.	/
1.8	Verify DG 2-3 Operable with STP M-9A, "Diesel Engine Generator Routine Surveillance Test," current for duration of project.	/
1.9	Verify DG 2-2 Operable with STP M-9A, "Diesel Engine Generator Routine Surveillance Test," current for duration of project.	/
1.10	Verify STP P-PDFOTP-01, "Routine Surveillance of Portable Diesel Fuel Oil Transfer Pump 0-1," current for duration of project.	/
1.11	Verify STP M-10A, "Diesel Fuel Oil Storage Tank Inventory," current for duration of project.	/
1.12	Verify STP V-303, "Exercising Valves LCV-85 Through LCV-90," current for duration of project.	/
1.13	Verify STP P-DFO-01, "Routine Surveillance Test of Diesel Fuel Oil Transfer Pump 0-1," current for duration or project.	/
1.14	Verify STP P-DFO-02, "Routine Surveillance Test of Diesel Fuel Oil Transfer Pump 0-2," current for duration of project.	/
1.15	Turbine Asset team has verified all parts and equipment necessary for the project have been procured and meet quality related checks.	/
1.16	Bio-fouling Group has performed an evaluation and had determined a High Swell Warning is not expected for the duration of the DG 2-1 maintenance project.	/
1.17	An assessment has been performed verifying there are no known maintenance related equipment problems that could result in the performance of the DG 2-1 maintenance project causing an unacceptable	
	risk.	/

. . .

*** UNCONTROLLED PROCEDURE - DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

03/02/01

TP TO-0105 (UNIT 2) ATTACHMENT 9.1

TITLE: Prerequisite Checklist

INIT / DATE

_/_____ _/

Page 3 of 3

1.18	CAUTION signs have been posted on the doors to the following rooms
	which require SFM permission to perform work within;

- 1.18.1 DG 2-3, 2-2,
- 1.18.2 Vital 4kV bus F, G and H (U-2)
- 1.18.3 Vital 480 V bus F, G and H (U-2)
- 1.18.4 Motor driven and turbine driven AFW Pp rooms (U-2)
- 1.19 Verify adequate diesel fuel oil is available to perform required project PMTs.
- 1.20 Verify cold or hot wash of transformers is not required for the duration of the project.

Date

Shift Foreman:_

Signature

3WFK52ZZ.DOC 09A 0309.0252

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

03/02/01

DIABLO CANYON POWER PLANT

TP TO-0105 ATTACHMENT 9.2

TITLE: Compensatory Measures

÷

<u>Discussion</u>: The table below summarizes the major project scope evolutions and the corresponding compensatory measures. The terminology of Normal and Level 1 periods refer to the compensatory measures in place during specified project phases.

Page two of this attachment details the compensatory measures required, based on the "Level" defined by the project evolution in progress.

The project prerequisites and the compensatory measures mitigate the probabilistic risk presented by this project. For this reason, any deviation from prerequisites and compensatory measures requires review and approval or Operations, Maintenance, Engineering and the Manager of Operations.

Page 1 of 2

EVOLUTION	Pre-start	Project start	Project End
COMP MEASURE LEVEL	NORMAL	LEVEL 1	NORMAL

Pre-start:This period is defined as prior to the start of the DG 2-1 maintenance project.Project start:This period begins when clearance removing DG 2-1 from service is hung and the
Turbine Asset Team reports on the DG 2-1 clearance.Project End:This period begins when the DG 2-1 clearance is no longer hung and DG is

This period begins when the DG 2-1 clearance is no longer hung and DG is Operable.

3WFK52ZZ.DOC 09A 0309.0252

*** UNCONTROLLED PROCEDURE - DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

03/02/01

TP TO-0105 (UNIT 2) ATTACHMENT 9.2

TITLE: Compensatory Measures

COMPENSATORY MEASURES

The following compensatory measures should be in effect unless reviewed by Operations, Maintenance, Engineering, and the Manager of Operations and determined to be unnecessary.

PROJECT PERIODS

APPLICABLE COMPENSATORY MEASURES

1) Level 1

- Work that may cause a trip hazard on Unit 1 or 2 should not be performed. Exceptions should be authorized in accordance with AD7.DC6 On-Line-Maintenance Risk Management.
- 1b. Wild land fire or other external events that may jeopardize offsite power sources need to be brought to the attention of; Operations, Maintenance, Engineering, and the Manager of Operations to determine if project postponement is warranted.
- 1c. No elective maintenance or testing (other than normally scheduled surveillances) should be performed on operable Unit 1 or Unit 2 diesel generators.
- 1d. No elective maintenance or testing on the 230Kv and 500Kv offsite power sources should be performed. Exceptions may be authorized by the Operations Manager.
- 1e. No testing or elective maintenance should be performed on Unit 1 or Unit 2 unless approved per the T1 schedule. Exceptions approved by the Shift Manager and/or Work Week Manager may be performed.
- 1f. Senior management will provide on shift support in the event conditions jeopardize plant operation (Wild land fires, High Swell Warning, electrical distribution problems.)

Page 2 of 2

*** UNCONTROLLED PROCEDURE = DO NOT USE TO PERFORM WORK or ISSUE FOR USE ***

03/02/01

Page 1 of 1

DIABLO CANYON POWER PLANT TP TO-0105 ATTACHMENT 9.3

TITLE: Support Information

Ĭ.,•

- -

1. BREAKERS USED TO CROSSTIE VITAL BUS' IN EOP APPENDIX X.

- 1.1 7 4KV auxiliary feeder breakers; 52-HH-13, 52-HG-13, and 52-HF-13.
- 1.2 4KV startup feeder breakers; 52-HH-14, 52-HG-14, and 52-HF-14.
- 1.3 m Startup feeder breaker to 4KV vital bus'; 52-HG-15.

2. ALTERNATE SOURCES OR EQUIPMENT FOR 480V BUS H BREAKERS/LOADS

- 2.1 SFM should direct the following equipment be placed in service for the duration of the DG 2-1 maintenance project.
 - 2.1.1 Boric Acid Pump 2-1 supplying the blender.
 - 2.1.2 Spent Fuel Pool Pump 2-2.
 - 2.1.3 Fuel handling ventilation supply fan S-2 (w/selector switch in S-2 position).
 - 2.1.4 Primary water pump 2-1.
 - 2.1.5 Control Room ventilation selected to Bus 2H.
 - 2.1.6 Aux Bldg Supply Fan S-34 (w/selector switch in S-34 position).

Enclosure 4 PG&E Letter DCL-03-xxx

Diablo Canyon Power Plant Surveillance Test Procedure STP M-9A, "Diesel Engine Generator Routine Surveillance Test"

Diablo Canyon Power Plant Surveillance Test Procedure STP M-9D1, "Diesel Generator Full Load Rejection Test"

***]	SSUED F	OR USE .	BY:		DATE:	EXPIRES:	***
PACIFIC GAS AND ELECTRIC COMPANY					Y	NUMBER	STP M-9A
NUCLEAR POWER GENERATION						REVISION	65
DIAI	BLO CAN	YON PO	WER	PLANT		PAGE	1 OF 32
SUR	VEILLAN	CE TES	Г PRC	DCEDURE		UNITS	
TITLE: Diesel Engine Generator R					Surveillance Test	1	AND 2
					· , ·		
						<u>/0-/0</u>	-0.5
		p	ROCK	DURF CLASS	IFICATION: OU	ALITY RELATED	VE DATE
			NUCL		MICATION: QU		
1.	<u>SCOPE</u>			•	· .	,	
	1.1	This pro 1-2, D/0 (PMT).	ocedur 3 1-3,	e is used to perfo D/G 2-1, D/G 2-	orm the monthly tes -2, and D/G 2-3. It i	t on diesel generator (D/G) may be used as a post main	1-1, D/G tenance test
	1.2	Diesel f	uel oil	transfer systems	s train A and train B	are tested.	
	1.3	The day	[,] tank i	is checked for wa	ater and verified to	contain \geq 250 gallons of di	esel fuel.
2.	DISCUS	<u>sion</u>					
	2.1 To demonstrate the OPERABILITY of the D/G, the following checks are performed.					formed.	
		2.1.1	Pre	firing Checks			
			a.	Cooling system	m level and tempera	iture.	
			b.	Lube oil level	and temperature.		
			c.	Day and primi	ing tanks fuel level.		•
			d.	Compressed a	ir availability.		
			e.	Governor oil l	evel.		
		2.1.2	Che	cks During Star	ting		
			а.	Starting circui	it OPERABILITY.		
			b.	D/G starts with	h one starting train.	,	
			c.	During timed	starts, cranking time	e to start.	
			d.	D/G starts eith	er from control room	m, solid state protection sys	stem, or on a
				simulated UV	signal (only one is]	proven each test).	,
			e.	Fuel system O	PERABILITY.	-	
			f.	Governing and	d control system OP	ERABILITY.	
			g.	OPERABILIT STP M-16A, S	Y of SI auto start fe STP M-16BA or STI	ature when run in conjunct P M-16BB.	ion with
					• • •		

:

NUMBER	STP M-9A
REVISION	65
PAGE	2 OF 32
UNITS	1 AND 2

TITLE: Diesel Engine Generator Routine Surveillance Test

2.1.3 Checks during operation while loading and loaded

- a. Fuel system OPERABILITY.
- b. Governing and control system OPERABILITY.
- c. Cooling system OPERABILITY.
- Ability of unit to accept and carry a sustained load ≥ 2.45 MW and ≤ 2.50 MW (≥ 2340 KW and ≤ 2600 KW Tech Spec) for one hour without apparent malfunctions.
- e. Ability of fuel oil transfer system to deliver fuel oil to D/G day tank.
- f. Fuel oil level in the day tank remains above the low level alarm.
- 2.1.4 Checks After Power Run
 - a. Lube oil system.
 - b. Cooling system.
 - c. Compressed air system.
 - d. Fuel priming system.
 - e. D/G alignment to associated emergency bus.
 - f. Day tank water accumulation.
- 2.2 After the D/G has operated at \geq 2.45 MW, the load will be reduced on the unit to about 0.50 MW and the unit will be allowed to cool before it is separated and shutdown.
- 2.3 Not all of the parameters observed during this test will indicate an inoperable D/G. Those variables which directly indicate OPERABILITY are marked on data sheets. Technical Specification (Tech Spec) 3.8.1, 3.8.2 or 3.8.3 actions must be taken, management notified without delay, and an action request (AR) initiated. Other variables, if out of limits, should be reported in a routine manner in an action request.
- 2.4 If one or both trains of the fuel oil transfer system are found to be inoperable, the appropriate Tech Spec 3.8.1 Action F.1 or G.1 for MODES 1 5 must be followed.
- 2.5 The diesel fuel oil transfer pumps 0-1 and 0-2 discharge check valves (DEG-0-35, DEG-0-36) and the fuel oil tanks 0-1 and 0-2 suction check valves (DEG-0-1114, DEG-0-1115 for DFOST 0-1 and DEG-0-1117, DEG-0-1118 for DFOST 0-2) will be checked by the operation of the diesel fuel oil transfer pumps 0-1 and 0-2.
- 2.6 If the D/G starts successfully, the starting air system and turbocharger air assist system solenoid valves will be considered acceptable.
- 2.7 Sampling of a D/G fuel oil day tank for particulate contamination (STP M-10B2) should coincide with performance of this test.

	T
 -	R
 £ .	-

NUMBER
REVISIONSTP M-9APAGE65J AGE3 OF 32UNITS1 AND 2

TITLE: Diesel Engine Generator Routine Surveillance Test

3. <u>RESPONSIBILITIES</u>

3.1 Shift foreman (SFM), for scheduling test, operation of equipment, obtaining data and data reduction required by this procedure, evaluation of the results, and determination of D/G operability.

4. <u>FREQUENCY</u>

2.

. . .

- 4.1 The D/G testing frequency is once every 31 days.
- 4.2 Each D/G will be tested on a schedule developed for Mode 1 integrated daily schedule (MOIDS).
 - 4.2.1 Even numbered months: A manual start from the control room should be performed. (Tech Spec SR 3.8.1.2 and Tech Spec SR 3.8.1.7)
 - 4.2.2 During manual starts in the months of April, August and December, use starting train A. During manual starts in months of February, June and October, use starting train B.
 - 4.2.3 Odd numbered months: A simulated loss of off-site power (undervoltage) should be performed. (Tech Spec SR 3.8.1.2).
 - 4.2.4 During the manual starts, the D/G is started from standby condition and accelerates to 900 rpm in ≤ 10 seconds and the D/G voltage is ≥ 3785 V and ≤ 4400 V in ≤ 13 seconds after the D/G start signal (with gauge readability and instrument accuracy included, limit becomes 113 V to 121 V as read from the "Diesel Output Voltmeter" on VB4) and the D/G frequency is 60 ± 1.2 HZ in ≤ 13 seconds after the D/G start signal (with gauge readability and instrument accuracy included, limit becomes 59.5 HZ to 60.5 HZ). A timed start is required every 184 days but is performed more frequently for D/G performance monitoring. (Tech Spec SR 3.8.1.7)
 - 4.2.5 If STP M-16A, M-16BA or M-16BB is being performed in conjunction with STP M-9A, the method of starting the D/G (i.e., with an SI signal) can be substituted for one of the methods in 4.2.1 or 4.2.3.
 - 4.2.6 If plant conditions require a different starting method than that specified above, the starting method may be changed with SFM concurrence.
- 4.3 This test is required to be current in MODES 1 through 6.

NUMBER REVISION	STP M-9A 65		
PAGE	4 OF 32		
UNITS	1 AND 2		

TITLE: Diesel Engine Generator Routine Surveillance Test

5. <u>TECHNICAL SPECIFICATIONS</u>

- 5.1 Tech Spec SR 3.8.1.2: Verify each D/G starts from standby conditions and achieves speed \geq 900 rpm, steady state voltage \geq 3785 V and \leq 4400 V, and frequency \geq 58.8 HZ and \leq 61.2 HZ.
- 5.2 Tech Spec SR 3.8.1.3: Verify each D/G is synchronized and loaded and operates for ≥ 60 minutes at a load ≥ 2340 KW and ≤ 2600 KW.
- 5.3 Tech Spec SR 3.8.1.4: Verify each day tank contains \geq 250 GAL of fuel oil.
- 5.4 Tech Spec SR 3.8.1.5: Check for and remove accumulated water from each day tank.
- 5.5 Tech Spec SR 3.8.1.6: Verify the fuel oil transfer system operates to transfer fuel oil from storage tanks to the day tank.
- 5.6 Tech Spec SR 3.8.1.7: Verify every 184 days each D/G starts from standby condition and achieves:
 - 5.6.1 in \leq 10 seconds, speed \geq 900 rpm; and
 - 5.6.2 in \leq 13 seconds, voltage \geq 3785 V and \leq 4400 V, and frequency \geq 58.8 HZ and \leq 61.2 HZ.
- 5.7 Tech Spec SR 3.8.3.4: Either air receiver A shall be \geq 180 PSIG or air receiver B shall be \geq 180 PSIG.
- 5.8 Tech Spec Bases for Action 3.8.3.E.1 and SR 3.8.3.4 assumes starting train A or starting train B will start the D/G. A single starting train test periodically checks this assumption.
- 5.9 Tech Spec SR 3.8.3.6: Verify turbocharger air receiver shall be \geq 180 PSIG.
- 5.10 ECG SR 21.3.1: Verify the D/G is aligned to provide standby power to the associated emergency bus.
- 5.11 ECG SR 21.3.2: Verify the D/G protective relay trip cutout switch is returned to the cutout position following each D/G test.
- 5.12 Tech Spec SR 3.8.2.1: Establishes which of the above requirements apply with the plant in MODES 5 or 6.

PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON POWER PLANT

.

	NUMBER REVISION	STP M-9A 65	
∇T	PAGE	5 OF 32	
• •,	UNITS	1 AND 2	

•

TITLE: Diesel Engine Generator Routine Surveillance Test

<u>ACCE</u>	PTANCE (CRITERIA
6.1	A D/G	shall be considered OPERABLE if the following acceptance criteria are met:
•• •	6.1.1	The D/G is started by either manual, startup bus undervoltage, or SI signal. (Tech Spec SR 3.8.1.2)
4 35 £	6.1.2	The D/G starts from standby condition and accelerates to \geq 900 rpm. (Tech Spec SR 3.8.1.2)
	6.1.3	The D/G voltage is \geq 3785 V and \leq 4400 V (with gauge readability and instrument accuracy included, limit becomes 113 V to 121 V as read from the "Diesel Output Voltmeter" on VB4). (Tech Spec SR 3.8.1.2)
	6.1.4	The D/G frequency is \geq 58.8 HZ and \leq 61.2 HZ after the D/G start signal (wit gauge readability and instrument accuracy included, limit becomes 59.5 HZ to 60.5 HZ). (Tech Spec SR 3.8.1.2)
	6.1.5	When the D/G is started and timed from standby condition it: (Tech Spec SR 3.8.1.7)
·* ;		a. Accelerates to 900 rpm in \leq 10 seconds,
		 b. The D/G voltage in ≤ 13 seconds is ≥ 3785 V and ≤ 4400 V (with gauge readability and instrument accuracy included, limit becomes 113 V to 121 V as read from the "Diesel Output Voltmeter" on VB4), and
		c. D/G is \geq 58.8 HZ and \leq 61.2 HZ in \leq 13 seconds after the D/G start signal (with gauge readability and instrument accuracy included, limit becomes 59.5 HZ to 60.5 HZ).
	6.1.6	When D/G is started with one starting train, the D/G shall meet the requirements of step 6.1.5.
	6.1.7	Operate the D/G at a power level of ≥ 2340 KW and ≤ 2600 KW for ≥ 60 minutes. The assumed power uncertainty is ± 71 KW and the power meter minor divisions are every 0.1 MW. Using these corrections the power out will be maintained ≥ 2.45 MW and ≤ 2.50 MW. Momentary transients outside the load range do not invalidate this test. (Tech Spec SR 3.8.1.3)
	6.1.8	The D/G protective relay cutout switch is returned to the CUTOUT position following the test. (ECG SR 21.3.2)
	6.1.9	The D/G is aligned to provide standby power to the associated emergency buses. (ECG SR 21.3.1)
	6.1.10	D/G fuel oil day tank inventory is above the low level alarm (\geq 250 GAL). (Tech Spec SR 3.8.1.4)

PACIFIC DIABLO	GAS AND ELECTRIC COMPANY CANYON POWER PLANT	NUMBER REVISION PAGE	STP M-9A 65 6 OF 32
TITLE:	Diesel Engine Generator Routine Surveillance Test	UNITS	1 AND 2

		6.1.11	Each fuel transfer pump starts and transfers fuel from the storage system to the D/G engine-mounted tank via installed lines for the unit under test. (Tech Spec SR 3.8.1.6)			
		6.1.12	Monthly check for removal of water from the day tank. (Tech Spec SR 3.8.1.5)			
		6.1.13	Either air receiver A shall be \geq 180 PSIG or air receiver B shall be \geq 180 PSIG. With instrument inaccuracy, at least one air receiver shall be \geq 195 PSIG. (Tech Spec SR 3.8.3.4)			
		6.1.14	Turbocharger air receiver shall be \geq 180 PSIG. With instrument inaccuracy the air receiver shall be \geq 195 PSIG. (Tech Spec SR 3.8.3.6)			
6.	6.2	Check valves and solenoid valves shall be considered acceptable as follows:				
		6.2.1	The diesel fuel oil transfer pumps 0-1 and 0-2 discharge check valve (DEG-0-35, DEG-0-36) shall be considered acceptable if the diesel fuel oil transfer pumps 0-1 and 0-2 deliver fuel into the day tank.			
		6.2.2	The fuel oil tanks 0-1 and 0-2 suction check valves (DEG-0-1114, DEG-0-1115 for DFOST 0-1 and DEG-0-1117, DEG-0-1118 for DFOST 0-2) shall be considered acceptable if the diesel fuel oil transfer pump delivers fuel into the day tank.			
		6.2.3	The starting air system and turbocharger air assist system solenoid valves shall be considered acceptable if the D/G starts and accelerates to at least 900 rpm in ≤ 10 seconds. Timing the D/G is required every 184 days (≈ 6 months). Administratively the D/Gs are timed on every manual start.			
DECEDENCES						

7. <u>REFERENCES</u>

- 7.1 PG&E Drawing No. 437579 Unit 1, 4KV Diesel Generator Control No. 11 and 12.
- 7.2 PG&E Drawing No. 437667 Unit 1, 4KV Diesel Generator Control No. 13.
- 7.3 PG&E Drawing No. 437546 Unit 1, 125 Volt DC System.
- 7.4 PG&E Drawing No. 106721 Unit 1.
- 7.5 PG&E Drawing No. 441357 Unit 2, 4KV Diesel Generator Control No. 21 and 22.
- 7.6 PG&E Drawing No. 496277 Unit 2, 4KV Diesel Generator Control No. 23.
- 7.7 PG&E Drawing No. 441240 Unit 2, 125 Volt DC System.
- 7.8 PG&E Drawing No. 107721 Unit 2.
- 7.9 NCR DCO-90-EN-N032.

		7.4
	,	R
, , , ,	¥ .	P/

8. <u>APPENDICES</u>

- 8.1 KW-KVAR, Power Factor Relations for Diesel Generators
- 8.2 Combined Engine and Generator Operating Limits

9. <u>ATTACHMENTS</u>

.

9.1 "Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators," 10/07/03.

.

- 9.2 "Data Sheet Routine Surveillance Test of Unit 2 Diesel Generators," 10/07/03
- 9.3 "Unit 1 Undervoltage Test at Switchgear Room," 10/07/03
- 9.4 "Unit 2 Undervoltage Test at Switchgear Room" 10/07/03

PACIFIC GAS AND ELECTRIC COMPANY NUM DIABLO CANYON POWER PLANT REVI PAGI							NUMBE REVISIO PAGE	R ON	STP M-9A 65 8 OF 32	
TITL	.E: Die	esel Engin	e Generat	or Routine S	Surveillance	Test	UNITS		1 AND 2	
START DATA SECTION										
										
10	DIESEL GENERATOR NO.						- TA	INITIAL S		
10.	 (Some of the following are repeated in the OP J-6B series on D/G manual operations) 10.1 If the D/G is paralleled to the auxiliary transformer and the main unit trips, the aux bus feeder breaker will automatically open and the D/G will carry the bus load. Verify that the bus feeder breaker opened and place the D/G MODE SEL switch into AUTO. 10.2 If the D/G is paralleled to startup power and a loss of offsite power occurs, the startup feeder breaker will not automatically open. The D/G will attempt to supply power to loads connected to the grid. Open the startup feeder breaker or verify the D/G breaker tripped. Place the D/G MODE SEL switch into AUTO if the feeder breaker was opened. 10.3 When paralleling a D/G to any off-site power source or the D/G MODE SEL switch is in MANUAL and the D/G is not running, declare the D/G inoperable. In MODES 1, 2, 3, and 4, perform the actions required for Tech Spec 3.8.1. In MODES 5, 6, and irradiated fuel movement, perform the actions required for Tech Spec 3.8.2. 							<u>•111</u>		
									_	
	10.4 The D/G should not be operated for an extended period of time below 0.65 MW.						ime		_	
		10.4.1	If a D/C action is	is operated a necessary.	< 0.65 MW 1	for < one hour, r	no			
		10.4.2	If a D/G < 10 ho ≥ 1.30 N	is operated urs, then the MW for \geq one	< 0.65 MW f D/G should l e hour.	for \geq one hour b be operated	ut			
		10.4.3	If the D ≤ 0.65 N > one ho	/G is to be op /IW, the D/G our at the end	berated for lo should be lo l of each 10 l	nger than 10 ho aded to ≥ 1.3 M nour period.	urs IW for	-		
		<u>NOTE</u> : time can be detrin	Operatior expose th nental to e	of D/G < 0. e engine to u ngine perforr	65 MW for a indesirable co mance and co	n extended peri onditions which omponent life.	od of may			

ł

.
ABLO CAI	NUMBER REVISION PAGE	STP M-9A 65 9 OF 32					
ГLE: Di	esel Engine Generator Routine Surveillance Test	UNITS	1 AND 2				
······			· · · · ·				
		<u>INII</u>	IALS				
10.5	Excessive field currents and rotor temperatures may occur	hergized.	_				
10.6 -2 : :	When paralleling a D/G, pick up load (0.50 MW) as soon possible (< 15 seconds) after the breaker is closed. This w prevent the D/G breaker from tripping on directional powe (DIR PWR).	as vill er					
10.7	There should be fuel oil in the priming tank. If there is no priming tank should be filled using the magnetic pump. Document problem in an AR.	t, the	_				
10.8	The fuel oil pressure should increase to above 40 PSIG with 60 seconds of engine start. Gauge response is about 15 seconds of engine start.	thin conds.					
10.9	'Do not violate the following limits during normal steady-state operation:						
	10.9.1 Maximum continuous generator current is 451 a	mperes.	_				
··· •	10.9.2 Maximum stator temperature is 240°F.	· . 					
	10.9.3 Minimum lube oil pressure is 60 PSIG.	·	<u> </u>				
1 m	10.9.4 Maximum lube oil temperature is 195°F.		_				
	10.9.5 Power factor: 1.0 to 0.8 lag (see Appendix 8.1).	· · ·	_				
	10.9.6 Load: 2.60 MW at 0.8 PF (see Appendix 8.2 for maximum limits).	r	_				
	<u>NOTE</u> : The D/G may operate at > 2.5 and ≤ 2 at 0.8 PF for up to 2000 hours per year.	.75 MW					
10.10	Normal shutdown of a D/G requires DC control power. If it becomes necessary to shutdown the D/G without control power, manually operate the trip lever on the north west corner of the engine, forward of the fuel oil filters.						
10.11	Do not operate more than one D/G at a time paralleled to a transformer (startup or unit auxiliary) in MODE 1, 2, 3, or 3.8.1.3 Note 3).	ny 4 (SR	_				
10.12	The applicable D/G MODE SEL switch on VB4 shall be in MANUAL prior to paralleling the D/G to the bus.	I	: _				

•

.

į

PACIFIC GAS DIABLO CAN	NUMBER REVISION PAGE	STP M-9A 65 10 OF 32	A 2				
TITLE: Die	esel Engine	Generator Routine Surveillance Test	UNITS	1 AND 2			
			INITI	IALS			
10.13	EQD Pa	nel, Control Power Selection					
	10.13.1	The D/G shall have its NORMAL DC source energy and selected in MODES 1-4. If the BACKUP source selected in these MODES, the D/G is considered inoperable.	gized rce is	_	·		
	10.13.2	The preferred alignment in MODE 5, 6 or defueled for the D/G to have its NORMAL DC source energy and selected.	l is gized				
	10.13.3	The D/G may have its BACKUP source selected in MODE 5, 6 or defueled and still be considered OPERABLE, provided cross tie capability exists (in capable to supply power to the battery charger align to the D/G's DC source.)	.e., ned	_			
10.14	10.14 Verification signoff spaces in this procedure may be for concurrent or independent verification. Concurrent verification is required when the letters "CV" are present between the "PERF" and "VERIF" signoff spaces. When no "CV" is present, independent verification is required.						
10.15	Day tank level columns respond very slowly to a level change. To avoid overflowing the day tank, use caution when manually filling the tank.						
10.16	The procedure is written to test all 6 D/Gs which is further broken down into a series of Unit 1 and Unit 2 component IDs in steps which require clear and specific designations of the intended components. For example a listing for a Unit 1 relay may be 27HHU (27HGU) (27HFU). The first device (27HHU) is the applicable component when D/G 1-1 is being tested, 27HGU applies to D/G 1-2 testing, etc. Similar logic applies to Unit 2 devices.						
10.17	Crankcase exhausters should be operating while engine is running. If they are not operating, the D/G is still OPERABLE. An AR shall be initiated and repairs should be made in a timely fashion. The D/G may experience more oil leakage from the block than normal if crankcase exhausters are not running.						
10.18	The D/G < 95°F un	should not be started if the lubricating oil temperatur less engineering has evaluated the condition.	e is	_	I		
10.19	Starting a described	r header and turbo air pressure should be monitored in Attachments 9.1 and 9.2, step 1.13.	as 	-	_		

}

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT NUMBER STP M-9 REVISION 65 PAGE 11 OF :									
FITI	LE: Die	esel Engin	e Generator Routine Surveillance Test		UNITS	1 AND 2			
	- ·		• a ·	<u> </u>		-			
					PERF	2			
11.	PRERE	QUISITES	2						
	11.1	Shift for	reman's permission given to perform the t	est.					
	•. 	Signatu	re:Shift Foreman	Date/Time	<u> </u>				
	11.2	D/G CC powder	D ₂ fire protection system OPERABLE or p fire extinguishers are available.	ortable dry		_			
	11.3	One of t	he following conditions is met:						
		11.3.1	The D/G is aligned for normal operatio with OP J-6B.	n in accordar					
			OR						
	 72 	11.3.2	The D/G is aligned for normal operatio with OP J-6B, except the EDQ panel is backup and the battery charger aligned power supply is cross tied to the D/G b available only in MODE 5, 6 or defuele	n in accordar switched to to the backup us. This opti d. N/A [nce 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5				
	11.4	The bus	The bus to which the D/G is to be paralleled shall be energized.						
	11.5	Utilizing annuncia OPERA	g the information in the control room (i.e., ators, etc.), check to see if the other D/Gs BLE.	clearance log for the unit a	gs, re				
		11.5.1	Verify the action requirements in Tech MODES 1-4 or Tech Spec 3.8.2, in MC irradiated fuel movement are being follo	Spec 3.8.1, in DES 5, 6 and owed.	1 · 1				

1

PACIFIC GA DIABLO CA TITLE: Di	AS AND ELECTRIC COMPANY N NYON POWER PLANT R P iesel Engine Generator Routine Surveillance Test U	TUMBER REVISION PAGE INITS	STP M-9A 65 12 OF 32 1 AND 2
		PERF	
11.6	The following test equipment is available and is in current calibration:		
	11.6.1 Three stopwatches if timing the start.		
	N/A[J	·	_
	ID # <u>Cal Due Date</u>		
	$11.6.2$ Vioration meter and pickup with $\pm 5\%$ of full scale accuracy or better.		_
	a. Vibration Meter ID No.		
	Cal Due Date		
11.7	When a vertical board recorder or instrument is not functioning properly, equivalent or more accurate M&TE equipment may be used. Install M&TE per CF4.ID7, "Temporary Modifications." Record in REMARKS the meter or recorder number, the parameter measured, the M&TE equipment number, and the calibration due date.		
	N/A []		-
11.8	If this test is being performed after work was conducted on the D/G, verify that no ground buggy is installed in the D/G output breaker switchgear cubicle.		
	N/A []		-
11.9	If test is used to satisfy Tech Spec SR 3.8.1.2 or Tech Spec SR 3.8.1.7, jacket water and lubricating oil temperature must be ≥ 95°F and ≤ 170°F. If M&TE is used to satisfy Tech Spec, use 90°F + M&TE uncertainty and 175 - M&TE	e	
	SR 3.8.1.7)	-	
	N/A []		
11.10	If the plant is in MODE 1, 2, 3 or 4, obtain an issued for use copy of STP I-1C, Attachment 12.4.		
	N/A []		

i

PACIFIC GAS AND DIABLO CANYON I	ELECTRIC COMPA OWER PLANT	NY	13 4 S	NUMBER REVISION PAGE	STP M-9A 65 13 OF 32
TITLE: Diesel Eng	gine Generator Routin	ne Surveillance	Test	UNITS	1 AND 2
				· · · · · · · · · · · · · · · · · · ·	
				PERI	2
11.11 Obta	in an issued for use ST start is attempted, STP	P M-91. Every 1 M-91 shall be p	time a D/G start erformed.	s or a	_
11.12 Com .: D/G	munications are establ switchgear rooms, and	ished between th I SSPS as approp	e control room, priate.	the	
11.13 Duri step	ng manual starts, isolat below, or as directed by	e starting train A y the shift forem	or starting train an.	n B per	
Isola	e Starting Train A in:	February Jun	e October	[]	
Isolat	e Starting Train B in:	April Au	gust December	· []	
	,		, N/A	·[]	
, 11.11	B.1 Based on the mon the air supply val	nth or shift foren ve to be closed.	nan's direction,	select	
•	D/G	1-1 (2-1)	1-2 (2-2)	1-3 (2-3)	
41	Train "A" Valve	DEG-63 []	DEG-89[]	DEG-115[]	
	Train "B" Valve	DEG-52[]	: DEG-78 []	DEG-104[]	
5. 11.12	.2 Based on the mor the blow-down va table below. Who 17-09, or 18-09, v	oth or shift foren alve to be uncap en the valve is op will alarm.	nan's direction, s ped and opened pened, PK16-09	select in the	_
	D/G	1-1 (2-1)	1-2 (2-2)	1-3 (2-3)	
	Train "A" Valve	DEG-227[]	DEG-249 []	DEG-271 []	
	Train "B" Valve	DEG-216[]	DEG-238[]	DEG-260[]	
	NOTE 1: When train "B" is being manipulated, trair	train "A" valves tested. When tr A is being teste	are manipulated ain "B" valves a d.	d, starting are	
	<u>NOTE 2:</u> This te starting train bein See Tech Spec Ba assumes one D/G	sting schedule s g able to start th ses B3.8.3.E.1. starting train wi	upports taking c e D/G in the req Tech Spec Base Il start the D/G.	redit for one uired time. es B SR 3.8.3.4	
		·		·.	

	PACI DIAB TITL	FIC GAS LO CAN	AND ELI YON POV	ECTR VER	LIC COMPANY PLANT erator Routine Surveillance	e Test	NUMBER REVISION PAGE UNITS	STP M-9A 65 14 OF 32 1 AND 2	
							PERF	· · · · · · · · · · · · · · · · · · ·	
]	12.	<u>PROCEI</u>	DURE						
		Diesel G	enerator N	lo					
		12.1	Notify th	ie con	trol operator that testing is r	eady to commence.			
			NOTE: methods method a	Some and lo and lo	e steps within this procedure bading. If the step does not a ading, mark the step N/A.	are for specific start apply to the starting	iing		
		12.2	Prestart	Check	s/Alignment				
			12.2.1	Hav sect to st are 1	e the field operator perform ion. If this is to be a single s ep 11.13 and inform the fiel to be manipulated.	the "PRETEST DA' starting train start, re d operator which va	TA" :fer lves	_	
			12.2.2	Mw	-Hr meter reading before tes	stMw	/-Hr	_	,
			12.2.3	List	alarms in prior to test			_	
									ᅴ
			12.2.4	Rec posi	ord the appropriate D/G MO tion.	DE SEL switch			. !
			12.2.5	The	following D/G protective re	lays are cutin:			•
					RELAY FEATURE	LOCATION			
				a.	Differential	on VB4 D/G PRO RELAYS CUT-IN DIFF light on.	Г , 	_	
				b.	Directional power, Loss of field, and Overcurrent*	Feature cutout swit on VB4, CUT-IN, directional power a loss of field lights	tch and are on	_	
				c.	4KV bus differential	on VB4 4KV BUS PROT RLY C/I lig	DIFF ht on.	_	1
				*	These features are required Specifications to be cutout however, these features sh duration of this test to prov D/G when paralleled to the are cutin for testing the D/ operable.	d by the Technical t for normal service; ould be cutin for the vide protection to the bus. While the rela G is considered	e ays		

:

-

PACIFIC GAS AND ELECTRIC COMPA	NY
DIABLO CANYON POWER PLANT	•

REV

NUMBER	STP M-9A
REVISION	65
PAGE	15 OF 32
UNITS	1 AND 2

TITLE: Diesel Engine Generator Routine Surveillance Test

D/G 1-1 T2802AD/G 2-1 T2802AD/G 1-2 T2803AD/G 2-2 T2803AD/G 1-3 T2804AD/G 2-3 T2804A	
	. .
12.2.7 If the plant is in MODE 1, 2, 3, or 4, perform visual check of offsite power supplies per standing orders. STP I-1C, Attachment 12.4 is required < 1 hour after	
D/G is inoperable. N/A []	
. · ·	

PACIFIC O DIABLO C	GAS AND EI ANYON PO	RIC COMPANY PLANT	NUMBER REVISION PAGE	STP M-9A 65 16 OF 32	
TITLE:	Diesel Engin	e Gen	erator Routine Surveillance Test	UNITS	1 AND 2
10.3	Starting	•		PERI	
12.5	NOTE underve with ST SI signa than spe approva	The oltage PM-1 al. If p ecified	D/G will normally be started manually or on an signal. This test may be performed in conjunct 6A, M-16BA or M-16BB and started on an lant conditions require a different starting method may be changed with SFI	n tion hod M	
	12.3.1	Rei	er to step 4.2 to determine the starting method		. ·
		MA UN SI	NUAL(Even Months)[]DERVOLTAGE(Odd Months)[](With STP M-16xx)[]		
		NO to r D/C the 12.2 ove	TE: On steps 12.3.7, 12.3.8, and 12.3.9, the ti each speed, voltage, and frequency vary with e G. Likewise, the overshoot varies depending up individual D/G governor. On steps 12.3.8 and 8.9, be aware that there may or may not be an rshoot in voltage and frequency; therefore, it w essary to carefully monitor these parameters.	imes each pon vill be	
	12.3.2	Des star	ignate a person to observe or time D/G speed v ting.	while	_
	12.3.3	Bef the take	ore starting D/G, be in direct communication wo operator in the D/G area so start-up data can be on within 60 seconds of D/G start.	vith e	
		a.	If required, verify the D/G starting train valv have been closed and opened. N/A	es	-
		b.	If M&TE is installed, inform maintenance so M&TE may be started or monitored as neces N/A	o the sary.	
				. •	

PACIFIC GA	AS AND ELECTRIC	COMPANY
DIABLO CA	NYON POWER PL	ANT

Diesel Engine Generator Routine Surveillance Test

TITLE:

يون. ج .

 .

NUMBER	STP M-9A
REVISION	65
PAGE	17 OF 32
UNITS	1 AND 2

· · ·				
子 (1) まった (2)教	NOTE: frequence was shur- range of speed at in ≤ 13 s A05627	1: If the two seconds $1 \ge 59.5$ the two seconds 32 .	the D/G was operated in manual mode and the not set to ≥ 60 HZ and ≤ 60.25 HZ when the D/G the frequency may stabilize outside the frequency 5 HZ and ≤ 60.5 HZ on the next manual start. If the 900 RPM in ≤ 10 seconds and the voltage stabilized s, the D/G is functioning as designed. (AR	PEKF
	NOTE 2 start sho undervol per shift	2: A ti ould be ltage st forem	med start is required every 184 days. Every manual timed for trending purposes. Simulated tarts and safety injection start signals may be timed an's direction.	
	12.3.4	If sta	arting the D/G manually, perform the following: N/A []	
• •		а.	Place the D/G appropriate D/G MODE SEL switch in MAN on VB4.	
5 A		b.	Declare D/G inoperable.	· · · ·
5 11.7 5 ^{- 1} - 2		c.	Simultaneously start the stopwatches and the D/G from the control room.	· · ·
	<u>NOTE</u> : delay.	If the	undervoltage start is timed, there is an 0.8 second	
	12.3.5	If sta follo	rting the D/G on an undervoltage, perform the wing: N/A []	
		а.	Station an operator in the appropriate vital 4KV switchgear room with Attachment 9.3 (9.4).	
		Ъ.	Establish communications between the D/G, control room, and appropriate vital 4KV switchgear room.	
		с.	Verify the appropriate D/G MODE SEL switch is in AUTO on VB4.	
		d.	Cutout the appropriate startup bus undervoltage (UV) relay per Attachment 9.3 (9.4).	
	12.3.6	If sta M-16 Proce	rting the D/G on an SI signal, use STP M-16A, BA or M-16BB to start the engine. edure used	
			N/A []	<u> </u>
		NOT STP I starts	E: STP M-16A starts D/G 1-1 and 2-2, M-16BB starts D/G 1-2 and 2-1, and STP M-16BA D/G 1-3 and 2-3.	

00316365.DOA 06 1007.0311

1

PACIFIC DIABLO	CAS AND EL CANYON POV	RIC COMPANY PLANT	NUMBER REVISION PAGE	STP M-9A 65 18 OF 32	
TITLE:	Diesel Engine	e Gen	erator Routine Surveillance Test	UNITS	1 AND 2
	NOTE:	Whe	in timing any start, record the stopwatch time. If	<u>PERF</u> Sight	
	time in s	steps	12.3.10, 15.1.2, 15.1.3 and 15.1.4.		
	12.3.7	Wł ≥9	nen the D/G starts, verify that the D/G speed rea 00 RPM.	ched	
		a.	Record the no-load stable speed prior to oper	ator	
			adjustment: RPM		
		<u>NC</u> ≤9 wit	<u>OTE</u>: It is acceptable for the stable speed to be 00 RPM or \geq 900 RPM so long as the frequency hin the required limits.	/ is	
	,	ь.	If applicable, record the starting time to reach 900 rpm. seconds (must be ≤ 10 seconds). N/A []	
			Stop Watch ID		_
	12.3.8	Ver ≤ 1	ify that the D/G voltage is stable ≥ 113 V and 21 V.		_
		.a.	If applicable, record the time for stable voltag \geq 113 V and \leq 121 V. seconds (must be \leq 13 seconds). N/A []	_
			Stop Watch ID		
	12.3.9	Ver 60.:	ify that the D/G frequency is stable \ge 59.5 HZ a 5 HZ.	nd ≤	_
		a.	If applicable, record the time for stable freque \geq 59.5 HZ and \leq 60.5 HZ. seconds (must be \leq 13 seconds).	ncy	
			Stop Watch ID	J <u> </u>	-

.|

PACIFIC DIABLO	IC GAS AND ELECTRIC COMPANY NUMBER O CANYON POWER PLANT REVISION PAGE				STP M-9A 65 19 OF 32
TTLE:	Die	sel Engine	Generator Routine Surveillance Test	UNITS	1 AND 2
			•	······	
		<u>NOTE</u> : subtract	When evaluating a UV timed start in step 12.3.10,).8 seconds.	PERF	<u>VERIF</u>
		12.3.10	If speed and voltage did not reach their required evaluate the D/G for operability. Submit an action request and contact the system engineer for further review. Otherwise mark this step N/A.	values, on er	
			AR#	·[]	
		12.3.11	If frequency did not reach its value it may be due frequency setting error. Refer to AR A0562732. Submit an action request and contact the system engineer for further review. It may be required to the frequency and reperform the test. Otherwise a this step N/A.	to a o adjust mark	
			N/A AR#	[]	-
	-	12.3.12	Have the field operator record data in the "STAR' DATA" section of Attachment 9.1 (9.2).	TUP	
		12.3.13	If the D/G was started on an undervoltage signal, the operator at the vital 4KV switchgear room cut startup bus relay per Attachment 9.3 (9.4).	have -in the	_
		12.3.14	N/A If the D/G was started on an undervoltage signal of SI signal, record the D/G ISOC frequency as indic by the frequency meter on VB4.	[] or an cated	-
			HZ N/A	[]	-
			a. Isoc frequency between 59.75 YES and 60.25 HZ. (Admin) []	NO []	
			b. If the indicated frequency is outside the 59.7 60.25 HZ range, record the D/G ISOC frequency as indicated by the frequency meter at the D/ exciter cubicle.	'5 to - ency /G	
			HZ	[]	

.

.

÷

PACIFIC DIABLO	CGAS AND ELECTRIC COMPANY CANYON POWER PLANT	r F
		F
TITLE:	Diesel Engine Generator Routine Surveillance Test	τ

NUMBER	STP M-9A
REVISION	65
PAGE	20 OF 32
UNITS	1 AND 2

			PERF
12.4	Paralleli	ing	
	12.4.1	Verify the D/G MODE SEL switch in MANUAL.	
	12.4.2	Verify the D/G has been declared inoperable.	
	12.4.3	Check D/G output voltage on each phase. Otherwise, when synchroscope is turned ON (next step) the voltmeter will lock on to phase C.	
	12.4.4	Cut in the FEEDER SYNC Switch.	
	12.4.5	Verify synchroscope working.	
		a. Lights OFF at the 12 o'clock position.	
		b. Lights FULL BRIGHT at the 6 o'clock position.	
	12.4.6	Adjust engine speed up and down to verify manual governor control.	
	12.4.7	Adjust engine speed so the synchroscope is turning slowly in the clockwise (FAST) direction. This will allow the D/G to pick up load when paralleled to the bus.	
	12.4.8	Adjust D/G voltage to within ± 2 volts of bus voltage.	
	12.4.9	When the synchroscope pointer is slightly before the 12 o'clock position, turn generator breaker control switch to the CLOSE position. Pick up load (0.5MW) promptly after the breaker is closed. This will prevent the D/G breaker from tripping.	
		Clock time D/G paralleled: hrs.	
	12.4.10	Adjust voltage with voltage control switch to maintain VARS-OUT.	
	12.4.11	Cut out the FEEDER SYNC Switch.	
	12.4.12	Increase the load to ≥2.45 MW and ≤2.50 MW at a rate of ≤ 0.50 MW every 2 minutes and record clock time D/G reaches ≥2.45 MW load:	
		Date/Time/	
	12.4.13	If the plant is in MODE 1, 2, 3, or 4, perform STP I-1C, Attachment 12.4 within 1 hour of declaring D/G inoperable.	
		•	

PACIFIC GAS AND EL DIABLO CANYON POV	NUMBER REVISION PAGE	STP M-9A 65 21 OF 32		
TITLE: Diesel Engine	UNITS	1 AND 2		
<u> </u>	•••	<u>. </u>	PERF	
12.4.14	Mark the D/G MW/Freq recorder			
	NOTE: The strip chart from the MW/Fr will be used to monitor any power variat steady state load run period. If recorder an equivalent or better M&TE recorder n Momentary transients outside the load ra invalidate this test.	req recorde ion during is not avail nay be usec nge do not	r the able, 1.	· ·
12.4.15	Periodically monitor the D/G real power spurious load change $\geq \pm 0.10$ MW (0.20M Peak, p-p) from steady state value. If exe ± 0.10 MW (0.20MW p-p), generate an Al system engineer.	output for AW Peak to ceeding R and route	any o to	_
	AR #			
- - 1.5 - - - - - - - - - - - - - - - - - - -	· · ·	•		

PACIFIC GA DIABLO CAN TITLE: Dia	S AND EL NYON PO esel Engino	ECTRIC COMPANY WER PLANT e Generator Routine Surveillance Test	NUMBER REVISION PAGE UNITS	STP M-9A 65 22 OF 32 1 AND 2
			PERF	
12.5	Operation	on and Shutdown		
	12.5.1	Record D/G operating information as follows: List alarms in		_
		Generator		
		Current, Amperes AØBØ	CØ	
		Load MW (≥2.45 and ≤2.50 required)		
		Freq. HZ		
	ı	MVAR		•
	12.5.2	Operate the D/G loaded to ≥ 2.45 MW and ≤ 2.50 M for ≥ 60 minutes. Momentary transients outside the load range do not invalidate this test.	1W •	_
	12.5.3	Have the field operator take the data specified in the "RUN DATA" section of Attachment 9.1 (9.2).	e 	
	12.5.4	Record steady state D/G stator temp (limit < 240°F))	
	<u>NOTE</u> : to bus) n from and another p applicab 12.5.11.	Per SFM discretion, the D/G alignment (D/G parallel hay be utilized for other testing. The shutdown sequent other procedure may be used. If the D/G is shutdown procedure, N/A steps 12.5.6, 12.5.8, 12.5.9. Record le data in steps 12.5.5a, 12.5.7, 12.5.10a, 12.5.10d an	ed nce by d	
	12.5.5	After all data has been recorded and the D/G has run loaded, ≥ 2.45 MW and ≤ 2.50 MW for ≥ 1 hr, recor the date and time below.	n 'd	
		a. Date/Time/		
	12.5.6	Reduce the D/G load to 0.50 MW at \leq 0.50 MW ever 2 minutes.	ery	
		N/A []	-

1

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT

1

	NUMBER	STP M-9A
	REVISION	65
2	PAGE	23 OF 32
	UNITS	1 AND 2

-;

TITLE: Diesel Engine Generator Routine Surveillance Test

		•	•
	•	PERF	
12.5.7	Calculate time D/G ran \geq 2.45 MW for this test.		
	Clock time at end of test or when load was reduced ≤ 2.45 MW		
-	hrs. (Step 12.5.5a)		
6 4° - 10	Clock time load reached ≥ 2.45 MW		
	hrs. (Step 12.4.12)		
	Time D/G ran ≥ 2.45 MW: minutes. (Must be ≥ 60 minutes for surveillance testing to satisfy Tech Spec.)		
12.5.8	Allow the D/G to operate at approximately 0.50 MW for about five minutes for cooldown.		
12.5.9	Reduce load on the D/G to ≤ 0.25 MW and ≥ 0.10 MW and separate the unit by opening the D/G output breaker.	. 1	
10.5.10			
12.5.10	After the unit has been separated,		
	a. Record MW-HR:	<u></u>	•
	reads 60.0 to 60.25 HZ.		
	c. Adjust the D/G voltage to 119 V indicated (4160 V on the bus).		
	d. Record the speed, frequency and voltage.	<u> </u>	
	RPMHZV	,	
12.5.11	Calculate MW-hrs generated during this test.		
	MW-hr meter reading after test (Step 12.5.10a)		
	MW-hr meter reading before test (Step 12.2.2)	-	
	MW-hrs generated		
DATA REDUCTIO	N AND EVALUATION		
	· · · · · ·		

PACIFIC GAS AND ELECTRIC COMPANYNUMDIABLO CANYON POWER PLANTREVPAGE						STP M-9A 65 24 OF 32
TITI	TITLE: Diesel Engine Generator Routine Surveillance Test UNI					1 AND 2
14	RESTO	RATION			PERF	
1 .	<u>14.1</u>	Shutdov MAN N	vn the 10DE	D/G from the control room by placing the STOP/START switch to stop.		
	14.2	Return t for the r	the D/ nain u	G MODE SEL switch on VB4 to AUTO if requining mode.	red	_
		D/G MO	DDE S	EL switch position		_
	14.3	Cut out protectic CUTOU	the D/ on rela JT pos	G directional power, overcurrent, and loss of fiency at VB4 by placing the toggle switch in the ition.	ld	_
	14.4	Verify S	STP M	-9I was initiated.		_
	14.5	If startin 'has resto reset the	ng train bred th alarm	n air valves were manipulated, verify a field open ne valves per Attachment 9.1 (9.2). When compl n.	rator ete,	
				N/A []	_
	14.6	After the have the DATA"	e unit field sectio	has been shutdown for approximately 10 minute operator record the data in the "SHUTDOWN n of Attachment 9.1 (9.2).	s,	_
	14.7	Verify th associate	nat the	D/G is aligned to provide standby power to its ergency bus by performing the following checks:	:	
		14.7.1	D/C	breaker OPERABLE (i.e., power available).		_
		14.7.2	For <u>not</u>	a Unit 1 D/G, verify the following alarms are in alarm: N/A []	
			a.	Diesel on local control. (PK16-03, PK17-03 o PK18-03)	r	_
			b .	Diesel control UV. (PK16-04, PK17-04 or PK	.18-04)	_
			c.	Diesel STRT-TURBO AIR PRESS. (PK16-09 PK17-09 or PK18-09)),	_
			d.	Diesel engine trip. (PK16-13, PK17-13 or PK1	8-13)	_
			e.	Diesel generator breaker trip. (PK16-14, PK17 or PK18-14)	7-14	_
			f.	Diesel generator shutdown relay trip. (PK16-1 PK17-15 or PK18-15)	5,	_
			g.	4KV bus differential lockout. (PK16-16, PK17-16 or PK18-16)		_
			h.	Diesel voltage regulator on MANUAL. (PK16-25, PK17-25 or PK18-25)		

.

.

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT

TITLE:

1

Diesel Engine Generator Routine Surveillance Test

Ξ.	3	1	

NUMBER	STP M-9A		
REVISION	65		
PAGE	25 OF 32		
UNITS	1 AND 2		

					PERF
		14.7.3	For <u>not</u>	a Unit 2 D/G, verify the following alarms are in alarm: N/A []	
	. * *		a.	Diesel on local control. (PK17-03, PK16-03 or PK18-03)	
-			b.	Diesel control UV. (PK17-04, PK16-04 or PK18-04)	
			c.	Diesel STRT-TURBO AIR PRESS. (PK17-09, PK16-09 or PK18-09)	
			d.	Diesel engine trip. (PK17-13, PK16-13 or PK18-13)	
•		ŧ	e.	Diesel generator breaker trip. (PK17-14, PK16-14 or PK18-14)	
			f.	Diesel generator shutdown relay trip. (PK17-15, PK16-15 or PK18-15)	
	- 		g.	4KV bus differential lockout. (PK17-16, PK16-16 or PK18-16)	
			h. _	Diesel voltage regulator on MANUAL. (PK17-25, PK16-25 or PK18-25)	
14.8		Remove ti (Referenc	he D/ e step	G stator temperature from PPC trend. (12.2.6)	
14.9		Verify Att by the fiel	tachm ld ope	ent 9.1 (9.2), field data sheets have been completed rator and attached to this procedure.	·
14.10		Verify D/	G fue	l oil level is above low level alarm. (LOA)	
		For Unit 1	:		
			D/G	11, PK16-07 alarm clear or alarm input 255 not in. []
			D/G	12, PK17-07 alarm clear or alarm input 182 not in. []
			D/G	13, PK18-07 alarm clear <u>or</u> alarm input 101 not in.]
		For Unit 2	:		-
			D/G	21, PK17-07 alarm clear <u>or</u> alarm input 182 not in. []
			D/G	22, PK16-07 alarm clear <u>or</u> alarm input 255 not in. []
			D/G	23, PK18-07 alarm clear <u>or</u> alarm input 101 not in. [)
14.11		If this is a STP M-10 Otherwise	mont B2, " mark	hly surveillance test, notify chemistry to perform Diesel Generator Day Tanks Fuel Oil Analysis." this step N/A.	
				N/A []	

••

00316565.DOA 06 1007.0311

PACIFIC GA DIABLO CAI	S AND ELECTRIC COMPAN NYON POWER PLANT	NUMBEF REVISIO PAGE	8 STP M-9A N 65 26 OF 32	
TITLE: Di	esel Engine Generator Routine	Surveillance Test	UNITS	1 AND 2
14.12	Describe any malfunctions and Otherwise mark N/A.	d list any discrepancies	<u>PE</u> s found. N/A []	<u>RF</u>
			· · · · · · · · · · · · · · · · · · ·	
14.13	Test performers and verifiers:			
	<u>Name</u>		<u>Date/Time</u> / / / / / / / / / / / / / / / / / / /	
	<u> </u>		<u> </u>	

_ - _

:

- -

PAC DIAI	IFIC G BLO CA	AS AND EL ANYON PO	ECTRIC COMPANY WER PLANT	NUMBER REVISION PAGE	STP M-9A 65 27 OF 32
TITL	E: I	Diesel Engine	e Generator Routine Surveillance Test	UNITS	1 AND 2
15.	PRIM	1ARY REVIE	EW	PERF	
	15.1	Verify t	he following acceptance criteria have been satisfied:		
		15.1.1	The D/G is started by either manual, startup bus undervoltage, or SI signal (steps 12.3.4, 12.3.5 or 12.3.6).		
			NOTE: When evaluating a UV timed start in steps 15.1.2, 15.1.3 and 15.1.4, subtract 0.8 seconds	• ,	· .
		15.1.2	The D/G accelerates to \geq 900 rpm. If performing a timed start, the D/G accelerated to \geq 900 rpm in \leq to (10) seconds. (Step 12.3.7).	en	_
		15.1.3	The D/G voltage stabilized ≥ 113 V to ≤ 121 V after start. If performing a timed start, the D/G voltage stabilized ≥ 113 V to ≤ 121 V in ≤ 13 seconds. (Step 12.3.8).	r 	_
	1	15.1.4	The D/G frequency stabilized between \ge 59.5 HZ an \le 60.5 HZ after start. If performing a timed start, th D/G frequency stabilized \ge 59.5 HZ and \le 60.5 HZ i \le 13 seconds. (Step 12.3.9)	nd e . in	
		15.1.5	If starting the D/G on a single starting train, verify the D/G started within the required times. Indicate the t that was tested. (Steps 15.1.2, 15.1.3, and 15.1.4) N/A [ne rain]	
			Starting train A (starting train B isolated, step 11.13) []		
			Starting train B (starting train A isolated, step 11.13) []		
		15.1.6	The D/G ran for \geq 60 minutes at \geq 2.45 MW and \leq 2.50 MW. (Step 12.5.7).		_
		15.1.7	The D/G protective relay cutout switch is returned to the CUTOUT position. (Step 14.3)	· .	-
		15.1.8	The D/G is aligned to provide standby power to the associated emergency buses. (Step 14.7)	-	-
		15.1.9	The fuel level in the D/G fuel oil day tank is above lo level alarm. (Step 14.10)		-

1

PACIFIC GAS DIABLO CANY	NUMBER REVISION PAGE	STP M-9A 65 28 OF 32	
TITLE: Dies	el Engine Generator Routine Surveillance Test	UNITS	1 AND 2
		PERF	2
	 15.1.10 If the day tank low level alarm is out of service, ve fuel level in the D/G fuel oil day tank is ≥ 300 galle D/G 1-3 is >1/2. (Attachment 9.1 (9.2) step 4.6). 	rify the ons or	
	N/A [15.1.11 Either air receiver A <u>OR</u> B is ≥ 195 PSIG. (Attachments 9.1 (9.2), step 4.3, data points 34 and	. J 140)	
	15.1.12 Turbocharger air receiver is ≥ 195 PSIG. (Attachments 9.1 (9.2), step 4.3, data point 39).		
	 15.1.13 Each diesel fuel oil transfer pump starts and transfer fuel from the storage system to the D/G engine-mounted tank via installed lines for the D/C under test (Attachment 9.1 (9.2), steps 3.1.1, 3.1.3, 3.1.6, 3.1.8). 	ers }	_
	15.1.14 Monthly check for and removal of water from the c tank. (Attachment 9.1 (9.2), step 4.10)	lay	_
	NOTE: This NOTE applies to steps 15.1.15 and 15.1.16 belo If the frequency bands in both steps were exceeded, generate a AR to adjust D/G ISOC frequency per MP E-21.6. If only the frequency band of step 15.1.15 was exceeded, generate an AR calibrate the frequency meter on VB4.	ow. an Sto	
	 15.1.15 If the D/G is started from the UV or SI signal, the I ISOC frequency was ≥ 59.75 and ≤ 60.25 HZ as indicated by the frequency meter on VB4. (Admin Limit) (Step 12.3.14))/G	
	N/A [AR #]	
	NOTE: Mark step 15.1.16 N/A if step 12.3.14b was marked 1	N/A.	
	 15.1.16 If the D/G is started from the UV or SI signal, the I ISOC frequency was ≥ 59.75 and ≤ 60.25 HZ as indicated by the frequency meter at the D/G exciter cubicle. (Admin Limit) (Step 12.3.14.) N/A [)/G 	_

PACIFIC GAS AND ELECTRIC COMPANY NUME DIABLO CANYON POWER PLANT REVIS PAGE					NUMBER REVISION PAGE	STP M-9A 65 29 OF 32	
TITLE: Die	esel Engine	Generator	Routine Surveil	lance Test		UNITS	1 AND 2
	•					PER	<u> </u>
15.2	Check v the follo	alves and so wing are me	olenoid valves sha et:	ll be consider	ed accepta	ble if	
	15.2.1	The starti system so satisfied i and Attac	ng air system and lenoid valves stro f the D/G started s hment 9.1 (9.2), s	turbocharger king requirer successfully. tep 2.1).	air assist nents are (Step 12.3	.7	
	15.2.2	The diese check val acceptable 0-2 delive (9.2), step	l fuel oil transfer p ve (DEG-0-35, DI e if the diesel fuel ers fuel into the da os 3.1.3 and 3.1.8)	oumps 0-1 an EG-0-36) sha oil transfer p y tank (Attac	d 0-2 disch ll be consid umps 0-1 a hment 9.1	arge lered and	
••	15.2.3،	The fuel c (DEG-0-1 DEG-0-1 considered 0-1 and 0 (Attachmo	bil tanks 0-1 and 0 114, DEG-0-1115 117, DEG-0-1118 d acceptable if die -2 delivers fuel int ent 9.1 (9.2), steps	-2 suction ch for DFOST for DFOST (sel fuel oil tr o the day tan 3.1.3 and 3.1	eck valves 0-1 and 0-2) shall b ansfer pum k l.8).	e ps	
15.3	Verify N	1&TE usage	recorded in PIMS	5 . .			_
15.4	Review of determin noted, no refer to a	completed p ation of D/C otify manage applicable L	rocedure and base G OPERABILITY ement promptly, so CO.	d on test data . If any malf ubmit an action	n, make unctions ar on request	e and	
	AR#						
	REMAR	KS:					
	Signature	e:	Shift Foreman]	Date/Time	/	/

.

÷

.

PACI DIAE TITL	IFIC GAS BLO CAN JE: Die	S AND ELECTRIC COMPANY YON POWER PLANT esel Engine Generator Routine Surveillance Test	NUMBER REVISION PAGE UNITS	STP M-9A 65 30 OF 32 1 AND 2
16.	SECON	DARY REVIEW	PER	<u>F</u>
	16.1	Review procedure for completeness and acceptability.		
	16.2	If this test was complete and the D/G are OPERABLE master schedule has been updated. REMARKS:	, then verify 	
	16.3	Reviewed By: Dat Second Reviewer	te	

<u>)</u> .

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT

NUMBER REVISION	STP M-9A 65
PAGE	31 OF 32
UNITS	1 AND 2

TITLE: Diesel Engine Generator Routine Surveillance Test



j ·

PACIFIC GAS AND ELECTRIC COMPANY DIABLO CANYON POWER PLANT

NUMBER REVISION	STP M-9A 65
PAGE	32 OF 32
UNITS	1 AND 2

TITLE: Diesel Engine Generator Routine Surveillance Test

APPENDIX 8.2

COMBINED ENGINE AND GENERATOR OPERATING LIMITS



ł

DIABLO CANYON POWER PLANT STP M-9A

ATTACHMENT 9.1

		FIELD DATA	
D.G.	NO	DATE TIME	
OPE	RATOR_		
(AT	DIESEL)		· .
1.	<u>PRETI</u>	EST DATA	ACTUAL VALUE
	1.1	Engine Hours:	
	1.2	Governor oil level (%) (minimum level = oil visible in glass*). (If below low level mark on sightglass, write an AR.)	
		AR#	
	1.3	Governor settings:	•
		Speed Droop:	
	.25	Load Limit:	
		Speed:	
	1.4	Record crankcase lubricating oil level, inches below high level mark on dipstick. If lubricating oil is > 2" below the high level mark, initiate an action request to add more lubricating oil. (Minimum level is 7" below high level mark.)	
	1.5	Priming tank level (inches from bottom of sightglass) (minimum level = oil visible in glass).	
		If the level in the priming tank is less than minimum, refill by manual operation of the magnetic pump or with the manual priming pump. If insufficient magnetic pump run time is suspected write an action request to maintenance to adjust the magnetic pump timer. If priming tank level cannot be established declare D/G inoperable.	
		AR#	
	1.6	Day tank fuel oil level Fill tank if < 275 gallons (1/2 full for D/G 13).	•
		**AR#	

- *
- If out of limits, declare D/G inoperable. If out of limits, initiate an action request. **

ł

1	0/07/03	
1	0/0//03	

Page 2 of 19

I

j

STP M-9A (UNIT 1) ATTACHMENT 9.1 --- • . . .

1.7 Jacket cooling water level, inches above low point in glass.(Minimum level=water visible in glass*).	ACTUAL VALUE
1.7 Jacket cooling water level, inches above low point in glass.(Minimum level=water visible in glass*).	
If the jacket cooling water level is less than the values listed below, refill the expansion tank to the appropriate fill level using demineralized water. Notify chemistry to test the jacket cooling water after D/G test.	
Level Below Fill To	
Cold 12" 15" Hot (≥160°F) 14.5" 17.5"	
Chemistry Notified: Date/Time	/
1.8 West roll up fire doors are in the full up position.*** Record Door Position	
•	PERF
1.9 Connect the D/G fuel oil leak-off collection bottles as follows:	
1.9.1 Obtain 2 five gallon poly bottles and tygon tubing from the storage box.	
1.9.2 Remove the pipe cap at the end of the fuel oil leak-off return lines on each side of the D/G.	
1.9.3 Connect the tygon tubing to the fuel oil leak-off return lines and route each to a 5 gallon poly bottle.	
1.9.4 Open the appropriate 1/2" whitey fuel oil leak-off drain valves to the poly bottle.	
D/G 1-1DEG-1-1055,DEG-1-1056D/G 1-2DEG-1-1053,DEG-1-1054D/G 1-3DEG-1-1057,DEG-1-1058	

If out of limits, declare D/G inoperable. At least one west roll up fire door must be open to maintain the D/G OPERABLE. (AR A0330481-E04) ***

Page 3 of 19

STP M-9A (UNIT 1) ATTACHMENT 9.1

Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators TITLE:

PERF

1.10 If directed by the control room operator or the shift foreman, isolate starting train A or starting train B. Mark the starting train where valves will be manipulated.

Isolate Starting Train A [] []

Isolate Starting Train B

N/A []

1.10.1

1

• • • • •

. · · · ·

· 11

Select the air supply valve to be closed in the table below.

D/G	1 - 1	1-2	1 - 3
Train "A" Valve	DEG-1-63 []	DEG-1-89[]	DEG-1-115[]
Train "B" Valve	DEG-1-52 []	DEG-1-78 []	DEG-1-104 []

1.10.2 Select the blow-down valve to be uncapped and opened in the table below. When the valve is opened, PK window 16-09, 17-09, or 18-09, will alarm.

D/G	1 - 1	1-2	1-3
Train "A" Valve	DEG-1-227 []	DEG-1-249[]	DEG-1-271 []
Train "B" Valve	DEG-1-216[]	DEG-1-238[]	DEG-1-260[]

NOTE: When train "A" valves are manipulated, starting train "B" will be tested. When train "B" valves are manipulated, train "A" will be tested.

 \dashv

1

	10/07/03					Pa
			STP M-9A (U ATTACHME	NIT 1) NT 9.1		·
TITLE: I	Data Sheet - Ro	outine Sur	veillance Test of U	nit 1 Diesel Gener	ators	
						PERF
1.11	Verify or	ne of the fo	ollowing:			
	1.11.1	Verify th NORMA on panel D/G bein D/G 11,	ne D/G control pow L position with th EQDxx, (Replace ng tested for panel etc.).	ver transfer switch e NORMAL ambo "xx" with the nun designation, e.g., l	is in the er light lit aber of the EQD11 for	
		<u>OR</u>				
	1.11.2	(This op when ste power tra the BAC "xx" with designati	tion available only p 11.3.2 is perform ansfer switch is in KUP amber light li h the number of the ion, e.g., EQD11 fo	in MODE 5, 6 or ned) Verify the D the BACKUP pos it on panel EQDxx D/G being tested or D/G 11, etc.).	defueled G control ition with (Replace for panel N/A []	
1.12	If test is u	used to sat	isfy Tech Spec SR	3.8.1.2 or SR 3.8.	1.7,	
	(Routine	M-9A Tes	t) record jacket wa	ter temperature ar	d	
	lubricatin	g oil temp	erature. If either to	emperature is not?	≥ 95°F and ≤	
	107 F 110		nt ioreman.]	N/A []	
	Water Ter	mperature:		Oil Temperature		-
	DIES GENERA 1-1 1-2 1-3	EL ATOR	WATER TEMPERATURE TI-1030 TI-1035 TI-1036	OIL TEMPERATU TI-527 TI-504 TI-505	RE .	
	101 / 0					
	It M&TE M&TE ur 175°. M&	is used, ca icertainty TE I.D	alculate the require to 90°F and subtrac	d temperature ran; cting M&TE unce	ge by adding rtainty from	

	Required Temperature Range for M&TE	Measured	
Water Temperature	°F	°F	-
Oil Temperature	°F	°F	
		N/A []	<u></u>

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

DATA	TA INSTRUMENT NO. FOR DIESEL							
POINT	PARAMETER	11	12	13	LIMITS	VALUE		
1	Lubricating Oil Pressure (PSIG)	PI-606	PI-629	PI-639	10-15***	·		
2	Room Air Temperature (°F)	TI-97	TI-98	TI-99	••	•		
3	Turbo Air Header Pressure (PSIG)	PI-843	PI-844	PI-845	≥200** ≥195 ²			
4	Air Header B Pressure (PSIG)	PI-598	PI-620	PJ-640	≥140 ¹ ≤160*			
5	Air Header A Pressure (PSIG)	PI-599	PI-621	PI-641	≥140 ¹ ≤160*			
6	Jacket Water Temperature (°F)	TI-1030	TI-1035	TI-1036	95-120** ³ (≥95*)			
7	Air Receiver A Pressure (PSIG)	PI-601	PI-623	PI-634	≥210** ≥195 ¹			
8	Lubricating Oil Temperature (°F)	TI-527	TI-504	TI-505	95-120** ³ (≥95*)	•		
9	Turbo Air Receiver Pressure (PSIG)	· PI-840	PI-841	PI-842	≥200** ≥195²			
10	Air Receiver B Pressure (PSIG)	PI-600	PI-622	PI-633	≥210** ≥195 ¹			

1.13 Record the following parameters:

¹<u>NOTE</u>: Either starting air receiver A must be ≥ 195 PSIG and starting air header A must be ≥ 140 PSIG <u>OR</u> starting air receiver B must be ≥ 195 PSIG and starting air header B must be ≥ 140 PSIG. If both starting air receivers are ≥ 165 PSIG and < 195 PSIG, restore one air receiver to ≥ 195 PSIG in ≤ 48 hours or declare the D/G inoperable. If both starting air receivers < 165 PSIG declare the D/G inoperable. If both air header A and air header B pressure is < 140 PSIG declare the D/G inoperable. If performing a single starting train start, either air header A or air header B will indicate 0 PSIG.

²<u>NOTE</u>: If the turbocharger receiver is \geq 165 PSIG and < 195 PSIG, restore the air receiver to \geq 195 PSIG \leq 48 hours or declare the D/G inoperable. If the turbocharger < 165 PSIG, declare the D/G inoperable.

³<u>NOTE</u>: If the D/G is still hot from a previous run and the oil or jacket water temperature is $> 120^{\circ}$ F, do not write an AR.

⁴<u>NOTE</u>: If the D/G lube oil is> 120°F from a previous run, the lube oil pressure is > 3 psi, and the pre-lube pump is on, do <u>NOT</u> write an AR.

- * If out of limits, declare D/G inoperable.
- ** If out of limits, initiate an action request.

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE	: Data	Sheet - Routine Surveillance Test of Unit 1 Diesel Generators	
			PERF
2.	<u>STARTU</u>	<u>P DATA</u>	
	NOTE 1: power, ma the engine	If it becomes necessary to shutdown the D/G without control anually operate the overspeed trip lever on the northwest corner of e, forward of the fuel oil filters.	
	NOTE 2: D/G start.	The next four steps should be performed within 60 seconds of	
	2.1	Verify D/G started.	
	2.2	Verify D/G lube oil pressure \geq 60 PSIG within 60 seconds of starting.** (Instrument console, PI-606, PI-629 or PI-639)	
	2.3	Verify jacket water pressure increases within 60 seconds of starting.** (No pressure limit) (Instrument console, PI-612, PI-643 or PI-645)	
	2.4	Verify D/G fuel oil pressure ≥ 40 PSIG within 60 seconds of starting.** (Instrument console, PI-604, PI-626 or PI-637)	
		(Gauge response is generally about 15 seconds.)	
	2.5	Verify the crankcase exhausters are operating.**	
	2.6	Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	

^{**} If out of limits, initiate an action request.

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

		PERF
2.7	Verify proper fuel oil flow to the priming system.	
	2.7.1 Verify magnetic priming pump is <u>NOT</u> running.	· · · · · · · · · · · · · · · · · · ·
	2.7.2 Verify <u>SMALL</u> amount of fuel flowing in overflow sightglass FI-313 (314) (315)	
- • •	NOTE: Fuel should <u>NOT</u> collect in the sightglass. If fuel is not flowing in the sightglass but the priming tank level is increasing, wait until the priming tank fills to the proper level. Valve DEG-1-530 (536) (542) should be approximately 1/4 turn open.	
	a. If there is no flow or too much flow in the sightglass, then adjust valve DEG-1-530 (536) (542) until a SMALL amount of fuel is flowing in the overflow sightglass.	
	N/A []	
2.8	Monitor the level in the poly bottles connected to the D/G fuel leak-off valves as needed to prevent poly bottle overfill while the drain valve is open and D/G is running.	
1 1		
•		
	· · · · · ·	
		•

1

ł

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

				PERF	<u>VERIF</u>
3.	<u>RUN DA</u>	<u>ATA</u>			
	NOTE: started.				
	3.1	Verify C followin	PERABILITY of the fuel oil transfer system in the g steps:		
****	*******	*******	***************************************	******	******
<u>CAUT</u> spill. 1 tank.	<u>'ION</u> : It i: Level colui	s possible mn respon	to overflow the fuel oil day tank in MANUAL control, and th ds very slowly to a level change. Exercise caution when man	us cause a ually fillin	i fuel oil ng a day
••••		NOTE: in parent	The numbers given below are for D/G 1-1. The numbers heses are for D/Gs 1-2 and 1-3 respectively.		
		3.1.1	Start fuel oil transfer pump 0-1 from D/G 1-1 (1-2) (1-3).		
		3.1.2	Open day tank fill valve LCV-88 (89) (90).		
		3.1.3	Observe an increase in day tank level. (Verifies foot valves DEG-0-1114, DEG-0-1115, and check valve DEG-0-35 are OPERABLE.)		
		3.1.4	Close LCV-88 (89) (90) and place in AUTO.		
		3.1.5	Stop fuel oil transfer pump 0-1 and place the switch in the AUTO position.		
		3.1.6	Start fuel oil transfer pump 0-2 from D/G 1-1 (1-2) (1-3).		
		3.1.7	Open day tank fill valve LCV-85 (86) (87).		
		3.1.8	Observe an increase in day tank level. (Verifies foot valves DEG-0-1117, DEG-0-1118, and check valve DEG-0-36 are OPERABLE)		
		3.1.9	Close LCV-85 (86) (87) and place in AUTO.	<u> </u>	
		3.1.10	Stop fuel oil transfer pump 0-2 and place the switch in the AUTO position.		
	3.2	Verify pro performin	oper operation of the fuel oil priming system by ng the following:	•	
		3.2.1	Place magnetic priming pump control switch in MANUAL and verify pump operation by increase in fuel oil flow through overflow sightglass.		
		3.2.2	Place magnetic priming pump control switch in AUTO.		

Page 9 of 19

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

3.3 Record the following Parameters after the D/G has run ≥ 60 minutes at ≥ 2.45 MW and ≤ 2.50 MW load.

DA	ΓΑ	INSTRUI	MENT NO. FC	R DIESEL	_	ACTUAL
POI	NT PARAMETER	. 11	12	13	LIMITS	VALUE
	NORTH SIDE OF DIESE	L			1	
11	 Lube Oil Pressure Leaving Filter (PSIG) 	PI-834	PI-836	PI-838		
12	Lube Oil Pressure Entering Filter (PSIG)	PI-607	PI-627	PI-638		
13	Secondary Fuel Oil Filter Inlet Press. (PSIG)	PI-603	PI-625	PI-636		
14	Secondary Fuel Oil Filter Outlet Press. (PSIG)	PI-829	PI-831	PI-833	•	
15	Primary Fuel Oil Filter dp (In. Hg.)	PIS-1021	PIS-1022	PI-1023	≤4.5**	<u> </u>
	INSTRUMENT CONSOL	E				
16	Lube Oil Pressure (PSIG)	PI-606	PI-629	PI-639	≥60*	<u>,</u>
17	Lube Oil Temperature Leaving Engine (°F)	TI-527	TI-504	TI-505 .	≤195***	
18	Jacket Water Pressure (PSIG)	PI-612	PI-643	PI-645		
19	Jacket Water Temperature Entering Radiator (°F)	TI-1030	TI-1035	TI-1036		· · · ·
20	Fuel Oil Pressure (PSIG)	PI-604	PI-626	PI-637	≥40	

* If out of limits, declare D/G inoperable and the D/G should be shutdown for insufficient lube oil pressure.

** If out of limits, initiate an action request.

^{***} If out of limits, initiate an action request. Verify temperature is not increasing. If temperature can not be maintained below limit the D/G should be shutdown.

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

DATA		INSTRU	MENT NO. FC	R DIESEL		ACTUAL
POINT	PARAMETER	11	12	13	LIMITS	VALUE
21	Radiator Discharge Air Temperature (°F)	TI-528	TI-529	TI-540	≤160**	
22	Turbo Air Discharge Pressure (PSIG)	PI-822	PI-826	PI-827		· · ·
23	Room Air Temperature (°F)	TI-97	TI-98	TI-99	≤120°F**	
24	No. of Crankcase Exhausters in Operation	⇒	⇒	⇒	1**, 0**	
	EXCITER CUBICLE					
25	Exciter Voltage, VDC Generator Output	⇒	⇒	⇒	VDC	
	Voltage, V	⇒	⇒	⇒	v	
26	Exciter Current, Amps	⇒	⇒	⇒	AMP	
	SOUTH SIDE OF DIESEL					
27	Lube Oil Strainer Inlet P (PSIG)	PI-835	PI-837	PI-839		
28	Lube Oil Strainer Outlet P (PSIG)	PI-608	PI-628	PI-644		
29	Jacket Water Temperature Leaving Radiator (°F)	TI-506	TI-507	TI-508	≤185**	
30	Lube Oil Temperature Leaving L.O. HX (°F)	TI-1028	TI-1032	TI-1034		

^{**} If out of limits, initiate an action request.

de

÷

÷

Page 11 of 19

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

DATA				INSTRUMENT NO. FOR DIESEL						A	CTUAL
PARAM	IETER			11	1	2	13		LIMITS	V	ALUE
<u>GËNER</u>	ATOR				•		1		· , .		
Horizont Vibration dot on sc generato	tal (x axis n taken or outh side r bearing	s) n blue of housing	(Use	e Portabl	le Vibrat	tion Me	ter set or	n IPS)			
Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Meter set on IPS							n IPS)				
Axial (z axis) Vibration taken on blue dot on end of generator bearing housing (Use Portable Vibration Meter set on IPS)											
nder and H	Exhaust T	'emperat	tures - In	nst. Con	sole		•	·		-	
nder	R1	R2	R3	. R4	R5	R6	R7	R8	R9	UR	LR
perature °	F							. <u> </u>			
nder	L1	L2	L3	L4	L5	L6	L7	L8	L9	UL	LL
perature °	F										
									PER	<u>F</u>	
.4 N](/erify the eakage fro	re is no om turbo	continu o afterco	ous or in ooler tatt	itermitte letale.*'	nt jacke *	t coolin	g water			
*	* AR #		<u> </u>								
3.5 Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.** If an AR is initiated, list the type of leakage.											
*	* AR #	·			· ·				e _		
6 V	erify gov	ernor oi	il is at o	r above	the low	level ma	ark in sig	ghtglass	5 .		
	PARAM <u>GENER</u> Horizont Vibration dot on so generato Vertical Vibration dot on to bearing h Axial (z Vibration dot on en bearing h nder and H nder perature ° 4	PARAMETER GÉNERATOR Horizontal (x axis Vibration taken of dot on south side generator bearing Vertical (y axis) Vibration taken of dot on top of gene bearing housing. Axial (z axis) Vibration taken of dot on end of gene bearing housing. Axial (z axis) Vibration taken of dot on end of gene bearing housing. nder and Exhaust T nder R1 perature °F add Verify the leakage fr ** AR #	PARAMETER GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. Ader and Exhaust Temperator bearing housing. ader and Exhaust Temperator hder L1 hder L1 perature °F A Verify there is no leakage from turbe ** AR #	PARAMETER GÉNERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use nder and Exhaust Temperatures - In nder R1 nder L1 L2 L3 perature °F adder L1 L4 Verify there is no continual leakage from turbo afterco ** AR #	INSTRUI PARAMETER 11 GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable) Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable) adder and Exhaust Temperatures - Inst. Commoder nder R1 R2 R3 R4 perature °F adder L1 L2 L3 L4 perature °F adder L1 L2 L3 L4 verify there is no continuous or in leakage from turbo aftercooler tatt ** AR #	INSTRUMENT N PARAMETER 11 1 GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable Vibration taken on blue dot on top of generator bearing housing. Vibration taken on blue (Use Portable Vibration taken on blue dot on top of generator bearing housing. Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. hder and Exhaust Temperatures - Inst. Console inder R1 nder L1 L2 L3 L4 L5 perature °F 4 Verify there is no continuous or intermitted leakage from turbo aftercooler tattletale.** ** AR #	INSTRUMENT NO. FOI PARAMETER 11 12 GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable Vibration Methods) Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Methods) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. bearing housing. (Use Portable Vibration Methods) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. hder and Exhaust Temperatures - Inst. Console ander R1 nder L1 L2 L3 A Verify there is no continuous or intermittent jacked leakage from turbo aftercooler tattletale.** ** AR #	INSTRUMENT NO. FOR DIESE PARAMETER 11 12 13 GENERATOR Horizontal (x axis) Vibration taken on blue of on south side of generator bearing housing. (Use Portable Vibration Meter set or Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Meter set or bearing housing. Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set or bearing housing. Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set or hoder and Exhaust Temperatures - Inst. Console Inder R1 R2 R3 R4 R5 R6 R7 perature °F	PARAMETER 11 12 13 GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable Vibration Meter set on IPS) Vertical (y axis) (Use Portable Vibration Meter set on IPS) Vertical (y axis) (Use Portable Vibration Meter set on IPS) Vertical (z axis) (Use Portable Vibration Meter set on IPS) Axial (z axis) (Use Portable Vibration Meter set on IPS) Axial (z axis) (Use Portable Vibration Meter set on IPS) Axial (z axis) (Use Portable Vibration Meter set on IPS) hder and Exhaust Temperatures - Inst. Console (Use Portable Vibration Meter set on IPS) nder R1 R2 R3 R4 R5 R6 R7 R8 perature °F	INSTRUMENT NO. FOR DIESEL PARAMETER 11 12 13 LIMITS GENERATOR Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable Vibration Meter set on IPS) (Use Portable Vibration Meter set on IPS) Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Meter set on IPS) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set on IPS) Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set on IPS) Meter set on IPS) Axial (z axis) Vibration taken on blue dot on end of generator Image: Second Sec	INSTRUMENT NO. FOR DIESELAdditionPARAMETER111213LIMITSVGENERATORHorizontal (x axis)Vibration taken on bluedot on south side of generator bearing housing. (Use Portable Vibration Meter set on IPS)

4.

ì

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

<u>SHUT</u>	DOWN DA	<u>ATA</u>	
4.1	Record	engine hours:	hrs.
4.2	If valve blow-de	es were manipulated in step 1.10, close and cap the own valve and open the air supply valve. N/A	[]
	4.2.1	Valve that was closed and capped:	
	4.2.2	Valve that was opened:	•

4.3 After the D/G has been shutdown for 10 minutes, record the following data:

DATA		INSTRUMENT NO. FOR DIESEL				ACTUAL
POINT	PARAMETER	11	12	13	LIMITS	VALUE
34	Air Receiver A Pressure (PSIG)	PI-601	PI-623	PI-634	≥210** ≥195 ¹	
35	Lubricating Oil Pressure (PSIG)	PI-606	PI-629	PI-639	<u>≥2</u> **	
36	Turbo Air Header Pressure (PSIG)	PI-843	PI-844	PI-845	≥200** ≥195 ²	
37	Air Header B Pressure (PSIG)	PI-598	PI-620	PI-640	≥140 ¹ ≤160*	
38	Air Header A Pressure (PSIG)	PI-599	PI-621	PI-641	≥140 ¹ ≤160*	
39	Turbo Air Receiver Pressure (PSIG)	PI-840	PI-841	PI-842	≥200** ≥195²	
40	Air Receiver B Pressure (PSIG)	PI-600	PI-622	PI-633	≥210** ≥195 ¹	

¹<u>NOTE</u>: Either starting air receiver A must be \geq 195 PSIG and starting air header A must be \geq 140 PSIG <u>OR</u> starting air receiver B must be \geq 195 PSIG and starting air header B must be \geq 140 PSIG. If both starting air receivers are \geq 165 PSIG and < 195 PSIG, restore one air receiver to \geq 195 PSIG in \leq 48 hours or declare the D/G inoperable. If both starting air receivers < 165 PSIG declare the D/G inoperable.

²<u>NOTE</u>: If the turbocharger receiver is \geq 165 PSIG and < 195 PSIG, restore the air receiver to \geq 195 PSIG \leq 48 hours or declare the D/G inoperable. If the turbocharger < 165 PSIG, declare the D/G inoperable.

- * If out of limits declare D/G inoperable.
- ** If out of limits initiate an action request.
Page 13 of 19

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE:	Data Sheet - J	Routine Surveil	lance Test of Unit	Diesel Generators
--------	----------------	-----------------	--------------------	-------------------

.

		·				ACTUAL <u>VALUE</u>
4.4	Record ja (Minimus inches an	acket cooling wate m level = water vi ad ≤ 17.5 inches.)	er level, inches a isible in glass*.)	bove low point in gla (Normal level \ge 14.	iss. 5	
	Did the le	evel increase from	step 1.7	YES[]N	0[]	
•	<u>NOTE</u> : jacket coo should in water leve stated bel	This check is perf oling water level i itiate an action red el indicator should ow.	ormed to allow ndicator. PPE r quest to investig d the level indic	detection of plugging eviewing this data sh ate the jacket cooling ate other than the tren	eet d	
	1.	If the D/G is star recorded in step 1 hour run.	rted cold, jacket 4.4 should incre	cooling water level ase after a normal		,
	2.	If the D/G is star (nominal) run, th remain relatively	ted cold for a le ne level recorded vunchanged.	ss than 20 minute I in step 4.4 should		
¥	3.	If the D/G is star should remain ur	ted warm, the le ichanged after t	evel recorded in step 4 he D/G run.	1.4	
··• –	If the jack expansion chemistry If chemist	tet cooling water I a tank to 16.5 inch to conduct a cher ry was notified in	evel is below 14 es with deminer nical test on the step 1.7, no act	1.5 inches, refill alized water and noti jacket cooling water. ion is needed. N/A []	fy	·
	Chemistry	Notified:		Date/Time		
NOTE: 7 parenthes	The number es are for D	rs given below are D/G's 1-2 and 1-3 r	e for D/G 1-1. 7 respectively.	he numbers in		
4.5	If the day stop for D (fuel oil pu	tank level is less t /G 1-3), fill the da ump AUTO stop f	han 500 gallons ay tank to appro for D/G 1-3) as :	(fuel oil pump AUT) ximately 500 gallons follows: N/A []	C	

.

If out of limits, declare D/G inoperable. If out of limits, initiate an action request. *

^{**}

Page 14 of 19

10/07/03 STP M-9A (UNIT 1) **ATTACHMENT 9.1** Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators TITLE: PERF VERIF CAUTION: It is possible to overflow the fuel oil day tank in MANUAL control, and thus cause a fuel oil spill. Level column responds very slowly to a level change. Exercise caution when manually filling a day tank. ****** ***** 4.5.1 If fuel oil transfer pump 0-1 is used perform the following: N/A [] Start fuel oil transfer pump 0-1. a. b. Open day tank fill valve LCV-88 (89) (90). When the day tank is filled to approximately c. 500 gallons (fuel oil pump AUTO stop for D/G 1-3), close day tank fill valve LCV-88 (89) (90). d. Place day tank fill valve control switch LCV-88 (89) (90) in AUTO. Stop diesel fuel oil transfer pump 0-1 and place in e. AUTO. 4.5.2 If fuel oil transfer pump 0-2 is used perform the following: N/A [] Start fuel oil transfer pump 0-2. a. b. Open day tank fill valve LCV-85 (86) (87). When the day tank is filled to approximately c. 500 gallons (fuel oil pump AUTO stop for D/G 1-3), close day tank fill valve LCV-85 (86) (87). d. Place day tank fill valve control switch LCV-85 (86) (87) in AUTO. Stop diesel fuel oil transfer pump 0-2 and place in e. AUTO.

10/07/03 Page 15 of 19 STP M-9A (UNIT 1) ATTACHMENT 9.1 Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators TITLE: PERF 4.6 Record day tank fuel level. Fuel level for D/G 1-1 or D/G 1-2. N/A this step for 4.6.1 D/G 1-3. 100 N/A [] 1 gallons NOTE: If the day tank low level alarm (LOA) is out of service, day tank level shall be \geq 300 gallons.* 4.6.2 Fuel level for D/G 1-3. N/A [] Dial reading. (>1/2, 3/4, AUTO stop level and etc.) NOTE: If the day tank low level alarm (LOA) is out of service, day tank level should be \geq fuel oil pump AUTO stop level and shall be > 1/2 day tank level.* 4.7 Record actual priming tank level (inches from bottom of sightglass) 21. (minimum level = level of return line = approx. 5"). Level ۰. If the level in the primary tank is less than minimum, refill by manual operation of the magnetic pump or with the manual priming pump. If insufficient magnetic pump run time is suspected write an action request to maintenance to adjust the magnetic pump timer. If priming tank level cannot be established, declare D/G inoperable. AR# 4.8 Record actual crankcase lubricating oil level, inches below full mark on dipstick. If lubricating oil is > 2" below the high level mark, initiate an action request to add more lubricating oil. (Minimum level is 7" below high level mark.) Level

* If out of limits, declare D/G inoperable.

į

Page 16 of 19

į.

STP M-9A (UNIT 1) ATTACHMENT 9.1

Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators TITLE: PERF 4.9 Blowdown all three air receivers inline filters a small amount through their drain valves to check for water accumulation. **NOTE:** To blowdown the filter units the screw on the bottom must be turned clockwise several turns when viewed from the bottom. 4.9.1 Air receiver systems blown down. Prefilter **Oil Filter** After Filter Turbo [] F 1 [] Starting A [] [] [] Starting B [] [] [] 4.9.2 If water is present, write an action request. (A small amount of mist out of the prefilter is acceptable). AR# N/A [] 4.10 Perform the following to drain any accumulated water in the day tank. 4.10.1 Open drain valve(s) on D/G fuel oil day tank and check for the presence of water. Remove any accumulated water. NOTE: For D/G with multiple drain valves, one or more of the following drain valves may be opened to remove any accumulated water. 4.10.2 Circle drain valve or valves opened below. D/G Valve 1-1 DEG-1-1059/1060/1061/1062/1063/1064 1-2 DEG-1-1065/1066/1067/1068/1069/1070 1-3 **DEG-1-520** 4.10.3 Day tank checked for presence of water.*** [] Removed accumulated water*** [] No water found 4.10.4 Close the drain valve(s) opened in step 4.10.1.

^{***} If check is not done or if any accumulated water is found and not removed, declare D/G inoperable.

Page 17 of 19

STP M-9A (UNIT 1) ATTACHMENT 9.1

ATTACHMENT 9.1 TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

		PERF	VERIF
Disconn	ect the D/G fuel oil leak-off collection bottles:		
4.11.1	Close the appropriate 1/2" whitey fuel oil leak-off drain valves to the poly bottle. (Reference step 1.9.4)		
4.11.2	Remove the tygon tubing from the fuel oil leak-off return lines.		
4.11.3	Reinstall the pipe cap at the end of the fuel oil leak-off return lines.	- 	
4.11.4	Empty the poly bottles into the protected area hazardous waste oil tank.		
4.11.5	Return the poly bottles and tygon tubing to the storage box.		
	Disconn 4.11.1 4.11.2 4.11.3 4.11.4 4.11.5	 Disconnect the D/G fuel oil leak-off collection bottles: 4.11.1 Close the appropriate 1/2" whitey fuel oil leak-off drain valves to the poly bottle. (Reference step 1.9.4) 4.11.2 Remove the tygon tubing from the fuel oil leak-off return lines. 4.11.3 Reinstall the pipe cap at the end of the fuel oil leak-off return lines. 4.11.4 Empty the poly bottles into the protected area hazardous waste oil tank. 4.11.5 Return the poly bottles and tygon tubing to the storage box. 	PERF Disconnect the D/G fuel oil leak-off collection bottles: 4.11.1 Close the appropriate 1/2" whitey fuel oil leak-off drain valves to the poly bottle. (Reference step 1.9.4) 4.11.2 Remove the tygon tubing from the fuel oil leak-off return lines. 4.11.3 Reinstall the pipe cap at the end of the fuel oil leak-off return lines. 4.11.4 Empty the poly bottles into the protected area hazardous waste oil tank. 4.11.5 Return the poly bottles and tygon tubing to the storage box.

ł

- -----

· ·

<u>TITLE: Da</u>	10/07/03 ta Sheet - Routine Survei	STP M-9A (UNIT 1) ATTACHMENT 9.1 illance Test of Unit 1 Diesel Ger	nerators	Page 18 of 19
4.12	REMARKS:			
	<u> </u>			
	<u> </u>			
	<u>-</u>		<u></u>	
	· · · · · · · · · · · · · · · · · · ·			
		<u></u>		
	ı		<u></u>	
	·			
			<u> </u>	
			· · · · · · · · · · · · · · · · · · ·	
		. <u>Marian () </u>		
	·			
		<u> </u>	<u> </u>	
4.13	Test performers and ve	erifiers:		
	Name	Signature	Date/Time	Init
			/	
			/	
			/	•
		·····	1	
			1	
		<u> </u>	/	
			1	
	·	<u> </u>	/	

1

STP M-9A (UNIT 1) ATTACHMENT 9.1

TITLE: Data Sheet - Routine Surveillance Test of Unit 1 Diesel Generators

5. <u>DATA REDUCTION</u>

5.1 Record values out of limits by observation:

Calculated values	Data Point:	
Lubricating oil filter ∆P (maximum limit 15 psid**)	12 minus 11	
Secondary fuel oil filter ΔP (maximum limit 35 psid**)	13 minus 14	
Calculated values:	Data Point:	
Lube oil strainer ∆P (maximum limit 9 psid**)	27 minus 28	<u> </u>
Radiator water ΔT	19 minus 29	<u> </u>
D/G hours operated this test	4.1 minus 1.1	
** AR #		
Misc. Data:		
(See page 11 of Attachment 9.1)	•	
Maximum cylinder exhaust temperature,	°F in Cylind	ler No
Minimum cylinder exhaust temperature,	°F in Cylind	er No
Difference (maximum lim	it 150°F**)	
** AR #		
		PERF
Transfer pump 0-1 increased day tank level	l. (Step 3.1.3)***	<u></u>
Transfer pump 0-2 increased day tank level	l. (Step 3.1.8)***	

^{**} If out of limits, initiate an action request.

^{***} An inoperable transfer pump puts the unit into an Action Statement.

.

Page 1 of 18

.

DIABLO CANYON POWER PLANT

STP M-9A ATTACHMENT 9.2

TITI	LE: Da	ta Sheet - Routine Surveillance Test of Unit 2 Diesel Generators	
		FIELD DATA	
D.G.	NO	DATETIME	
OPE	RATOR_		
(A I .	DIESEL)	5T D A T A	ACTUAL VALUE
1.	PRETE	SI DATA	ACTUAL VALUE
	1.1	Engine Hours:	
	1.2	(minimum level = oil visible in glass*).	
		(If below low level mark on sightglass, write an AR.)	
	•	AR#	
	1.3	Governor settings:	
		Speed Droop:	
		Load Limit:	·
		Speed:	
	1.4	Record crankcase lubricating oil level, inches below high level mark on dipstick. If lubricating oil is > 2" below the high level mark, initiate an action request to add more lubricating oil. (Minimum level is 7" below high level mark.)	
	1.5	Priming tank level (inches from bottom of sightglass) (Minimum level for D/G 2-1 and D/G 2-2 is oil visible in glass. Minimum level for D/G 2-3 is 6" from bottom of sightglass).	
		If the level in the priming tank is less than minimum, refill by manual operation of the magnetic pump or with the manual priming pump. If insufficient magnetic pump run time is suspected write an action request to maintenance to adjust the magnetic pump timer. If priming tank level cannot be established declare D/G inoperable.	
		AR#	
	1.6	Day tank fuel oil level Fill tank if < 275 gallons.	-
		**AR#	

If out of limits, declare D/G inoperable. If out of limits, initiate an action request. *

**

ł

Page 2 of 18

ł

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE:	Data Sheet -	Routine Surve	illance Test o	f Unit 2 Dies	el Generators	
						ACTUAL VALUE
1.7	Jacket (Minii	cooling water mum level=wat	level, inches a ter visible in g	above low po glass*).	int in glass.	
	If the below demin water	jacket cooling v , refill the expa eralized water. after D/G test.	water level is nsion tank to Notify chem	less than the the appropria istry to test tl	values listed te fill level using ne jacket cooling	
		· J	Level Below	<u>Fill To</u>		
	Cold		12"	15"		
	Hot	(≥160°F)	14.5"	17.5"		
	Chemi	stry Notified:			Date/Time	
1.8	West r	oll up fire door	rs are in the fu Reco	III up positior ord Door Posi	1.*** tion	
	ľ					PERF
1.9	Conne	ct the D/G fuel	oil leak-off c	ollection bott	les as follows:	
	1.9.1	Obtain 2 fr the storage	ve gallon poly box.	y bottles and	tygon tubing from	
	1.9.2	Remove the return lines	e pipe cap at i s on each side	the end of the of the of the D/G.	fuel oil leak-off	
	1.9.3	Connect the lines and re	e tygon tubing oute each to a	g to the fuel o 5 gallon poly	il leak-off return bottle.	. ·
	1.9.4	Open the ap valves to th	ppropriate 1/2 ae poly bottle.	" whitey fue	oil leak-off drain	
		D/G 2-1 D/G 2-2 D/G 2-3	D D D	EG-2-1051, 1 EG-2-1053, 1 EG-2-1057, 1	DEG-2-1052 DEG-2-1054 DEG-2-1058	

If out of limits, declare D/G inoperable. At least one west roll up fire door must be open to maintain the D/G OPERABLE. (AR A0330481-E04) ***

: :

۰.

• • •

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

PERF

1.10 If directed by the control room operator or the shift foreman, isolate starting train A or starting train B. Mark the starting train where valves will be manipulated.

Isolate Starting Train A []

Isolate Starting Train B []

N/A []

•

1.10.1 Select the air supply valve to be closed in the table below.

D/G	2 - 1	2 - 2	2-3
Train "A" Valve	DEG-2-63 []	DEG-2-89[]	DEG-2-115[]
Train "B" Valve	DEG-2-52[]	DEG-2-78 []	DEG-2-104[]

1.10.2 Select the blow-down value to be uncapped and opened in the table below. When the value is opened, PK window 16-09, 17-09, or 18-09 will alarm.

D/G	2 - 1	2-2	2-3
Train "A" Valve	DEG-2-227 []	DEG-2-249 []	DEG-2-271 []
Train "B" Valve	DEG-2-216[]	DEG-2-238 [·]	DEG-2-260[]

NOTE: When train "A" valves are manipulated, starting train "B" will be tested. When train "B" valves are manipulated, train "A" will be tested.

Page 4 of 18

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

PERF 1.11 Verify one of the following: 1.11.1 Verify the D/G control power transfer switch is in the NORMAL position with the NORMAL amber light lit on panel EQDxx, (Replace "xx" with the number of the D/G being tested for panel designation, e.g., EQD21 for D/G 21 etc.). <u>OR</u> 1.11.2 (This option available only in MODE 5, 6 or defueled when step 11.3.2 is performed) Verify the D/G control power transfer switch is in the BACKUP position with the BACKUP amber light lit on panel EQDxx (Replace "xx" with the number of the D/G being tested for panel designation, e.g., EQD21 for D/G 21 etc.). N/A [] If test is used to satisfy Tech Spec SR 3.8.1.2 or SR 3.8.1.7, 1.12 routine M-9A test, record jacket water temperature and lubricating oil temperature. If either temperature is not \geq 95°F and \leq 167°F notify the shift foreman. N/A [] Oil Temperature Water Temperature: -DIESEL WATER OIL **GENERATOR TEMPERATURE TEMPERATURE** 2-1 TI-1035 TI-504 2-2 TI-1030 TI-527 2-3 TI-1036 TI-505 OR If M&TE is used, calculate the required temperature range by adding M&TE uncertainty to 90°F and subtracting M&TE uncertainty from 175°. M&TE I.D. **Required Temperature** Range for M&TE Measured Water Temperature °F °F °F °F **Oil Temperature** N/A []

1.13

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

Record the following parameters:

DATA		INSTRUM	AENT NO. FC	R DIESEL	_	ACTUAL
POINT	PARAMETER	21	22	23	LIMITS	VALUE
1	Lubricating Oil Pressure (PSIG)	PI-629	PI-606	PI-639	10-15***	
2	Room Air Temperature (°F)	TI-98	TI-97	TI-99		. 1
3	Turbo Air Header Pressure (PSIG)	PI-844	PI-843	РІ-845	≥200** ≥195²	· .
4	Air Header B Pressure (PSIG)	PI-620	PI-598	PI-640	≥140 ¹ ≤160*	
5	Air Header A Pressure (PSIG)	PI-621	PI-599	PI-641	≥140 ¹ ≤160*	
6	Cold Jacket Water Temperature (°F)	TI-1035	TI-1030	TI-1036	95-120** ³ (≥95*)	
7	Air Receiver A Pressure (PSIG)	PI-623	PI-601	PI-634	≥210** ≥195 ¹	
8	Lubricating Oil Temperature (°F)	TI-504	TI-527	TI-505	95-120** ³ (≥95*)	
9	Turbo Air Receiver Pressure (PSIG)	PI-841	PI-840	PI-842	≥200** ≥195²	
10	Air Receiver B Pressure (PSIG) ** A D#	PI-622	PI-600	PI-633	≥210** ≥195 ¹	

¹<u>NOTE</u>: Either starting air receiver A must be \geq 195 PSIG and starting air header A must be \geq 140 PSIG <u>OR</u> starting air receiver B must be \geq 195 PSIG and starting air header B must be \geq 140 PSIG. If both starting air receivers are \geq 165 PSIG and < 195 PSIG, restore one air receiver to \geq 195 PSIG in \leq 48 hours or declare the D/G inoperable. If both starting air receivers < 165 PSIG declare the D/G inoperable. If both air header A and air header B pressure is < 140 PSIG declare the D/G inoperable. If performing a single starting train start, either air header A or air header B will indicate 0 PSIG.

²<u>NOTE</u>: If the turbocharger receiver is \geq 165 PSIG and < 195 PSIG, restore the air receiver to \geq 195 PSIG \leq 48 hours or declare the D/G inoperable. If the turbocharger < 165 PSIG, declare the D/G inoperable.

<u>NOTE</u>: If the D/G is still hot from a previous run and the oil or jacket water temperature is > 120°F, do not write an AR.

⁴<u>NOTE</u>: If the D/G lube oil is> 120°F from a previous run, the lube oil pressure is > 3 psi, and the pre-lube pump is on, do <u>NOT</u> write an AR.

- * If out of limits, declare D/G inoperable.
- ** If out of limits, initiate an action request.

2.

Ì

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

		PERF
<u>STAR</u>	TUP DATA	
NOTE power, the eng	1: If it becomes necessary to shutdown the D/G without control manually operate the overspeed trip lever on the northwest corner of the fuel oil filters.	
<u>NOTE</u> D/G sta	2: The next four steps should be performed within 60 seconds of art.	
2.1	Verify D/G started.	·
2.2	Verify D/G lube oil pressure ≥ 60 PSIG within 60 seconds of starting.** (Instrument console, PI-629, PI-606 or PI-639)	
2.3	Verify jacket water pressure increases within 60 seconds of starting.** (No pressure limit) (Instrument console, PI-643, PI-612 or PI-645)	
2.4	Verify D/G fuel oil pressure ≥ 40 PSIG within 60 seconds of starting.** (Instrument console, PI-626, PI-604 or PI-637) (Gauge response is generally about 15 seconds.)	
2.5	Verify the crankcase exhauster or exhausters are operating.**	<u></u>
2.6	Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	

** If out of limits, initiate an action request.

Page 7 of 18

•

.

STP M-9A (UNIT 2) ATTACHMENT 9.2

Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators TITLE:

										PERF	
2.7	Verify p	roper fu	el oil flo	w to the	priming	, system	l .				
	2.7.1	- Verify	/ magnet	ic primi	ng pump	o is <u>NO</u>	<u>r</u> unnii	ng.			
	2.7.2	Verify sightg	/ <u>SMAL</u> lass FI-3	<u>L</u> amour 14 (313	nt of fue (315)	l flowin	g in ove	erflow			
		NOTI fuel is level i the pro approx D/G 2	E: Fuel: not flow s increas oper leve cimately -3 should	should <u>N</u> ving in t sing, wa el. Valv 1/4 turn d be app	<u>NOT</u> coll he sightg it until th e DEG-2 n open. Noroximate	lect in tl glass bu he primi 2-530 (5 Valve D ely 1/8 1	he sight t the pri ing tank (36) sho (EG-2-5 turn ope	glass. If iming tan fills to ould be 42 for en.	ık		•
·		a. I 5 (f	f there is sightglas (536) (54 lowing i	s no flov s, then a 2) until n the ov	w or too adjust va a SMAI verflow s	much fl lve DE(LL amor ightglas	ow in tl G-2-530 unt of fi ss.	he uel is V/A []	•		
2.8	Monitor	the level	in the n	olv bott	les conn	ected to	the D/0	G fuel			
۰. ۲	leak-off	valves as	s needed	to preve	ent poly	bottle o	verfill v	while the			
• (<u>,</u>	leak-off v drain val	valves as ve is ope	s needed en and D	to preve /G is run	ent poly nning.	bottle o	verfill v	while the			
• (<u>)</u> • 47	leak-off v drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill v	while the			
• (. • 4 7	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is run	ent poly nning.	bottle o	verfill v	while the			
• (<u>,</u>	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill v	while the			
• (<u>,</u>	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill v	while the			
• (<u>,</u> • 4 7	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the			
• •	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the			
• : <u>,</u>	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the			
• (<u>,</u>	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the			
• (<u>,</u>	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the	· · ·		
• (<u>,</u> • , ,,	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o	verfill	while the		•	
• ;, • ;; ;	leak-off drain val	valves as ve is ope	s needed en and D	to preve /G is ru	ent poly nning.	bottle o		while the		-	

1

Page 8 of 18

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

_		-		PERF	VERIF
3. .	<u>RUN DA</u>	<u>TA</u>			
	NOTE: started.	Steps 3.1 a The D/G do	and 3.2 can be performed anytime after the D/G has been been not need to have been running for at least 1 hour.		
	3.1	Verify O following	PERABILITY of the fuel oil transfer system in the g steps:		
*****	******	*******	************	******	******
CAUT spill. L tank.	ION: It is evel colur	s possible to nn respond	o overflow the fuel oil day tank in MANUAL control, and thu is very slowly to a level change. Exercise caution when manu	us cause a ually fillin	fuel oil ng a day
*****	******	*******	· · · · · · · · · · · · · · · · · · ·	******	*****
		<u>NOTE</u> : in parentl	The numbers given below are for D/G 2-1. The numbers neses are for D/G's 2-2 and 2-3 respectively.		
		3.1.1	Start fuel oil transfer pump 0-1 from D/G 2-1 (2-2) (2-3).	·	
		3.1.2	Open day tank fill valve LCV-89 (88) (90).		
		3.1.3	Observe an increase in day tank level. (Verifies foot valves DEG-0-1114, DEG-0-1115, and check valve DEG-0-35 are OPERABLE.)		
		3.1.4	Close LCV-89 (88) (90) and place in AUTO.		
		3.1.5	Stop fuel oil transfer pump 0-1 and place the switch in the AUTO position.		
		3.1.6	Start fuel oil transfer pump 0-2 from D/G 2-1 (2-2) (2-3).		
		3.1.7	Open day tank fill valve LCV-86 (85) (87).		
		3.1.8	Observe an increase in day tank level. (Verifies foot valves DEG-0-1117, DEG-0-1118, and check valve DEG-0-36 are OPERABLE)		
		3.1.9	Close LCV-86 (85) (87) and place in AUTO.		
		3.1.10	Stop fuel oil transfer pump 0-2 and place the switch in the AUTO position.		
	3.2	Verify pro performing	oper operation of the fuel oil priming system by g the following:		
		3.2.1	Place magnetic priming pump control switch in MANUAL and verify pump operation by increase in fuel oil flow through overflow sightglass.		
		3.2.2	Place magnetic priming pump control switch in AUTO.	<u> </u>	

	10/07/03	STP M-9	A (UNIT 2) IMENT 9.2	Pa	age 9 of 18	
TITLE:	Data Sheet - Routine Surve	eillance Test	of Unit 2 Diese	el Generators		
	3.3 Record the following ≤ 2.50 MW load.	g parameters	after the D/G h	nas run ≥ 60 mi	nutes at ≥2.45	MW and
DATA	· · ·	INSTRUM	MENT NO. FO	R DIESEL		ACTUAL
POINT	PARAMETER	21	22	23	LIMITS	VALUE
	NORTH SIDE OF DIESEL		•			
11	Lube Oil Pressure Leaving Filter (PSIG)	PI-836	PI-834	PI-838		<u> </u>
12	Lube Oil Pressure Entering Filter (PSIG)	PI-627	PI-607	PI-638		
13	Secondary Fuel Oil Filter Inlet Press. (PSIG)	PI-625	PI-603 .	PI-636		- 23
14	Secondåry Fuel Oil Filter Outlet Press. (PSIG)	PI-831	PI-829	PI-833		
15	Primary Fuel Oil Filter dp (In. Hg.)	PIS-1021	PIS-1022	PIS-1023	≤4.5**	
16	Lube Oil Pressure (PSIG)	PI-629	PI-606	PI-639	≥60*	
17	Lube Oil Temperature Leaving Engine (°F)	TI-504	TI-527	TI-505	≤195***	· ·
18	Jacket Water Pressure (PSIG)	PI-643	PI-612	PI-645	· . ·	· · ·
19	Jacket Water Temperature Entering Radiator (°F)	TI-1035	TI-1030	TI-1036	· · ·	
20	Fuel Oil Pressure (PSIG)	PI-626	PI-604	PI-637	≥40	• • • • • • • • • • • • • • • • • • •

* If out of limits, declare D/G inoperable and the D/G should be shutdown for insufficient lube oil pressure.

** If out of limits, initiate an action request.

*** If out of limits, initiate an action request. Verify temperature is not increasing. If temperature cannot be maintained below limit, the D/G should be shutdown.

ł

Page 10 of 18

i

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

<u> </u>			·			
DATA	_	INSTRUM	<u>1ENT NO. FO</u>	R DIESEL	_	ACTUAL
POINT	PARAMETER	21	22	23	LIMITS	VALUE
21	Radiator Discharge Air Temperature (°F)	TI-529	TI-528	TI-540	≤160**	
22	Turbo Air Discharge Pressure (PSIG)	PI-826	PI-822	PI-827		<u>.</u>
23	Room Air Temperature (°F)	TI-98	TI-97	TI-99	≤120°F**	
24	No. of Crankcase Exhausters in Operation (D/G 23 has only one exhauster)	⇒	⇒	⇒	1**, 0** 0**(D/G 23)	
	EXCITER CUBICLE					
25	Exciter Voltage, VDC	⇒	⇒	⇒	VDC .	
	Voltage, V	⇒	⇒	⇒	v	
26	Exciter Current, Amps	⇒	⇒	⇒	AMP	<u>_,</u>
	SOUTH SIDE OF DIESEL					
27	Lube Oil Strainer Inlet P (PSIG)	PI-837	PI-835	PI-839	-	·
28	Lube Oil Strainer Outlet P (PSIG)	PI-628	PI-608	PI-644	-	
29	Jacket Water Temperature Leaving Radiator (°F)	TI-507	TI-506	TI-508	≤185 * *	
30	Lube Oil Temperature Leaving L.O. HX (°F)	TI-1032	TI-1028	TI-1034	-	

** If out of limits, initiate an action request.

Ì

ł

Page 11 of 18

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

POINT PARAMETER 21 22 23 LIMITS VALUE GENERATOR I Horizontal (x axis)	DATA				N	ISTRUN	MENT N	IO. FOR	DIESE	EL		A	CTUAL
GENERATOR 31 Horizontal (x axis) Vibration taken on blue dot on south side of generator bearing housing. (Use Portable Vibration Meter set on IPS) 32 Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Meter set on IPS) 33 Axial (z axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set on IPS) Cylinder and Exhaust Temperatures - Inst. Console	POINT	· PAR	AMET	ER		21	2	2	23		LIMITS	<u>۱</u>	ALUE
32 Vertical (y axis) Vibration taken on blue dot on top of generator bearing housing. (Use Portable Vibration Meter set on IPS) 33 Axial (z.axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set on IPS) Cylinder and Exhaust Temperatures - Inst. Console	31	GENERAT Horizontal Vibration t dot on sout generator b	<u>FOR</u> (x axis aken o h side bearing	s) n blue of housing	(]]se	Portab	le Vibrat	tion Met	ter set o	n IPS)			
33 Axial (z,axis) Vibration taken on blue dot on end of generator bearing housing. (Use Portable Vibration Meter set on IPS) Cylinder and Exhaust Temperatures - Inst. Console Cylinder R1 R2 R3 R4 R5 R6 R7 R8 R9 UR LR Cylinder R1 R2 R3 R4 R5 R6 R7 R8 R9 UR LR Temperature °F	32	Vertical (y Vibration t dot on top bearing hou	axis) aken or of gene using.	n blue erator	(Use	Portabl	le Vibrat	ion Met	ter set o	n IPS)			
Cylinder and Exhaust Temperatures - Inst. ConsoleCylinderR1R2R3R4R5R6R7R8R9URLRTemperature °FCylinderL1L2L3L4L5L6L7L8L9ULLLTemperature °F3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.4Verify cooling water or lube oil leaks < 2 drops per minute (DPM) out of the water pump tattletale.**3.5Verify cooling water or lube oil leaks < 2 drops per minute (DPM) out of the water pump tattletale.**3.6Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	33	Axial (z, ax Vibration t dot on end bearing hou	is) aken or of gene using.	n blue ⁻ erator	(Use	Portabl	e Vibrat	ion Met	er set o	n IPS)			
CylinderR1R2R3R4R5R6R7R8R9URLRTemperature °FCylinderL1L2L3L4L5L6L7L8L9ULLLTemperature °F3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.5Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.**If an AR is initiated, list the type of leakage. ** AR #3.6Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	Cylir	nder and Ex	haust I	Temperat	ures - Ir	ist. Con	sole					_	
Temperature °FCylinderL1L2L3L4L5L6L7L8L9ULLLTemperature °F3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**PERF3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**	Cylir	nder	R1	R2	R3	R4	R5	R6	R7	R8	R9	UR	LR
CylinderL1L2L3L4L5L6L7L8L9ULL1Temperature °F3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.4Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.**3.5Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.**3.5Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.**If an AR is initiated, list the type of leakage. ** AR #3.6Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	Tem	perature °F						•				,	:
PERF 3.4 Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.** ** AR # 3.5 Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.** If an AR is initiated, list the type of leakage. ** AR # 3.6 Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.	Cylir	nder perature °F	LI	L2	L3	L4	L5	L6	L7	L8	L9	UL	LL
 3.4 Verify there is no continuous or intermittent jacket cooling water leakage from turbo aftercooler tattletale.** ** AR #					········				<u> </u>		PEF	<u>RF</u>	
 ** AR # 3.5 Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.** If an AR is initiated, list the type of leakage. ** AR # 3.6 Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable. 	3.	4 Ve leal	rify the kage fr	ere is no om turbo	continu o afterco	ous or ir ooler tati	ntermitte tletale.*'	nt jacke	t coolin	g wate	r 		
 3.5 Verify cooling water or lube oil leaks ≤ 2 drops per minute (DPM) out of the water pump tattletale.** If an AR is initiated, list the type of leakage. ** AR # 3.6 Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable. 		**	AR #				• •		· ·				
 ** AR # 3.6 Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable. 	3.:	5 Ver out typ	rify coo of the e of lea	oling wa water pu akage.	ter or lu imp tatt	be oil le letale.**	aks≤2 * If an A	drops pe AR is ini	er minut tiatèd, l	e (DPN ist the	(1)	•	•
3.6 Verify governor oil is at or above the low level mark in sightglass. If below the mark write an AR. If not visible, declare D/G inoperable.		**.	AR #		,						-		
	3.0	6 Ver If b ino	rify gov elow ti perable	vernor oi he mark e.	il is at o write an	r above AR. If	the low not visi	level ma ble, dec	ark in si lare D/C	ghtglas G	'S.	 	
									•.			•	,

ì

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE: Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators

4.	<u>SHUT</u>	DOWN DA	<u>ATA</u>			
	4.1	Record	engine hours:	hrs.		
	4.2	If valve blow-de	If valves were manipulated in step 1.10, close and cap the blow-down valve and open the air supply valve.			
		4.2.1	Valve that was closed and capped:	<u> </u>		
		4.2.2	Valve that was opened:			

4.3	After the D/G has been shutdown for 10 minutes, record the
	following data:

DATA		INSTRU	MENT NO. FO	OR DIESEL		ACTUAL
POINT	PARAMETER	21	22	23	LIMITS	VALUE
34	Air Receiver A Pressure (PSIG)	PI-623	PI-601	PI-634	≥210** ≥195 ¹	
35	Lubricating Oil Pressure (PSIG)	PI-629	PI-606	PI-639	≥2**	
36	Turbo Air Header Pressure (PSIG)	PI-844	PI-843	PI-845	≥200 ** ≥195 ²	
37	Air Header B Pressure (PSIG)	PI-620	PI-598	PI-640	≥140 ¹ ≤160*	
38	Air Header A Pressure (PSIG)	PI-621	PI-599	Pl-641	≥140 ¹ ≤160*	
39	Turbo Air Receiver Pressure (PSIG)	PI-841	PI-840	PI-842	≥200** ≥195 ²	
40	Air Receiver B Pressure (PSIG)	PI-622	PI-600	PI-633	≥210** ≥195¹	

¹<u>NOTE</u>: Either starting air receiver A must be \geq 195 PSIG and starting air header A must be \geq 140 PSIG <u>OR</u> starting air receiver B must be \geq 195 PSIG and starting air header B must be \geq 140 PSIG. If both starting air receivers are \geq 165 PSIG and < 195 PSIG, restore one air receiver to \geq 195 PSIG in \leq 48 hours or declare the D/G inoperable. If both starting air receivers < 165 PSIG declare the D/G inoperable.

²<u>NOTE</u>: If the turbocharger receiver is \geq 165 PSIG and < 195 PSIG, restore the air receiver to \geq 195 PSIG \leq 48 hours or declare the D/G inoperable. If the turbocharger < 165 PSIG, declare the D/G inoperable.

- * If out of limits, declare D/G inoperable.
- ** If out of limits, initiate an action request.

Page 13 of 18

ACTUAL VALUE

.

STP M-9A (UNIT 2) ATTACHMENT 9.2

Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators TITLE:

			(
4.4	Record (Minin inches	d jacket cooling water level, in mum level = water visible in gl and ≤ 17.5 inches.)	ches above low point ass*.) (Normal level	in glass. ≥ 14.5	
· `.	Did th	e level increase from step 1.7	YES []NO[]	
	NOTH jacket should water stated	E: This check is performed to a cooling water level indicator. I initiate an action request to in level indicator should the level below.	Illow detection of plu PPE reviewing this day vestigate the jacket co indicate other than th	gging ata sheet oling e trend	
	1.	If the D/G is started cold, j recorded in step 4.4 should hour run.	acket cooling water le increase after a norm	evel nal 1	
	2.	If the D/G is started cold for (nominal) run, the level rec remain relatively unchange	or a less than 20 minu corded in step 4.4 shou d.	te uld	
、	3.	If the D/G is started warm, should remain unchanged a	the level recorded in after the D/G run.	step 4.4	
4	 If the j expans chemis If chem 	acket cooling water level is bel ion tank to 16.5 inches with de stry to conduct a chemical test on histry was notified in step 1.7, a	ow 14.5 inches, refill mineralized water and on the jacket cooling v to action is needed. N/A	I notify water.	
	Chemis	stry Notified:	Date/T	ime	<u> </u>
<u>NOTE</u> : parenthe	The num eses are fo	bers given below are for D/G for D/G for D/G's 2-2 and 2-3 respective	2-1. The numbers in ly.		
4.5	If the d	ay tank level is less than 500 g	allons, fill the day tan	k to	

If out of limits, declare D/G inoperable. If out of limits, initiate an action request. *

**

!

Page 14 of 18

1.

i

STP M-9A (UNIT 2) ATTACHMENT 9.2

TITLE:	Data Sheet - 1	Routin	e Surveillance Test of Unit 2 Diesel Generators		
		•		PERF	VERIE
*******	*******	****	******	********	<u>• Litti</u>
CAUTION spill. Leve tank.	I: It is possible l column respo	to ov nds ve	erflow the fuel oil day tank in MANUAL control, and ry slowly to a level change. Exercise caution when m	thus cause a anually filli	a fuel oil ng a day
	4.5.1	lf f	uel oil transfer pump 0-1 is used perform the owing:		
			N/A []		
		a.	Start fuel oil transfer pump 0-1.		
		ь.	Open day tank fill valve LCV-89 (88) (90).		
		с.	When the day tank is filled to approximately 500 gallons, close day tank fill valve LCV-89 (88) (90).		
	1	d.	Place day tank fill valve control switch LCV-89 (88) (90) in AUTO.		
		e.	Stop diesel fuel oil transfer pump 0-1 and place in AUTO.		
	4.5.2	If fi foll	el oil transfer pump 0-2 is used perform the owing:		
			N/A [] .		
		а.	Start fuel oil transfer pump 0-2.	<u>-</u>	·
		b.	Open day tank fill valve LCV-86 (85) (87).		
		c.	When the day tank is filled to approximately 500 gallons, close day tank fill valve LCV-86 (85) (87).		
		đ.	Place day tank fill valve control switch LCV-86 (85) (87) in AUTO.		
		e.	Stop diesel fuel oil transfer pump 0-2 and place in AUTO.		
4.6	Record of	lay tar	k fuel level.	•	
			gallons	<u> </u>	
	<u>NOTE</u> : day tank	If the level	- day tank low level alarm (LOA) is out of service, shall be ≥ 300 gallons.*		

^{*} If out of limits, declare D/G inoperable.

Page 15 of 18

STP M-9A (UNIT 2) ATTACHMENT 9.2 Data Sheet - Routine Surveillance Test of Unit 2 Diesel Generators TITLE: PERF 4.7 Record actual priming tank level (inches from bottom of sightglass) (minimum level = level of return line = approx. 5"). ** Level **8**2 E If the level in the primary tank is less than minimum, refill by •1 manual operation of the magnetic pump or with the manual priming pump. If insufficient magnetic pump run time is suspected write an action request to maintenance to adjust the magnetic pump timer. If priming tank level cannot be established, declare D/G inoperable. AR# 4.8 Record actual crankcase lubricating oil level, inches below full mark on dipstick. If lubricating oil is > 2" below the high level mark, initiate an action request to add more lubricating oil. (Minimum level is 7" below high level mark.) Level Blowdown all three air receivers inline filters a small amount 4.9 through their drain valves to check for water accumulation. -**NOTE:** To blowdown the filter units the screw on the bottom must be turned clockwise several turns when viewed from the bottom. 4.9.1 Air receiver systems blown down. Prefilter Oil Filter After Filter Turbo [] ſĨ 1 Starting A [] [] [] Starting B [] [] [.] 4.9.2 If water is present, write an action request. (A small amount of mist out of the prefilter is acceptable). AR# N/A []

If out of limits, declare D/G inoperable.

Page 16 of 18

} •

STP M-9A (UNIT 2) ATTACHMENT 9.2

minul C

			PERF	VERI
4.10	Perform tank.	the following to drain any accumulated water in the day		
	4.10.1	Open drain valve(s) on D/G fuel oil day tank and check for the presence of water. Remove any accumulated water.		
		NOTE: For D/G with multiple drain valves, one or more of the following drain valves may be opened to remove any accumulated water.		
	4.10.2	Circle drain valve or valves opened below.		
		D/G Valve		
		2-1DEG-2-1059/1060/1061/1062/1063/10642-2DEG-2-1065/1066/1067/1068/1069/10702-3DEG-2-520/521/1078/1079/1080		
	4.10.3	Day tank checked for presence of water.*** [] Removed accumulated water*** [] No water found		
	4.10.4	Close the drain valve(s) opened in step 4.10.1.		
4.11	Disconn	ect the D/G fuel oil leak-off collection bottles:		
	4.11.1	Close the appropriate 1/2" whitey fuel oil leak-off drain valves to the poly bottle. (Reference step 1.9.4)		
	4.11.2	Remove the tygon tubing from the fuel oil leak-off . return lines.		
	4.11.3	Reinstall the pipe cap at the end of the fuel oil leak-off return lines.		
	4.11.4	Empty the poly bottles into the protected area hazardous waste oil tank.		
	4.11.5	Return the poly bottles and tygon tubing to the storage		

*** If check is not done or if any accumulated water is found and not removed, declare D/G inoperable.

	10/07/03 S	TP M-9A (UNIT 2) ATTACHMENT 9.2		Page 17 of 18
TITLE: Da	ta Sheet - Routine Surveillar	nce Test of Unit 2 Diesel G	enerators	
	· · · · · · · ·			· ·
4.12	REMARKS:	<u> </u>	·	
	<u></u>	······································		
نڈ :	•	· · · · · · · · · · · · · · · · · · ·	·····	
•	<u> </u>		·	
** - * *		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	
	<u> </u>	· · · · · · · · · · · · · · · · · · ·		
			· · · · · · · · · · · · · · · · · · ·	
	<u></u>			
		,, <u>,</u> ,		
•:		<u></u>		
	<u> </u>		······	
	<u></u>	<u> </u>	· · · · · · · · · · · · · · · · · · · · ·	
ł	•	. <u></u>		
	<u> </u>			
4 13	Test performers and verif	iers:		
	Name	Signature	Date/Time	<u>Init</u>
			/	
	· · · · · · · · · · · · · · · · · · ·		<u> </u>	
				<u> </u>
	<u> </u>	<u></u>	/	
			/	
		•	/	• •
		<u> </u>	· /	
		and the Angle Angle and Angle Ang	<u> </u>	
			/	
	<u></u>	<u></u>		
	<u> </u>		/	

00316365.DOA 06 1007.0311

.

j

.

		10/07/03		Page 18 of 18
		STP M-9A (UNIT	2)	,
		ATTACHMENT 9	.2	
TITLE	: Data	Sheet - Routine Surveillance Test of Unit 2	Diesel Generators	
		··· . ·		
5.	<u>DATA R</u>	EDUCTION		
	5.1	Record values out of limits by observation:		<u></u>
		· · ·		
	5.2 ·	Calculated values:	Data Point:	· · · · · · · · · · · · · · · · · · ·
		Lubricating oil filter ∆P (maximum limit 15 psid**)	12 minus 11	psid
		Secondary fuel oil filter ∆P (maximum limit 35 psid**)	13 minus 14	psid
		Calculated values:	Data Point:	
		Lube oil strainer ∆P (maximum limit 9 psid**)	27 minus 28	psid
		'Radiator water ∆T	19 minus 29	°F
		D/G hours operated this test	4.1 minus 1.1	hrs.
		** AR #		
	5.3	Misc. Data:		
		(See page 11 of Attachment 9.2)	•	
		Maximum cylinder exhaust temperature,	°F in Cylinder No.	
		Minimum cylinder exhaust temperature,	°F in Cylinder No)
		Difference (maximum limi	t 150°F**)	
		** AR #	·	
				PERF
	5.4	Transfer pump 0-1 increased day tank level	. (Step 3.1.3)***	
	5.5	Transfer pump 0-2 increased day tank level.	. (Step 3.1.8)***	

Ĵ.

ł

If out of limits, initiate an action request. An inoperable transfer pump puts the unit into an Action Statement. ***

^{**}

Page 1 of 2

DIABLO CANYON POWER PLANT STP M-9A ATTACHMENT 9.3



	10/07/03	- STP M-9A (UNIT 1) ATTACHMENT 9.3		Page 2 of 2
TITLE	E: Unit 1 Undervoltage Tes	t at Switchgear Room	<u></u>	
3.	REMARKS:			
				······································
4.	Test performers and verifiers:	;		
	<u>Name</u>	<u>Signature</u>	<u>Date/Time</u> / / / / /	<u>Init</u>
			/	• <u> </u>

.

.

i

1

.

Z

.

DIABLO CANYON POWER PLANT STP M-9A •

10/07/03

ATTACHMENT 9.4

	ъ. · .	PROCI	EDURE STEPS PERFO	DRMED AT SWITCHGEA	R
).G. N	0		DATE	TIME	-
OPERA	TORAT	SWITCHGEA	R	····	
•	Starting t	he D/G on an u	indervoltage, perform t	he following: N/A []	
	1.1 QT	Establish com appropriate vi	nmunications between t ital 4KV switchgear roo	he D/G, control room, and om.	
		DIESEL -	SWITCHGEAR		
	• •	2-1 2-2. 2-3	HG HH HF		
	· · ·	NOTE: The The cutout sw	UV relays are located a vitches are labeled:	t the safeguard relay board	
		"4KV BUS G SWITCH."	(H) (F) STARTUP TR	ANSF FEEDER UV TEST	
	1.2	Cutout the app simulate UV of	propriate startup bus un on the startup bus.	dervoltage (UV) relay to	CV
		DIESEL	<u>S/U BUS UV</u>	•	
		2-1 2-2 2-3	27HGU 27HHU 27HFU		
	When inst	ructed by the c	control room operator:		
	2.1	Cut-in the app (27HFU) at th appropriate au	ropriate startup bus UV e safeguard relay board to transfer test switch 1	' relay 27HGU (27HHU) bus G (H) (F) by placing t abeled:	he
		4KV BUS G (SWITCH in th	H) (F) STARTUP TRA	NSF FEEDER UV TEST	
	2.2	Reset the targe at the safeguar	et drop flag on UV relay rd relay board bus G (H	y 27HGU (27HHU) (27HF) (F).	U)

į

	10/07/03	STP M-9A (UNIT 2) ATTACHMENT 9.4		Page 2 of 2
TITLI	E: Unit 2 Undervoltage Te	est at Switchgear Room		
3.	REMARKS:			
4	Test performers and verifier	s:		_
	Name	Signature	Date/Time	<u>Init</u>
			/	
			/	
	·		/	
			1	

j.

***]	SSUED F	OR USE BY:	DATE:	EXPIRES: ***				
PAC	IFIC GAS	AND ELECTRIC COMPANY		NUMBER STP M-9D1				
NUC	LEAR PO	WER GENERATION		REVISION 11				
DIAI	BLO CAN	YON POWER PLANT		PAGE 1 OF 12				
SUR	VEILLAN	CE TEST PROCEDURE		UNITS				
,		· · · · · ·	•• ,• •	·				
TITI	LE: Die	sel Generator Full Load Rejectio	on Test					
	، نگر ه			12-03 00 (
	-7;			EFFECTIVE DATE				
	9	PROCEDURE CLASSIF	ICATION: QUALIT	TY RELATED				
1.	<u>SCOPE</u>							
	1.1	This procedure is performed to te Generator (D/G). The D/G is par ≤ 2.50 MW with power factor of D/G ouput breaker. The D/G is v	est the full load rejection ralleled to the grid and ≤ 0.87 . The full load r verified not to trip and	on capability of the Diesel is then loaded to ≥ 2.45 MW and ejection is initiated by opening the the voltage remains ≤ 143.6 V.				
2.	<u>RESPONSIBILITIES</u>							
	2.1	Power Production Engineer (PPE during the test, final data reduction OPERABILITY.	b), for coordination of t on, reporting of results	test, providing technical guidance and determination of D/G				
3.	FREQUE	ENCY						
	3.1	This test will be performed at leas	st once per 24 months.					
	3.2	This test is required to be current	in MODES 1, 2, 3, 4,	5 and 6.				
	3.3	This test shall not be performed in OPERABILITY following unplar	n MODES 1 or 2 unles nned maintenance.	ss required to demonstrate				
4.	<u>TECHNI</u>	CAL SPECIFICATIONS						
	4.1	Technical Specification (Tech Spe by this test.	ec) SR 3.8.1.10 and pa	art of SR 3.8.2.1 will be satisfied				
5.	ACCEPT	ANCE CRITERIA						
	5.1	Following a full load rejection of and ≤ 2600 KW) with a reactive lo (128 KVARs for inaccuracies) and Attachment 8.2 for the reactive point.	\geq 2.45 MW and \leq 2.50 oad so the power facto d \geq 0.80, the D/G will ower setting for a given	0 MW (Tech Spec ≥ 2340 KW or is ≤ 0.87 + 128 KVARs remain running. See n power out.				
	5.2	Following a full load rejection of z so the power factor is $\leq 0.87 + 12z$ (Tech Spec $\leq 5075V$) 143.6 volts.	≥ 2.45 MW and ≤ 2.50 8 KVARs and ≥ 0.80,	D MW with enough reactive load the D/G voltage will not exceed				

PACIFIC DIABLO	GAS AND ELECTRIC COMPANY CANYON POWER PLANT	NUMBER REVISION PAGE	STP M-9D1 11 2 OF 12
TITLE:	Diesel Generator Full Load Rejection Test	UNITS	1 AND 2

6. <u>REFEREN</u>	CES
-------------------	-----

- 6.1 Instruction Manual for ALCO Diesel DC663082-80.
- 7. <u>APPENDICES</u>

None

8. ATTACHMENTS

8.1 "Data Sheet - Diesel Generator Full Load Rejection Test; Calibration of Test Recorder," 07/12/01

t

8.2 "D/G Power Factor vs Real Power and Reactive Power," 02/12/02

..

9. <u>SPONSOR</u>

C. Wheeler

PAC DIA	CIFIC GAS BLO CAN	S AND ELECTRIC COMPANY IYON POWER PLANT	NUMB REVIS PAGE	ER STP M-9D1 ION 11 3 OF 12
TIT	LE: Die	sel Generator Full Load Rejection Test	UNITS	1 AND 2
		START DATA SECTION		
	INIT	OPERATING MODE DATE/TIME	2	
	DIESEL		·	
10.	PRECA	UTIONS AND LIMITATIONS		<u>INITIALS</u>
	10.1	Observe the Precautions & Limitations of STP M-9A when performing this test.		<u></u> ,
	10.2	During this test, equipment that is necessary for current plant operations should not be powered from the vital bus associate with the D/G to be tested.	ed .	
	10.3	Utilizing the information in the Control Room (i.e., clearance annunciators, etc.), check to see if the other diesels for the un OPERABLE.	logs, it are	
		10.3.1 The directional power, overcurrent and loss of field relays for the diesel to be tested should be cutin to protect the diesel when it is paralleled to its bus. T relays shall be cutout following the test. While the relays are cutin for testing, the diesel is considered OPERABLE.	d hese	
		10.3.2 Declare the test diesel inoperable when paralleled t off-site power source.	o the	·
		10.3.3 If a diesel is inoperable, verify the action requirement in Tech Spec LCO 3.8.1 in MODES 1-4 or Tech Sp LCO 3.8.2 in MODES 5 and 6 are being followed.	ents pec	
	10.4	In MODES 1, 2, 3, and 4, if paralleling a diesel to Startup Pow declare the diesel inoperable and perform the action required in Tech Spec LCO 3.8.1.	wer, in	
			· .	
			• • • • • •	•.

•

:

×

.

PAC DIA TITI	IFIC GA BLO CAI LE: Di	NUMBER REVISION PAGE UNITS	STP M- <u>9</u> D1 11 4 OF 12 1 AND 2		
				PERF	VERIF
11.	PRERE	<u>QUISITES</u>			
	11.1	Obtain Shift Foreman's approval	to perform this test.		
		Signature:	Date/Time		/
		Shift For	reman		
	11.2	Request maintenance to calibrate per Attachment 8.1.	and setup test (M&TE) recor		_
	11.3	With SFM's permission, have an recorder set across frequency meter frequency meter of the diesel bein fused lead.	electrician install the calibrate ter terminals 3 and 5 of the ng tested on VB4 with a 1 am	ed p	
		NOTE: The fused lead should be terminal of the diesel frequency ne fused lead is used to protect the 6 upstream of the frequency meter is accidentally grounded.	e connected to the positive neter which is terminal 3. The Amp. potential transformer f if the connection to the record	e iuse ler	
	11.4	Verify the following main contro calibration:	board meters are in current		
		Diesel to be tested is			
		MW/Freq recorder. Cal D	ue Date		_
		(1RW, 2RW, 3RW, or 2-VB4-12	5)		
		Volt/MVAR recorder. Cal D	ue Date		_
		(1RVAR, 2RVAR, 1/2-VB4-129))		
		MVAR meter. Cal D	ue Date		_
		(1/2-VB4-58/59/60-VAR)			
		MWATT meter. Cal D	ue Date		_
		(1/2-VB4-52/53/54-W)			
	·	<u>NOTE</u> : To find Cal Due Dates, u the instrument number and press of "PME" & press enter. A list of w screen. One of these work orders this procedure W/O and check the	ise PIMS search = 3.211. E enter. In the command line, t ork orders will show on the will be for calibration. Selec due date.	nter - ype t	

;

PACIFIC DIABLO	GAS AND ELECTRIC COMPANY CANYON POWER PLANT	· · · ·	NUMBER REVISION	STP M-9D1 11
•		۰.	PAGE	5 OF 12
TITLE:	Diesel Generator Full Load Rejection Test		UNITS	1 AND 2

•

11.5 th	ough 11.8 N/A.
11.5	The diesel to be tested is aligned for normal operation in accordance with OP J-6B.
•	N/A []
11.6	Perform a prefiring check per STP M-9A for the D/G to be tested, or per the appropriate section(s) of the Turbine Building Round
	Sheet. Note that the second structure of the second st
11.7	Diesel CARDOX fire protection system for the Diesel to be tested should be OPERABLE or compensatory action taken.
	N/A []
11.8	Have STP M-91 data sheet(s) available to be fill out for any diesel start associated with this test.
- -	N/A[]
	and an

. • .

> ---

.

Ϊ.

.

PAC DIA TIT	CIFIC GA BLO CA LE: D	AS AND EL NYON POV iesel Genera	ECTI VER ator F	RIC COMPANY PLANT Full Load Rejection Test	NUMBER REVISION PAGE UNITS	STP M-9D1 11 6 OF 12 1 AND 2
					PERF	
12.	PROC	EDURE				
	12.1	Notify tl	ne cor	strol operator that testing is ready to commence.	<u></u>	
	<u>NOTI</u>	E: If the dies	el wa	s already running, mark Step 12.2 N/A.		
	12.2	Pre-test	diesel	run	N/A []
		12.2.1	Cut Ove test	in the Directional Power, Loss of Field and ercurrent Protective features for the Diesel being ed with the FCO switch on VB4.		_
		12.2.2	Ma	nually start the Diesel to be tested per OP J-6B.		
		12.2.3	Pla the	ce/Verify the appropriate D/G MODE SEL swite MANUAL position.	:h in 	
		12.2.4	Che Oth the	eck diesel generator output voltage on each phase erwise, when synchroscope is turned ON (next s voltmeter will lock on to phase C.	e. tep)	_
		12.2.5	Cut	in the FEEDER SYNC Switch.		_
		12.2.6	Ver	ify synchroscope working.		
			a.	Lights OFF at the 12 o'clock position.		
			b.	Lights FULL BRIGHT at the 6 o'clock positio	n.	
		12.2.7	Adj gov	ust engine speed up and down to verify the man ernor is in control.	ual	_
		12.2.8	Set in tl dies	engine speed so the synchroscope is turning slow the clockwise (FAST) direction. This will allow sel to pick up load when paralleled to the bus.	vly the	_
		12.2.9	Adj volt	ust generator voltage to within ± 2 volts of bus age.		_
		12.2.10	Wh o'cle to the the the	en the synchroscope pointer is slightly before the ock position, turn generator breaker control switch the CLOSE position. Pick up load (0.5MW) nptly after the breaker is closed. This will preve D/G breaker from tripping open due to actuation cut-in reverse power relay.	e 12 ch _ ent of	
			Clo	ck time D/G paralleled: hrs.		

.

PACIFIC GA DIABLO CAI	S AND ELI NYON POV	ECTRIC COMPAN VER PLANT	NY .	15 ¹	NUMBER REVISION PAGE	STP M-9D) 11 7 OF 12
ITLE: Di	esel Genera	tor Full Load Reje	ction Test	N.	UNITS	1 AND 2
	.*				PERI	F
	12.2.11	Adjust voltage wit VARS-OUT.	h voltage contr	ol switch to n	naintain	_
	12.2.12	Cut out the FEED	ER SYNC Swit	ch.		
	12.2.13	Increase the load to of ≤ 0.50 MW ever DG reaches ≥2.45	o ≥2.45 MW ar ry 2 minutes ar MW load:	nd ≤2.50 MW nd record cloc	at a rate k time	
		Date/Time	· / · · · ·	· · · ·	·	_
	12.2.14	Complete applicab	ole sections of S	TP M-91 for	the start	
		of the dieser for the	13 1031. · · · / i	N	/A[]	_
12.3	Warmup	or verify that the die	esel has been w	armed up for	the test.	
:: :	[] Run [] The	the diesel at ≥ 2.45] Diesel was consider be discretion of the l	MW and ≤ 2.50 ed warmed up of PPF	MW for \geq of Δ	ne hour. 1s testing	
*	peri	ne discretion of the		.*		
			· · · ·			
			· · · · ·		-	
				•		
			2 • X		、 _	
		· · · · ·			,	
		· .	• • •	• .	. ,	
		. • .	· · · · · · · · · · · ·			
		·.	· ·			

÷
PACIFIC (DIABLO (GAS AND EL CANYON POV	ECTRIC COMPANY WER PLANT	NUMBER REVISION PAGE	STP M-9D 11 8 OF 12
TITLE:	Diesel Genera	ator Full Load Rejection Test	UNITS	1 AND 2
			PERF	
12.4	Full Loa	d Rejection Test.		
	12.4.1	Verify diesel is paralleled to the grid. If not, diesel per Steps 12.2.3 through 12.2.12.	parallel	
	12.4.2	Adjust diesel load to ≥ 2.45 MW and ≤ 2.50 I reactive load ≥ 1.6 MVAR and ≤ 1.75 MVAR load at a rate ≤ 0.50 MW every 2 minutes.	MW with a R. Change	_
	12.4.3	Verify that the temporary M&TE recorder set properly set up to record the diesel voltage.	t is	_
	12.4.4	Switch or verify switched the following Cont recorders associated with the diesel being test Speed and are inking properly.	rol Room ted to High	
		Diesel MW/HZ recorder in High Speed.		_
		Diesel MW/HZ recorder inking properly.		_
		Diesel KV/MVAR recorder in High Speed.		_
		Diesel KV/MVAR recorder inking properly.	<u> </u>	
	12.4.5	Record the Load and Reactive Load.		_
		Load MW		
		Reactive Load MVARs		
		Date/Time/		
	12.4.6	Start the temporary M&TE recorder.		
	12.4.7	Open the D/G output breaker associated with being tested.	the diesel	_
	12.4.8	Verify the diesel engine remains running and trip during this full load rejection transient. If engine trips, notify SFM, take immediate reco action and discontinue the test.	does not f the diesel overy	_
	12.4.9	Shutdown the M&TE recorder after the diesel stabilized.	lis _	_
	12.4.10	After the transient is settled, adjust the follow	ing:	
		a. D/G speed to approximately 900 RPM.		_
		b. D/G voltage to approximately 119V.		_
	12.4.11	Parallel the D/G to its vital bus and load the D 0.50 MW. See Steps 12.2.4 through 12.2.12 f paralleling guidance.	V/G to For	

-

!

ACIFIC GA	S AND EL	VER PLANT	REVISION	11 9 OF 12
ITLE: Di	esel Genera	tor Full Load Rejection Test	UNITS	1 AND 2
		the second s		
	;	•	PERF	VERIF
;	12.4.12	Make a quick preliminary evaluation of the voltage c recorded.	lata -	
-		a. Peak Diesel Voltage (must be ≤ 143.6	5V)	
<u>.1</u>	12.4.13	If the limit is exceeded, make a detailed evaluation o the trace. If the problem is determined to be from the diesel, inform the SFM and generate an Action Requ N/A []	f e est. 	_
12.5	Post Tes	t Alignment.		
	12.5.1	Have an electrician disconnect the recorder set from a diesel frequency meter.	the	<u> </u>
	12.5.2	Per PPE's discretion, evaluate the need to take advantage of equipment and diesel alignment to continue other tests.		_
- t 2		[] Shutdown the diesel per this procedure, continuity with Step 12.5.3.	ue	
· · · · ·		[] exit to other test Skip Steps 12.5.3 through 12.5.9; mark N/A ar continue with the Post Test Alignment Section (Step 12.5.10).	nđ	
	12.5.3	Run the D/G at about 0.50 MW for approximately 5 minutes for cooldown.		_
	12.5.4	Reduce load on the diesel to ≥ 0.1 MW and ≤ 0.25 M Then separate the diesel from the bus.	W	_
	12.5.5	Adjust the diesel speed so the frequency meter reads > 60 HZ and < 60.25 HZ. HZ.	. ,	
	12.5.6	Adjust the diesel voltage to 119V AC. Volts.		-
	12.5.7	Shutdown the D/G.	-	-
	12.5.8	Align the diesel MAN/AUTO switch per SFM's direction.		-
		[] AUTO [] MAN		

na interación

.

.

•

•

٠

.

٠

PACIFIC GAS DIABLO CAN TITLE: Die	S AND ELECTRIC COMPANY YON POWER PLANT sel Generator Full Load Rejection Test	NUMBER REVISION PAGE UNITS	STP M-9D1 11 10 OF 12 1 AND 2
	12.5.9 Cut out diesel LOSS OF FIELD, OVERO DIRECTIONAL POWER protective feat toggle switch on VB4.	PERF CURRENT & tures using the	
	12.5.10 Place the MW/HZ recorders on Low Spe	ed	
	12.5.11 Place the KV/MVAR recorders on Low S	Speed.	_
	12.5.12 Mount the voltage trace from the M&TE regular size paper and attach it to this pro	recorder to	_
12.6	Describe any malfunctions and list any discrepancie Otherwise, mark N/A.	n/A []	_
	REMARKS:		
12.7	Test performers and verifiers:		
	<u>Name</u> <u>Signature</u>	Date/Time	<u>Init</u>
			<u>_</u>
	<u> </u>	/	
		/	
		/	

DATA REDUCTION AND EVALUATION

.

Incorporated as part of Section 12.

PACIFIC GAS AND ELECTRIC COMPANY	
DIABLO CANYON POWER PLANT	

· •

:

• • ...

. . .

.

1

TITLE: Diesel Generator Full Load Rejection Test

NUMBER	STP M-9D1
REVISION	11
PAGE	11 OF 12
UNITS	1 AND 2

•

	A 1977 1	
		PERF
PRIMA	RY REVIEW	
14.1	Verify if Step 12.4 was performed, the D/G Acceptance Criteria have been satisfied for Tech Spec SR 3.8.1.10 and part of Tech Spec SR 3.8.2.1.	·
	14.1.1 Following a full load rejection of at least \geq 2.45 MW and \leq 2.50 MW with a reactive load so the power factor is \leq 0.87 + 128 KVARs and \geq 0.80, the diesel engine remained running and did not trip during and after the full load rejection transient. (Step 12.4.8)	
	 14.1.2 Following a full load rejection of at least ≥ 2.45 MW and ≤ 2.50 MW with a reactive load so the power factor is ≤ 0.87 + 128 KVARs and ≥ 0.80, the D/G voltage during and after the transient is ≤ 143.6 volts. (Step 12.4.12a) 	
14.2 -	The acceptable limit for the peak diesel voltage is 143.6 volts based on the chart from the temporary recorder. If the limit is exceeded, make a detailed evaluation of the trace. If the problem is determined to be from the diesel, inform the SFM and generate an Action Request.	
143	Verify M&TE usage recorded in PIMS	
14.4	Review completed procedure and based on test data, make determination of D/G OPERABILITY. If any malfunctions are noted, notify management promptly and submit an ACTION REQUEST.	
14.5	Describe any malfunction, explain any NO or N/A entries in any of the data and list any discrepancies found. Indicate if this test was performed due to modifications on the D/Gs and briefly describe modifications performed.	
	REMARKS:	
	Signature: Date/Time	/

. .

÷.,:

.

er . e

PAC DIAI TITI	EIFIC GA BLO CAI LE: Di	S AND ELECTRIC COMPANY NYON POWER PLANT esel Generator Full Load Rejection Test	NUMBER REVISION PAGE UNITS	STP M-9D1 11 12 OF 12 1 AND 2
			PERF	<u></u>
15.	<u>SECOI</u>	NDARY REVIEW		
	15.1	Review procedure for completeness and acceptability.		
	15.2	If this test was a complete test and the D/Gs are OPERABL update Master Schedule.	E, then	
		RT W/O #		_
		REMARKS:		
	15.3	Reviewed By: Date Second Reviewer		

07/12/01

.

: ;

، سب

Page 1 of 1

DIABLO CANYON POWER PLANT STP M-9D1 ATTACHMENT 8.1

•

 $1^{\text{AND}}2$

		PERF
8.1	Obtain one recorder (high impedance input) such as the Gould Windograf with an AC RMS converter.	
<u> </u>	[] Gould Windograf (with AC RMS converter, preferred)	
÷ •	[] Other type of recorder	
-	CO. ID. Cal. Due Date	
8.2	If Windograf is to be used, the following instruments are required to calibrate the voltage scales.	
	N/A[]	
	Fluke 8842A or HP 34401A.	
	CO. ID. Cal. Due Date	
	8.2.2 Calibrate the Windograf as follows:	
	<u>NOTE</u>: The following calibration steps are for general guideline only. The settings and steps may be modified per supervisor, maintenance or PPE's discretion. Document the changes in the REMARK Section.	
	a. Calibrate the Windograf with the high accurate DVM to a span from 100 VAC to 150 VAC.	
	<u>NOTE</u>: The scale suggested here may be changed per PPE's discretion.	
	b. Mark the Windograf chart paper with the calibrated scale.	<u> </u>
	c. Set the Windograf speed to 50mm/sec.	
8.3	REMARKS:	
		<u></u>
0.4		

02/12/02

DIABLO CANYON POWER PLANT STP M-9D1 ATTACHMENT 8.2

Page 1 of 1

 $1 \operatorname{AND} 2$

TITLE: D/G Power Factor vs Real Power and Reactive Power



01275601.XLS