

**MASTER EXAMINATION AND ANSWER KEY  
LICENSED OPERATOR INITIAL TRAINING PROGRAM**

**Course: RO / SRO NRC Exam 2003**

**Exam Activity Code:      Date Exam Prepared: 19 September 2003**

**Date Exam Taken: 3 October 2003**


Prepared By



Date

9/19/03

Approved By



Date

9/19/03

Facility: Vermont YankeeDate of Examination: 10/3/03Examination Level (circle one): RO / SROOperating Test Number: 1

Administrative Topic /Subject Description— (see Note)	Describe activity to be performed <del>method of evaluation:</del> 1. <del>ONE Administrative JPM, OR</del> 2. <del>TWO Administrative Questions</del>
A.1 • Conduct of Operations	Isolate leaking RHR piping weld leak (New) Generic 2.1.24 <b>Ability to obtain and interpret station electrical and mechanical drawings.</b> (CFR: 45.12 / 45.13) IMPORTANCE RO 2.8
A.2 • Conduct of Operations	Preparation of Control Room Shift Turnover Checklist, HPCI flow control setpoint tape not properly set (New) Generic 2.1.3 <b>Knowledge of shift turnover practices.</b> (CFR: 41.10 / 45.13) IMPORTANCE RO 3.0
A.3 • Equipment Control	Perform Secondary Containment Capability Test (New) Generic 2.2.12 <b>Knowledge of surveillance procedures</b> (CFR 41.10 / 45.13) Importance RO 3.0
A.4 • Emergency Plan	Control Room Emergency Communications Check (New) Generic 2.4.43 <b>Knowledge of emergency communication systems and techniques</b> (CFR: 45.13) Importance RO 2.8
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when 5 are required.	

Facility: Vermont YankeeDate of Examination: 10/3/03Examination Level (circle one): RO / SROOperating Test Number: 1

Administrative Topic /Subject Description— (see Note)	Describe activity to be performed <del>method of evaluation:</del> 1. <del>ONE Administrative JPM, OR</del> 2. <del>TWO Administrative Questions</del>
A.1  Conduct of Operations	Take actions for inadequate shift staffing (new) Generic 2.1.5 <b>Ability to locate and use procedures and directives related to shift staffing and activities.</b> (CFR: 41.10 / 43.5 / 45.12) IMPORTANCE SRO 3.4
Conduct of Operations	Isolate leaking RHR piping leak and determine Technical Specification impact (new) Generic 2.1.24 <b>Ability to obtain and interpret station electrical and mechanical drawings.</b> (CFR: 45.12 / 45.13) IMPORTANCE SRO 3.1
A.2  Equipment Control	Determine if equipment can be removed from service for minor unscheduled maintenance (new) Generic 2.2.17 <b>Knowledge of the process for managing maintenance activities during power operations.</b> (CFR: 43.5 / 45.13) IMPORTANCE SRO 3.5
A.3  Radiation Control	Review and approve Emergency plan allowed radiation exposure (new) Generic 2.3.4 <b>Knowledge of radiation exposure limits and contamination control / including permissible levels in excess of those authorized.</b> (CFR: 43.4 / 45.10) IMPORTANCE SRO 3.1
A.4  Emergency Plan	Determine protective action recommendation (bank) Generic 2.4.29 <b>Knowledge of the emergency plan.</b> (CFR: 43.5 / 45.11) IMPORTANCE SRO 4.0

NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when 5 are required.

Facility: Vermont YankeeDate of Examination: 10/3/03Exam Level (circle one): RO / SRO(I) / SRO(U)Operating Test No.: 1**B.1 Control Room Systems (8 for RO; 7 for SRO-I; 2 or 3 for SRO-U)**

System / JPM Title	Type Code*	Safety Function
a. Perform Weekly Operable Control Rod Check (Stuck Rod) (20107F)	D, A, S	1
b. Parallel Main Generator to Grid (24507)	D, L, S	4
c. RPV venting via the MSIVs (20043)	D, S	3
d. Bypass Reactor Building HVAC Trips (20041)	D, C	5
e. Transfer MCC 89A from the Maintenance Tie to RUPS (26209)	D, S	6
f. Core Spray Pump Surveillance (20901F)	D, S, A	2
g. Initiate Manual Scram (OE 3107 Appendix F) (20023F)	M, S, A	7
h. Swap SJAE Suction Valves (516) (27106)	D, S	9

**B.2 Facility Walk-Through In-Plant Systems (3 for RO; 3 for SRO-I; 3 or 2 for SRO-U)**

i. Place Standby CRD FCV in Service (Loss of CRD Regulating Function) (20106)	D, R	1
j. Respond to High Service Water Strainer D/P (27601)	D	8
k. Startup RPS Motor Generator (21202F)	D, A	7

\* Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)lternate path, (C)ontrol room, (S)imulator, (L)ow-Power, (R)CA



SRO NRC Exam 2003

\*\*\*\*\*

Question No. 1 Exam Bank Question No.: 5614 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-202 Objective: CRO 3j

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

While operating at full power, you observe the following parameter changes:

MWe net 520 to 472

Turbine Control valves step change in the close direction

Reactor Pressure 1010 to 998 psig

Core Plate D/P 16 to 14 psid

Core Flow 47 mlbs/hr to 48 mlbs/hr

Based on these indications, your action should be to enter the procedure for:

	Answer/Distractor	Justification
a.	Inadvertent opening of an SRV.	Incorrect - Increasing flow and decreasing power can only be caused by a jet pump failure.
b.	Inadvertant opening of a bypass valve.	Incorrect - Ibypass valve opening would cause a reactor over increase due to a reduction in feedwater temperature which would cause an increase in reactor pressure.
c.	Jet pump failure.	Correct Response - These indications are scaled data from the Quad Cities jet pump failure that occurred in 2002. These parameters closely match ON 3141 symptoms, but not identical. On 3141 requires the J.P. Surveillance be performed.
d.	Reactor low pressure from EPR failure.	Incorrect - Increasing flow and decreasing power can only be caused by a jet pump failure.

References: LOT-00-601 CRO Obj. 1, 3

ON 3141, rev 8

Quad Cities J.P. Failure 2002

New

Task Associations

Task Number	Task Title
-------------	------------

2000090501	Respond to Jet Pump Failure
------------	-----------------------------

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295001	AA2.05	Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION:(CFR 41.10, 43.5, 45.13): Jet pump operability: Not-BWR-1&2	3.1	3.4

Static Simulator Exams: None

Last Revised: 09/16/2003 7:51:38 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 2 Exam Bank Question No.: 5615 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-262 Objective: CRO 6

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Off-site power has been lost (LNP) and a large break LOCA has occurred. The "A" EDG failed to start. Reactor pressure is 50 psig and lowering. Reactor level is off scale low.

What are your required actions:

	Answer/Distractor	Justification
a.	Enter EOP 1 and 3 and confirm HPCI, RCIC, 2 RHR pumps, 1 CS pump injecting.	Incorrect - HPCI and RCIC have isolated on low steam supply pressure and can not inject.
b.	Enter EOP 1 and 4 and confirm 4 RHR pumps, 2 CS pumps injecting.	Incorrect - The "A" EDG start failure causes a loss of 4 KV Bus 4, and 3 of 6 low pressure ECCS pumps are without power.
c.	Enter EOP 1 and 3 and confirm 2 RHR pumps, 1 CS pump injecting.	Correct Response - The "B" EDG starts and powers 4 KV Bus 3. Two RHR and 1 CS pump are powered from this bus. HPCI and RCIC have isolated on low steam supply pressure. EOP 1 is entered on low reactor water level and EOP 3 is entered on high drywell pressure
d.	Enter EOP 1 and 4 and confirm 1 RHR pump, 1 CS pump injecting.	Incorrect - There is one RHR pump in each RHR loop powered from each EDG, 2 RHR pumps will be running and injecting. There are no entry conditions for EOP 4

References: EOP-1, rev 2

OT 3122, rev 19

New

Must integrate: Bus 4 is deenergized, all ECCS and RCIC have start signals, HPCI & RCIC have isolated on low steam supply pressure. Both RHR and one core spray injection valves have power available.

Task Associations

Task Number	Task Title
-------------	------------

2000310501     Respond to Low Reactor Water Level

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295003	2.4.01	Knowledge of EOP entry conditions and immediate action steps (CFR 41.10, 43.5, 45.13)	4.3	4.6

Static Simulator Exams: None

Last Revised: 09/16/2003 8:01:01 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 3 Exam Bank Question No.: 5616 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-601 Objective: CRO 2, 3, 4

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A reactor startup is in progress. Plant electrical loads are still on the startup transformers. Breaker #13 on 125 VDC Bus 1 has tripped causing a loss of control power to 4 KV Bus 1. A reactor scram occurs and after the initial shrink RPV level is 177" and rising. Reactor Feed Pumps A & C are running.

Reactor Feed Pump breakers will respond as follows:

	Answer/Distractor	Justification
a.	A & C will trip.	Incorrect - A has no control power and will not trip.
b.	C will trip.	Correct Response - High level trip logic is powered from DC-1C/DC-2C and is functional. A Reactor Feed Pump is powered from 4 KV Bus 1 and there is no control power. High RPV trip logic can not trip the A RFP breaker. C RFP breaker control power is available and will trip C RFP on high RPV level.
c.	A will trip.	Incorrect - A has no control power and will not trip.
d.	None will trip.	Incorrect - C has control power and will trip.

References: ON 3159, rev 4, page 4 note, third bullet  
New

Must integrate: 173" high level trip will be reached. A RFP is powered from 4 KV Bus 1 and with no control power available can not be tripped by the high RPV level signal.

## Task Associations

Task Number	Task Title
2000320501	Respond to a Loss of DC-1, 2, 3

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
--------	---------	-----------	----	-----

295004	AA1.03	Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF D.C. POWER: (CFR 41.7, 45.6): A.C. electrical distribution	3.4	3.6
--------	--------	---	-----	-----

Static Simulator Exams: None

Last Revised: 08/12/2003 3:05:38 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 4 Exam Bank Question No.: 5617 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-249 Objective: CRO 8

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

345 KV Breaker 81-1T is open and white tagged for maintenance during full power operation. A large air leak occurs on 345 KV Breaker 1T and it trips open on low air pressure.

The Reactor Protection System (RPS) will:

	Answer/Distractor	Justification
a.	not initiate a scram.	Incorrect - A scram will occur above 30% reactor/turbine power and a load reject.
b.	initiate a scram on control valve fast closure.	Correct Response - With 81-1T open and 1T then tripping, a complete load reject occurs. The acceleration relay actuates to control turbine speed and sends a scram signal to RPS. The scram is armed when operating above 30% power.
c.	initiate a scram on stop valve closure.	Incorrect - The turbine stop valves will be open, the control valves will shut rapidly to control turbine speed, a reactor scram will occur, turbine first stage pressure will decrease to < 30% load and bypass the stop valve closure scram and 30 seconds later low scram air header pressure will trip the turbine, shutting the stop valves.
d.	initiate a scram on stop valve closure and control valve fast closure.	Incorrect - The stop valve closure scram will be bypassed before the stop valves are tripped shut.

References: LOT-00-212 Obj. CRO 3

ON 3154 rev 10

New

Task Associations

Task Number	Task Title
2007300501	Respond to Generator Load Reject

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295005	AK2.01	Knowledge of the interrelations between and the following MAIN TURBINE TRIP: (CFR 41.7, 45.8): RPS	3.8	3.9

Static Simulator Exams: None

Last Revised: 07/25/2003 9:24:56 AM by Hallonquist, Nora E.



## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 5** Exam Bank Question No.: 5618 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-129 Objective: 31

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The reactor has been operating at 100% power for 300 days. An I&C Technician causes a full reactor scram during testing due to a human performance error. (Scram discharge instrument volume high)

Fission product decay heat after the prompt drop will equal approximately \_\_\_\_\_ % core thermal power and will be removed by the \_\_\_\_\_ .

	Answer/Distractor	Justification
a.	14%, safety and relief valves	Incorrect - Decay heat value is too high. SRV lift setpoint will not be reached.
b.	14%, bypass valves	Incorrect - Decay heat value is too high.
c.	7%, safety and relief valves	Incorrect - SRV lift setpoints will not be reached.
d.	7%, bypass valves	Correct Response - Decay heat after the prompt drop is approximately 6 to 7% CTP after long periods of full power operation. EPR is in service and will control reactor pressure dissipating the decay heat at a reactor pressure of ~932 psig.

References: EOP-1, rev 2

OT 3100, rev 7

New

Task Associations

Task Number	Task Title
2000330501	Respond to a Reactor SCRAM

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295006	AK1.01	Knowledge of the operational implications of the following concepts as they apply to SCRAM: (CFR 41.8 to 41.10): Decay heat generation and removal	3.7	3.9

Static Simulator Exams: None

Last Revised: 07/31/2003 10:08:31 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 6 Exam Bank Question No.: 5619 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-612 Objective: A2, A4

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The Control Room has been abandoned.

RCIC is in operation from the alternate shutdown panel due to a large fire in the cable vault.

As torus pressure rises, RCIC:

	Answer/Distractor	Justification
a.	Will trip on high exhaust pressure.	Incorrect - High back pressure (exhaust) is bypassed when operating from the alternate shutdown panel.
b.	Operation remains unaffected by backpressure.	Incorrect -RCIC operation is negatively affected by high torus pressure and will not provide adequate feed to the RPV at high backpressures.
c.	Operation is affected and when it is SRV 71A & B should be opened and RPV level restored with RHR.	Correct Response - OP 2126
d.	Operation is affected and when it is SRV 71A & B should be opened and RPV level restored with core spray.	Incorrect - Core Spray can not be operated at the alternate shutdown panels.

References: OP 3126 rev 16, Appendix C, page 5 caution, Appendix A, page 3 of 7

New

## Task Associations

Task Number	Task Title
2007170501	Perform Shutdown from Outside the Control Room

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295016	AA2.07	Ability to determine and/or interpret the following as they apply to CONTROL ROOM ABANDONMENT :(CFR 41.10, 43.5, 45.13): Suppression chamber pressure	3.2	3.4

Static Simulator Exams: None

Last Revised: 09/18/2003 5:22:27 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 7 Exam Bank Question No.: 5620 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-603 Objective: CRO 3g

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

The running RBCCW pump has tripped and the standby pump can not be started. If no operator action is taken, which of the following components will be damaged?

	Answer/Distractor	Justification
a.	Recirc Motor Generator bearings, RWCU demineralizers	Incorrect - Recirc MGs are cooled by SW and the bearings are air cooled.
b.	Recirc Pump Seals, RWCU demineralizers	Incorrect - RWCU demineralizers are protected by an automatic isolation at 140°F, no resin damage occurs at this temperature.
c.	Recirc Motor Generator bearings, running CRD pump	Incorrect - Recirc MGs are cooled by SW and the bearings are air cooled.
d.	Recirc Pump Seals, running CRD pump	Correct Response - Recirc pump seals will be damaged and the recirc pumps are required to be shutdown 2 minutes after RBCCW is lost. CRD pump bearings and reduction gear are cooled by RBCCW and must be manually shutdown to prevent damage.

References: ON 3147 rev 10

New

## Task Associations

Task Number	Task Title
2000110501	Respond to RBCCW Failure

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295018	AK2.01	Knowledge of the interrelations between and the following PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER: (CFR 41.7, 45.8): System loads	3.3	3.4

Static Simulator Exams: None

Last Revised: 07/25/2003 9:32:53 AM by Hallonquist, Nora E.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 8 Exam Bank Question No.: 5621 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-279 Objective: CRO 1e, 5

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

While operating at full power, the following annunciators are received:

CRP 6-D-1 Inst Air Receiver HDR Press LO

CRP 5-C-8 Scram Pilot Air Hdr Press Hi/Lo

CRP 5-E-2 FW VLV Lockup Signal/Air Fail

Instrument air header pressure is continuing to lower. Procedurally you are required to confirm:

	Answer/Distractor	Justification
a.	Lag compressors running and SA-PCV-1 shut.	Correct Response - Low scram air alarm 60 psig, low instrument air 90 psig, lag compressors start at 95 psig, SA-PCV-1 starts shut at 85 psig in the instrument air header and is full shut at 80 psig. The continuing lower pressure causes SA-PCV-1 to fully shut.
b.	Lead compressors running and SA-PCV-1 open.	Incorrect - The procedure assumes lead compressors running and does not require them checked.
c.	Lag compressors running and SA-PCV-1 open.	Incorrect -
d.	Lead compressors running and SA-PCV-1 shut.	Incorrect -

References: ON 3146, rev 15

ARS-5-C-8, rev 4

ARS-6-D-1, rev 3

New

Must integrate Alarm Set Points, compressors control logic and PCV-1 operation, and required procedure steps.

Task Associations

Task Number	Task Title
2000130501	Respond to a Loss of Instrument Air Pressure

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295019	AA1.04	Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF INSTRUMENT AIR: (CFR 41.7, 45.6): Service air isolations valves: Plant-Specific	3.3	3.2

Static Simulator Exams: None

Last Revised: 09/16/2003 8:14:50 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 9 Exam Bank Question No.: 5622 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-601 Objective: CRO 3, 4

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Shutdown cooling is operating and reactor pressure is 100 psig, cooling down for a scheduled outage. RHR 18 MOV (shut down cooling suction) shorts out and strokes the valve shut. The RHR pump trips and the valve can not be opened by any means. RWCUC was secured for startup of shutdown cooling.

ON 3156, Loss of Shutdown Cooling, requires reactor level be restored to > 185". The reason for this step is to:

	Answer/Distractor	Justification
a.	reduce natural circulation providing more accurate reactor coolant temperature monitoring via bottom head drain temperature.	Incorrect - Bottom head drain temperature is not required to be monitored during a Loss of Shutdown Cooling. Reducing natural circulation is caused by lowering RPV level, not raising it.
b.	promote natural circulation providing more accurate reactor coolant temperature monitoring via bottom head drain temperature.	Incorrect - Bottom head drain temperature is not required to be monitored during a Loss of Shutdown Cooling.
c.	reduce natural circulation providing more accurate reactor coolant temperature monitoring via skin temperatures.	Incorrect - Reducing natural circulation is caused by lowering RPV level, not by raising it.
d.	promote natural circulation providing more accurate reactor coolant temperature monitoring via skin temperatures.	Correct Response - Must recall ON 3156 references SIL-357 and raises RPV level to promote natural circulation by placing a water seal on the dryer skirt. Must recall that skin temperatures are required to be monitored during a Loss of Shutdown Cooling. Must integrate the two variables.

References: ON 3156, rev6, page 7 note, and step 96  
New

Task Associations

Task Number	Task Title
-------------	------------

2000150501 Respond to a Loss of Shutdown Cooling

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295021	AK1.04	Knowledge of the operational implications of the following concepts as they apply to LOSS OF SHUTDOWN COOLING: (CFR 41.8 to 41.10): Natural circulation	3.6	3.7

Static Simulator Exams: None

Last Revised: 07/25/2003 9:35:20 AM by Hallonquist, Nora E.



## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 10** Exam Bank Question No.: 5623 Revision: 5 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-620 Objective: 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Refueling operations are in progress. An exposed bundle is full up, when the fuel grapple cable breaks and the bundle is dropped onto the core. 125 fuel pins are ruptured.

What response(s), if any, are you expected to confirm in the control room?

	Answer/Distractor	Justification
a.	No hi hi trips on the reactor building ventilation radiation monitors.	Incorrect -
b.	A hi hi trip from the refuel floor radiation monitors only.	Incorrect -
c.	A hi hi trip from the reactor building ventilation radiation monitors only.	Incorrect -
d.	A hi hi trip from the refuel floor radiation monitors and the reactor building ventilation radiation monitors.	Correct Response

References: Tech Spec, Bases 211, page 78

UFSAR, rev 18, Ch 14.6.4.4

New

### Task Associations

Task Number	Task Title
2737060101	Respond to Automatic Actions from Local Monitors

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295023	AK2.03	Knowledge of the interrelations between and the following REFUELING ACCIDENTS: (CFR 41.7, 45.8): Radiation monitoring equipment	3.4	3.6

Static Simulator Exams: None

Last Revised: 09/18/2003 6:20:32 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 11 Exam Bank Question No.: 5624 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-205 Objective: CRO 2

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Given the following sequence of events:

0800 "A" Loop of RHR is started in torus cooling

0810 Reactor coolant leak in the drywell occurs

0820 Drywell pressure is 2.5 psig and rising

0830 Reactor water level is 127" and lowering

0840 Reactor water level is 82.5" and lowering

0850 Reactor pressure is 350 psig and lowering

Under these conditions, which of the following times is the earliest time that the torus cooling (RHR 39A/34A) valves would close at:

	Answer/Distractor	Justification
a.	0820	Correct Response - The high drywell signal alone will close all non-LPCI injection paths
b.	0830	Incorrect - If the operator does not know his low verses low low level setpoints this is a valid distractor.
c.	0840	Incorrect - If the operator is not aware that low low level and low reactor pressure are required this is a valid distractor.
d.	0850	Incorrect - This is a close signal to RHR 34A/39A, but they were already closed at 0820.

References: OP 2124, rev 50, page 5

Pilgrim 2003 NRC

New

## Task Associations

Task Number	Task Title
2000070501	Respond to Containment Hi Pressure

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295024	EK2.12	Knowledge of the interrelations between HIGH DRYWELL PRESSURE and the following: (CFR 41.7, 45.8): Suppression pool cooling	3.5	3.5

Static Simulator Exams: None

Last Revised: 09/18/2003 6:24:32 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 12 Exam Bank Question No.: 5625 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-302 Objective: CRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

During a reactor startup in accordance with OP-0105, reactor pressure must be maintained below \_\_\_\_\_ to prevent a high reactor pressure scram until low condenser vacuum isolation bypass switches are in \_\_\_\_\_ .

	Answer/Distractor	Justification
a.	850 psig, bypass	Incorrect - Low vacuum bypass must be in normal before exceeding 850 psig.
b.	950 psig, bypass	Incorrect - 850 psig can not be exceeded with the low vacuum isolation bypassed, procedure requires pressure > 750 and <850 psig to return it to service.
c.	850 psig, normal	Correct Response - For startup vac trip 1 & 2 are tripped to ensure Tech Spec compliance. Reactor heatup is begun without pressure control. The low vacuum isolation bypass must be returned to service to allow bypass valves to control pressure. If the steps/caution are not followed a high reactor pressure scram will occur.
d.	950 psig, normal	Incorrect - 850 psig can not be exceeded with the low vacuum isolation bypassed, procedure requires pressure > 750 and <850 psig to return it to service..

References: OP 0150, rev 10, page 40

Pilgrim 2003 NRC

New

## Task Associations

Task Number	Task Title
2017400201	Perform Heating and Pressurization of the Reactor

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
--------	---------	-----------	----	-----

295025	2.1.32	Ability to explain and apply system limits and precautions (CFR 41.10, 43.2, 45.12)	3.4	3.8
--------	--------	--	-----	-----

Static Simulator Exams: None

Last Revised: 09/16/2003 8:23:39 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 13 Exam Bank Question No.: 5626 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-607 Objective: CRO 2

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Given the following conditions:

Reactor Level is 70" and steady

Drywell and Torus pressure are 5.0 psig and lowering

Drywell temperature is 240°F and lowering

The "A" Loop of RHR is operating in drywell spray, torus sprays, and torus cooling

When torus pressure is < 2.5 psig you should confirm isolation of:

	Answer/Distractor	Justification
a.	Drywell Sprays only.	Incorrect -
b.	Torus Sprays only.	Incorrect -
c.	Drywell and Torus Sprays.	Correct Response - With an accident signal present, drywell and torus sprays automatically isolate when drywell pressure is less than or equal to 2.5 psig. With a vacuum breaker failed open, torus and drywell pressure are equal.
d.	Drywell and Torus Sprays and Torus cooling.	Incorrect - Torus cooling does not isolate when drywell pressure goes below 2.5 psig.

References: EOP-3, rev 3

EOP-3 is a required reference

Pilgrim 2003 NRC Modified

Task Associations

Task Number	Task Title
2000210501	Respond to High Drywell Temperature

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295028	EA2.05	Ability to determine and/or interpret the following as they apply to HIGH DRYWELL TEMPERATURE:(CFR 41.10, 43.5, 45.13): Torus/suppression chamber pressure:	3.6	3.8

		Plant-specific		
--	--	----------------	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 8:25:43 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 14 Exam Bank Question No.: 5627 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-217 Objective: CRO 5b

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

RCIC is operating in the injection mode with its suction path from the torus. A slow leak develops in the torus.

As torus level continues to lower, RCIC:

	Answer/Distractor	Justification
a.	will trip on low suction pressure.	Incorrect - The slow reduction in torus level will allow RCIC to continue to run with its exhaust line uncovered and its suction line submerged pressurizing the containment preventing a low suction pressure trip
b.	will trip on high exhaust pressure.	Correct Response EOP 3 study guide page 8-37. RCIC high exhaust pressure trip occurs at 43 psig and the primary containment vent rupture disc ruptures at 59 psig and is isolated by TSV 86 during operation
c.	suction will auto transfer to the CST on low torus water level.	Incorrect - We have an Auto Swap on Low CST level. It makes sense to have one on low torus level but VYN does not.
d.	suction will auto transfer to the CST on low suction pressure.	Incorrect - A low suction pressure suction transfer makes sense but VYN does not have one.

References: OP 2121, rev 29

Pilgrim 2003 NRC

EOP 3 study guide page 8-37

New

## Task Associations

Task Number	Task Title
2170030101	Manually Initiate Startup of the RCIC System

## Knowledge and Abilities Associations



System	K/A No.	Statement	RO	SRO
295030	EA1.02	Ability to operate and/or monitor the following as they apply to LOW SUPPRESSION POOL WATER LEVEL: (CFR 41.7 , 45.6): RCIC: Plant-specific	3.4	3.5

Static Simulator Exams: None

Last Revised: 09/16/2003 8:41:11 AM by Brown, Scott T.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 15** Exam Bank Question No.: 5628 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-256 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

All reactor feedwater pumps have tripped causing a scram. HPCI and RCIC are unavailable. Condensate pumps will be capable of feeding the reactor when reactor pressure is less than \_\_\_\_\_ and their motor amps should be maintained less than \_\_\_\_\_ amps.

	Answer/Distractor	Justification
a.	850 psig, 190 amps	Incorrect -
b.	600 psig, 250 amps	Incorrect -
c.	400 psig, 190 amps	Correct Response - RP 2170 Precaution 7, RP 2170 Precaution 6
d.	250 psig, 250 amps	Incorrect -

References: LOT-00-610, CRO Obj. 6, 7, 12

RP 2170, rev 21, page 6

New

### Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295031	EA1.11	Ability to operate and/or monitor the following as they apply to REACTOR LOW WATER LEVEL: (CFR 41.7 , 45.6): Condensate	4.1	4.1

Static Simulator Exams: None

Last Revised: 09/18/2003 6:26:19 PM by Brown, Scott T.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 16 Exam Bank Question No.: 5629 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-610 Objective: CRO 2

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Given the following conditions:

ATWS in progress

Reactor power is 20%

Torus temperature is 115°F

Reactor pressure control is on SRVs 800-1000 psig

Reactor water level is +25"

Injection has been terminated/prevented IAW OE 3107 Appendix GG

Which of the following conditions would establish the upper end of the RPV level control band?

	Answer/Distractor	Justification
a.	APRM downscales come in.	Correct Response
b.	reactor power reaches the heating range with a negative period.	Incorrect - This is indication of the reactor being shutdown but is applicable when a cooldown is commenced and no boron has been injected.
c.	reactor water level reaches -19 inches.	Incorrect - This is the bottom of the ATWS level band of +6 to -19", injection should recommence at +6" - TAF.
d.	only one SRV is open for reactor pressure control.	Incorrect - Regardless of SRV conditions, injection is recommenced at TAF to insure adequate core cooling.

References: EOP-2, rev 4

Pilgrim 2003 NRC

New

EOP-2 is a required student reference

Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295031	EA2.02	Ability to determine and/or interpret the following as they apply to REACTOR LOW WATER LEVEL:(CFR 41.10, 43.5, 45.13).: Reactor power	4.0	4.2

Static Simulator Exams: None

Last Revised: 08/20/2003 8:41:46 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 17 Exam Bank Question No.: 5630 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-610 Objective: CRO 2

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Given the following conditions:

ATWS

15% of the SLC tank has been injected

Reactor level band is -19" to 40"

At this point \_\_\_\_\_ has been injected into the RPV. This amount of boron will allow \_\_\_\_\_ .

	Answer/Distractor	Justification
a.	hot shutdown boron weight, a cooldown	Incorrect -
b.	hot shutdown boron weight, restoration of level to 127" to 177"	Correct Response - EOP-2 Step ARC/L-10 and Table I. Hot shutdown boron weight is 15% of the SLC tank. Cold shutdown boron weight is 30% of the SLC tank. Can raise the level band, can not cooldown.
c.	cold shutdown boron weight, a cooldown	Incorrect -
d.	cold shutdown boron weight, restoration of level to 127" to 177"	Incorrect -

References: EOP-2, rev 4

New

EOP-2 is a required student reference

Task Associations

Task Number	Task Title
2000200501	Respond to ATWS Event(s)

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295037	EK3.04	Knowledge of the reasons for the following responses as they apply to SCRAM CONDITION PRESENT AND REACTOR POWER ABOVE APRM DOWNSCALE OR UNKNOWN: (CFR 41.5, 45.6): Hot shutdown boron weight: Plant-specific	3.2	3.7

Static Simulator Exams: None

Last Revised: 07/25/2003 9:47:32 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 18 Exam Bank Question No.: 5631 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-286 Objective: CRO 4a

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

An electrical fire is burning in MCC89A in the reactor building. To use water to fight the fire in MCC89A:

	Answer/Distractor	Justification
a.	it <u>must</u> be deenergized and the Brigade Commander's permission is required to use water on an electrical fire.	Incorrect -
b.	it <u>should</u> be deenergized and the Brigade Commander's permission is required to use water on an electrical fire.	Incorrect -
c.	it <u>must</u> be deenergized and the Shift Manager's permission is required to use water on an electrical fire.	Incorrect -
d.	it <u>should</u> be deenergized and the Shift Manager's permission is required to use water on an electrical fire.	Correct Response- Fire hose stations in the area of MCC 89A are equipped with "E nozzles". They are brass, smaller than regular nozzles, and opened by lever action as opposed to twist action. They are also smaller when compared to regular nozzles. They are specifically placed so that water can be used on energized electrical equipment to fight a fire.

References: OP 3020, rev 25, definitions and page 10

New

## Task Associations

Task Number	Task Title
2867290401	Respond to Pyrotechnics Panel Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
600000	AK3.04	Knowledge of the reasons for the following responses as they apply to PLANT FIRE ON SITE:: Actions contained in the abnormal procedure for plant fire on site	2.8	3.4

Last Revised: 09/16/2003 8:49:39 AM by Brown, Scott T.



# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 19 Exam Bank Question No.: 5632 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-607 Objective: CRO 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

When entering EOP-3, Primary Containment Control, which of the following is the preferred indication to be used to determine torus water temperature?

	Answer/Distractor	Justification
a.	ERFIS average torus temperature	Correct Response
b.	TI-16-19-33C torus water temperature CRP 9-3	Incorrect -
c.	TI-16-19-33A torus water temperature CRP 9-3	Incorrect -
d.	The higher of TI-16-19-33 A or C	Incorrect -

References: EOP, rev 11, Vol 4, Section 8, page 8-4  
New

## Task Associations

Task Number	Task Title
2000190501	Respond to High Torus Water Temperature

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295026	EK2.04	Knowledge of the interrelations between SUPPRESSION POOL HIGH WATER TEMPERATURE and the following: (CFR 41.7, 45.8): SPDS/ERIS/CRIDS/GDS: Plant-specific	2.5	2.8

Static Simulator Exams: None

Last Revised: 07/29/2003 12:05:31 PM by Hallonquist, Nora E.

### SRO NRC Exam 2003

\*\*\*\*\*

Question No. 20 Exam Bank Question No.: 5633 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-138 Objective: 17, 19

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

A reactor pressure transient has occurred causing a violation of the high power MCPR safety limit of \_\_\_\_\_ for two loop operation, and the resulting fuel damage could cause a member of the public to exceed \_\_\_\_\_ mRem total body dose allowed for the year at the site boundary.

	Answer/Distractor	Justification
a.	1.10, 500	Correct Response
b.	1.49, 500	Incorrect - This is the MCPR LCO.
c.	1.10, 1200	Incorrect - This is twice the allowed dose.
d.	1.49, 1200	Incorrect - This is the MCPR LCO.

References: ODCM (formerly T.S.), rev 30

Tech Specs 1.1 176

New

#### Task Associations

Task Number	Task Title
-------------	------------

2007090501	Respond to High Off-Gas Radiation
------------	-----------------------------------

#### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295038	2.2.25	Knowledge of bases in technical specifications for limiting conditiond for operations and safety limits (CFR 43.2)	2.5	3.7

Static Simulator Exams: None

Last Revised: 07/31/2003 10:11:05 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 21 Exam Bank Question No.: 5634 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-602 Objective: CRO 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

During power operation an air leak into the main condenser causes SJAE off gas flow on CRP 9-6 FR-102-3 to go off scale high.

This will cause AS-FCV-36, 36A, and 37 (steam jet air ejector steam supply valves) to trip shut when:

	Answer/Distractor	Justification
a.	condenser backpressure reaches 22" Hg abs.	Incorrect - Lowering condenser vacuum does not affect the operation of FCV 36, 36A, 37.
b.	temperature in the SJAE discharge/AOG inlet reaches 375°F.	Incorrect - Increased air inleakage causes the off gas temperature to decrease, not increase. FCV 36, 36A, & 37 do not trip on off gas temperature changes.
c.	condenser backpressure reaches 12" Hg abs.	Incorrect - Lower vacuum does not affect the operation of FCV 36, 36A, 37.
d.	pressure in the SJAE discharge/AOG inlet reaches 4 psig.	Correct Response - AS-FCV-36, 36A, 37 are tripped shut by increasing SJAE discharge/AOG inlet pressure at 4.0 psig and increasing as sensed by PS-OG-1403.

References: LOT-00-271 CRO obj. 5

OT 3120, rev 13

OP 2150, rev 27

New

Task Associations

Task Number	Task Title
2000080501	Respond to a Loss of Condenser Vacuum

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295002	AK1.04	Knowledge of the operational implications of the following concepts as they apply to LOSS OF MAIN CONDENSER VACUUM: (CFR 41.8 to 41.10): Increased	3.0	3.3

		offgas flow		
--	--	-------------	--	--

Static Simulator Exams: None

Last Revised: 08/20/2003 8:40:59 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 22 Exam Bank Question No.: 5635 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-288 Objective: CRO 5

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A large reactor coolant leak has occurred in the drywell. Primary Containment Control, EOP-3 was entered. Drywell cooling was maximized as directed by EOP-3. Several minutes later the Shift Technical Advisor observes all drywell RRUs are off.

The reason they tripped is:

	Answer/Distractor	Justification
a.	thermal overload.	Correct Response - Increased drywell pressure and moisture increase the work done by the RRU motors and cause the thermal overloads to trip at drywell pressures of 10-14 psig.
b.	low drywell pressure (RHR drywell pressure logic).	Incorrect - Low drywell pressure causes an isolation of the drywell sprays and torus but does not affect RRU operation.
c.	high drywell pressure (RHR drywell pressure logic).	Incorrect - The operator had already bypassed the RRU high drywell pressure RRU trip to restart them after the large leak caused drywell pressure to exceed 2.5 psig which trips the RRUs and is the entry condition for EOP-3.
d.	short circuit.	Incorrect - The RRUs are qualified to operate post LOCA. The high humidity will not cause them to short out.

References: DP 0166, rev 7, page 6

DR 93-0078

EDCR 90-405

New

## Task Associations

Task Number	Task Title
2227020401	Startup Drywell RRUS Following a LOCA

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295010	AK3.02	Knowledge of the reasons for the following responses as they apply to HIGH DRYWELL PRESSURE: (CFR 41.5, 45.6): Increased drywell cooling	3.4	3.4

Static Simulator Exams: None

Last Revised: 09/16/2003 8:52:26 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 23 Exam Bank Question No.: 5636 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-618 Objective: 1, 13, 15

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The "A" Recirculation Loop has just experienced a double-ended rupture of the suction line.

LPCI injection must be shifted to the containment cooling mode no later than \_\_\_\_\_ after the break to limit \_\_\_\_\_.

	Answer/Distractor	Justification
a.	600 seconds, peak torus temperature	Correct Response-USAR requires containment cooling established at 600 seconds post DBA LOCA
b.	600 seconds, peak drywell temperature	Incorrect - USAR 14.6 page 21 requires containment in 30 minutes to limit drywell temperature
c.	60 minutes, peak torus temperature	Incorrect - 60 minutes is beyond the USFAR specified maximum time.
d.	60 minutes, peak drywell temperature	Incorrect - 60 minutes is beyond the USFAR specified maximum time.

References: USFAR, rev 18, 14.6.25

New

## Task Associations

Task Number	Task Title
2000190501	Respond to High Torus Water Temperature

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295013	AK3.01	Knowledge of the reasons for the following responses as they apply to HIGH SUPPRESSION POOL WATER TEMPERATURE: (CFR 41.5, 45.6): Suppression pool cooling operation	3.6	3.8

Static Simulator Exams: None

Last Revised: 09/16/2003 9:29:43 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 24 Exam Bank Question No.: 5637 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-308 Objective: CRO 2, 3, 4, 5

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The outboard MSIVs have failed shut due to a loss of instrument air. Some control rod motion has occurred. Reactor power is 60%.

This transient has caused the violation of the \_\_\_\_\_ Safety Limit (SL) and may exceed the torus temperature limiting condition for power operation (LCO) of \_\_\_\_\_.

	Answer/Distractor	Justification
a.	Reactor pressure, 120°F	Incorrect - 60% power is within the capacity of the SRVs/RVs.
b.	Fuel Cladding, 110°F	Correct Response - MSIV closure in RUN is a required scram and the scram did not occur. The safety limit shall be assumed to be exceeded. 110°F is the torus temperature LCO. MCPR is the actual thermal limit that is challenged.
c.	Reactor pressure, 110°F	Incorrect -60% power is within the capacity of the SRVs/RVs.
d.	Fuel Cladding, 120°F	Incorrect - Technical Specifications require a reactor scram when torus temperature exceeds 110°F.

References: LOT-00-607 CRO Obj. 1

Tech Specs 188, 7, page 146

New

## Task Associations

Task Number	Task Title
2000200501	Respond to ATWS Event(s)

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295015	2.2.22	Knowledge of limiting conditions for operations and safety limits (CFR 43.2, 45.2)	3.4	4.1

Static Simulator Exams: None



Last Revised: 09/18/2003 6:31:48 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 25 Exam Bank Question No.: 5638 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-607 Objective: CRO 2, 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

EOP-3, Primary Containment Control, requires an RPV-ED if torus level can not be restored and maintained below 14.75 feet.

The reason for this action is:

	Answer/Distractor	Justification
a.	during a DBA LOCA, the integrity of the primary containment can not be assured.	Correct Response - EOP Basis page 8-45
b.	the volume of the gas in the containment would be insufficient to absorb the energy of a full RPV-ED.	Incorrect -
c.	operation of an SRV at this level could damage Tee-quencher supports.	Incorrect -
d.	during a DBA LOCA, the reactor pressure vessel must be depressurized before the torus spray function is lost.	Incorrect -

References: EOP, rev 11, Volume 4

LOI-EB 3769

## Task Associations

Task Number	Task Title
2000230501	Respond to High Torus Water Level

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295029	EK1.01	Knowledge of the operational implications of the following concepts as they apply to HIGH SUPPRESSION POOL WATER LEVEL: (CFR 41.8 to 41.10): Containment integrity	3.4	3.7

Static Simulator Exams: None

Last Revised: 07/31/2003 10:12:51 AM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

Question No. 26 Exam Bank Question No.: 5639 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-611 Objective: CRO 3, 5

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

EOP-4, Secondary Containment Control, has been entered. To determine if any area radiation level is above its maximum safe level, which of the following should be reported to the CRS:

	Answer/Distractor	Justification
a.	ARM readings on the Allen Bradley on CRP 9-21	Incorrect - Allen Bradley provides area temperatures for EOP use and is next to the reactor building back panel ARM panels.
b.	Local radiation readings as reported by an RP tech	Incorrect - It is not expected or required to enter the reactor building to determine radiation level.
c.	ARM readings on ERFIS	Correct Response - ERFIS is used for EOP decision making and provides the necessary reactor building radiation levels.
d.	Local radiation readings at the ARMs in the reactor building	Incorrect - It is not expected or required to enter the reactor building to determine radiation level.

References: EOP-4, rev 2

DP 0166, rev 7, page 7

New

### Task Associations

Task Number	Task Title
2727150401	Respond to ARM Alarms

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295033	EA2.01	Ability to determine and/or interpret the following as they apply to HIGH SECONDARY CONTAINMENT AREA RADIATION LEVELS:(CFR 41.10, 43.5, 45.13):. Area radiation levels	3.8	3.9

Static Simulator Exams: None

Last Revised: 09/16/2003 9:40:29 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 27 Exam Bank Question No.: 5640 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-223 Objective: CRO 4, 5

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Reactor building ventilation radiation monitor "A" is bypassed by I&C for testing and is downscale. The "B" reactor building ventilation radiation monitor reading increases to 20 mR/hr.

Your response should be to:

	Answer/Distractor	Justification
a.	direct I&C to return the "A" channel to service so that RB ventilation can be left on.	Incorrect - This is a logical action if the student does not understand system operation during I&C testing.
b.	confirm PCIS Group 3 isolations and SBT system startup.	Correct Response - Student must know that I&C keylocks only bypass upscale trips. Two downscale on RB vent exhaust is an isolation signal, one upscale is an isolation. Only one key lock bypass is allowed in bypass at any time. RB ventilation will trip and isolate and SBT will start.
c.	manually secure RB ventilation, isolate HVAC 9, 10, 11, 12 and start SBT.	Incorrect - This is a logical action if the student does not understand system operation during I&C testing.
d.	direct RP to monitor RB ventilation exhaust in accordance with the ODCM.	Incorrect - This is a logical action if the student does not understand system operation during I&C testing.

References: OP 2117, rev 17, Discussion  
New

## Task Associations

Task Number	Task Title
2737060101	Respond to Automatic Actions from Local Monitors

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295034	EA1.02	Ability to operate and/or monitor the following as they apply to SECONDARY CONTAINMENT	3.9	4.0

		VENTILATION HIGH RADIATION: (CFR 41.7 , 45.6): Process radiation monitoring system		
--	--	---	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 9:41:58 AM by Brown, Scott T.

SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 28** Exam Bank Question No.: 5641 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-205 Objective: CRO 2, 4

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Given the following conditions:

Drywell pressure is 11 psig and rising  
 Reactor pressure is 300 psig and lowering  
 Reactor level is +20" and steady  
 Core Spray A/B are injecting  
 RHR A is operating in torus cooling  
 RHR B is operating in torus spray  
 UPS Feeder block keylocks are in block, the 5 minute timers are timed out

Reactor level rapidly lowers to -150" and continues down. The RHR system will:

	Answer/Distractor	Justification
a.	open A & B LPCI injection valves, close "A" torus cooling valves, close "B" torus spray valves.	Incorrect - RHR 27A and B injection signals 5 minutes timers have timed out and the UPS FDR blocks have been placed in block and RHR 27 A & B have been manually shut to establish torus cooling torus spray. RHR 27 A & B will remain shut.
b.	close RHR A torus cooling valves, close RHR B torus spray valves.	Correct Response - At -48 the non LPCI injection paths are isolated.
c.	open RHR Heat exchanger bypass valves, close "A" torus cooling valves, close "B" torus spray valves, open A & B LPCI injection valves.	Incorrect - The RHR 65 open signal was present for one minute and the time must have passed to establish torus cooling. To establish torus cooling/sprays, the RHR 27 valves had to be shut which means that 5 minutes have passed since they auto opened and the UPS Feeders are in block.
d.	open RHR A & B LPCI injection valves, open A & B heat exchanger bypass valves.	Incorrect - All four valves will remain shut.

References: LOT-03-262 CRO Obj. 6, 7

OP 2124, rev 50, Appendix B & C

New

### Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
203000	A3.05	Ability to monitor automatic operations of the RHR/LPCI: INJECTION MODE (PLANT SPECIFIC) including: (CFR 41.7 / 45.7): Reactor water level	4.4	4.4

Static Simulator Exams: None

Last Revised: 08/20/2003 9:04:48 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 29 Exam Bank Question No.: 5642 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-205 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Given the following conditions:

"A" Loop of RHR is operating in shutdown cooling  
Reactor pressure is 100 psig and slowly rising

If reactor pressure continues to increase, the RHR system will:

	Answer/Distractor	Justification
a.	shut RHR 17 & 18 (shutdown cooling suction) to protect the piping from overpressure at 150 psig.	Correct Response - Correct isolation valves, correct setpoint for protective instrumentation.
b.	trip the pump running in shutdown cooling to protect it from cavitation damage at 366 degrees F	Incorrect - The height of water above the pump suction prevents cavitation.
c.	shut RHR 17 & 18 (shutdown cooling suction) to protect the piping from overpressure at 350 psig.	Incorrect - The piping on the suction line is only rated for 150 psig.
d.	trip the pump running in shutdown cooling to protect it from cavitation damage at 436 degrees F.	Incorrect - The height of water above the pump suction prevents cavitation.

References: Tech Spec Table 3.2.1 186

New

## Task Associations

Task Number	Task Title
2000150501	Respond to a Loss of Shutdown Cooling

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
205000	2.1.28	Knowledge of the purpose and function of major system components and controls (CFR 41.7)	3.2	3.3

Static Simulator Exams: None

Last Revised: 09/16/2003 10:02:17 AM by Brown, Scott T.



SRO NRC Exam 2003

\*\*\*\*\*

Question No. 30 Exam Bank Question No.: 5643 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-206 Objective: 10c

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The initiation logic that provides automatic HPCI initiation signals is powered from:

	Answer/Distractor	Justification
a.	Vital AC	Incorrect -
b.	Instrument AC	Incorrect -
c.	DC-1C, DC-2C	Correct Response - OP 2145 Appendix A, pages 1, 5
d.	DC-3, DC-3A	Incorrect -

References: OP 2145, rev 24, Appendix A

New

Task Associations

Task Number	Task Title
2000320501	Respond to a Loss of DC-1, 2, 3

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
206000	K2.03	Knowledge of electrical power supplies to the following: (CFR 41.7): Initiation logic: BWR-2, 3, 4	2.8	2.9

Static Simulator Exams: None

Last Revised: 07/29/2003 12:09:15 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 31 Exam Bank Question No.: 5644 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-206 Objective: CRO 3, 5b, 6b, 7

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

HPCI has started automatically on a high drywell pressure signal. The CRS directs you to inhibit HPCI.

When you lock the collar in inhibit, you expect the turbine:

	Answer/Distractor	Justification
a.	to trip and the minimum flow valve to open.	Incorrect - The inhibit switch shuts the min flow valve.
b.	to run at 2200 rpm and the minimum flow valve to open.	Incorrect - The inhibit switch does not act on the turbine speed control system, and it shuts the min flow valve.
c.	to trip and the minimum flow valve to close.	Correct Response - The inhibit switch energizes the turbine trip solenoid, and shuts the min flow valve so the CST does not drain to the torus.
d.	to run at 2200 rpm and the minimum flow valve to close.	Incorrect - The inhibit switch does not act on the turbine speed control system.

References: OP 2120, rev 27

ARS 9-3-5-1, rev 0

New

## Task Associations

Task Number	Task Title
2007450501	Terminate and Prevent Injection to the RPV During an ATWS

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
206000	A1.08	Ability to predict and/or monitor changes in parameters associated with operating the HIGH PRESSURE COOLANT INJECTION SYSTEM controls including: (CFR 41.5 / 45.5): System lineup: BWR-2, 3, 4	4.1	4.0

Static Simulator Exams: None

Last Revised: 07/25/2003 10:08:31 AM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 32** Exam Bank Question No.: 5645 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-218 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

An ADS blowdown is in progress. All six low pressure ECCS pumps are running, when both Core Spray pumps trip due to improper overload trip settings.

The ADS system will:

	Answer/Distractor	Justification
a.	maintain both logics energized and shut all SRVs.	Incorrect -
b.	deenergize the "A" logic and shut SRVs A & C.	Incorrect -
c.	deenergize the "B" logic and shut SRVs B & D.	Incorrect -
d.	maintain both logics energized and all SRVs open.	Correct Response - Any one pump running (RHR or CS) will keep both ADS logics energized and all SRVs open.

References: LOT-00-206, CRO Obj. 8

CWD 750-756

New

### Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
209001	K3.02	Knowledge of the effect that a loss or malfunction of the LOW PRESSURE CORE SPRAY SYSTEM will have on following: (CFR 41.7 / 45.4): ADS logic	3.8	3.9

Static Simulator Exams: None

Last Revised: 07/29/2003 12:09:36 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 33** Exam Bank Question No.: 5646 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-211 Objective: AO 2g

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

The high pressure sensing line for the core plate D/P instrumentation has a fitting leak of 10 gpm at the D/P cell. An ATWS event occurs and SLC "A" system is started.

The SLC system will inject:

	Answer/Distractor	Justification
a.	all of the boron above the core plate.	Incorrect -
b.	some of the boron above the core plate, some of the boron on the floor in the Southeast Corner Room.	Incorrect -
c.	all of the boron below the core plate.	Incorrect -
d.	some of the boron below the core plate, some on the floor in the Northeast Corner Room.	Correct Response - The core plate D/P instrument high pressure tap is below the core plate and is the SLC injection path. 10 gpm of SLC in will go out the leak.

References: LOT-00-216, CRO Obj. 1b, c

G191267 Sheet 1

New

Task Associations

Task Number	Task Title
2110050101	Inject Poison Solution into the Reactor Vessel

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
211000	K1.02	Knowledge of the physical connections and/or cause-effect relationships between STANDBY LIQUID CONTROL SYSTEM and the following: (CFR 41.2 to 41.9 / 45.7 to 45.8): Core plate differential pressure indication	2.7	2.7

Static Simulator Exams: None

Last Revised: 08/12/2003 3:09:46 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 34 Exam Bank Question No.: 5647 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-626 Objective: CRO 4

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

During an ATWS with the Standby Liquid Control System out of service, which one of the following is a procedurally directed method of alternate boron injection?

	Answer/Distractor	Justification
a.	Add sodium pentaborate to the condensate storage tank and mix/inject with HPCI.	Incorrect -
b.	Add sodium pentaborate to the condensate demineralizer precoat tank and inject with condensate and feedwater systems.	Incorrect -
c.	Connect the SLC tank to CRD pump suction and inject with a CRD pump.	Correct Response - This is the only correct flow path available in procedure OE 3107, the other flow paths would work but no procedure directs their use.
d.	Connect the SLC tank to the RWCU demineralizer precoat tank and inject with RWCU pump.	Incorrect -

References: OE 3107, rev 16, Appendix K, Modified Distractors

Grand Gulf NRC 3/27/1998

INPO Bank

## Task Associations

Task Number	Task Title
2007600501	Perform Boron Injection Using CRD System from SLC Tank

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
211000	K3.01	Knowledge of the effect that a loss or malfunction of the STANDBY LIQUID CONTROL SYSTEM will have on following: (CFR 41.7 / 45.4): Ability to shutdown the reactor in certain conditions	4.3	4.4

Static Simulator Exams: None

Last Revised: 09/16/2003 10:04:37 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 35 Exam Bank Question No.: 5648 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-212 Objective: CRO 2

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

When resetting a full scram the reset switch is positioned to the Group 1 and 4 position last. This ensures the relays that \_\_\_\_\_ on reset, \_\_\_\_\_ the solenoid valve that supplies air to open the scram discharge vent and drain valves when all the scram inlet and outlet valves are closed or are closing.

	Answer/Distractor	Justification
a.	energize, energize	Correct Response - OP 2134, rev 16, page 9, Step 6b; P&ID G191170
b.	deenergize, energize	Incorrect - RPS relays energize to reset, not deenergize.
c.	energize, deenergize	Incorrect - The solenoid valve energizes to supply air to open the SDV vent and drain valves, not deenergize.
d.	deenergize, deenergize	Incorrect - RPS relays energize to reset, not deenergize.

References: OP 2134, rev 16, Page 9 Caution

New

## Task Associations

Task Number	Task Title
2127060101	Reset RPS Trips

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
212000	A1.09	Ability to predict and/or monitor changes in parameters associated with operating the REACTOR PROTECTION SYSTEM controls including: (CFR 41.5 /45.5): Individual relay status: Plant-Specific	2.7	3.0

Static Simulator Exams: None

Last Revised: 09/18/2003 6:34:50 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 36 Exam Bank Question No.: 5649 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-02-215 Objective: CRO 2i

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

An LNP occurs while operating at full power. Post scram reactor power can be monitored on:

	Answer/Distractor	Justification
a.	APRMs and ERFIS(CTP)	Incorrect - Core thermal power can not be accurately calculated with no RFPs running.
b.	IRMs and APRMs	Incorrect - IRMs can not be driven into the core. Motor drive power is from PP6A on MCC6A powered from Bus 1 which has lost power during the LNP.
c.	IRMs	Incorrect - IRMs can not be driven into the core. Motor drive power is from PP6A on MCC6A powered from Bus 1 which has lost power during the LNP.
d.	APRMs	Correct Response - RPS MG sets trip on the LNP and APRMs automatically transfer to Vital/Inst AC

References: OP 2131, rev 14, Prerequisites  
New

## Task Associations

Task Number	Task Title
2000330501	Respond to a Reactor SCRAM
2007020501	Respond to Loss of Normal Power

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
215003	K3.04	Knowledge of the effect that a loss or malfunction of the INTERMEDIATE RANGE MONITOR (IRM) SYSTEM will have on following: (CFR 41.7 / 45.4): Reactor power indication	3.6	3.6

Static Simulator Exams: None

Last Revised: 09/16/2003 10:06:05 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 37 Exam Bank Question No.: 5650 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-02-215 Objective: CRO 8

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

A reactor startup is in progress. Reactor power is 50/125 scale on Range 7. IRM detectors A & D were replaced during the outage and both have just failed downscale. The CRS directs IRM A & D bypassed.

Under these conditions the remaining IRMs detectors satisfy operability requirements for:

	Answer/Distractor	Justification
a.	both RPS trip systems.	Correct Response - IRMs A, C & E provide signals to RPS A. IRMs B, D & F provide signals to RPS B. With IRMs A & D failed, each RPS trip system still has two inputs and satisfied T.S. Table 3.1.1.
b.	RPS trip system "A" only.	Incorrect -
c.	RPS trip system "B" only.	Incorrect -
d.	neither RPS trip system.	Incorrect -

References: OP 2130, rev 14, page 1

Tech Spec Table 3.1.1 Notes

New

## Task Associations

Task Number	Task Title
2157160401	Respond to IRM System Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
215003	K6.04	Knowledge of the effect that a loss or malfunction of the following will have on the INTERMEDIATE RANGE MONITOR (IRM) SYSTEM: (CFR 41.7 / 45.7): Detectors	3.0	3.0

Static Simulator Exams: None

Last Revised: 09/16/2003 10:07:35 AM by Brown, Scott T.



# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 38 Exam Bank Question No.: 5651 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-215 Objective: CRO 6

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The SRM detector high voltage power supply is powered from:

	Answer/Distractor	Justification
a.	208 VAC PP6A CKT 25	Incorrect - This is the power source to the drive motor.
b.	120 VAC Instrument AC CKT 7	Incorrect - This is the control power to the detector drive control circuits.
c.	125 VDC DC-1C/DC-2C CKT 2/2	Incorrect - DC-1C/DC-2C provide no power to the SRMs.
d.	24 VDC A/B CKT 5/5	Correct Response - OP 2130, page 2A, Power Supplies

References: OP 2130, rev 15

New

## Task Associations

Task Number	Task Title
2157170401	Respond to SRM System Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
215004	K2.01	Knowledge of electrical power supplies to the following: (CFR 41.7): SRM channels/detectors	3.6	2.8

Static Simulator Exams: None

Last Revised: 07/25/2003 11:56:54 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 39 Exam Bank Question No.: 5652 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-05-215 Objective: CRO 6

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

APRM downscale alarm has come in and APRM "E" indicates downscale on the CRP 9-5 bench board. The BOP is sent to the APRM cabinet to investigate. While attempting to check LPRM inputs, the BOP inadvertently positions the APRM "E" Mode Switch from the operate to the power position.

This action will cause:

	Answer/Distractor	Justification
a.	alarms only.	Incorrect -
b.	alarms and rod block only.	Incorrect -
c.	alarms, rod block and 1/2 scram on RPS "A".	Correct Response - Function switch out of operation causes alarms, rod block (withdrawal) and 1/2 scram.
d.	alarms, rod block and 1/2 scram on RPS "B".	Incorrect - APRM E is assigned to RPS system "A"

References: OP 2132, rev 16, page 2 of 5  
new

## Task Associations

Task Number	Task Title
2157150401	Respond to APRM System Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
215005	A1.02	Ability to predict and/or monitor changes in parameters associated with operating the AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM controls including: (CFR 41.5 / 45.5): RPS status	3.9	4.0

Static Simulator Exams: None

Last Revised: 09/16/2003 10:12:04 AM by Brown, Scott T.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 40** Exam Bank Question No.: 5653 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-217 Objective: CRO 4b

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

RCIC is operating and injecting. The RCIC controller is in manual. As reactor pressure lowers from 1000 psig to 600 psig, the RCIC turbine speed will:

	Answer/Distractor	Justification
a.	increase because the controller is flow sensing.	Incorrect - Speed will not increase, the controller does not sense flow in manual.
b.	remain the same because the controller is flow sensing.	Incorrect - The controller does not sense flow in manual.
c.	remain the same because the controller is speed sensing.	Correct Response - In manual, controller operation RCIC turbine speed is held constant.
d.	decrease because the controller is speed sensing.	Incorrect - In manual, the controller maintains a constant turbine speed.

References: OP 2121 rev 19

New

### Task Associations

Task Number	Task Title
2170030101	Manually Initiate Startup of the RCIC System

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
217000	K5.06	Knowledge of the operational implications of the following concepts as they apply to REACTOR CORE ISOLATION COOLING SYSTEM (RCIC): (CFR 41.5 / 45.3): Turbine operation	2.7	2.7

Static Simulator Exams: None

Last Revised: 09/18/2003 6:36:41 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 41 Exam Bank Question No.: 5654 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-218 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

An ADS blowdown is in progress with all RHR and CS pumps running. The pump discharge pressure switches for RHR pumps A and C and CS A fail to the low discharge pressure condition.

The ADS system will:

	Answer/Distractor	Justification
a.	Continue the blowdown with all four SRVs	Correct Response- There are two pressure switches in the discharge of each of the six low pressure pumps. The loss of signal from six of these twelve pressure switches will have no impact on the ADS blown in progress
b.	Continue the blowdown with A and C SRVs only	Incorrect -
c.	Continue the blowdown with B and D SRVs only	Incorrect -
d.	Stop the blowdown by shutting all SRVs	Incorrect -

References: CWD 750/751

Modified bank 1703

## Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
218000	K3.02	Knowledge of the effect that a loss or malfunction of the AUTOMATIC DEPRESSURIZATION SYSTEM will have on following: (CFR 41.7 / 45.4): Ability to rapidly depressurize the reactor	4.5	4.6

Static Simulator Exams: None

Last Revised: 09/16/2003 10:46:28 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 42 Exam Bank Question No.: 5655 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-206 Objective: CRO 5, 7, 10a

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

DC-1 has been lost due to a fault. To comply with Technical Specifications and operating procedures, HPCI \_\_\_\_\_ must be shut and its ACB \_\_\_\_\_.

	Answer/Distractor	Justification
a.	HPCI-16 outbd isolation, kept closed.	Incorrect -
b.	HPCI-15 inbd isolation, kept closed.	Incorrect -
c.	HPCI-16 outbd isolation, opened.	Incorrect -
d.	HPCI-15 inbd isolation, opened.	Correct Response - Tech Spec to require that another valve in the process line must be closed and its position logged daily. The student must know that an initiation signal would open HPCI 16 and cause rapid piping pressurization, possible valve or piping damage, therefore, the MOV ACB must be opened.

References: LOT-01-223 CRO Obj. 1, 4

OP 2120, rev 27, page 21

Tech Spec 3.7, page 158

OP 2115, rev 43, page 10

New

Students should have T.S. 3.7 as a reference

## Task Associations

Task Number	Task Title
2067090401	Respond to Automatic HPCI System Trip or Isolation

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
223002	A2.02	Ability to (a) predict the impacts of the following on the PRIMARY CONTAINMENT ISOLATION SYSTEM/ NUCLEAR STEAM SUPPLY SHUT-OFF; and (b) based those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or	2.9	3.2

		operations: (CFR 41.5 / 45.6): D.C. electrical distribution failures		
--	--	--	--	--

Static Simulator Exams: None

Last Revised: 09/18/2003 6:38:34 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 43 Exam Bank Question No.: 5656 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-239 Objective: CRO 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A spurious MSIV isolation occurs from full power. All control rods fully insert. SRVs B, C, D (RV-71 B, C, D) lift and safety valve "A" (RV-SV2-70A) lifts. Drywell pressure rapidly rises to 5 psig and is now steady.

The lifting of Safety Valve "A" was \_\_\_\_\_. The rapid rise in drywell pressure when Safety Valve "A" lifted was \_\_\_\_\_.

	Answer/Distractor	Justification
a.	expected, unexpected	Incorrect -
b.	unexpected, unexpected	Incorrect -
c.	expected, expected	Incorrect -
d.	unexpected, expected	Correct Response - The student must know SRVs lift before SVs and 3 of 4 SRVs will prevent a SV lift on a spurious isolation (Transient Analysis) and that the SVs discharge to the drywell air space.

References: SEI-03-200 Obj. 9  
USAF, rev 18, 4.4.3  
Pilgrim 2003 NRC (modified)  
New

## Task Associations

Task Number	Task Title
2000180501	Respond to High Reactor Pressure

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
239002	K1.09	Knowledge of the physical connections and/or cause-effect relationships between RELIEF/SAFETY VALVES and the following: (CFR 41.2 to 41.9 / 45.7 to 45.8): Drywell pressure (for safety valves which discharge to the drywell airspace): Plant-Specific	4.0	4.0

Static Simulator Exams: None

Last Revised: 09/18/2003 6:40:36 PM by Brown, Scott T.



# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 44 Exam Bank Question No.: 5657 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-259 Objective: CRO 5e

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

The plant is operating at 100% power. The "A" main steam line flow D/P instrument fails to zero PSID.

Which one of the following describes the response of the feedwater level control system?

	Answer/Distractor	Justification
a.	Total steam flow signal increases, feed flow/steam flow mismatch increases reactor water level	Incorrect -
b.	Total steam flow signal decreases, feed flow/steam flow mismatch decreases reactor water level	Correct Response - Loss of one steam flow detector will result in indicated steam flow being less than actual. FWLC will close the feed reg valves to match feed flow to steam flow. Reactor level will lower opening the FRVs. Final reactor level will be lower.
c.	Total steam flow signal increases, feed flow/steam flow mismatch decreases reactor water level	Incorrect -
d.	Total steam flow signal decreases, feed flow/steam flow mismatch increases reactor water level	Incorrect -

References: USAR 7.10, rev 18

Pilgrim 2003

New

## Task Associations

Task Number	Task Title
2000310501	Respond to Low Reactor Water Level

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
259002	K5.01	Knowledge of the operational implications of the following concepts as they apply to REACTOR WATER	3.1	3.1

		LEVEL CONTROL SYSTEM: (CFR 41.5 / 45.3): GEMAC/Foxboro/Bailey controller operation: Plant-Specific		
--	--	---	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 11:00:35 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 45 Exam Bank Question No.: 5658 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-261 Objective: CRO 5

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

During full power operation HPCI is started in full flow test for a post maintenance operability run. Initially torus pressure will:

	Answer/Distractor	Justification
a.	increase due to the exhaust heat added to the pool from HPCI.	Incorrect - The torus pressure decreases, not increases, on an HPCI start for Surveillance.
b.	increase due to the exhaust heat added to the torus air space.	Incorrect - HPCI does not exhaust to the torus air space.
c.	decrease due to the startup of the SBT system.	Correct Response - The torus is vented through the 3" line to SBT during power operation. HPCI exhaust blower start starts both SBT fans but leaves the reactor building suction valves shut. SBT draws a vacuum on the torus.
d.	decrease due to the reduction in torus water volume.	Incorrect - Torus water volume increases during a HPCI run.

References: OP 4120

OP 2117, rev 17

New

## Task Associations

Task Number	Task Title
2060030201	Perform HPCI Pump Operability Test

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
261000	K1.03	Knowledge of the physical connections and/or cause-effect relationships between STANDBY GAS TREATMENT SYSTEM and the following: (CFR 41.2 to 41.9 / 45.7 to 45.8): Suppression Pool	2.9	3.1

Static Simulator Exams: None

Last Revised: 07/29/2003 12:15:21 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 46 Exam Bank Question No.: 5659 Revision: 6 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-264 Objective: CRO 11

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

When paralleling an EDG for Surveillance Testing, which of the following conditions, as a minimum, must be satisfied for breaker closure to occur?

	Answer/Distractor	Justification
a.	Sync Switch ON, breaker control switch to CLOSE	Incorrect - Timer is not timed out.
b.	Sync Switch ON, Sync Scope in the window, breaker control switch to CLOSE	Incorrect - This window is too wide and will not work.
c.	Sync Switch ON, Sync Scope in the window, timer timed out, breaker control switch to CLOSE	Correct Response
d.	Sync Switch ON, Sync Scope in the window, timer timed out, breaker control switch to CLOSE and held for 3 seconds	Incorrect - a & b justifications above. The breaker control switch is not required to be held in the close position.

References: OP 2142, rev 20, Discussion Section

ARS 9-8-J-9, rev 7

New

Task Associations

Task Number	Task Title
2640030201	Perform Emergency Diesel Generator Load Tests

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
262001	K4.05	Knowledge of A.C. ELECTRICAL DISTRIBUTION design feature(s) and/or interlocks which provide for the following: (CFR 41.7): Paralleling of A.C. sources (synchroscope)	3.4	3.6

Static Simulator Exams: None

Last Revised: 09/18/2003 6:41:58 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 47 Exam Bank Question No.: 5660 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-262 Objective: 1d, 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

An air leak has developed on 345 KV Breaker ATB-379. High pressure cylinder pressure is 425 psig and lowering. The compressor has tripped on overload. VELCO has authorized opening the 379 ATB.

The breaker :

	Answer/Distractor	Justification
a.	Must be opened before air pressure lowers to 400 psig and all tripping capability is lost.	Correct Response - OP 2140 Appendix A
b.	can be opened from the control room at air pressure down to 67 psig.	Incorrect - 67 psig is the minimum SF-6 pressure that will allow breaker operation.
c.	Must be opened before air pressure lowers to 400 psig and automatic opening occurs.	Incorrect - 379 ATB does not automatically trip on low air pressure.
d.	can not be opened from the control room.	Incorrect - The breaker can be opened from the control room down to an air pressure of 400 +/- 10 psig.

References: OP 2140, rev 24, Appendix A

ARS 9-8-B-2, rev 4

ARS 9-8-B-5, rev 3

New

## Task Associations

Task Number	Task Title
2997180301	Follow the 345KV Voltage Schedule

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
262001	A4.01	Ability to manually operate and/or monitor in the control room: (CFR 41.7 / 45.5 to 45.8): All breakers and disconnects (including available switch yard): Plant-Specific	3.4	3.7

Static Simulator Exams: None

Last Revised: 09/16/2003 11:02:28 AM by Brown, Scott T.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 48** Exam Bank Question No.: 5661 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-03-262 Objective: CRO 7

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The plant has experienced a DBA LOCA. RUPS units will:

	Answer/Distractor	Justification
a.	continue to operate as before if no LNP signal is present.	Incorrect - The RUPS must transfer to DC drive, it's AC power source has been removed by the LOCA signal.
b.	automatically transfer MCC 89A/B to MCC 8B/9B (respectively).	Incorrect - MCC 89A/B transfers to 8B/9B (Maintenance Tie) are manual only.
c.	transfer from AC to DC drive and continue to power MCC 89A/B.	Correct Response - USAR 8.4.5.2.1
d.	transfer from AC to DC drive and back to AC drive when the LOCA signal is reset.	Incorrect - The AC Supply breaker is tripped by the accident signal and must be manually reshut.

References: UASR, rev 18, 8.4.5.2.1

Bank LOI VYN #97, modified distractor "D"

### Task Associations

Task Number	Task Title
2627260101	Energize 480V Buses and MCCS

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
262002	K4.01	Knowledge of UNINTERRUPTABLE POWER SUPPLY (A.C./ D.C.) design feature(s) and/or interlocks which provide for the following: (CFR 41.7): Transfer from preferred power to alternate power supplies	3.1	3.4

Static Simulator Exams: None

Last Revised: 07/25/2003 12:19:07 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 49 Exam Bank Question No.: 5662 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-601 Objective: CRO 2, 3, 4

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The plant is operating at full power. Electrical Maintenance has requested permission to cycle the 4 KV Bus 1 DC control power knife switch to verify operability of the knife switch.

Your direction to Electrical Maintenance is:

	Answer/Distractor	Justification
a.	No, the "A" recirc pump is likely to trip.	Correct Response
b.	Yes, do it in less than 6 seconds.	Incorrect - The recirc MG Low Lube Oil Trip is delayed for 6 seconds. Up until the last outage, the lube oil pumps tripped on a loss of DC control power. Now the lube oil pumps continue to run.
c.	No, the reactor feed pumps are likely to trip.	Incorrect - The removal and restoration of control power to 4 KV Bus will not cause RFPS to trip.
d.	Yes, do it in less than 15 seconds.	Incorrect - 15 seconds is the time window for the recirc MG start sequence, which will trip the drive motor breaker on an incomplete start sequence.

References: OP 2142, rev 20, page 6, Precaution 3

VYN LOI Bank #1809, modified

ON 3159, rev 4, page 4

## Task Associations

Task Number	Task Title
2000320501	Respond to a Loss of DC-1, 2, 3
2627390401	Respond to Loss of DC Control Power to a 4KV Bus

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
263000	K1.01	Knowledge of the physical connections and/or cause-effect relationships between D.C. ELECTRICAL DISTRIBUTION and the following: (CFR 41.2 to 41.9 / 45.7 to 45.8): A.C. electrical distribution	3.3	3.5



Static Simulator Exams: None

Last Revised: 09/18/2003 6:44:17 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 50 Exam Bank Question No.: 5663 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-263 Objective: CRO 2

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A ground has been detected on 125 VDC Bus DC-2. Ground meter indication is +127 VDC. Under these conditions, DC-2 loads \_\_\_\_\_ operate correctly, and you are required to initiate a priority \_\_\_\_\_ work request.

	Answer/Distractor	Justification
a.	should, 1	Correct Response - OP 2145, page 7
b.	should not, 1	Incorrect -
c.	should, 2	Incorrect -
d.	should not, 2	Incorrect -

References: OP 2145, rev 24, page 7

New

## Task Associations

Task Number	Task Title
2637090401	Respond to a DC Ground

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
263000	A2.01	Ability to (a) predict the impacts of the following on the D.C. ELECTRICAL DISTRIBUTION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Grounds	2.8	3.2

Static Simulator Exams: None

Last Revised: 07/31/2003 10:14:40 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 51 Exam Bank Question No.: 5664 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-603 Objective: CRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The "B" EDG is running for surveillance. 125 VDC Bus DC-1 is lost.

Which of the following is correct?

	Answer/Distractor	Justification
a.	All engine protective trips are disabled and the engine can be shutdown from the control room.	Incorrect - The control room can not open the output breaker or shutdown the engine under these conditions.
b.	No engine protective trips are disabled and the engine can be shutdown from the control room.	Incorrect - All engine protective features are lost (except overspeed).
c.	All engine protective trips are disabled and the engine can only be shutdown locally .	Correct Response - ON 3159
d.	No engine protective trips are disabled and the engine can only be shutdown locally .	Incorrect - All engine protective features are lost (except overspeed).

References: LOT-00-264 CRO Obj. 9c

ON 3159, rev 4 Step 3

ARS DB-F-3

New

## Task Associations

Task Number	Task Title
2000320501	Respond to a Loss of DC-1, 2, 3
2647010401	Respond to DG Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
264000	K6.09	Knowledge of the effect that a loss or malfunction of the following will have on the EMERGENCY GENERATORS (DIESEL/JET): (CFR 41.7 / 45.7): D.C. power	3.3	3.5

Static Simulator Exams: None

Last Revised: 08/20/2003 9:00:58 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 52 Exam Bank Question No.: 5665 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-279 Objective: AO 9d, 11; CRO 1d

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Air temperature in the instrument air dryer towers can be monitored on \_\_\_\_\_ and will provide a Tower Overtemperature Alarm at \_\_\_\_\_ on the tower that is \_\_\_\_\_.

	Answer/Distractor	Justification
a.	a local panel, 400°F, reactivating	Incorrect - The inservice tower has no energy source to make it this hot.
b.	ERFIS, 400°F, inservice	Incorrect - The inservice tower has no energy source to make it this hot.
c.	a local panel, 600°F, reactivating	Correct Response - Student must integrate location of indications, alarm setpoints and potential cause of the alarm - the heaters on the reactivating tower have failed to deenergize at their setpoint and temperatures have not stabilized out at 400-425°F.
d.	ERFIS, 600°F, in service	Incorrect - Air dryer temperatures can not be read on ERFIS.

References: OP 2190, rev 29

New

## Task Associations

Task Number	Task Title
2997070304	Monitor Plant Systems During Operator Rounds, Surveillance and Normal Plant Operations

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
300000	A3.02	Ability to monitor automatic operations of the INSTRUMENT AIR SYSTEM including: (CFR 41.7 / 45.7): Air temperature	2.9	2.7

Static Simulator Exams: None

Last Revised: 09/16/2003 11:05:57 AM by Brown, Scott T.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 53** Exam Bank Question No.: 5666 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-208 Objective: CRO 7

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

A leak has developed in the RBCCW System. Makeup to the RBCCW expansion tank normally is \_\_\_\_\_ and the standby pump is automatically started at \_\_\_\_\_ header pressure.

	Answer/Distractor	Justification
a.	manual, 70 psig	Incorrect - Manual is a backup to the automatic makeup.
b.	automatic, 70 psig	Correct Response
c.	manual, 90 psig	Incorrect - Manual is a backup to the automatic makeup.
d.	automatic, 90 psig	Incorrect - Standby pump starts at 70 psig not 90 psig.

References: ON 3147, rev 10

New

### Task Associations

Task Number	Task Title
2000110501	Respond to RBCCW Failure

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
400000	A3.01	Ability to monitor automatic operations of the COMPONENT COOLING WATER SYSTEM including: (CFR 41.7 / 45.7): Setpoints on instrument signal levels for normal operations, warnings, and trips that are applicable to the CCWS	3.0	3.0

Static Simulator Exams: None

Last Revised: 09/18/2003 6:45:41 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 54 Exam Bank Question No.: 5667 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-02-201 Objective: CRO 1a, c, e, 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The reactor is operating at 50% CTP. A control rod is selected and notched out one notch from position 32 to 34. The rod sequence control timer fails, the withdraw bus remains energized and the control rod continues out.

The 2 second cycle auxiliary timer will provide a control rod:

	Answer/Distractor	Justification
a.	select block, and you should confirm the control rod deselected.	Correct Response
b.	withdraw block, and you should confirm the control rod stopped moving.	Incorrect - A select block is applied, not a withdraw block.
c.	withdraw block, and you should confirm the control rod deselected.	Incorrect - The control rod should not drift but stop on the next notch. A drift alarm may occur.
d.	select block, and you should confirm the control rod stops moving.	Incorrect - The control rod is deselected with no settle function.

References: ARS 9-5-D-6 rev 4

New

## Task Associations

Task Number	Task Title
2010050101	Operate Control Rods Using Single Notch Mode

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
201002	A2.01	Ability to (a) predict the impacts of the following on the REACTOR MANUAL CONTROL SYSTEM; and (b) based on these predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Rod movement sequence timer malfunctions	2.7	2.8

Static Simulator Exams: None

Last Revised: 09/16/2003 11:11:53 AM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 55 Exam Bank Question No.: 5668 Revision: 5 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-202 Objective: CRO 4, 5

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

During full power operation the "A" Recirc Motor Generator trips on differential overcurrent and repairs will take several weeks.

Which of the following limits must be changed to satisfy Tech Specs?

	Answer/Distractor	Justification
a.	MCPR limits are increased.	Incorrect -
b.	APRM Rod Blocks are reduced.	Correct Response
c.	MAPLHGR limits are increased.	Incorrect -
d.	LHGR limits are reduced.	Incorrect -

References: COLR Cycle 23, rev 0

Tech Specs 3.6.G.1.a, 203

LOI EB #1650, modified

## Task Associations

Task Number	Task Title
2007900501	Respond to a Loss of Bus 1 Using ON 3169

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
202002	2.1.33	Ability to recognize indications for system operating parameters which are entry-level conditions for Technical Specifications (CFR 43.2, 43.3, 45.3)	3.4	4.0

Static Simulator Exams: None

Last Revised: 09/18/2003 6:53:10 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 56 Exam Bank Question No.: 5669 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-03-201 Objective: CRO 1f,1j,2

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A reactor startup is in progress.

Reactor power on APRMs is 80%. Core flow is 85% of rated. Recirc drive flow is 80% of rated. Reactor power is being increased by control rod withdrawals when an RBM rod block occurs. RBM A is reading 89 and RBM B is reading 81.

To continue the power increase you must:

	Answer/Distractor	Justification
a.	Depress the "push to setup" button on RBM A	Incorrect -
b.	Depress the "push to setup" button on RBM B	Incorrect -
c.	Depress the "push to setup" button on RBM A and B	Correct Response
d.	Stop control rod withdrawals until flow is increased	Incorrect -

References: OP 2133, rev 16

ARS 9-5-M-7

New

## Task Associations

Task Number	Task Title
2017360401	Respond to RBM HI/INOP
2157180401	Respond to RBM System Alarms

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
215002	A2.01	Ability to (a) predict the impacts of the following on the ROD BLOCK MONITOR SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Withdrawal of control rod in high power region of core: BWR-3, 4, 5	3.3	3.5



Static Simulator Exams: None

Last Revised: 09/18/2003 6:53:45 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 57 Exam Bank Question No.: 5670 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-216 Objective: CRO 4, 11a, 14

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

A reactor cooldown is in progress. LT-2-3-72A (ECCS) on CRP 9-5 will read \_\_\_\_\_ when compared to actual RPV level, and as the cooldown continues you should transition to the \_\_\_\_\_ level instrument.

	Answer/Distractor	Justification
a.	high, LI-2-3-86 (refuel)	Correct Response - The correct indicator is recall, but must also recall range & calibration conditions that make this instrument the preferred instrument for shutdown cooling operations. (This is a recent procedure change, 9/19/02) Must also determine calibration conditions for LT-2-3-72A and how the cooldown affects it.
b.	Low, LT-2-3-68A/B (transient)	Incorrect - LI-2-3-68 is not preferred and not cold calibrated.
c.	high, LT-2-3-68A/B (transient)	Incorrect - LI-2-3-68A/B is no longer the procedurally preferred instrument.
d.	low, LI-2-3-86 (refuel)	Incorrect -LT-2-3-72 will read higher than actual level during a cooldown because it is hot calibrated.

References: OP 2124, rev 50, LPC #7

VYC 332

New

## Task Associations

Task Number	Task Title
2057090101	Operate the RHR System in the Shutdown Cooling Mode

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
216000	A2.11	Ability to (a) predict the impacts of the following on the NUCLEAR BOILER INSTRUMENTATION; and (b) based on those predictions, use procedures to correct,	3.2	3.3

		control, or mitigate the onsequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Heatup or cooldown of the reactor vessel		
--	--	--	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 12:55:46 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 58 Exam Bank Question No.: 5671 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-205 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

480 VAC Bus 9 has been lost due to an electrical fault.

Which RHR Loop(s) could be used for torus cooling without the use of local manual valve operations:

	Answer/Distractor	Justification
a.	Neither "A" nor "B" Loop is available.	Incorrect - "A" Loop valves have no power, "B" Loop valves have power.
b.	"A" Loop is available.	Incorrect - "A" RHR Loop valves (65, 34, 38, 39, 26, 31) needed for torus cooling are powered from MCC 9B -> Bus 9 no power.
c.	"B" Loop is available.	Correct Response - "B" Loop valves have power.
d.	Both "A" and "B" Loops are available.	Incorrect - "A" Loop valves have no power.

References: OP 2124, rev 50

New

## Task Associations

Task Number	Task Title
2057190101	Startup the RHR System in the Torus Cooling Mode

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
219000	K2.01	Knowledge of electrical power supplies to the following: (CFR 41.7): Valves	2.5	2.9

Static Simulator Exams: None

Last Revised: 09/16/2003 12:57:09 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 59 Exam Bank Question No.: 5672 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-229 Objective: CRO 5

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

During power operation the drywell oxygen concentration is monitored \_\_\_\_\_ and the torus oxygen concentration is monitored \_\_\_\_\_ .

	Answer/Distractor	Justification
a.	continuously, periodically	Correct Response - The drywell is continuously monitored. The torus is only sampled for surveillance.
b.	periodically, continuously	Incorrect -
c.	continuously, continuously	Incorrect -
d.	periodically, periodically	Incorrect -

References: OP 2125, rev 19, page 3  
New

## Task Associations

Task Number	Task Title
2297130101	Operate CAD Panel H2/O2 Analyzer

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
223001	K5.13	Knowledge of the operational implications of the following concepts as they apply to PRIMARY CONTAINMENT SYSTEM AND AUXILIARIES: (CFR 41.5 / 45.3): Oxygen concentration measurement: Plant-Specific	2.7	2.8

Static Simulator Exams: None

Last Revised: 07/25/2003 12:38:13 PM by Hallonquist, Nora E.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 60 Exam Bank Question No.: 5673 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-234 Objective: AO 2a, b, c, 10a

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Refueling is in progress. You are over the fuel pool, grapple closed, bundle seated in the rack. A loss of off-site power occurs (LNP). The refueling equipment will \_\_\_\_\_ and OP 1101 requires the Refueling Crew to \_\_\_\_\_.

	Answer/Distractor	Justification
a.	continue to operate, open the grapple.	Incorrect - All refueling motors are variable speed DC motors. This distractor is plausible if the student believes them to be powered from the station 125 VDC batteries.
b.	stop as is, halt refueling operations, inform the Shift Manager.	Correct Response - The student must analyze that the LNP causes a loss of power to refueling equipment which fails as it. Then he must analyze that the EDG repowers the bus in 13 seconds. He must know that the refueling equipment is not load shed, and will be repowered. He must know that the bridge will not auto restart when power is restored. He must also know that OP 1101 requires halting refueling should an LNP occur. His natural desire will be to restart the bridge and open the grapple.
c.	continue to operate, halt refueling operations.	Incorrect - All refueling motors are variable speed DC motors. This distractor is plausible if the student believes them to be powered from the station 125 VDC batteries.
d.	stop as is, restart the bridge and, with the refueling SRO's concurrence, open the grapple.	Incorrect -

References: OP 1101, rev 35, Appendix A

OT 3122, rev 19, Appendix B

New

Task Associations

Task Number	Task Title
-------------	------------

2007020501	Respond to Loss of Normal Power
------------	---------------------------------

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
234000	A2.03	Ability to (a) predict the impacts of the following on the FUEL HANDLING; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Loss of electrical power	2.8	3.1

Static Simulator Exams: None

Last Revised: 08/20/2003 8:54:15 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 61 Exam Bank Question No.: 5674 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-302 Objective: RO 13

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A plant startup is in progress. The turbine steam chest is warmed and the turbine is on the jacking gear. 1&1/2 bypass valves are open. MS-6 (steam seal regulator inlet) motor shorts out and strokes the valve closed.

This will cause main condenser backpressure to \_\_\_\_\_ and you should open \_\_\_\_\_.

	Answer/Distractor	Justification
a.	Remain constant , MS-10 (steam seal regulator bypass)	Incorrect - Back pressure will increase under the given conditions due to condenser air in leakage
b.	Remain constant , MS-9 (steam seal regulator unloader)	Incorrect -Back pressure will increase under the given conditions due to condenser air in leakage
c.	Increase , MS-10 (steam seal regulator bypass)	Correct Response-Student must analyze that the turbine steam seal normally comes from first stage turbine leakage at power. During a startup at this point the turbine control valves are shut, and turbine first stage pressure is at a vacuum. Steam seal steam must be supplied by the main steam system through the regulator which has just been isolated. Loss of seal steam will cause backpressure to rise and opening MS 10 will restore sealing steam and condenser backpressure will return to normal.
d.	Increase , MS-9 (steam seal regulator unloader)	Incorrect - Opening the gland seal steam unloader will have no affect on the increasing condenser backpressure

References: ARS 9-7-K-9

New

Task Associations



Task Number	Task Title
2450020101	Startup the Turbine to Rated Speed

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
239001	K3.06	Knowledge of the effect that a loss or malfunction of the MAIN AND REHEAT STEAM SYSTEM will have on following: (CFR 41.7 / 45.4): Seal steam/gland seal system	2.6	2.7

Static Simulator Exams: None

Last Revised: 09/16/2003 4:38:30 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 62 Exam Bank Question No.: 5675 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-249 Objective: CRO 5, 7, 9

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Turbine emergency governor testing is in progress at full power. After moving the emergency governor test switch from the Trip to the Reset position by procedure you would expect the:

	Answer/Distractor	Justification
a.	Lockout light to remain energized and the reset light to energize.	Correct Response
b.	Reset light to energize and the lockout light to de-energize.	Incorrect -
c.	Lockout light to remain de-energized and the reset light to energize.	Incorrect -
d.	Reset light to energize and then de-energize and the lockout light to remain energized	Incorrect - If the emergency governor is pushed in without reset indication, the turbine will trip.

References: OP 4160, rev 32, page 20

New

Task Associations

Task Number	Task Title
2457110201	Perform Emergency Governor Test

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
241000	A3.12	Ability to monitor automatic operations of the REACTOR/TURBINE PRESSURE REGULATING SYSTEM including: (CFR 41.7 / 45.7): Turbine trip testing	2.9	2.9

Static Simulator Exams: None

Last Revised: 09/18/2003 7:02:59 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 63 Exam Bank Question No.: 5676 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-256 Objective: 1j, 2

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

CRP 9-6 Alarm D-4 "Atmos DRN Tk LVL Hi/Lo" is in alarm. Main condenser vacuum is slowly degrading.

When you direct the TB AO to investigate, in your prejob brief would tell him to expect:

	Answer/Distractor	Justification
a.	Tank Level Low, and the level control valve stuck open.	Correct Response - This event has happened at the plant and operators had difficulty diagnosing it. When the level control valve sticks open, the tank level goes Low and allows air to be drawn into the main condenser. ARS 9-6-D-4 discusses how to fail the LCV shut and stop the loss of vacuum.
b.	Tank Level High, and the level control valve stuck open.	Incorrect - When the tank overfills, vacuum is not affected.
c.	Tank Level Low, and the level control valve stuck shut.	Incorrect - The LCV sticking shut will overflow the tank - vacuum will not be affected.
d.	Tank Level High, and the level control valve stuck shut.	Incorrect - These conditions are possible, but main condenser vacuum will not be affected.

References: ARS 9-6-D-4, rev 3

New

## Task Associations

Task Number	Task Title
2567190401	Respond to Low Level Alarm in Atmosphere Drain Tank System

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
256000	A4.07	Ability to manually operate and/or monitor in the control room: (CFR 41.7 / 45.5 to 45.8): Lights and alarms	2.9	2.9

Static Simulator Exams: None

Last Revised: 09/16/2003 1:03:02 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 64** Exam Bank Question No.: 5677 Revision: 1 Point Value: 1  
 SRO Only: No Instructor Guide: LOT-01-288 Objective: AO 3, CRO 3, 5  
 Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

The CRS has directed you to restart reactor building ventilation in accordance with OP 2192. To perform this task the reactor building exhaust fan control switch must be held in the "on" position for approximately \_\_\_\_\_ seconds to allow for the startup of the \_\_\_\_\_.

	Answer/Distractor	Justification
a.	10, transfer fans	Incorrect - The transfer fans do not experience this time delay.
b.	20, supply fan	Incorrect - 20 seconds is too long, something is not working correctly.
c.	10, supply fan	Correct Response - VYN has had many events (ER 960321 OP Ref) where these controls were not properly set or operated incorrectly. The time delay allows for relay timing, pneumatic damper positioning --> making up limit switches allowing fan start. Once the exhaust fan starts, the whole sequence occurs again with the supply fan.
d.	20, transfer fans	Incorrect - 20 seconds is too long, something is not working correctly.

References: OP 2192, rev 30, page 27

New

## Task Associations

Task Number	Task Title
2887210401	Respond to a Loss of Reactor Building Ventilation

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
290001	2.1.30	Ability to locate and operate components, including local controls (CFR 41.7, 45.7)	3.9	3.4

Static Simulator Exams: None

Last Revised: 09/16/2003 1:04:12 PM by Brown, Scott T.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 65 Exam Bank Question No.: 5678 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-04-215 Objective: CRO 1, FND 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

By station procedure Op 2425 inter-calibration of the three TIP units is accomplished by:

	Answer/Distractor	Justification
a.	traversing a common position in the core.	Correct Response
b.	algorithmic comparison of the three individual automatic TIP traces.	Incorrect -
c.	using the hand crank to manually position each TIP unit at its respective reference point.	Incorrect -
d.	using the semi-automatic mode to achieve equalized incremental positioning of each TIP unit.	Incorrect -

References: OP 2425

USAR rev 18 7.5.9.2.2

LOI-EB # 1912

Task Associations

Task Number	Task Title
2150230101	Operate the Neutron Monitoring System

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
290002	K1.19	Knowledge of the physical connections and/or cause-effect relationships between REACTOR VESSEL INTERNALS and the following: (CFR 41.2 to 41.9 / 45.7 to 45.8): TIP	2.5	2.6

Static Simulator Exams: None

Last Revised: 09/16/2003 1:06:00 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 66 Exam Bank Question No.: 5679 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-302 Objective: CRO 2

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

You are performing a plant startup IAW OP 0105 and come to a step with an asterisk (\*) at the end.

This asterisk means this is a:

	Answer/Distractor	Justification
a.	Check sheet sign off required by an on shift RO licensed operator only.	Incorrect -
b.	check sheet sign off required by any on shift licensed operator.	Correct Response - Start-up check sheet sign offs are identified by asterisks following steps that operators must sign for when performing.
c.	Check sheet sign off required by an on shift SRO licensed operator only.	Incorrect -
d.	Chemistry hold point that requires contacting the on shift Chemistry Tech	Incorrect -

References: LOT-01-400 CRO Obj. 1

OP 0105, rev 10, Page 14 of 137

New

## Task Associations

Task Number	Task Title
2017400201	Perform Heating and Pressurization of the Reactor
2990060301	Maintain Required Logs, Records, Charts, Printouts and Status Boards

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.1.18	Ability to make accurate, clear and concise logs, recordsm, status boards, and reports (CFR 45.12, 45.13)	2.9	3.0

Static Simulator Exams: None

Last Revised: 09/16/2003 1:11:29 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 67 Exam Bank Question No.: 5680 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-03-400 Objective: CRO 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The reactor has been manually scrammed due to the loss of EPR and MPR. The CRS directs you to control reactor pressure 800-1000 psig using the Bypass Opening Jack (BPOJ), before the SRVs lift again.

DP 0166 allows operation of the bypass opening jack( BPOJ):

	Answer/Distractor	Justification
a.	From memory.	Correct Response - DP 0166 states this action can be performed from memory post scram. If the operator takes the time to refer to the procedure, he will cause additional challenges to the SRVs and add heat to the torus unnecessarily.
b.	Only after procedure review.	Incorrect - Not required, challenges SRVs
c.	Only with the procedure in hand, no place keeping required.	Incorrect - Not required, challenges SRVs
d.	Only with the procedure in hand, place keeping required.	Incorrect - Not required, challenges SRVs

References: DP 0166, rev 7, page 6

New

## Task Associations

Task Number	Task Title
2000330501	Respond to a Reactor SCRAM

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.1.20	Ability to execute procedure steps (CFR 41.10, 43.5, 45.12)	4.3	4.2

Static Simulator Exams: None

Last Revised: 09/18/2003 7:06:15 PM by Brown, Scott T.



# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 68 Exam Bank Question No.: 5681 Revision: 2 Point Value: 1

SRO Only: No Instructor Guide: LOT-01-400 Objective: CRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

You are relieving the reactor operator during power operation and have not been on shift for 20 days. The "A" EDG is out of service due to cylinder failure several days ago.

To determine when the failure occurred, you would review the current copy of :

	Answer/Distractor	Justification
a.	VYAPF 0152.01 Control Room Shift Turnover Check List	Incorrect -
b.	VYAPF 0152.02 Tech Spec/TRM Components Inoperable Check List	Correct Response - 0152.02 requires logging date & time. Tech Spec equipment is declared inoperable.
c.	VYAPF 0152.03 Shift Briefing Check List	Incorrect -
d.	VYAPF 0152.04 Control Room Turnover Sheet	Incorrect -

References: OP 0152, rev 22

New

Task Associations

Task Number	Task Title
2990030301	Conduct Shift and Relief Turnover

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.2.23	Ability to track limiting conditions for operations (CFR 43.2, 45.13)	2.6	3.8

Static Simulator Exams: None

Last Revised: 09/16/2003 1:15:03 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 69 Exam Bank Question No.: 5682 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-402 Objective: CRO 2, 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Due to a failed vibration switch, the RECIRC PUMP MOTOR A VIBR HI annunciator (4-C-7) is in constant alarm and has been disabled. It is anticipated the annunciator will remain disabled for 15 months until the next refueling outage.

Which one of the following is correct regarding the disabled annunciator?

	Answer/Distractor	Justification
a.	A Temporary Modification (TM) will be written for this configuration change and will require PORC review after six months.	Correct Response - OP 3140/AP 0020
b.	A Minor Modification (MM) will be written for this configuration change and will require PORC review after six months.	Incorrect -
c.	A Temporary Modification (TM) will be written for this configuration change and will require PORC review after twelve months.	Incorrect -
d.	A Minor Modification (MM) will be written for this configuration change and will require PORC review after twelve months.	Incorrect -

References: AP 0020, rev 25, page 8

OP 3140, rev 17, page 4

LOI EB #3271, modified

## Task Associations

Task Number	Task Title
3410110302/0	Approve Temporary Modifications
3	

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
--------	---------	-----------	----	-----

0	2.2.11	Knowledge of the process for controlling temporary changes (CFR 41.10, 43.3, 45.13)	2.5	3.4
---	--------	---	-----	-----

Static Simulator Exams: None

Last Revised: 07/02/2003 3:23:25 PM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 70** Exam Bank Question No.: 5683 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-02-201 Objective: CRO 1a, b, 7

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

You are performing control rod coupling checks IAW OP 4111, Section C (VYOPF 4111.03), on a control rod at position 48 prior to a reactor startup.

To perform this check you must:

	Answer/Distractor	Justification
a.	go to ROD OUT and hold for 3-5 seconds.	Incorrect -
b.	go to NOTCH OVERRIDE AND ROD OUT and hold for 3-5 seconds.	Correct Response - OP 4111 page 12
c.	go to ROD OUT and hold for 5-10 seconds.	Incorrect -
d.	go to NOTCH OVERRIDE AND ROD OUT and hold for 5-10 seconds.	Incorrect -

References: OP 4111, rev 39, page 12

New

### Task Associations

Task Number	Task Title
2017130201	Perform Nuclear Instrumentation Response and Coupling Integrity Verification - First Withdrawal

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.2.01	Ability to perform pre-startup procedures for the facility, including operating those controls associated with plant equipment that could affect reactivity (CFR 45.1)	3.7	3.6

Static Simulator Exams: None

Last Revised: 08/12/2003 3:39:03 PM by Hallonquist, Nora E.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 71 Exam Bank Question No.: 5684 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-271 Objective: CRO 5

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

A valid off gas Hi-Hi radiation alarm has been in for 35 minutes on RAN-OG-3127 and 3128 (Final Delay Line Inlet Monitors).

You must confirm the closure of:

	Answer/Distractor	Justification
a.	OG-516 A & B (Steam Jet Air Ejector Suctions)	Incorrect -
b.	FCV-11 and OG-3 (Inlet to Stack and Drain)	Correct Response - OP 2150, page 6; ON 3152
c.	FCV-36, 36A, 37 (SJAЕ Supplies)	Incorrect -
d.	OG-101 A & B (Recombiner Inlets)	Incorrect -

References: OP 2150, rev 27, page 6  
LOI EB #71, modified

Task Associations

Task Number	Task Title
2007090501	Respond to High Off-Gas Radiation

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.3.11	Ability to control radiation releases (CFR 45.9, 45.10)	2.7	3.2

Static Simulator Exams: None

Last Revised: 08/12/2003 3:39:32 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 72 Exam Bank Question No.: 5685 Revision: 4 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-602 Objective: CRO 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A reactor startup is in progress. The reactor is critical and reactor pressure is 300 psig. Main Condenser backpressure is 15" Hg Abs. A high worth control rod which was stuck at position 00 drops to position 46.

You should confirm automatic closure of:

	Answer/Distractor	Justification
a.	MSIVs and recirc sample valves	Incorrect - This isolation was removed in 2002.
b.	MSIVs, main steam drains, and recirc sample valves	Incorrect - This isolation was removed in 2002.
c.	Hogger discharge valve, steam packing exhauster suction valves	Incorrect - SPE have no suction valves. Hogger discharge valve is manual valve - no auto closure
d.	Hogger suction valve, steam packing exhauster discharge valves	Correct Response - Tech Spec Amendment 212, Plant Design Change, removed the MSIV isolation in the fall of 2002. OT 3112

References: OT 3112 rev 14, page 5

New

## Task Associations

Task Number	Task Title
2007100501	Respond to Fuel Element Failure

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.3.10	Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure (CFR 43.4, 45.10)	2.9	3.3

Static Simulator Exams: None

Last Revised: 09/16/2003 1:17:27 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 73 Exam Bank Question No.: 5686 Revision: 3 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-610 Objective: CRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

If torus temperature or RPV pressure can not be maintained below the Heat Capacity Temperature Limit Curve (HCTL), then EOP-3 Primary Containment Control, requires RPV/ED.

This action is performed to avoid:

	Answer/Distractor	Justification
a.	Damaging SRV downstream piping during RPV/ED	Incorrect -
b.	Loss of all RPV level instruments after RPV/ED	Incorrect -
c.	Overpressurizing the Primary Containment during RPV/ED	Correct Response
d.	Excessive hydrodynamic loading on downcomer during RPV/ED	Incorrect - .

References: EOP Vol 4, rev 11, Ch 13.7

LOI-EB # 2226

## Task Associations

Task Number	Task Title
2000200501	Respond to ATWS Event(s)

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.4.18	Knowledge of specific bases for EOPs (CFR 41.10, 45.13)	2.7	3.6

Static Simulator Exams: None

Last Revised: 09/16/2003 2:06:42 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 74 Exam Bank Question No.: 5687 Revision: 1 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-607 Objective: CRO 2, 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A small LOCA has occurred. Conditions are listed below. No operator actions have been taken.

Reactor pressure 800 psig and slowly lowering  
 Reactor level 100" and steady  
 Drywell temperature 240°F and slowly rising  
 Drywell pressure 11 psig and slowly rising  
 Torus pressure 11 psig and slowly rising  
 Torus air temperature 236°F and slowly rising  
 Torus level 11.60 feet and slowly rising  
 Torus water temperature 91°F and slowly rising

The crew's priority should be:

	Answer/Distractor	Justification
a.	torus cooling so the heat capacity of the torus will be preserved.	Incorrect -
b.	torus and drywell spray because the pressure suppression function of the primary containment has failed.	Correct Response - Torus air temperature ~ 140°F above torus water temperature indicates the pressure suppression function has failed and sprays are required to prevent containment failure.
c.	torus cooling and torus level control so the heat capacity of the torus will be preserved.	Incorrect -
d.	vent the drywell before exceeding the pressure suppression pressure.	Incorrect -

References: EOP-3, rev 11, Study guide Page 8-4

New

## Task Associations

Task Number	Task Title
2000190501	Respond to High Torus Water Temperature
2000210501	Respond to High Drywell Temperature
2000230501	Respond to High Torus Water Level



Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.4.23	Knowledge of the bases for prioritizing emergency procedure implementation during emergency operations (CFR 41.10, 45.13)	2.8	3.8

Static Simulator Exams: None

Last Revised: 07/29/2003 12:24:31 PM by Hallonquist, Nora E.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 75 Exam Bank Question No.: 5688 Revision: 0 Point Value: 1

SRO Only: No Instructor Guide: LOT-00-622 Objective: CRO 4

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

An EOP override is identified by a \_\_\_\_ box, and applies to all steps \_\_\_\_ within the procedure leg.

	Answer/Distractor	Justification
a.	red, below it	Correct Response - EOP Users Guide page 9
b.	yellow, below it	Incorrect -
c.	red, above and below it	Incorrect -
d.	yellow, above and below it	Incorrect -

References: VY EOP Users Guide, rev 1

New

Task Associations

Task Number	Task Title
2000200501	Respond to ATWS Event(s)

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.4.19	Knowledge of EOP layout, symbols, and icons (CFR 41.10, 45.13)	2.7	3.7

Static Simulator Exams: None

Last Revised: 07/25/2003 12:58:32 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 76 Exam Bank Question No.: 5689 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-05-215 Objective: SRO 1

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The A & B Recirc pumps are operating when the "A" pump trips. Parameters are as follows:

"B" Loop Drive flow 19,700 gpm  
 "A" Loop Drive flow 0 gpm  
 B Loop Jet Pump flow 18 mlbm/hr  
 A Loop Jet Pump flow 2 mlbm/hr  
 Delta W = 0

The APRM scram setpoint is less than or equal to \_\_\_\_\_ under these conditions

	Answer/Distractor	Justification
a.	54.0%	Incorrect - This answer is plausible if the operator assumes a complete loss of the flow signal.
b.	67.2%	Incorrect - This answer is plausible if the operator believes the JP flow provides the flow bias signal: $.66(W - \Delta W) + 54 = .66(18 - 2) + 54$
c.	74.0%	Correct Response - $.66(W - \Delta W) + 54 = .66(19700/65000 - 0) = 74\%$ APRM flow bias scram uses recirc drive flow signal
d.	81.5%	Incorrect - $.66(W - \Delta W) + 54 = .66(20) + 54$

References: LOI EB #1377 modified  
 T.S. Table 3.1.1

## Task Associations

Task Number	Task Title
3107190302/0	Direct Response to Recirc Pump Trip
3	

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295001	AA2.02	Ability to determine and/or interpret the following as they	3.1	3.2

		apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION:(CFR 41.10, 43.5, 45.13): Neutron monitoring		
--	--	--	--	--

Static Simulator Exams: None

Last Revised: 08/19/2003 4:00:57 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 77 Exam Bank Question No.: 5690 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-601 Objective: SRO 8

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The HPCI system is operating in full flow test for surveillance. CRP 9-8-N-2 "Batt chg fail/DC-1 GND" has been cycling in and out since HPCI was started.

The probable cause for the ground is the:

	Answer/Distractor	Justification
a.	HPCI Aux Oil Pump, HPCI surveillance can continue.	Incorrect - The HPCI aux oil pump starts on system startup and shuts down based on pressure supplied by the attached lube oil pump - will not cycle.
b.	HPCI Exhaust Blower, HPCI surveillance can continue.	Incorrect - The HPCI exhaust blower runs continuously when HPCI runs - will not cycle.
c.	HPCI Condensate Pump, HPCI should be secured.	Correct Response - The condensate pump cycles on hotwell level - on-off-on, etc. It is the probable cause of the ground which if left unattended could degrade to a fault and a loss of DC power.
d.	HPCI MOV 14 valve, HPCI should be secured.	Incorrect - MOV 14 stroked open and remains deenergized for the HPCI run - will not cycle.

References: LOT-00-203 CRO 8c, SRO

OP 2145, rev 24

ARS 9-8-N-2, rev 5

New

## Task Associations

Task Number	Task Title
2637090401	Respond to a DC Ground

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295004	AA1.01	Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF D.C.	3.3	3.4

		POWER: (CFR 41.7, 45.6): D.C. electrical distribution systems		
--	--	---	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 2:11:52 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 78 Exam Bank Question No.: 5691 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-601 Objective: SRO 8

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The plant is operating at full power when CRP 9-4-C-5 "Pump Motor A CLG WTR Flow Lo" alarms (Recirc Pump). As the CRS you would direct:

	Answer/Distractor	Justification
a.	an AO to the northeast corner room to check local indications.	Incorrect - The core spray spargers have local indications here, not the recirc pump cooling flows, which can only be seen in the drywell.
b.	an AO to the Bentley Nevada unit in the reactor building to check flow.	Incorrect - The Bentley Nevada provides many recirc data points, but none of them are pump motor cooling.
c.	the ACRO to CRP 9-21 to monitor recirc pump motor temperatures.	Correct Response - ARS 9-4-C-5
d.	the ACRO to monitor recirc pump motor cooling flows on ERFIS.	Incorrect - ERFIS does not receive a signal from the recirc pump motor cooling water flow detector.

References: ARS 9-4-C-5, rev 5  
New

## Task Associations

Task Number	Task Title
3440380302/0 3	Direct Shift Personnel Actions to Ensure Plant Safety During off Normal Conditions

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295018	AA2.04	Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER:(CFR 41.10, 43.5, 45.13): System flow	2.9	2.9

Static Simulator Exams: None

Last Revised: 09/16/2003 2:14:27 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 79 Exam Bank Question No.: 5692 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-601 Objective: SCRO (CRS) 5, 7

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Shutdown cooling has been lost due to an electrical fault on RHR 17 MOV which destroyed the valve stem.

Primary containment is open

Reactor head is on

Reactor coolant temperature is 195°F and increasing

RHR A pump is running - Torus suction and discharging to the reactor

SRV A is open

RHR B pump is running - Torus cooling

In this lineup reactor pressure must be maintained < 250 psig to protect the \_\_\_\_\_ and torus temperature must be maintained > 80°F to protect the \_\_\_\_\_.

	Answer/Distractor	Justification
a.	Main Steam Lines, RPV bottom head	Incorrect -
b.	Main Steam Lines, RPV beltline	Incorrect -
c.	SRV tailpipes, feedwater nozzles	Incorrect -
d.	SRV tailpipes, RPV head flange	Correct Response - ON 3156, page 8; Tech Specs 3.6.A.3, bases page 138, last paragraph, Figure 3.6.1

References: ON 3156, rev 6, page 8

Tech Spec 3.6

New

## Task Associations

Task Number	Task Title
2000150501	Respond to a Loss of Shutdown Cooling

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295021	AA1.02	Ability to operate and/or monitor the following as they apply to LOSS OF SHUTDOWN COOLING: (CFR 41.7, 45.6): RHR/shutdown cooling	3.5	3.5



Static Simulator Exams: None

Last Revised: 07/31/2003 10:25:45 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 80 Exam Bank Question No.: 5693 Revision: 3 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-614 Objective: SRO 1

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The "A" Main Steam Line is leaking in the drywell. The following plant conditions exist.

All control rods are in  
 Drywell temperature is 285°F and rising  
 Drywell pressure is 3.0 psig and rising  
 Drywell RRUs have been restarted  
 Reactor water level is 145"  
 Reactor pressure is 920 psig  
 Torus level is 11 ft

As the CRS you should order:

	Answer/Distractor	Justification
a.	Recirc pumps secured, drywell RRUs secured, drywell spray initiated.	Incorrect - Drywell sprays are not allowed, UNSAFE on the DWSIL curve
b.	Drywell sprays initiated.	Incorrect - Drywell sprays are not allowed, UNSAFE on the DWSIL curve
c.	RPV-ED.	Correct Response - RPV-ED is required because drywell temperature cannot be restored to < 280°F.
d.	RPV-ED and enter RPV Flooding.	Incorrect - RPV Flooding is not required. Must determine still safe on RPV Level Instrument Saturation Curve at SRV reclosing pressure of 50 psig.

References: EOP-3, rev 3

New

EOP-3 is required for student reference.

## Task Associations

Task Number	Task Title
2000210501	Respond to High Drywell Temperature

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295024	EA2.02	Ability to determine and/or interpret the following as they apply to HIGH DRYWELL PRESSURE:(CFR 41.10, 43.5, 45.13).: Drywell temperature	3.9	4.0

Static Simulator Exams: None

Last Revised: 08/19/2003 3:55:49 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 81 Exam Bank Question No.: 5694 Revision: 0 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-602 Objective: SRO 6

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A plant startup is in progress. Reactor power is 398 MWT and plant loads are on the Auxiliary Transformer. Reactor pressure is 930. The CRO reports EPR Stroke is failing to zero.

As the CRS you should direct:

	Answer/Distractor	Justification
a.	OT 3116, High Reactor Pressure, cutout EPR, lower MPR setpoint, and continue the startup.	Incorrect - Not allowed to exceed 25% CTP with a pressure regulator out of service
b.	OT 3115, Low Reactor Pressure, if unsuccessful in controlling pressure with EPR and MPR, scram the reactor.	Incorrect - Wrong procedure, misdiagnosed
c.	OT 3116, High Reactor Pressure, cutout EPR, lower MPR setpoint, and stop the startup.	Correct Response - Must diagnose that lowering EPR Stroke causes high reactor pressure. OT 3116 directs EPR cutout, and MPR setpoint lowered. When operating < 25% RTP thermal limits are suspect, proceeding > 25% is not allowed. 398 MWT = 25% CTP, Thermal Limits compliance is required to satisfy Tech Specs
d.	OT 3115, Low Reactor Pressure, go to raise on EPR to raise reactor pressure, if unsuccessful, cutout EPR, if unsuccessful with MPR, scram the reactor.	Incorrect - Wrong procedure, misdiagnosed

References: OT 3116, rev 8

OP 0105

New

## Task Associations

Task Number	Task Title
2000180501	Respond to High Reactor Pressure
3440420302/0	Direct Corrective Actions to Mitigate the Consequences of an Off Normal Event
3	

Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295025	EA2.02	Ability to determine and/or interpret the following as they apply to HIGH REACTOR PRESSURE:(CFR 41.10, 43.5, 45.13).: Reactor power	4.2	4.2

Static Simulator Exams: None

Last Revised: 08/19/2003 3:54:03 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 82 Exam Bank Question No.: 5695 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-614 Objective: SRO 1

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

An earthquake has caused an LNP and a crack in the torus. Plant conditions are as follows:

RPV level band 127"-177"

RPV pressure is 100 psig and lowering

A & B RHR Loops in torus cooling

Torus level is 8 ft lowering

CS "A" is injecting at 1000 gpm

As the CRS you should direct torus temperature monitored on:

	Answer/Distractor	Justification
a.	ERFIS - average torus water temperature	Incorrect -
b.	CRP 9-3 TI-19-33C torus water temperature	Incorrect -
c.	ERFIS - Points MO62/MO64 (RHR heat exchanger inlet temperatures)	Correct Response - ERFIS average torus temperature is preferred but at this torus level the detectors are monitoring torus air space temperature and not water temperature. The EOP Study Guide directs monitoring of points MO62/MO64.
d.	CRP 9-47 TR-16-19-40 Torus water temperature	Incorrect -

References: LOT-00-614, SRO 1

EOP Study Guide, rev 11, page 8-6

New

## Task Associations

Task Number	Task Title
2000190501	Respond to High Torus Water Temperature

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295026	2.4.03	Ability to identify post-accident instrumentation (CFR 41.6, 45.4)	3.5	3.8

Static Simulator Exams: None

Last Revised: 09/18/2003 7:12:01 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 83 Exam Bank Question No.: 5696 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-603 Objective: SRO 4

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A large fire is burning on the Turbine Building roof. Light smoke is entering the control room.

As CRS you should direct:

	Answer/Distractor	Justification
a.	OP 3126, Shutdown Using Alternate Shutdown Methods.	Incorrect - OP 3126 is used for fires in the cable vault or switchgear rooms that cause a loss of control room habitability/functionality.
b.	OP 2192, Shutdown Turbine Building HVAC.	Incorrect - Shutting down Turbine Building HVAC will not stop the smoke from entering the control room.
c.	OP 2192, Control Room HVAC Switch on CRP 9-25 to Emergency.	Correct Response
d.	OP 3020, App M, Fire in Turbine Building Area FZ-6/FZ-7/FZ-8 and the "A" EDG Room.	Incorrect - These zones are all inside the turbine building, not outside on the roof.

References: OP 2192, rev 30, Section J.2.a, Discussion Section page 4  
New

## Task Associations

Task Number	Task Title
3447020302/0	Call in Off Site Fire Department
3	

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
600000	AA1.05	Ability to operate and/or monitor the following as they apply to PLANT FIRE ON SITE:: Plant and control room ventilation systems	3.0	3.1

Static Simulator Exams: None

Last Revised: 07/25/2003 1:06:24 PM by Hallonquist, Nora E.



# SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 84** Exam Bank Question No.: 5697 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-308 Objective: SCRO 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The reactor coolant system pressure safety limit is based on the \_\_\_\_\_ and will not be exceeded during the design basis overpressure transient with \_\_\_\_\_ SRV(s) out of service.

	Answer/Distractor	Justification
a.	Pressure Vessel, 1	Correct Response - Tech Specs 1.2, 3.6
b.	Recirc Loop piping, 1	Incorrect -
c.	Pressure Vessel, 2	Incorrect -
d.	Recirc Loop piping, 2	Incorrect -

References: LOT-00-239, SCRO 1

T.S. 12, rev 160, page 19

T.S. 3.6, rev 196, page 142

New

## Task Associations

Task Number	Task Title
2000180501	Respond to High Reactor Pressure

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295007	2.2.22	Knowledge of limiting conditions for operations and safety limits (CFR 43.2, 45.2)	3.4	4.1

Static Simulator Exams: None

Last Revised: 08/12/2003 3:47:17 PM by Hallonquist, Nora E.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 85 Exam Bank Question No.: 5698 Revision: 4 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-610 Objective: SRO 3, 4

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A high reactor water level transient has occurred. Reactor water level is 250". MSIVs are shut. All high pressure injection sources are secured. Operators are attempting to control pressure with SRVs. From CRP 9-3, it appears that the SRVs are not responding to the manual actuations. No tailpipe pressure switch actuations. Pressure control is sluggish and remains > 1055 psig.

In accordance with station procedures you should direct as a minimum:

	Answer/Distractor	Justification
a.	SRV operations to stop, RPV head vents used for pressure control.	Incorrect - RPV head vents are not allowed to be used for RPV pressure control under these conditions.
b.	SRV operations to stop, RPV head vents used for pressure control, and RWCU started in the letdown mode.	Incorrect - RPV head vents are not allowed for RPV pressure control under these conditions.
c.	SRV tailpipe temperatures and primary containment parameters monitored.	Incorrect - Allowing continued SRV operations with flooded steam lines increases the potential for tailpipe damage. Actions must be taken to drain the main steam lines.
d.	SRV tailpipe temperatures and primary containment parameters monitored, and RWCU started in the letdown mode.	Correct Response - OP 3114 requires primary containment parameters to be monitored when SRVs are opened with flooded steam lines. SRV tailpipe pressure switches may not indicate open SRVs when the steam lines are flooded. OT 3114 directs monitoring tailpipe temperatures. EOP-1 pressure control leg directs use of RWCU in letdown if not fuel failure exists. This action will also lower RPV water level and reduce the potential for damage to SRV tailpipes.

References: OT 3114, rev 12

EOP-1 rev 2

1/26/2000 Plant Hatch event

New

Task Associations: 2000060501 Respond to high reactor water level

**Knowledge and Abilities Associations**

System	K/A No.	Statement	RO	SRO
295008	2.2.02	Ability to manipulate the console controls as required to operate the facility between shutdown and designated power levels (CFR 45.2)	4.0	3.5

Static Simulator Exams: None

Last Revised: 09/16/2003 4:45:53 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 86 Exam Bank Question No.: 5699 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-615 Objective: SRO 1

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

Reactor pressure is being controlled manually with SRVs. When the third SRV is opened a step increase in Primary Containment pressure occurs. Drywell pressure remains greater than torus pressure.

As the CRS you must order:

	Answer/Distractor	Justification
a.	"B" SRV to remain shut, due to a tail pipe vacuum breaker failure	Correct Response - OP 2122 requires SRVs to be opened in sequence a,c,b,d. "B" is the third SRV to be opened. The student must know this from memory. The student must then determine where the piping from the SRV to below the torus water line has failed by analyzing Primary Containment response. Drywell pressure remaining above torus pressure indicates the pressure suppression function is working and that the failure must be in the drywell.
b.	"C" SRV to remain shut, due to a tail pipe vacuum breaker failure	Incorrect -
c.	"B" SRV to remain shut ,due to a tail pipe break in the torus air space	Incorrect -
d.	"C" SRV to remain shut, due to tail pipe break in the torus air space	Incorrect -

References: P&ID G191167, 191156  
Clinton NRC 2000 MODIFIED

## Task Associations

Task Number	Task Title
2000070501	Respond to Containment Hi Pressure

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
--------	---------	-----------	----	-----

295010	AA2.02	Ability to determine and/or interpret the following as they apply to HIGH DRYWELL PRESSURE:(CFR 41.10, 43.5, 45.13): Drywell pressure	3.8	3.9
--------	--------	---	-----	-----

Static Simulator Exams: None

Last Revised: 09/16/2003 2:35:35 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 87 Exam Bank Question No.: 5700 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-261 Objective: SRO 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Which of the following is the basis for the automatic initiation of SBGT on reactor building ventilation exhaust high radiation levels?

	Answer/Distractor	Justification
a.	Provides for the maintenance of a positive pressure in the secondary containment, therefore preventing any of the fission products released into the containment from being released into the environment	Incorrect -
b.	Provides for the cleanup of the secondary containment atmosphere, allowing personnel entry into the secondary containment during a DBA LOCA	Incorrect -
c.	Provides for the recirculation of the secondary containment atmosphere without exhausting air outside of containment	Incorrect -
d.	Provides for the filtration of the secondary containment atmosphere of radionuclides prior to their release into the environment, maintaining off site releases within limits	Correct Response

References: OP 2117, rev 17, page 1

Tech Spec 3.7 Bases

Grand Gulf 1 1998 NRC

## Task Associations

Task Number	Task Title
3410320302/0 3	Evaluate Plant System Performance and Coordinate Appropriate Actions per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
295034	EK3.02	Knowledge of the reasons for the following responses as	4.1	4.1

		they apply to SECONDARY CONTAINMENT VENTILATION HIGH RADIATION: (CFR 41.5, 45.6): Starting SBTG/FRVS: Plant-specific		
--	--	--	--	--

Static Simulator Exams: None

Last Revised: 08/19/2003 3:49:54 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 88 Exam Bank Question No.: 5701 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-205 Objective: SCRO 1

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The reactor has been shutdown for 20 days. Shutdown cooling is in service. Parameters are as follows:

Reactor level 160" for I&C Surveillances

Reactor coolant temperature is 95°F

SDC flow is 4500 gpm

Under these conditions, thermal stratification:

	Answer/Distractor	Justification
a.	will not occur. Flow may be lowered to 1100 gpm before stratification is a concern.	Incorrect - 1100 gpm is the RHRSW Pump min flow limit, not a thermal stratification limit.
b.	will occur. OP 2124 directs flow raised to a minimum of 5500 gpm.	Incorrect - 4100 gpm is for pump min flow concerns, not thermal stratification. OP 2124 has no 5500 gpm limit.
c.	will not occur. Flow may be lowered to 4100 gpm.	Incorrect - Thermal stratification will occur under these conditions and that is why the procedure does not allow operation here.
d.	will occur. OP 2124 directs flow raised to 6700 gpm.	Correct Response - OP 2124

References: OP 2124, rev 50, Precaution #37  
GESIL 357

## Task Associations

Task Number	Task Title
2057970101	Swap Shutdown Cooling Loops

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
205000	A2.12	Ability to (a) predict the impacts of the following on the SHUTDOWN COOLING SYSTEM (RHR SHUTDOWN COOLING MODE); and (b) based on those predictions,	2.9	3.0



		use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Inadequate system flow		
--	--	---	--	--

Static Simulator Exams: None

Last Revised: 09/16/2003 2:37:06 PM by Brown, Scott T.

SRO NRC Exam 2003

\*\*\*\*\*

Question No. 89 Exam Bank Question No.: 5702 Revision: 2 Point Value: 1  
 SRO Only: Yes Instructor Guide: LOT-00-614 Objective: SRO 1, 2  
 Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

An earthquake has caused a breach of the reactor coolant system and the torus.

RPV-ED is complete  
 "A" Core Spray is injecting at 3500 gpm  
 Torus level is 6 ft  
 RPV level is -30" and steady  
 Torus temperature is 185°F  
 "A" and "B" RHR are running in torus cooling  
 Torus pressure is 4 psig

You \_\_\_\_\_ meet the NPSH requirements for the Core Spray Pump and by procedure  
 \_\_\_\_\_ can be used to makeup to the torus.

	Answer/Distractor	Justification
a.	do, RHRSW	Incorrect - Not safe on NPSH curve
b.	do not, RHRSW	Correct Response - NPSH is not satisfied under these conditions.
c.	do, HPCI	Incorrect - HPCI can not be run with torus level < 7 ft
d.	do not, HPCI	Incorrect - HPCI can not be run with torus level < 7 ft

References: LOT-00-610, SRO 3  
 EOP-1, rev 2  
 EOP-3, rev 3  
 EOP Study Guide 13.18, rev 11  
 EOP App T & X, rev 16  
 New

Student required reference: EOP-1, EOP-3

Task Associations

Task Number	Task Title
2000240501	Respond to Low Torus Water Level
2000310501	Respond to Low Reactor Water Level

#### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
209001	A2.09	Ability to (a) predict the impacts of the following on the LOW PRESSURE CORE SPRAY SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): Low suppression pool level	3.1	3.3

Static Simulator Exams: None

Last Revised: 09/16/2003 2:39:00 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 90 Exam Bank Question No.: 5703 Revision: 0 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-223 Objective: SRO 3

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

A plant shutdown is in progress to repair a recirc pump seal leak. Reactor power is 6%. The drywell is being purged through the 18" line to allow early primary containment entry.

This mode of operation is allowed by Technical Specifications for \_\_\_\_\_ per calendar year. This restriction assures the integrity of the \_\_\_\_\_.

	Answer/Distractor	Justification
a.	90 hours, SBT	Correct Response - Must know 90 clock of Tech Spec, must also understand the concept that on a LOCA SBT 2A/B open before the primary containment isolation valves can stroke shut. This event has the potential to rupture both SBT trains and make secondary containment unavailable. By limiting the time the 18" valves are open when containment is required, the probability of this happening is reduced to near zero.
b.	30 days, SBT	Incorrect -
c.	90 hours, Primary Containment	Incorrect -
d.	30 days, Primary Containment	Incorrect -

References: Tech Spec Bases, rev 197, page 165/166, Section 3.7

OP 2115, rev 43, page 4

New

## Task Associations

Task Number	Task Title
3410320302/0	Evaluate Plant System Performance and Coordinate Appropriate Actions
3	per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
261000	2.1.27	Knowledge of system purpose and/or function (CFR 41.7)	2.8	2.9

Static Simulator Exams: None

Last Revised: 07/25/2003 1:14:46 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 91 Exam Bank Question No.: 5704 Revision: 4 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-264 Objective: SCRO 1a

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

The plant is operating at full power. The "B" Core Spray pump is inoperable. The "A" EDG air compressor has tripped on thermal overload. Air receiver pressure is 190 psig and slowly lowering. Both receivers are in service. CRP 9-8-E-7 EDG low starting air pressure is in.

For these conditions you should declare the "A" EDG inoperable:

	Answer/Distractor	Justification
a.	Immediately, enter a 7 day LCO, and verify the other EDG is operable within 24 hours.	Incorrect -
b.	When receiver pressure is < 150 psig, enter a 7 day LCO, and verify the other EDG is operable within 24 hours.	Incorrect -
c.	Immediately, and be in cold shutdown in 24 hours.	Correct Response
d.	When receiver pressure is < 150 psig and be in cold shutdown in 24 hours.	Incorrect -

References: OP 2126, rev 33, Precaution 25  
Tech Spec 3.10  
New

Tech Spec 3.10 is a required student reference

## Task Associations

Task Number	Task Title
3410320302/0 3	Evaluate Plant System Performance and Coordinate Appropriate Actions per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
264000	K6.01	Knowledge of the effect that a loss or malfunction of the following will have on the EMERGENCY GENERATORS (DIESEL/JET): (CFR 41.7 / 45.7):	3.8	3.9

Static Simulator Exams: None

Last Revised: 09/16/2003 2:43:15 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 92 Exam Bank Question No.: 5705 Revision: 3 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-205 Objective: SCRO 1

Question Level: Comprehension

\*\*\*\*\*

Select the correct answer:

When the "A" RHR Loop is placed in torus cooling OP 2124 (RHR) procedure requires a \_\_\_\_\_ LCO to be entered.

When the second loop of torus cooling is placed in service, a \_\_\_\_\_ LCO is entered.

These actions reduce the potential challenges to the RPV water level safety limit of \_\_\_\_\_ inches above top of enriched fuel.

	Answer/Distractor	Justification
a.	7 day, 24 hour, 12"	Correct Response - The LCOs are required by procedure to ensure LPCI availability. The concern is a loss of power to the torus cooling valves.
b.	7 day, 24 hour, 6"	Incorrect -
c.	30 day, 7 day, 12"	Incorrect -
d.	30 day, 24 hour, 6"	Incorrect -

References: Tech Spec 3.7.A.1, rev 192

OP 2124, rev 50, Precaution 41

New

Tech Spec 3.7 is a required student reference

## Task Associations

Task Number	Task Title
3410320302/0 3	Evaluate Plant System Performance and Coordinate Appropriate Actions per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied
3440470302/0 3	Clarify Technical Specifications/TRM/ODCM and Application of Action Statement Requirements

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
230000	2.2.25	Knowledge of bases in technical specifications for limiting conditiond for operations and safety limits (CFR 43.2)	2.5	3.7



Static Simulator Exams: None

Last Revised: 09/16/2003 2:51:44 PM by Brown, Scott T.

## SRO NRC Exam 2003

\*\*\*\*\*

Question No. 93 Exam Bank Question No.: 5706 Revision: 3 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-233 Objective: SRO 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

Refueling is in progress. Shutdown cooling is out of service for MOV testing of RHR 17 & 18. Fuel pool temperature is 118°F and rising. RBCCW cooling has been maximized.

Prior to \_\_\_\_\_°F normal fuel pool cooling should be secured and standby fuel pool cooling started. Refueling operations tending to raise fuel pool temperature must be stopped when \_\_\_\_\_°F is reached.

	Answer/Distractor	Justification
a.	140, 150	Correct Response - Tech Spec 3.12 page 236 150°F; OP 2184 Precaution 9 140°F
b.	120, 150	Incorrect -
c.	140, 170	Incorrect -
d.	120, 170	Incorrect -

References: OP 2184, rev 22, Precaution 9  
Tech Spec 3.12  
New

Tech Spec 3.12 is a required student reference

### Task Associations

Task Number	Task Title
2337140401	Respond to Fuel Pool Cooling System Alarms
3410320302/0	Evaluate Plant System Performance and Coordinate Appropriate Actions
3	per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
233000	A2.07	Ability to (a) predict the impacts of the following on the FUEL POOL COOLING AND CLEAN-UP; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: (CFR 41.5 / 45.6): High fuel pool temperature	3.0	3.2

Static Simulator Exams: None

Last Revised: 09/16/2003 2:52:52 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 94 Exam Bank Question No.: 5707 Revision: 0 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-308 Objective: SCRO (CRS) 1

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

The MSIVs are shut. The reactor is critical in accordance with OP 0105, Appendix A, "Reactor Heatup with the MSIVs Closed."

Which one of the following defines the Tech Spec mode of operation?

	Answer/Distractor	Justification
a.	Startup	Incorrect -
b.	Hot Standby	Correct Response - Tech Spec definition 1.0.C
c.	Startup/Hot Standby	Incorrect -
d.	Run	Incorrect -

References: Tech Spec definitions

New

## Task Associations

Task Number	Task Title
3410320302/0 3	Evaluate Plant System Performance and Coordinate Appropriate Actions per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.1.22	Ability to determine Mode of Operation (CFR 43.2, 45.13)	2.8	3.3

Static Simulator Exams: None

Last Revised: 07/25/2003 1:24:08 PM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 95** Exam Bank Question No.: 5708 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-138 Objective: 22, 24

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

Core flow is 60%. The recirculation motor generator scope tube mechanical stops are set for 109.5% speed. MCPR Option "A" has been selected based on full core scram times. Core exposure is 11,000 MWd/St. The MCPR operating limit is:

	Answer/Distractor	Justification
a.	1.49	Incorrect - Incorrect exposure used
b.	1.61	Incorrect - Correct for full flow
c.	1.64	Incorrect - Incorrect exposure used
d.	1.77	Correct Response - From COLR Table 2.2-1: Option A > 10,375 MWd/ST, MCPR = 1.61; From Figure 2.2-1: 60% flow intersects 109.5 at 1.1 $(1.1)(1.61) = 1.771$

References: COLR, rev 0, Cycle 23

Tech Spec

New

COLR is a required student reference

### Task Associations

Task Number	Task Title
3410320302/0	Evaluate Plant System Performance and Coordinate Appropriate Actions
3	per Technical Specifications/TRM/ODCM in the Event A Limiting Condition for Operation is Entered or not Satisfied

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.1.25	Ability to obtain and interpret station reference materials such as graphs, monographs, and tables which contain performance data (CFR 41.10, 43.5, 45.12)	2.8	3.1

Static Simulator Exams: None

Last Revised: 09/16/2003 2:54:41 PM by Brown, Scott T.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 96 Exam Bank Question No.: 5709 Revision: 0 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-400 Objective: SCRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

RPS "A" System has been tripped for replacement of backup scram relay contacts. The work party has informed the Shift Manager that work is complete and the equipment can be returned to service. The RPS A trip can be reset under \_\_\_\_\_ to allow the post maintenance testing required to demonstrate its operability provided that \_\_\_\_\_ is completed first.

	Answer/Distractor	Justification
a.	administrative controls, all other testing	Correct Response - AP 0125 Section 5.2
b.	Local Permissive Test Tags, all other testing	Incorrect -
c.	administrative controls, resistance testing	Incorrect -
d.	Local Permissive Test Tags, resistance testing	Incorrect -

References: AP 0125, rev 12, Admin Limit 5.2

New

## Task Associations

Task Number	Task Title
3420180302/0 3	Assist in Evaluating the Progress of Maintenance on Technical Specifications/TRM/ODCM or Safety Related Equipment

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.2.21	Knowledge of pre-and post maintenance operability requirements (CFR 43.2)	2.3	3.5

Static Simulator Exams: None

Last Revised: 07/25/2003 1:26:06 PM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

Question No. 97 Exam Bank Question No.: 5710 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-223 Objective: SRO 3

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

OP 2115 Figure 2 provides a graph of purge flow rate verses purge time for the drywell and torus. This minimum purge time for a given flow rate:

	Answer/Distractor	Justification
a.	allows temperatures to stabilize.	Incorrect -
b.	minimizes the amount of nitrogen used.	Incorrect -
c.	helps ensure oxygen is below Tech Spec requirements.	Correct Response - LER 271-97011; OP 2115
d.	helps ensure the purge vaporizers are not overloaded.	Incorrect -

References: OP 2115, rev 43  
New

## Task Associations

Task Number	Task Title
2230020104	Purge Containment with Nitrogen (Inerting)
3450150102/0	Direct Purge/Vent of the Containment Building
3	

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.3.09	Knowledge of the process for performing a containment purge (CFR 43.2, 45.10)	2.5	3.4

Static Simulator Exams: None

Last Revised: 07/25/2003 1:26:58 PM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 98** Exam Bank Question No.: 5711 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-404 Objective: SRO 1

Question Level: Analysis

\*\*\*\*\*

Select the correct answer:

A point source in the reactor building is reading 500 mr/hr at a distance of two (2) feet. Two options exist to complete rework on a valve located near this radiation source.

Option 1: Operator "X" can perform the task in thirty (30) minutes working at a distance of four (4) feet from the point source

Option 2: Operators "X" and "Y", who are trained in the use of a special extension tool, can perform the task in seventy five (75) minutes at a distance of eight (8) feet from the point source

Which one of the following options is preferable and consistent with the ALARA program?

	Answer/Distractor	Justification
a.	Option 1, since "X" would receive 31.25 mRem	Incorrect -
b.	Option 1, since "X" would receive 62.5 mRem	Correct Response - Inverse square rule x time x 1
c.	Option 2, since the exposure per person is 39.06 mRem	Incorrect -
d.	Option 2, since the exposure per person is 78.12 mRem	Incorrect -

References: LOT-00-059, rev 6, page 5 of 12  
Palisades 2001 NRC

### Task Associations

Task Number	Task Title
3430290302/0	Assess Exposure Limits of Personnel for Assigned Duties
3	

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.3.10	Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure (CFR 43.4, 45.10)	2.9	3.3



Static Simulator Exams: None

Last Revised: 08/19/2003 3:44:38 PM by Hallonquist, Nora E.

## SRO NRC Exam 2003

\*\*\*\*\*

Question No. 99 Exam Bank Question No.: 5712 Revision: 2 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-900 Objective: SRO 1, 4

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

AT 12:00 the plant experiences a full power ATWS with no control rod motion after initiation of ARI/RPT.

As the Plant Emergency Director (PED) you should classify this event no later than \_\_\_\_\_ and you should notify outside authorities no later than \_\_\_\_\_ minutes after the classification is made.

	Answer/Distractor	Justification
a.	12:15, 15	Correct Response
b.	12:15, 30	Incorrect -
c.	12:30, 15	Incorrect -
d.	12:30, 30	Incorrect -

References: DP 0093, rev 2, Appendix A page 3

New

### Task Associations

Task Number	Task Title
3440170302/0 3	Analyze Indications to Determine that an Emergency Plan Event is in Progress

### Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.4.40	Knowledge of the SRO's responsibilities in emergency plan implementation (CFR 45.11)	2.3	4.0

Static Simulator Exams: None

Last Revised: 07/31/2003 10:49:28 AM by Hallonquist, Nora E.

# SRO NRC Exam 2003

\*\*\*\*\*

**Question No. 100** Exam Bank Question No.: 5713 Revision: 1 Point Value: 1

SRO Only: Yes Instructor Guide: LOT-00-900 Objective: SRO (CRS) 1, 4

Question Level: Fundamental Knowledge/Memory

\*\*\*\*\*

Select the correct answer:

An alert EAL was declared 35 minutes ago. You are the Plant Emergency Director (PED). The Operations Support Center (OSC) and the Technical Support Center (TSC) are manned and have relieved you of your responsibilities. The Emergency Operations Facility (EOF) has not assumed any responsibilities yet.

An escalation to the Site Area Emergency is made by the OSC Coordinator/TSC Coordinator/PED. Who is responsible to notify the states?

	Answer/Distractor	Justification
a.	PED	Correct Response
b.	OSC Coordinator	Incorrect - The OSC does not have an NAS Orange phone
c.	TSC Coordinator	Incorrect - The TSC does not have an NAS Orange phone
d.	Site Recovery Manager	Incorrect - The EOF does have an NAS Orange phone but they have not yet assumed responsibility for states notifications.

References: OP 3540, rev 3, page 5 of 16

## Task Associations

Task Number	Task Title
3440390302/0 3	Perform Required Notifications of On Site and Off Site Personnel for Off Normal Events

## Knowledge and Abilities Associations

System	K/A No.	Statement	RO	SRO
0	2.4.43	Knowledge of emergency communications systems and techniques (CFR 45.13)	2.8	3.5

Static Simulator Exams: None

Last Revised: 07/25/2003 1:30:16 PM by Hallonquist, Nora E.