



Progress Energy

Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

November 11, 2003
3F1103-01

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001


Subject: Crystal River Unit 3 – Monthly Operating Report

Dear Sir:

Progress Energy Florida, Inc. hereby submits the Crystal River Unit 3 (CR-3) October 2003 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,



J. A. Franke
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE November 3, 2003
COMPLETED BY J. E. Lane *JEL*
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year): October 2003

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	860		
2 MAXIMUM DEPENDABLE CAPACITY (Mwe-Net)	834		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	73.5	6,624.5	164,739
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	72.0	6,623.0	162,438
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	44,698	5,505,200	126,774,771

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302
 UNIT NAME FLCRP-3
 DATE November 3, 2003
 COMPLETED BY J. E. Lane
 TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD: October 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
						Comments
03-01	10/4/2003	S	672.98	C	1	Shutdown for Refuel Outage 13.

SUMMARY:

Crystal River Unit 3 shutdown on 10/4/03 to start Refuel Outage 13. The unit is expected to return to service in the early part of November.

(1) Reason:

- A-EQUIPMENT FAILURE (Explain)
- B-MAINTENANCE OR TEST
- C-REFUELING
- D-REGULATORY RESTRICTION
- E-OPERATOR TRAINING / LICENSE EXAMINATION
- F-ADMINISTRATIVE
- G-OPERATIONAL ERROR (Explain)
- H-OTHER (Explain)

(2) Method

- 1-MANUAL
- 2-MANUAL TRIP / SCRAM
- 3-AUTO TRIP / SCRAM
- 4-CONTINUATION
- 5-OTHER (Explain)