

From: Leon Whitney  
To: Charles R. Ogle; Phil Qualls  
Date: 8/7/02 3:43PM  
Subject: Manual Actions at Harris

Ed,

Phil and I talked to Chuck Ogle of RII. He described a violation closeout during which the inspector discovered both A and B train unprotected redundant shutdown components in an alternative shutdown room (its own separate fire area as part of the violation corrective action). The licensee told RII that in May they had talked to Ed Connell about this and (of course the licensee then said) Mr. Connell said it was OK to have manual actions instead of barriers in III.G.2 areas.

Could you please inform all of us as to what actually transpired in your interactions with the Harris licensee? Chuck needs to decide on calling a conference call with the licensee, HQ and RII to help them sort out this technical issue.

Leon

CC: EWW; JNH

N/6