

NOV 17 2003

LR-N03-0470



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 2  
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **October 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Fricker", written over a horizontal line.

Carl J. Fricker  
Salem Plant Manager

Attachments

C Distribution

IE24

DOCKET NO.: 50-311  
 UNIT: Salem 2  
 DATE: 11/11/03  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period October 2003

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1131		
1092		
Month	Year-to-date	Cumulative
212	6553	126969
212	6520	123478
0	0	0
233103	7205179	126394154

### UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
3	10/9/03 - 10/31/03	S	533 Hrs.	C	1	Refuel Outage

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-311  
UNIT: Salem 2  
DATE: 11/11/03  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

**Summary Of Monthly Operating Experience**

- Salem 2 entered the month at approximately 100% power and remained there until October 9, when the unit was shutdown for a refueling outage.
- Salem 2 remained in the refueling outage at the end of the month.