



November 25, 2003

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
License Amendment Request: Revision to Technical Specification P-T Curves

REFERENCE: (a) Letter from P. E. Katz (CCNPP) to Document Control Desk (NRC),
dated May 28, 2003, License Amendment Request: Revision to
Technical Specification P-T Curves

In Reference (a), Calvert Cliffs Nuclear Power Plant requested an amendment to the Renewed Operating Licenses to revise the Unit 1 and Unit 2 cooldown curves, to change the range of temperatures for which a cooldown rate of 100°F/hr is acceptable. We request a delay in the implementation of this amendment for 120 days after approval to support Unit 1 2004 refueling outage activities.

This information does not affect the Determination of Significant Hazards or the Environmental Assessment in the referenced letter.

ADD1

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,




STATE OF MARYLAND :
 : TO WIT:
COUNTY OF CALVERT :

I, Bruce S. Montgomery, being duly sworn, state that I am Manager - Engineering Services for Calvert Cliffs Nuclear Power Plant, Inc. (CCNPP), and that I am duly authorized to execute and file this License Amendment Request on behalf of CCNPP. To the best of my knowledge and belief, the statements contained in this document are true and correct. To the extent that these statements are not based on my personal knowledge, they are based upon information provided by other CCNPP employees and/or consultants. Such information has been reviewed in accordance with company practice and I believe it to be reliable.



Subscribed and sworn before me, a Notary Public in and for the State of Maryland and County of Calvert, this 25th day of November, 2003.

WITNESS my Hand and Notarial Seal:


Notary Public

My Commission Expires:

January 1, 2003
Date

GV/PSF/bjd

cc: J. Petro, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
G. S. Vissing, NRC

H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR

