

Exelon Generation  
4300 Winfield Road  
Warrenville, IL 60555

www.exeloncorp.com

RS-03-225

November 25, 2003

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Dresden Nuclear Power Station, Units 2 and 3  
Facility Operating License Nos. DPR-19 and DPR-25  
NRC Docket Nos. 50-237 and 50-249

Subject: Partial Withdrawal of Request for Changes Related to Technical Specifications Section 3.4.9, "Reactor Coolant System Pressure and Temperature (P/T) Limits"


Reference: Letter from P. R. Simpson (Exelon Generation Company, LLC) to U. S. NRC, "Request for Changes Related to Technical Specifications Section 3.4.9, 'Reactor Coolant System Pressure and Temperature (P/T) Limits'"

In the referenced letter, Exelon Generation Company, LLC (EGC) requested an amendment to Facility Operating License Nos. DPR-19 and DPR-25 for Dresden Nuclear Power Station (DNPS), Units 2 and 3. The proposed change revises Technical Specification 3.4.9, "Reactor Coolant System Pressure and Temperature (P/T) Limits," to incorporate revised P/T limits curves for both 32 and 54 effective full power years (EFPY). In addition, the proposed change deletes license conditions specified in Facility Operating License Sections 2.C(8) and 3.P for DNPS Units 2 and 3, respectively.

EGC, after recent discussions with the NRC, has decided to partially withdraw the referenced amendment request. Specifically, EGC is withdrawing the 54 EFPY curves from the scope of the request. The proposed 54 EFPY curves would not have become effective prior to the expiration dates of the current operating licenses for DNPS Units 2 and 3.

Should you have any questions concerning this letter, please contact Mr. Kenneth M. Nicely at (630) 657-2803.

Respectfully,



Patrick R. Simpson  
Manager – Licensing

cc: Regional Administrator – NRC Region III  
NRC Senior Resident Inspector – Dresden Nuclear Power Station  
Illinois Emergency Management Agency – Division of Nuclear Safety

A001