

## REACTOR COOLANT SYSTEM

### OPERATING

#### LIMITING CONDITION FOR OPERATION

---

3.4.2.2 All pressurizer Code safety valves shall be OPERABLE with a lift setting<sup>1</sup> of 2485 psig + 2%, - 3%.<sup>2</sup>

APPLICABILITY: MODES 1, 2, and 3.

#### ACTION:

With one pressurizer Code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 1 hour or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.4.2.2 No additional requirements other than those required by Specification 4.0.5.

---

<sup>1</sup>The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

<sup>2</sup>The as left lift setting shall be within  $\pm 1\%$  following valve testing.