

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

Re: 10 CFR 2.202

December 5, 2003

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Serial No.: 03-571A
NL&OS/ETS R0
Docket Nos.: 50-280/281
License Nos.: DPR-32/37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
SURRY POWER STATION UNITS 1 AND 2
ORDER FOR INTERIM INSPECTION REQUIREMENTS FOR REACTOR PRESSURE
VESSEL HEADS AT PRESSURIZED WATER REACTORS
PRESERVICE INSPECTION OF REPLACEMENT REACTOR PRESSURE VESSEL
HEAD AND PRESSURE RETAINING COMPONENTS ABOVE THE RPV HEAD

On February 11, 2003, the Nuclear Regulatory Commission (NRC) issued an Order for Interim Inspection Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactor licensees. The Order requires specific inspection of the reactor pressure vessel (RPV) head and associated penetration nozzles at pressurized water reactors (PWRs). The Commission stated that the actions in the Order are interim measures that are necessary to ensure that licensees implement and maintain appropriate measures to inspect and, as necessary, repair RPV heads and associated penetration nozzles. The Order required that licensees immediately start implementation of the requirements of the Order and report the results of the required inspections. As required by Section IV.E of the Order, Virginia Electric and Power Company (Dominion) is providing the results of the preservice inspection of the Surry Units 1 and 2 replacement RPV heads and pressure retaining components above the RPV head.

During the 2003 refueling outages, the Surry Units 1 and 2 reactor vessel heads were replaced. Prior to the replacement, the new heads were inspected to satisfy ASME Section XI requirements for pre-service inspection and to establish a baseline for future anticipated inspections required by ASME Code or that might be required by future regulation. The inspections conducted for the ASME Code preservice requirement included ultrasonic (UT) and magnetic particle (MT) examination of the head dome to flange weld for Surry Unit 1 (Surry Unit 2 is a one-piece forged construction RPV head) and liquid penetrant (LP) examination of the control rod drive mechanism (CRDM) housing to CRDM adapter welds. In addition, non-Code required examinations were performed on the RPV heads. Each CRDM housing to head weld was LP inspected and each CRDM housing was UT inspected from the bottom of the housing to above

A101

the top surface of the head (at least 2 inches above the housing to head weld). Furthermore, each CRDM housing to CRDM adapter weld was UT inspected. No relevant indications were noted. These examinations comply with and exceed the requirements of the NRC Order (EA-03-009).

Although a formal bare-metal visual examination was not specifically performed on the Surry Unit 1 replacement RPV head, the replacement head was observed during the above referenced NDE examinations, cleaning and packaging activities, as well as during subsequent activities associated with head installation (e.g., CRDM canopy seal and RCS vent line welding and installation of the new insulation package). During these activities, it was noted that the replacement head and the pressure-retaining components above the RPV head were clean and free of any evidence of corrosion, boric acid residue, or any other condition that could either interfere with any future bare-metal visual examination or complicate the interpretation of the results of a future bare-metal visual examination. These observations included 100% of the surface of the head including 360° around each head penetration. Separately, a formal bare-metal visual examination was performed on the Surry Unit 2 replacement RPV head. Consequently, we conclude that we are in compliance with the Order (EA-03-009) relative to the initial bare-metal visual inspections for both Surry Units 1 and 2.

If you have any questions, please contact Mr. Thomas Shaub at (804) 273-2763.

Very truly yours,

A handwritten signature in black ink, appearing to read "L. Hartz", with a stylized flourish at the end.

Leslie N. Hartz
Vice President – Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Federal Atlanta Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, GA 30303

Mr. G. J. McCoy
NRC Senior Resident Inspector
Surry Power Station

Mr. C. Gratton
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8-G9
Rockville, MD 20852

Mr. R. A. Smith
Authorized Nuclear Inspector
Surry Power Station

Subject: Response to RPV Head and Penetration Nozzles Inspection Order

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by Leslie N. Hartz who is Vice President – Nuclear Engineering of Virginia Electric and Power Company. She has affirmed before me that she is duly authorized to execute and file the foregoing document in behalf of that Company, and that the statements in the document are true to the best of her knowledge and belief.

Acknowledged before me this 5th day of December, 2003.

My Commission Expires: 3/31/04.

Maggie McClure
Notary Public

