



Progress Energy

Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

December 9, 2003
3F1203-01

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Crystal River Unit 3 – Monthly Operating Report

Dear Sir:

Progress Energy Florida, Inc. hereby submits the Crystal River Unit 3 (CR-3) November 2003 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. A. Franke', written over a horizontal line.

J. A. Franke
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

Progress Energy Florida, Inc.
Crystal River Nuclear Plant
15760 W. Powerline Street
Crystal River, FL 34428

JE24

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE December 1, 2003
COMPLETED BY J. E. Lane *JEL*
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year):

November 2003

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	860		
2 MAXIMUM DEPENDABLE CAPACITY (MWe-Net)	834		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	587.9	7,212.4	165,327
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	554.3	7,177.3	162,993
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	444,060	5,949,259	127,218,830

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302
 UNIT NAME FLCRP-3
 DATE December 1, 2003
 COMPLETED BY J.E. Lane
 TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD: November 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
						Comments
03-01	11/1/2003	S	108.3	C	1	Continuation of Refuel Outage 13.
03-02	11/5/2003	F	19.8	A	3	Reactor trip due to Reactor Coolant System reaching high pressure trip setpoint. The cause was traced to an electronic card installed in the Integrated Control System which drove the "B" Main Feedwater pump speed to zero.
03-03	11/7/2003	F	37.6	A	1	The plant shutdown to replace the stator for Control Rod Drive 2-1. Cooling water to the stator was lost after a quick disconnect separated.

SUMMARY:

Crystal River Unit 3 started up from Refuel Outage 13 on 11/5/2003. During startup, a reactor trip occurred due to the Integrated Control System. During startup from the Integrated Control System problem on 11/6/2003, cooling was lost to the stator for Control Rod Drive 2-1. The plant shut down to repair the stator on 11/7/2003. The plant started up on 11/7/2003 after repairing the Control Rod Drive problem.

(1) Reason:

A-EQUIPMENT FAILURE (Explain)
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING / LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR (Explain)
 H-OTHER (Explain)

(2) Method:

1-MANUAL
 2-MANUAL TRIP / SCRAM
 3-AUTO TRIP / SCRAM
 4-CONTINUATION
 5-OTHER (Explain)