



DEC 1 0 2003

SERIAL: HNP-03-138

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
MONTHLY OPERATING REPORT

Ladies and Gentlemen:

In accordance with Technical Specification 6.9.1.5 for Progress Energy Carolinas, Inc's Harris Nuclear Plant, the report of operating statistics and shutdown experience for the month of November 2003 is provided.

Sincerely,

A handwritten signature in black ink that reads 'John R. Caves'.

John R. Caves
Supervisor, Licensing/Regulatory Programs
Harris Nuclear Plant

MGW/mgw

Enclosure

c: Mr. R. A. Musser (NRC Senior Resident Inspector, HNP)
Mr. L. A. Reyes (NRC Regional Administrator, Region II)
Mr. C. P. Patel (NRC Project Manager, HNP)

Progress Energy Carolinas, Inc.
Harris Nuclear Plant
P.O. Box 165
New Hill, NC 27562

Handwritten initials 'JED4' in black ink, located in the bottom right corner of the page.

OPERATING DATA REPORT

DOCKET NO. 050-400
UNIT NAME Shearon Harris Nuclear Power Plant
DATE December 8, 2003
COMPLETED BY Charles L. George
TELEPHONE (919) 362-2937

REPORTING PERIOD November 2003
(Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net)	941.7	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	900.0	N/A	N/A
3. Number of Hours the Reactor Was Critical:	720.0	7,421.0	125,400.1
4. Number of Hours the Generator Was On Line:	720.0	7,338.6	124,287.5
5. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6. Net Electrical Energy (MWH):	668,416.0	6,541,505.0	105,104,018.0

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 050-400
UNIT NAME Shearon Harris Nuclear Power Plant
DATE December 8, 2003
COMPLETED BY Charles L. George
TELEPHONE (919) 362-2937

REPORTING PERIOD

November 2003
(Month/Year)

NO.	DATE (yyymmdd)	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

SUMMARY: There were no significant events to report for the month of November, 2003.
The plant operated at full power for the entire reporting period.

(1) Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method:

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)