



FRAMATOME ANP

Realistic LBLOCA Methodology Roadmap

***L. D. O'Dell, Manager
Research and Development Richland***

***December 9, 2003
Washington, D.C.***

Realistic LBLOCA Methodology Roadmap

- > Purpose: The Methodology Roadmap provides an upper level overview of the complete methodology**

Realistic LBLOCA Methodology Roadmap

- > Agenda**
 - ♦ Methodology Roadmap**
 - Requirements and Capabilities**
 - CSAU Element 1, Steps 1 through 6**
 - Assessment and Ranging of Parameters**
 - CSAU Element 2, Steps 7 through 10**
 - Sensitivity and Uncertainty Analysis**
 - CSAU Element 3, Steps 11 through 14**

Requirements and Code Capabilities (CSAU Element 1)

- > **Specify Scenario (CSAU Step 1)**
 - ♦ *Selection of the transient to be analyzed dictates the processes that must be addressed*
 - *Specified the large break LOCA scenario*
- > **Select Plant (CSAU Step 2)**
 - ♦ *Selection of plant type influences the dominant phenomena and their interactions*
 - *Selected W 3- and 4-loop plants and CE plants*
 - *All three plant types have inverted U-tube steam generators, a pressurizer connected to a hot leg, and ECCS injection into the cold legs*
 - *Experience with Appendix K LBLOCA analyses indicate that all three plant types behave similarly in the blowdown, refill, and reflood phases of a LBLOCA*

A
FRAMATOME ANP

Requirements and Code Capabilities (CSAU Element 1)

- > **Identify and Rank Phenomena (CSAU Step 3)**
 - ♦ **Develop Process Identification and Ranking Table (PIRT)**
 - *Performed by experts who are knowledgeable of specified LBLOCA scenario*
 - *Initial PIRT developed from Compendium*
 - *Average of expert and analytical hierarchy process*
 - *Reviewed by three independent experts who recommended additional phenomena and ranking changes*
 - *Final PIRT generated through peer review (Table 3.4 of EMF-2103(P))*
 - *Framatome ANP personnel*
 - *External experts (Dr. Hochreiter and M. J. Thurgood)*
 - *Consistent definitions applied for LBLOCA phases and phenomena*

A
FRAMATOME ANP

Requirements and Code Capabilities (CSAU Element 1)

- > Select Frozen Codes (CSAU Step 4)**
 - ◆ **Frozen versions of computer codes used for consistency throughout process**
 - **Selected frozen versions of RODEX3A and S-RELAP5**
 - ICECON containment code included in S-RELAP5
- > Provide Complete Documentation (CSAU Step 5)**
 - ◆ **Documentation supporting the codes must be consistent with the frozen code versions**
 - **Developed models and correlations document, programmers guide, and user manuals for frozen codes**
 - **Code verification performed to insure consistency between codes and associated documentation**

7

A
FRAMATOME ANP

Requirements and Code Capabilities (CSAU Element 1)

- > Determine Code Applicability (CSAU Step 6)**
 - ◆ **Confirm presence of code models for important phenomena in PIRT**
 - **Verification performed on S-RELAP5 confirmed presence of documented models**
 - **Presence of PIRT required conservation and closure equations confirmed in S-RELAP5**
 - **Code numerics demonstrated through the performance of code sensitivity studies, assessments, and sample problem analyses**
 - **Code ability to model selected NPP confirmed by comparison of required NPP components and code component modeling capabilities**
 - ◆ **S-RELAP5 demonstrated applicable to LBLOCA**

8

A
FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Assessment Matrix (CSAU Step 7)

- ◆ *Select assessment matrix of separate and integral effect tests (SET/IET)*
 - *Support code evaluation of Important PIRT phenomena*
 - *Provide validation of selected NPP nodalization*
 - *Support demonstration of code scalability from experimental facilities to NPP*
 - *Support demonstration that even if compensating errors exist in the code, the code is capable of reliably predicting the selected scenario*


Assessment and Ranging of Parameters (CSAU Element 2)

> Assessment Matrix (CSAU Step 7)


- ◆ *PIRT Phenomena*
 - *Sensitivity analyses were performed for all 44 phenomena ranked 5 or higher*
 - *Over 250 analyses performed using the 3 and 4-loop NPP models*

- *Based on the sensitivity studies evaluation*
 - *Experimental facilities and specific tests were chosen for the important phenomena*
 - *Required plant data identified*

**Assessment and Ranging of Parameters
(CSAU Element 2)**



**Assessment and Ranging of Parameters
(CSAU Element 2)**



Assessment and Ranging of Parameters (CSAU Element 2)

Assessment and Ranging of Parameters (CSAU Element 2)

> Assessment Matrix (CSAU Step 7)

◆ Nodalization

- *Based on the assessment matrix generated from the PIRT, only the SCTF was added to specifically address nodalization*

◆ Scaling Considerations

- *The assessment matrix generated for the PIRT covered a scaling range from 1:1500 to 1:1*
- *Counter part LOFT and Semiscale Integral effect tests were selected to specifically support scaling*

Assessment and Ranging of Parameters (CSAU Element 2)

> Assessment Matrix (CSAU Step 7)

◆ Compensating Errors

- Occur if/when an error in one code model is compensated for by an error in another code model
- May result in the code being able to predict some assessments but not others or produce different results in the assessments and the NPP calculations
- Addressed by including integral effect and larger scale separate effect tests in the assessment matrix that covered a wide range of PCT's
 - FLECHT, FLECHT-SEASET, SCTF, CCTF, and THTF for core phenomena
 - UPTF for most other NPP components
 - LOFT and Semiscale for Integral LBLOCA scenario evaluation

Assessment and Ranging of Parameters (CSAU Element 2)

> Final Assessment Matrix

<u>Facility</u>	<u>Tests</u>	<u>Purpose</u>
THTF Heat Transfer	35	Heat transfer
THTF Level Swell	3	Void distributions
GE Level Swell	1	Void distributions
FRIGG-2	27	Void distributions
Bennett Tube	2	Heat transfer
FLECHT-SEASET and FLECHT	9	Heat transfer, Nodalization, Axial power distributions, Scalability, Upper plenum and hot leg entrainment
PDTF/SMART	4	Spacer effects
Marviken	9	Break flow

Assessment and Ranging of Parameters (CSAU Element 2)

> Final Assessment Matrix (continued)

<u>Facility</u>	<u>Tests</u>	<u>Purpose</u>
W/EPRI 1/3 Scale	9	Cold leg condensation, Interfacial heat transfer
Mini-loop CCFL	3	Upper tie plate CCFL
Multi-dimensional flow	3	Core flow distributions
UPTF	14	ECCS bypass, Steam binding, CCFL, Scalability, Nodalization
CCTF	4	Steam binding, Nodalization, Scalability
SCTF	6	Nodalization
ACHILLES	1	Accumulator nitrogen discharge

17

A
FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Final Assessment Matrix (continued)

<u>Facility</u>	<u>Tests</u>	<u>Purpose</u>
LOFT	4	Overall code performance, Nodalization, Scalability, Compensating errors
Semiscale	2	Blowdown heat transfer, Nodalization, Scalability, Compensating errors

18

A
FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Final Assessment Matrix

- ◆ **15 SET facilities and 130 tests**
- ◆ **2 IET facilities and 6 tests**
- ◆ **Facility scaling ranged from 1:1500 to 1:1**
- ◆ **Maximum assessment PCT of 2218 F**

19


FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Nodalization (CSAU Step 8)

- ◆ **Select common nodalization for use in SET, IET, and plant analyses**
 - **Selected nodalization must**
 - **Preserve dominant phenomena**
 - **Minimize code uncertainty**
 - **Support NPP design characteristics**
 - **Remain economical**

20


FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Nodalization (CSAU Step 8)

- ◆ Select common nodalization for use in SET, IET, and plant analyses
 - Initial nodalization selected based on previous industry and Framatome ANP experience
 - Revised based on initial plant model studies
 - Further revised based on peer review
 - Final nodalization validated/refined based on performance of SET and IET assessments
 - UPTF, SCTF, CCTF, and FLECHT-SEASET
 - LOFT and Semiscale
 - Key features of the RLBLOCA plant nodalization is the use of 2-dimensional components in the reactor vessel model
 - Downcomer
 - Core
 - Upper plenum

21


FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)


> Nodalization (CSAU Step 8)

- ◆ Select common nodalization for use in SET, IET, and plant analyses

22


FRAMATOME ANP


Core Axial Nodalization Study



23

FRAMATOME ANP

Core Radial Nodalization Study



CALC ID: 47872
CALC ID: 91197
DATA ID: 10071

24

FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Code and Experiment Accuracy (CSAU Step 9)

- ◆ **Determine individual parameter uncertainty for identified important PIRT phenomena**
 - **Code model biases and uncertainties determined by comparison of code to SET experiments defined in Assessment matrix**
 - **Code model biases confirmed through the performance of independent SET and IET analyses with biases applied**
 - CCTF tests 54, 62, 67, and 68
 - LOFT tests L2-3, L2-5, LP-02-6, and LP-LB-1
 - Semiscale tests S-06-3 and S-07-1

25


ARAMATOME ANP


Dispersed Flow Film Boiling

> Applied Biases

26


ARAMATOME ANP


CCTF TEST 54 Temperatures at Measured PCT Node



A
FRAMATOME ANP

27


CCTF TEST 54 Temperatures Near Calculated PCT Node



A
FRAMATOME ANP


28

CCTF TEST 54 PCT Profile



FRAMATOME ANP

LOFT LP-LB-1 Temperatures at Measured PCT Node




FRAMATOME ANP

LOFT LP-LB-1 PCT Profile

LOFT LP-LB-1 S-RELAP5 ANALYSIS REPORT FILE NAME: LOFT_LP-LB-1_S-RELAP5_ANALYSIS.DAT DATE: 11/20/98 10:00 AM P01 2001

LOFT LP-LB-1 S-RELAP5 ANALYSIS




31

A
FRAMATOME ANP

Semiscale S-07-1 PCT Profile

SEMISCALE S-07-1 S-RELAP5 ANALYSIS

Semiscale S-07-1 S-RELAP5 ANALYSIS



32

A
FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Effects of Scale (CSAU Step 10)

- ◆ **Potential code scaling effects must be quantified for bias and deviation**
 - **Scale effects address two issues**
 - *First is the scalability of the tests to a NPP*
 - *Second is the scalability of the code models from the tests to the NPP*
 - **Scalability of tests**
 - **Blowdown**
 - *Power-to-volume scaling demonstrated applicable for blowdown phase*
 - **Refill**
 - *Power-to-volume scaling demonstrated not applicable to refill phase*
 - *Full scale UPTF tests used to address refill phase*
 - **Refflood**
 - *Power-to-volume scaling demonstrated applicable for refflood phase*

33

A
FRAMATOME ANP

Assessment and Ranging of Parameters (CSAU Element 2)

> Effects of Scale (CSAU Step 10)

- ◆ **Potential code scaling effects must be quantified for bias and deviation**
 - **Scalability of Code models**
 - *Single-phase vapor heat transfer model demonstrated scalable*
 - *Film boiling heat transfer model demonstrated scalable*
 - *Core entrainment model demonstrated conservative and scalable*
 - *Critical flow model demonstrated by application to full scale tests*
 - *Carry-over to steam generator demonstrated conservative*
 - *Pump model uses full scale pump data with two-phase degradation*
 - *Cold leg condensation model validated on full scale UPTF test*
 - *ECCS downcomer bypass demonstrated conservative for full scale UPTF tests*
 - *Lower plenum sweep-out demonstrated conservative for full scale UPTF tests*

34

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Reactor Input Parameters and State (CSAU Step 11)

- ◆ *Plant specific variations in input and process parameters are determined based on plant data or analytical studies*
 - *Analysis must address the Technical Specification limits for those parameters impacting the LBLOCA*

35

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Reactor Input Parameters and State (CSAU Step 11)

- ◆ *Plant specific variations in input and process parameters are determined based on plant data or analytical studies*

35

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Plant Sensitivity Calculations (CSAU Step 12)

- ◆ *The code's PCT sensitivity to the plant specific input and process parameter variations is determined from sensitivity studies using the NPP model*
 - *Sensitivity studies were performed for the identified NPP parameters to quantify the impact on the LBLOCA*

uniform distribution can be used with little impact on margin to limits

37


FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Determine Combined Bias and Uncertainty (CSAU Step 13)

- ◆ *Framatome ANP Approach*
 - *Uses uncertainties developed from assessments as input to analysis*
 - *Propagates uncertainties through transient using plant model*
 - *Unlike CSAU Technical Program Group (TPG) approach does not rely on the use of a response surface*
 - *Instead uses non-parametric statistics*
 - *Allows statistical treatment of a large number of variables with an acceptable number of calculations*
 - *Provides 95/95 PCT and associated maximum nodal, and total core oxidation*

38


FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Response Surface Methods

- ♦ *These methods were used by the Technical Program Group (TPG) to apply CSAU to LBLOCA*
- ♦ *A series of cases is run using various combinations of the inputs to represent their uncertainty ranges*
- ♦ *The results of all of the runs are fit with a simplified functional form – usually a polynomial with non-linear terms*
- ♦ *The functional form is then used to calculate the probability distributions for the results*
- ♦ **Advantages**
 - *They give the complete probability distributions for PCT, localized cladding oxidation, core wide cladding oxidation*
 - *These can be combined with additional uncertainties not considered in the original analysis*

39

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Response Surface Methods (continued)

- ♦ **Weaknesses**
 - *They are time consuming and severely limited in the number of parameters they can treat*
 - *The largest errors in the fits are at the extremes of the fit range*
 - *The tails of the probability distribution have the largest uncertainty*
 - *To include a large number of variables, subsets are treated independently and multiple response surfaces created and then combined*
 - *Uncertainties propagated at different conditions*
 - *Interactions between uncertainties are not considered*

40

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Non-Parametric Methods

- ◆ *The current methodology uses non-parametric tolerances*
- ◆ *The acceptance criteria for LBLOCA are expressed as criteria on PCT and on cladding oxidation*
- ◆ *All one needs to compare to these criteria are tolerances*
- ◆ **Advantages**
 - *The number of parameters which can be treated statistically is limited only by the ability of the user to define and implement uncertainties*
 - *All uncertainties are propagated together and the sensitivities and cross-correlations between them are treated concurrently*
 - *Uses plant model/code to account for cross-correlations*
- ◆ **Weaknesses**
 - *Does not produce probability distributions*
 - *Tolerance limits are conservatively bounding of the real limits*

41

 FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Determine Combined Bias and Uncertainty (CSAU Step 13)

- ◆ **Non-Parametric Statistics**
 - *Relies on the execution of a defined number of cases to determine a 95/95 condition*
 - *59 cases: highest value calculated is 95/95*
 - *93 cases: second highest value calculated is 95/95*
 - *124 cases: third highest value calculated is 95/95*
 - *153 cases: fourth highest value calculated is 95/95*
 - *etc.*
 - *Each case defined by randomly selecting a value for each parameter being treated statistically*

42

 FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Determine Combined Bias and Uncertainty (CSAU Step 13)

◆ Define cases to be run

- Parameter Case 1...Case 2.....Case N

» A

» B

» .

» .

» .

» .

» .

» .

» ZZZ

43

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> Determine Combined Bias and Uncertainty (CSAU Step 13)

44

A
FRAMATOME ANP

Sensitivity and Uncertainty Analysis (CSAU Element 3)

> **Total Uncertainty (CSAU Step 14)**

- ♦ *The statement of total uncertainty for the analysis is given as a statement of probability for the limiting value of the primary safety criteria*
- ♦ *For the sample problems the limiting values for the primary safety criteria are:*

<u>Criteria</u>	<u>4-loop Case 22</u>	<u>3-loop Case 41</u>
95/95 PCT	1686 F	1853 F
Maximum Nodal Oxidation	0.8 %	1.3 %
Maximum Core Oxidation	0.02 %	0.04 %
50/50 PCT	1375 F	1500 F

45

A
FRAMATOME ANP

Realistic LBLOCA Methodology Roadmap

> **Conclusions**

- ♦ *An overview of the complete Framatome ANP Realistic LBLOCA methodology has been provided*
 - *Demonstrated use of the CSAU methodology elements and steps*
 - *Demonstrated improved statistical treatment*
 - *Non-parametric statistics allowed treatment of a large number of parameter uncertainties, eliminating the need to determine penalties*
 - *Used SET's to remove biases from code models and to determine model uncertainties*
 - *Used IET's to evaluate code model biases on Independent data sets*

46

A
FRAMATOME ANP