

ENERGY NORTHWEST

P.O. Box 968 ■ Richland, Washington 99352-0968

December 8, 2003
GO2-03-182


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397
MONTHLY OPERATING REPORT
NOVEMBER 2003**

Dear Sir or Madam:

Transmitted herewith is the Monthly Operating Report for the month of November 2003 as required by Technical Specification 5.6.4.

Respectfully,



WS Oxenford
Plant General Manager
Mail Drop 927M

Attachment

cc: BS Mallett - NRC RIV
BJ Benney - NRC NRR
NRC Senior Resident Inspector - 988C
TC Poindexter - Winston & Strawn
INPO
ANI Library
Utility Data Institute
RN Sherman - BPA / 1399

JE24

OPERATING STATUS REPORT
for Columbia Generating Station

Date: December 1, 2003

1. Docket: 50-397
2. Reporting Period: November 2003
3. Utility Contact: **Patricia Campbell** (509) 377-4664
4. Design Electrical Rating (Net MWe): 1153
5. Maximum Dependable Capacity - summer (Net MWe): 1107

	MONTH	YEAR	CUMULATIVE
6. Hours Reactor Critical	720.0	6,419.0	126,114.5
7. Hours Generator On-Line	720.0	6,298.1	122,669.6
8. Unit Reserve Shutdown Hours	0.0	0.0	3,274.7
9. Net Electrical Energy (MWH)	806,785	6,783,709	122,036,488

UNIT SHUTDOWNS

DOCKET NO.: 50-397
 UNIT NAME: Columbia Generating Station
 DATE: December 1, 2003
 COMPLETED BY: P. Campbell
 TELEPHONE: (509) 377-4664

REPORT PERIOD: November, 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions Comments
NA						

SUMMARY: The plant began and ended the month at 100% power.

(1) REASON

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction

- E - Operator Training &
License Examination
- F - Administration
- G - Operational Error
- H - Other

(2) METHOD

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Auto Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)