

December 22, 2003  
EN-03-053

OFFICE OF ENFORCEMENT  
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Entergy Operations, Inc. (EA-03-077)  
River Bend Station  
Docket Nos. 50-458

Subject: ISSUANCE OF FINAL SIGNIFICANCE DETERMINATION AND NOTICE OF VIOLATION

This is to inform the Commission that a Notice of Violation associated with a White Significance Determination Process (SDP) finding will be issued on or around December 29, 2003, to Entergy Operations, Inc. as a result of inspections at the River Bend Station. This White finding, an issue with low to moderate increased importance to safety, involved the failure to properly lock open condensate prefilter vessel bypass flow control Valve CNM-FCV200 resulting in a loss of feed water flow to the reactor on September 18, 2002, when the valve unexpectedly closed following a reactor scram. The failure to properly lock open the valve is a violation of Technical Specification 5.4.1.a. Accordingly, a Notice of Violation associated with the White finding is being issued.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Final Significance Determination	December 29, 2003
Telephone Notification of Licensee	December 29, 2003

The State of Louisiana will be notified.

Contacts: J. Dixon-Herrity, OE, 415-1980 J. Luehman, OE, 415-2741

Distribution:

<u>OWFN</u>	<u>OWFN</u>	<u>TWFN</u>	<u>Regional Offices</u>	
Chairman Diaz	EDO	OCFO	RI	RII
Comm. McGaffigan	DEDR	OP CENTER	RIII	RIV
Comm. Merrifield	DEDE	NMSS		
SECY	OE	NSIR		
OCA	OGC	OIG	<u>MAIL</u>	
PA	NRR	OCIO	ADAMS	
IP	OI	RES		
	SP	ACRS		

ADAMS Accession No. ML033560356  
C:\ORPCheckout\FileNET\ML033560356.wpd

OFFICE	OE-ES	OE
NAME	JDixon-Herrity	RPedersen
DATE	12/22/03	12/22/03