

Harris fp call 2/13

I got the call. (Duncan, Caves, Morton)

1. They want to set up a meeting to discuss their plans, schedule and root cause evaluation associated with their fire protection program.

~~2. They disagree with the characterization in the report of inadequate corrective action associated with the ACP room:~~

a) They planned to ask for a deviation for these manual actions

b) The modification to accept these manual actions was still a work in progress (pending a above)

c) They have maintained the compensatory measure of a fire watch in this area since the issue first started.

d) New info- They don't think a loop would occur for a fire in the room. (We had some specific concerns with a subset of the manual actions associated with post-loop fire recovery.)

When I questioned them on whether the procedure implementing the manual actions was a valid procedure that they expected would be used, they said yes.

We can talk about this more upon your RTP.

I briefed Vic.

2-1