

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

2. Verifying proper operation of the Motor Driven Feedwater Pump lube oil interlocks.
  3. Verifying proper operation of manual valves by shifting the Motor Driven Feedwater Pump between the Main Feedwater System and the Auxiliary Feedwater System.
- e. After any modification or repair to the Motor Driven Feedwater Pump System that could affect the system's capability to deliver water from the Condensate Storage Tanks to the Auxiliary Feedwater System, the affected flow path shall be demonstrated available as follows:\*
1. If the modification or repair is in the Auxiliary Feedwater flow path downstream of the Motor Driven Feedwater Pump test flow line tie-in, the Motor Driven Feedwater Pump shall pump water from the Condensate Storage Tanks to the Auxiliary Feedwater System and the flow path availability will be verified by either steam generator level change or Auxiliary Feedwater Safety Grade Flow Indication.
  2. If the modification or repair is upstream of the Motor Driven Feedwater Pump test flow line tie-in, the Motor Driven Feedwater Pump shall pump water from the Condensate Storage Tanks to the test flow line and the flow path availability will be verified by Motor Driven Feedwater Pump flow indication.
- f. Following each extended COLD SHUTDOWN (greater than 30 days in MODE 5), by:
1. Verifying that there is a flow path between the Motor Driven Feedwater System and the Auxiliary Feedwater System by pumping water from the Condensate Storage Tanks to the steam generators. The flow path to the steam generators shall be verified prior to entering MODE 3 from MODE 4 by either steam generator level change or Auxiliary Feedwater Safety Grade Flow Indication. Verification of Motor Driven Feedwater Pump flow capacity is not required.

---

\* This surveillance testing shall be performed prior to entering MODE 3 from MODE 4 if the modification is made in MODES 4, 5, or 6. Verification of the Motor Driven Feedwater Pump flow capacity is not required.