



Duke Energy Corporation  
526 South Church Street  
P.O. Box 1006  
Charlotte, NC 28201-1006

December 15, 2003

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Duke Energy Corporation  
Oconee Nuclear Station, Docket Nos. 50-269, -270, -287  
McGuire Nuclear Station, Docket Nos. 50-369, -370  
Catawba Nuclear Station, Docket Nos. 50-413, -414  
Monthly Performance and Operation Status – November, 2003

Please find attached information concerning the performance and operation status of the Oconee, McGuire and Catawba Nuclear Stations for the month of November 2003.

Please direct any questions or comments to Roger A. Williams at (704) 382-5346.

Sincerely,

A handwritten signature in black ink, appearing to read 'W. R. McCollum, Jr.' with a stylized flourish at the end.

W. R. McCollum, Jr.  
Senior Vice President  
Nuclear Support

IE24

U.S. Nuclear Regulatory Commission  
Monthly Performance and Operation Status  
December 15, 2003  
Page 2

xc: L. A. Reyes, Regional Administrator  
U.S. Nuclear Regulatory Commission  
Sam Nunn Atlanta Federal Center  
61 Forsythe Street SW, Suite 23T85  
Atlanta, GA 30303-8931

L. N. Olshan, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8 H12  
Washington, DC 20555

R. E. Martin, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8 H12  
Washington, DC 20555

S. E. Peters, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8 H12  
Washington, DC 20555

Ms. Margaret Aucoin  
Nuclear Assurance Corporation  
3930 E. Jones Bridge Road #300  
Norcross, GA 30092-2107

INPO Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957

Dottie Sherman, ANI Library  
American Nuclear Insurers  
Town Center, Suite 300S  
29 South Main Street  
West Hartford, CT 06107-2445

M. Shannon, Senior Resident Inspector, Oconee Nuclear Station  
J. Brady, Senior Resident Inspector, McGuire Nuclear Station  
E. Guthrie, Senior Resident Inspector, Catawba Nuclear Station

U.S. Nuclear Regulatory Commission  
Monthly Performance and Operation Status  
December 15, 2003  
Page 3

bx: R. L. Gill – EC05P  
B. G. Davenport - ON03RC  
C. J. Thomas - MG01RC  
L. A. Keller – CN01RC  
R. A. Williams - ECO5Z (2 copies)  
L. B. Jones – EC05O  
Catawba Date File - CN01RC (Attn: Jill Ferguson)  
North Carolina Municipal Power  
Piedmont Municipal Power Agency  
North Carolina Electric Membership Corp.  
Saluda River Electric  
Catawba File 801.01 - CN04DM  
McGuire File 801.01 - MG01DM  
Oconee File 801.01 - ON03DM  
ELL - EC05O

# Operating Data Report

Docket No.	<u>50-269</u>
Date	<u>December 15, 2003</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                                      |
|---|--------------------------------------|
| 1. Unit Name:   | Oconee 1                             |
| 2. Reporting Period:  | November 1, 2003 - November 30, 2003 |
| 3. Licensed Thermal Power (MWt):  | 2568                                 |
| 4. Nameplate Rating (Gross MWe):  | 934                                  |
| 5. Design Electrical Rating (Net Mwe):  | 886                                  |
| 6. Maximum Dependable Capacity (Gross MWe):   | 886                                  |
| 7. Maximum Dependable Capacity (Net MWe):   | 846                                  |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                                      |

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	266281.0
12. Number of Hours Reactor was Critical	0.0	6289.1	209852.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	0.0	6288.0	206348.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0	15701986	510904640
17. Gross Electrical Energy Generated (MWH)	0	5497806	176749113
18. Net Electrical Energy Generated (MWH)	0	5253052	168127098
19. Unit Service Factor	0.0	78.4	77.5
20. Unit Availability Factor	0.0	78.4	77.5
21. Unit Capacity Factor (Using MDC Net)	0.0	77.5	74.0
22. Unit Capacity Factor (Using DER Net)	0.0	74.0	71.3
23. Unit Forced Outage Rate	0.0	0.0	9.0
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: December 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	11/01/03	S	720.00	C	4		END OF CYCLE 21 REFUELING AND STEAM GENERATOR/REACTOR VESSEL HEAD REPLACEMENT OUTAGE

**Summary:**

Oconee unit 1 began the month of November in a outage due to end-of-cycle 21 refueling and steam generator/reactor vessel head replacement. The unit remained in the end-of-cycle 21 refueling and steam generator/reactor vessel head replacement outage for the remainder of the month.

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 177  
(b) in the spent fuel pool: 938\*  
(c) in the ISFSI: 1848\*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: Decemeber 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* On March 29, 1990, received a site specific license for ISFSI which will store 2112 assemblies (88 modules). Forty (40) site specific modules were constructed and loaded.

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.

\*\*\*\* Represents the combined total for Units 1, 2, and 3

# Operating Data Report

Docket No.	<u>50-270</u>
Date	<u>December 15, 2003</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: November 1, 2003 - November 30, 2003
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	256201.0
12. Number of Hours Reactor was Critical	720.0	8016.0	209101.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	8016.0	206522.7
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1849576	20583855	511137410
17. Gross Electrical Energy Generated (MWH)	651582	7227117	175880101
18. Net Electrical Energy Generated (MWH)	623979	6926266	167652584
19. Unit Service Factor	100.0	100.0	80.6
20. Unit Availability Factor	100.0	100.0	80.6
21. Unit Capacity Factor (Using MDC Net)	102.4	102.1	76.7
22. Unit Capacity Factor (Using DER Net)	97.8	97.5	73.9
23. Unit Forced Outage Rate	0.0	0.0	8.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME: Oconee 2

DATE: December 15, 2003

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)





# Operating Data Report

Docket No.	<u>50-287</u>
Date	<u>December 15, 2003</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: November 1, 2003 - November 30, 2003
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	253848.0
12. Number of Hours Reactor was Critical	720.0	6822.7	201875.6
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	6723.9	199130.0
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1847727	17005500	498265160
17. Gross Electrical Energy Generated (MWH)	646557	5936884	172486159
18. Net Electrical Energy Generated (MWH)	619026	5671489	164571134
19. Unit Service Factor	100.0	83.9	78.4
20. Unit Availability Factor	100.0	83.9	78.4
21. Unit Capacity Factor (Using MDC Net)	101.6	83.6	76.0
22. Unit Capacity Factor (Using DER Net)	97.0	79.9	73.2
23. Unit Forced Outage Rate	0.0	6.3	8.9
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: December 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: October 2004
3. Scheduled restart following refueling: January 2005

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 177  
  (b)     in the spent fuel pool: 476  
  (c)     in the ISFSI: See Unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 825  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: Decemeber 15, 2003

Name of Contact:           R. A. Williams

Phone: (704) - 382-5346

\*\* See footnote of Unit 1

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded. Additional modules will be installed on an as-needed basis.

\*\*\*\* See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

OCTOBER 2003

1. Personnel Exposure -

The total station liquid release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

# Operating Data Report

Docket No.	<u>50-369</u>
Date	<u>December 15, 2003</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                                      |
|---|--------------------------------------|
| 1. Unit Name:   | McGuire 1                            |
| 2. Reporting Period:  | November 1, 2003 - November 30, 2003 |
| 3. Licensed Thermal Power (MWt):  | 3411                                 |
| 4. Nameplate Rating (Gross MWe):  | 1305 *                               |
| 5. Design Electrical Rating (Net Mwe):  | 1180                                 |
| 6. Maximum Dependable Capacity (Gross MWe):   | 1144                                 |
| 7. Maximum Dependable Capacity (Net MWe):   | 1100                                 |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                                      |

Notes: \*Nameplate Rating (GrossMWe) calculated as 1450.000 MVA \* .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	192840.0
12. Number of Hours Reactor was Critical	720.0	8016.0	151041.5
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	8016.0	149740.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2454636	27203492	484108747
17. Gross Electrical Energy Generated (MWH)	848917	9392717	166895375
18. Net Electrical Energy Generated (MWH)	817776	9054747	159970590
19. Unit Service Factor	100.0	100.0	77.7
20. Unit Availability Factor	100.0	100.0	77.7
21. Unit Capacity Factor (Using MDC Net)	103.3	102.7	73.2
22. Unit Capacity Factor (Using DER Net)	96.3	95.7	70.3
23. Unit Forced Outage Rate	0.0	0.0	8.9
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

## UNIT SHUTDOWNS

DOCKET NO. 50-369UNIT NAME: McGuire 1DATE: December 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
<b>Summary:</b>							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 1
2. Scheduled next refueling shutdown: March 2004
3. Scheduled restart following refueling: April 2004

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193  
(b) in the spent fuel pool: 1011
8. Present licensed fuel pool capacity: 1463  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity: November 2005

DUKE POWER COMPANY

DATE: Decemeber 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346



# Operating Data Report

Docket No.	<u>50-370</u>
Date	<u>December 15, 2003</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                                      |
|---|--------------------------------------|
| 1. Unit Name:   | McGuire 2                            |
| 2. Reporting Period:  | November 1, 2003 - November 30, 2003 |
| 3. Licensed Thermal Power (MWt):  | 3411                                 |
| 4. Nameplate Rating (Gross MWe):  | 1305 *                               |
| 5. Design Electrical Rating (Net Mwe):  | 1180                                 |
| 6. Maximum Dependable Capacity (Gross MWe):   | 1144                                 |
| 7. Maximum Dependable Capacity (Net MWe):   | 1100                                 |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                                      |

Notes: \*Nameplate Rating (GrossMWe) calculated as 1450.000 MVA \* .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	173136.0
12. Number of Hours Reactor was Critical	720.0	7280.7	143067.5
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.0	7280.7	141813.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2454157	24477933	468666293
17. Gross Electrical Energy Generated (MWH)	856270	8480602	163036707
18. Net Electrical Energy Generated (MWH)	825831	8169374	156552168
19. Unit Service Factor	100.0	90.8	81.9
20. Unit Availability Factor	100.0	90.8	81.9
21. Unit Capacity Factor (Using MDC Net)	104.3	92.6	80.2
22. Unit Capacity Factor (Using DER Net)	97.2	86.4	76.6
23. Unit Forced Outage Rate	0.0	0.6	5.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

### UNIT SHUTDOWNS

DOCKET NO. 50-370

UNIT NAME: McGuire 2

DATE: December 15, 2003

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

**Summary:**

  
  
  
  
  
  
  
  
  
  

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 2
2. Scheduled next refueling shutdown: March 2005
3. Scheduled restart following refueling: April 2005

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 193  
(b) in the spent fuel pool: 1138  
(c) in the ISFSI: 320
8. Present licensed fuel pool capacity: 1463  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:  
June 2003

DUKE POWER COMPANY

DATE: Decemeber 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

OCTOBER 2003

1. Personnel Exposure -

The total station liquid release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

# Operating Data Report

Docket No. 50-413  
 Date December 15, 2003  
 Completed By Roger Williams  
 Telephone 704-382-5346

## Operating Status

1. Unit Name: Catawba 1  
 2. Reporting Period: November 1, 2003 - November 30, 2003  
 3. Licensed Thermal Power (MWt): 3411  
 4. Nameplate Rating (Gross MWe): 1305 \*  
 5. Design Electrical Rating (Net Mwe): 1145  
 6. Maximum Dependable Capacity (Gross MWe): 1192  
 7. Maximum Dependable Capacity (Net MWe): 1129  
 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: \*Nameplate Rating (GrossMWe) calculated as 1450.000 MVA \* .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	720.0	8016.0	161497.0
12. Number of Hours Reactor was Critical	169.1	7171.4	134276.7
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	168.9	7159.6	132755.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	550978	24234194	439098679
17. Gross Electrical Energy Generated (MWH)	196437	8653939	155899862
18. Net Electrical Energy Generated (MWH)	182907	8198521	147096207
19. Unit Service Factor	23.5	89.3	82.2
20. Unit Availability Factor	23.5	89.3	82.2
21. Unit Capacity Factor (Using MDC Net)	22.5	90.6	80.5
22. Unit Capacity Factor (Using DER Net)	22.2	89.3	79.5
23. Unit Forced Outage Rate	0.0	4.1	5.5
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

## UNIT SHUTDOWNS

DOCKET NO. 50-413UNIT NAME: Catawba 1DATE: December 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
3	11/08/03	S	551.15	C	1		END OF CYCLE 14 REFUELING OUTAGE AND GENERATOR REWIND OUTAGE

**Summary:**

Catawba unit 1 began the month of November operating at 100% power. On 11/05/03 at 2007 the unit began decreasing power and held at 95% power from 11/06/03 at 0033 to 11/07/03 at 1600 to perform main steam safety valve testing. The unit began decreasing power on 11/07/03 at 1600 and was taken off-line on 11/08/03 at 0051 to begin end-of-cycle 14 refueling and generator rewind outage. The unit remained in the end-of-cycle 14 refueling and generator rewind outage the remainder of the month.

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193  
(b) in the spent fuel pool: 1021
8. Present licensed fuel pool capacity: 1418  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:  
November 2009

DUKE POWER COMPANY

DATE: Decemeber 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346





## UNIT SHUTDOWNS

DOCKET NO. 50-414

UNIT NAME: Catawba 2

DATE: December 15, 2003

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: November, 2003

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

**Summary:**

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction

- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

OCTOBER 2003

1. Personnel Exposure -

The total station liquid release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for OCTOBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.