

December 30, 2003

Mr. George A. Williams
Site Vice President
Grand Gulf Nuclear Station
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - ISSUANCE OF AMENDMENT
RE: REVISED ACTION FOR SCRAM DISCHARGE VOLUME VENT AND
DRAIN VALVES (TAC NO. MC1114)

Dear Mr. Williams:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 161 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment revises the Technical Specifications (TSs) in response to your application dated October 24, 2003.

The amendment revises TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. A notice of availability for this technical specification improvement using the consolidated line item improvement process was published in the Federal Register on April 15, 2003 (68 FR 18294).

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Bhalchandra Vaidya, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-416

Enclosures: 1. Amendment No. 161 to NPF-29
2. Safety Evaluation

cc w/encls: See next page

December 30, 2003

Mr. George A. Williams
Site Vice President
Grand Gulf Nuclear Station
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1 - ISSUANCE OF AMENDMENT
RE: REVISED ACTION FOR SCRAM DISCHARGE VOLUME VENT AND
DRAIN VALVES (TAC NO. MC1114)

Dear Mr. Williams:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 161 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment revises the Technical Specifications (TSs) in response to your application dated October 24, 2003.

The amendment revises TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. A notice of availability for this technical specification improvement using the consolidated line item improvement process was published in the Federal Register on April 15, 2003 (68 FR 18294).

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Bhalchandra Vaidya, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-416

DISTRIBUTION:

PUBLIC

PDIV-1 Reading

RidsNrrDlpmPdiv (HBerkow)

RidsNrrDlpmPdivLpdiv1 (RGramm)

RidsNrrPMBVaidya

RidsOgcRp

RidsNrrLADJohnson

RidsRgn4MailCenter (AHowell)

DRIP/RORP/TSS

G.Hill (2)

RidsAcrcAcnwMailCenter

Enclosures:

- 1. Amendment No. 161 to NPF-29
- 2. Safety Evaluation

cc w/encls: See next page

Accession No.:ML033640483

OFFICE	CLIIP LPM	PDIV-1/PM	PDIV-1/LA	PDIV-1/SC
NAME	WReckley	BVaidya	DJohnson	RGramm
DATE	12/15/03	12/29/03	12/15/03	12/29/03

OFFICIAL RECORD COPY

ENERGY OPERATIONS, INC.
SYSTEM ENERGY RESOURCES, INC.
SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION
ENERGY MISSISSIPPI, INC.
DOCKET NO. 50-416
GRAND GULF NUCLEAR STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 161
License No. NPF-29

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated October 24, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-29 is hereby amended to read as follows:

- (2) Technical Specifications

- The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 161, are hereby incorporated into this license. Entergy Operations, Inc. shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Robert A. Gramm, Chief, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: December 30, 2003

ATTACHMENT TO LICENSE AMENDMENT NO. 161

FACILITY OPERATING LICENSE NO. NPF-29

DOCKET NO. 50-416

Replace the following page of the Appendix A Technical Specifications with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove

3.1-26

Insert

3.1-26

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 161 TO

FACILITY OPERATING LICENSE NO. NPF-29

ENTERGY OPERATIONS, INC., ET AL.

GRAND GULF NUCLEAR STATION, UNIT 1

DOCKET NO. 50-416

1.0 INTRODUCTION

By application dated October 24, 2003, Entergy Operations, Inc., et al. (the licensee), requested changes to the Technical Specifications (TSs) for Grand Gulf Nuclear Station, Unit 1. The requested changes would revise the required action within TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. These changes are based on Technical Specifications Task Force (TSTF) change traveler TSTF-404 (Revision 0) that has been approved generically for the Boiling Water Reactor/6 (BWR) Standard Technical Specifications, NUREG-1434, Revision 2. A notice announcing the availability of this proposed TS change using the consolidated line item improvement process was published in the *Federal Register* on April 15, 2003 (68 FR 18294).

2.0 REGULATORY EVALUATION

U.S. Nuclear Regulatory Commission (NRC) regulations and review standards such as Appendix A, "General Design Criteria for Nuclear Power Plants," to Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, include specific requirements for reactor protection and reactivity control systems. The reactor protection systems for BWRs use a hydraulic system to insert control rods into the reactor core. During an actuation of the reactor protection system (a scram), water is exhausted from the control rod drive mechanisms to the SDVs. Proper maintenance and operation of the SDVs in terms of instrumentation and limiting water volumes are essential for assuring the reliability of the reactor protection system (see NRC Bulletin 80-17, "Failure of Control Rods to Insert During a Scram at a BWR," related Orders to specific facilities, and information provided in plant final safety analysis reports and TS Bases). Maintaining the SDVs to ensure that accumulated water does not hamper or slow the insertion of control rods requires vent and drain valves. The vent and drain valves isolate during a scram to limit the amount of coolant discharged so that adequate core cooling is maintained and offsite doses remain within regulatory limits.

Specific regulatory requirements for SDV vent and drain valves are defined in TS 3.1.8. The existing Limiting Condition for Operation 3.1.8, requires that each SDV vent and drain valve be operable. The operability of all SDV vent and drain valves ensures that the SDV vent and drain

valves will close during a scram to contain reactor water discharged to the SDV piping. Since the vent and drain lines are provided with two valves in series, the single failure of one valve in the open position will not impair the isolation function of the system. Additionally, the valves are required to open on scram reset and during plant operation to control the amount of water accumulating in the SDV. If one or more SDV vent and drain lines have a single valve that is inoperable, the existing required action is to restore the valve(s) to operable status within 7 days. If an inoperable valve is not restored to operable status, a plant shutdown to MODE 3 is required within 12 hours.

If one or more SDV vent or drain lines have both valves inoperable, the associated line must be isolated within 8 hours. In this condition, the plant is allowed to operate indefinitely. A note associated with the required action clarifies that the valves may be opened under administrative controls to allow draining of the SDV. The existing SDV vent and drain valve required actions are inconsistent in that, although the operational and safety concerns are similar for having one or both valves in a line being inoperable, the actions for a single inoperable valve do not allow for the isolation of the line and administrative controls to support the draining of the SDV.

The proposed change would revise the required actions to be more consistent with the safety significance of one inoperable valve in a SDV line versus two inoperable valves in an SDV line.

3.0 TECHNICAL EVALUATION

The proposed changes to TS 3.1.8 are:

- A. Required Action A.1 is revised from restoring the single inoperable SDV vent and drain valve in one or more SDV vent and drain lines to operable status to isolating the associated line.
2. The Note to Required Action B.1, which allows an isolated line to be unisolated under administrative controls for the purpose of draining and venting the SDV, is moved to a note that applies to both Conditions A (single inoperable valve) and B (both valves inoperable).

With one SDV vent or drain valve inoperable in one or more lines, the isolation function would be maintained since the redundant valve in the affected line would perform its safety function of isolating the SDV. The current ACTION statement allows 7 days to repair the inoperable valve; the proposed change is to allow for the isolation of the affected line and continue operation. If the affected line is not isolated within the 7-day time period (or the inoperable valve is not restored), the licensee would then be required to proceed to MODE 3 in the next 12 hours. Maintaining the 7-day Completion Time is acceptable because of the low probability of the concurrent events of a scram within the 7 days of the Completion Time and a failure of the redundant valve(s). Alternately, if the inoperable valve was initially closed, there would be ample time and warning available to drain the SDV before an automatic scram would occur due to SDV high level.

The allowance to administratively open a line that is isolated to comply with the actions (to permit draining and venting the SDV) is allowed by existing Required Action B.1. This allowance is being moved to apply to all ACTIONS based on the change proposed to Action A. This would allow any accumulated water in the line to be drained, to preclude a reactor scram

on SDV high level. A reactor scram is initiated if the SDV water level in the instrument volume exceeds a specified setpoint. The setpoint is chosen so that all control rods are inserted before the SDV has insufficient volume to accept a full scram. Regarding the isolation of the SDV, the remaining operable SDV vent and drain valve(s) would close automatically on a scram signal to isolate the lines. Or, if both valves in a line were inoperable (and opened under this provision), the reactor coolant release could be terminated by resetting the scram from the control room, or by manually closing the valves. Resetting the scram automatically closes the scram outlet valves, isolating the control rod drive discharge path to the SDV.

Based on the low probability of an event occurring during the defined Completion Time associated with this condition, the subsequent isolation of the affected lines, and the ability to open and drain the lines before an automatic scram due to SDV high water level, the proposed change maintains the necessary safety features and is therefore acceptable.

The licensee stated that associated changes to the Bases Section for TS 3.1.8 will be made in accordance with the Bases Control Program defined by TS 5.5.11. The NRC staff agrees that the TS Bases Control Program is the appropriate process for updating the affected TS Bases pages.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Mississippi State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (68 FR 66135, published November 25, 2003). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. Reckley

Date: December 30, 2003

Grand Gulf Nuclear Station

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, DC 20005-3502

Chief
Energy and Transportation Branch
Environmental Compliance and
Enforcement Division
Mississippi Department of Environmental
Quality
P. O. Box 10385
Jackson, MS 39289-0385

President
Claiborne County
Board of Supervisors
P. O. Box 339
Port Gibson, MS 39150

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 399
Port Gibson, MS 39150

General Manager, GGNS
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, LA 70804-9005

State Health Officer
State Board of Health
P. O. Box 1700
Jackson, MS 39205

Office of the Governor
State of Mississippi
Jackson, MS 39201

Attorney General
Asst. Attorney General
State of Mississippi
P. O. Box 22947
Jackson, MS 39225

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Director
Nuclear Safety Assurance
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, MS 39150

Mr. Michael A. Krupa, Director
Nuclear Safety & Licensing
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213-8298

November 2003