



December 22, 2003

AEP:NRC:3591-02

Docket No. 50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop O-P1-17
Washington, DC 20555-0001

Donald C. Cook Nuclear Plant Unit 2
CORRECTION OF UNIT 2 CD EMERGENCY DIESEL GENERATOR
PERCENT UNAVAILABILITY

- Reference: 1) Letter from J. N. Jensen, Indiana Michigan Power Company (I&M), to U. S. Nuclear Regulatory Commission (NRC) Document Control Desk, "Emergency License Amendment Request for One-Time Extension of Allowed Outage Time for the Unit 2 AB Emergency Diesel Generator," dated December 9, 2003
- 2) Letter from D. S. Hood, NRC, to M .K. Nazar, I&M, "Donald C. Cook Nuclear Plant, Unit 2 - Issuance of Emergency Amendment, Regarding One-Time Allowed Outage Time Extension for AB Emergency Deisel Generator (TAC No. MC1498)," dated December 10, 2003

This letter provides a corrected value for the Unit 2 CD emergency diesel generator (EDG) percent unavailability.

By Reference 1 and Reference 2, respectively, I&M requested and was granted an emergency license amendment allowing a one-time 72 hour extension of the Technical Specification allowed outage time for the Unit 2 AB EDG. The extension was requested to allow continued operation of the unit while repairs and related testing of the EDG were completed. Section 4.0 of Enclosure 2 to Reference 1 stated that the reactor oversight process data for the third quarter of 2003 indicated that the Unit 2 CD EDG unavailability over the previous 12 quarters was 0.8 percent. However, the actual value was 1.0 percent. Although the Unit 2 CD EDG unavailability was slightly higher than indicated in Reference 1, the unavailability still less than the white threshold of 2.5 percent.

A001

The enclosure to this letter provides an affirmation affidavit. This letter contains no new regulatory commitments.

Should you have any questions, please contact Mr. Brian D. Mann, Acting Manager of Regulatory Affairs, at (269) 697-5806.

Sincerely,

A handwritten signature in black ink, consisting of a large, stylized 'J' followed by a horizontal line extending to the right.

Joseph N. Jensen
Site Vice President

JW/rdw

Enclosure: Affidavit

c: J. L. Caldwell, NRC Region III
K. D. Curry, AEP Ft. Wayne, w/o enclosure
J. T. King, MPSC, w/o enclosure
MDEQ – WHMD/HWRPS, w/o enclosure
NRC Resident Inspector
J. F. Stang, Jr., NRC Washington DC

AFFIRMATION

I, Joseph N. Jensen, being duly sworn, state that I am Site Vice President of Indiana Michigan Power Company (I&M), that I am authorized to sign and file this request with the Nuclear Regulatory Commission on behalf of I&M, and that the statements made and the matters set forth herein pertaining to I&M are true and correct to the best of my knowledge, information, and belief.

Indiana Michigan Power Company



Joseph N. Jensen
Site Vice President

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 22nd DAY OF December, 2003

Julie E. Newmiller
Notary Public

My Commission Expires 8-22-2004

JULIE E. NEWMILLER
Notary Public, Berrien County, MI
My Commission Expires Aug 22, 2004

