

December 23, 2003

Mr. W. R. McCollum, Jr.
Senior Vice President
Duke Energy Corporation
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2, AND MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM ACCUMULATORS (TAC NOS. MB9999, MC0001, MC0002, AND MC0003)

Dear Mr. McCollum:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 211 to Renewed Facility Operating License NPF-35 and Amendment No. 205 to Renewed Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2, and Amendment No. 218 to Renewed Facility Operating License NPF-9 and Amendment No. 200 to Renewed Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 14, 2003, as supplemented by letter dated October 1, 2003.

The amendments extend from 1 hour to 24 hours the completion time (CT) for Condition B of TS 3.5.1, which defines requirements for the emergency core cooling system accumulators. Condition B of TS 3.5.1 specifies a CT to restore an accumulator to operable status when it has been declared inoperable for a reason other than the boron concentration of the water in the accumulator not being within the required range.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-413, 50-414, 50-369, and 50-370

Enclosures:

1. Amendment No. 211 to NPF-35
2. Amendment No. 205 to NPF-52
3. Amendment No. 218 to NPF-9
4. Amendment No. 200 to NPF-17
5. Safety Evaluation

cc w/encls: See next page

December 23, 2003

Mr. W. R. McCollum, Jr.
Senior Vice President
Duke Energy Corporation
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2, AND MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS RE: EMERGENCY CORE COOLING SYSTEM ACCUMULATORS (TAC NOS. MB9999, MC0001, MC0002, AND MC0003)

Dear Mr. McCollum:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 211 to Renewed Facility Operating License NPF-35 and Amendment No. 205 to Renewed Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2, and Amendment No.218 to Renewed Facility Operating License NPF-9 and Amendment No. 200 to Renewed Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated July 14, 2003, as supplemented by letter dated October 1, 2003.

The amendments extend from 1 hour to 24 hours the completion time (CT) for Condition B of TS 3.5.1, which defines requirements for the emergency core cooling system accumulators. Condition B of TS 3.5.1 specifies a CT to restore an accumulator to operable status when it has been declared inoperable for a reason other than the boron concentration of the water in the accumulator not being within the required range.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-413, 50-414, 50-369, and 50-370

DISTRIBUTION:

PUBLIC ACRS
PDII-1 R/F GHill (8)
RHaag,RII OGC

Enclosures:

1. Amendment No. 211 to NPF-35
2. Amendment No. 205 to NPF-52
3. Amendment No. 218 to NPF-9
4. Amendment No. 200 to NPF-17
5. Safety Evaluation

cc w/encls: See next page

Package: ML033640666

TSPages: ML033650440, ML033650441

Amendment: ML033640662

OFFICE	CLIIP LPM	PDII-1/PM	PDII-1/LA	PDII-1/SC
NAME	WReckley	RMartin	CHawes	JNakoski
DATE	9/08/2003	12/17/03	12/16/03	12/18/03

OFFICIAL RECORD COPY

DUKE ENERGY CORPORATION
NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION
SALUDA RIVER ELECTRIC COOPERATIVE, INC.
DOCKET NO. 50-413
CATAWBA NUCLEAR STATION, UNIT 1
AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 211
Renewed License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Renewed Facility Operating License No. NPF-35 filed by the Duke Energy Corporation, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees), dated July 14, 2003, as supplemented by letter dated October 1, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 211, which are attached hereto, are hereby incorporated into this license. Duke Energy Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: December 23, 2003

DUKE ENERGY CORPORATION
NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1
PIEDMONT MUNICIPAL POWER AGENCY
DOCKET NO. 50-414
CATAWBA NUCLEAR STATION, UNIT 2
AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 205
Renewed License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Renewed Facility Operating License No. NPF-52 filed by the Duke Energy Corporation, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees), dated July 14, 2003, as supplemented by letter dated October 1, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 205, which are attached hereto, are hereby incorporated into this license. Duke Energy Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: December 23, 2003

ATTACHMENT TO LICENSE AMENDMENT NO. 211
RENEWED FACILITY OPERATING LICENSE NO. NPF-35
DOCKET NO. 50-413
AND LICENSE AMENDMENT NO. 205
RENEWED FACILITY OPERATING LICENSE NO. NPF-52
DOCKET NO. 50-414

Replace the following pages of the Appendix A Technical Specifications and associated Bases with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3.5.1-1	3.5.1-1
B 3.5.1-1	B 3.5.1-1
B 3.5.1-2	B 3.5.1-2
B 3.5.1-3	B 3.5.1-3
B 3.5.1-4	B 3.5.1-4
B 3.5.1-5	B 3.5.1-5
B 3.5.1-6	B 3.5.1-6
B 3.5.1-7	B 3.5.1-7
B 3.5.1-8	B 3.5.1-8

DUKE ENERGY CORPORATION

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 218
Renewed License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Renewed Facility Operating License No. NPF-9 filed by the Duke Energy Corporation (licensee) dated July 14, 2003, as supplemented by letter dated October 1, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-9 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 218, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: December 23, 2003

DUKE ENERGY CORPORATION

DOCKET NO. 50-370

MCGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 200
Renewed License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility), Renewed Facility Operating License No. NPF-17 filed by the Duke Energy Corporation (licensee) dated July 14, 2003, as supplemented by letter dated October 1, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Renewed Facility Operating License No. NPF-17 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 200, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: December 23, 2003

ATTACHMENT TO LICENSE AMENDMENT NO. 218
RENEWED FACILITY OPERATING LICENSE NO. NPF-9
DOCKET NO. 50-369
AND LICENSE AMENDMENT NO. 200
RENEWED FACILITY OPERATING LICENSE NO. NPF-17
DOCKET NO. 50-370

Replace the following pages of the Appendix A Technical Specifications and associated Bases with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
3.5.1-1	3.5.1-1
B 3.5.1-1	B 3.5.1-1
B 3.5.1-2	B 3.5.1-2
B 3.5.1-3	B 3.5.1-3
B 3.5.1-4	B 3.5.1-4
B 3.5.1-5	B 3.5.1-5
B 3.5.1-6	B 3.5.1-6
B 3.5.1-7	B 3.5.1-7
B 3.5.1-8	B 3.5.1-8

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 211 TO RENEWED FACILITY
OPERATING LICENSE NPF-35,
AMENDMENT NO. 205 TO RENEWED FACILITY OPERATING LICENSE NPF-52,
AMENDMENT NO. 218 TO RENEWED FACILITY OPERATING LICENSE NPF-9,
AND AMENDMENT NO. 200 TO RENEWED FACILITY OPERATING LICENSE NPF-17
DUKE ENERGY CORPORATION, ET AL.
CATAWBA NUCLEAR STATION, UNITS 1 AND 2
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2
DOCKET NOS. 50-413, 50-414, 50-369, AND 50-370

1.0 INTRODUCTION

By letter dated July 14, 2003, as supplemented by letter dated October 1, 2003, Duke Energy Corporation, et al. (DEC, the licensee), submitted a request for changes to the Catawba Nuclear Station, Units 1 and 2, and McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS).

The proposed changes would extend from 1-hour to 24 hours the completion time (CT) for Condition B of TS 3.5.1, which defines requirements for accumulators. Condition B of TS 3.5.1 specifies a CT to restore an accumulator to operable status when it has been declared inoperable for a reason other than the boron concentration of the water in the accumulator not being within the required range. The supplement dated October 1, 2003, provided clarifying information that did not change the scope of the July 14, 2003, application nor the initial proposed no significant hazards consideration determination.

2.0 BACKGROUND

The Westinghouse Owners Group (WOG) submitted Topical Report WCAP-15049, "Risk-Informed Evaluation of an Extension to Accumulator Completion Times," to the NRC on August 20, 1998. The WCAP evaluates the risk associated with extending the accumulator CT from 1-hour to 24 hours when an accumulator is declared inoperable for reasons other than its boron concentration being out of specification. The NRC staff approved the topical report in a letter dated February 19, 1999. The WOG subsequently submitted the approved version of the topical report, WCAP-15049-A, by its letter dated May 18, 1999.

Wolf Creek was the lead plant for the WOG program and received plant-specific approval for changes to the TSs on April 27, 1999 (License Amendment No. 124). In the NRC letter of

February 19, 1999, the staff indicated that it will not repeat its review of the matters described in Topical Report WCAP-15049 when the report appears as a reference in license applications, except to ensure that the material presented applies to the specified plants involved.

The WOG, through the industry's Technical Specification Task Force (TSTF), proposed a generic change to the standard technical specifications (STSs) for Westinghouse plants (NUREG-1431). This proposed generic TSs change, identified as TSTF-370, revises the CT from 1 hour to 24 hours for Condition B of TS 3.5.1, "Accumulators," and its associated Bases. Condition B of TS 3.5.1 currently specifies a CT of 1-hour to restore a reactor coolant system (RCS) accumulator to operable status when it has been declared inoperable due to any reason except not being within the required boron concentration range. Following its review of TSTF-370, the NRC staff, following the consolidated line item improvement process (CLIIP), issued a notice of opportunity for comment on this model Safety Evaluation (SE) and a model no significant hazards consideration (July 15, 2002, 67 FR 46542). The NRC staff subsequently issued a notice of availability of the models for referencing in license amendment applications using the CLIIP (March 12, 2003, 68 FR 11880).

3.0 EVALUATION

Deterministic Evaluation

The purpose of the emergency core cooling system (ECCS) accumulators is to supply water to the reactor vessel during the blowdown phase of a loss-of-coolant accident (LOCA). The accumulators are large volume tanks, filled with borated water and pressurized with nitrogen. The cover-pressure is less than that of the RCS so that following an accident, when the RCS pressure decreases below tank pressure, the accumulators inject the borated water into the RCS cold legs. The current deterministic safety analysis has not been changed, and thus, the limiting condition of operation (LCO), i.e., the lowest functional capability required for safe operation continues to be:

"LCO 3.5.1 [Four] ECCS accumulators shall be operable.
Applicability: Modes 1 and 2, Mode 3 with RCS pressure > [1000] psig."

Where the bracketed information is nominal, and is subject to substitution of plant-specific values.

Under Actions, TSs allow for limited deviations from the LCO. Historically, these Actions and associated CTs have been set using judgement and are not part of the deterministic safety analysis discussed above. Currently, the TS allows for one accumulator to be inoperable for 1-hour for reasons other than boron concentration not within limits during Modes 1, 2, and in Mode 3 with pressurizer pressure > a plant specific pressure. The WCAP, as well as this TSTF, proposes to increase this CT to 24 hours. The proposed CT of 24 hours is an extension of the current ACTION statement. CTs are by their nature determined by conditions of risk and the impact of the proposed change on risk is reviewed in the following section.

Risk Evaluation

A three-tiered approach, consistent with Regulatory Guide (RG) 1.177¹, was used by the NRC staff to evaluate the risk associated with the proposed accumulator CT, or allowed outage time (AOT), extension from 1-hour to 24 hours. The need for the proposed change was that the current 1-hour CT would be insufficient in most cases for licensees to take a reasonable action when an accumulator was found to be inoperable.

Tier 1: Quality of Probabilistic Risk Assessment (PRA) and Risk Impact

Westinghouse used a reasonable approach to assess the risk impact of the proposed accumulator CT extension. The approach is generally consistent with the intent of the applicable NRC RGs 1.174² and 1.177. The quantitative risk measures addressed in the topical report included the change in core damage frequency (CDF) and incremental conditional core damage probability (ICCDP³) for a single CT. The change in large early release frequency (LERF) and incremental conditional large early release probability (ICLERP⁴) for a single CT was qualitatively addressed. Representative calculations were performed to determine the risk impact of the proposed change. Various accumulator success criteria were considered in these calculations to encompass the whole spectrum of Westinghouse plants, e.g., two-, three- and four-loop plants. A reasonable effort was also made to address the differences in other components of risk analysis such as initiating event (IE) frequency and accumulator unavailability among Westinghouse plants.

Westinghouse considered a comprehensive range of IEs in the risk analysis. LOCAs in all sizes - large, medium and small - were included, and reactor vessel failure and interfacing system LOCA were also considered. Modeling of accumulators for mitigation of events other than large, medium and small LOCAs was identified to have insignificant risk impact; therefore, the analysis was performed only on accumulator injection in response to large, medium and small LOCA events.

¹RG 1.177, "An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications," September 1998.

²RG 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," July 1998.

³ICCDP = [(conditional CDF with the subject equipment out-of-service) - (baseline CDF with nominal expected equipment unavailabilities) x (duration of single CT under consideration)].

⁴ICLERP = [(conditional LERF with the subject equipment out-of-service) - (baseline LERF with nominal expected equipment unavailabilities) x (duration of single CT under consideration)].

The success criteria considered are summarized as follows:

<u>LOCA Category</u>	<u>No. of Loops</u>	<u>Success Criteria</u>
Large	4	3 accumulators to 3 of 3 intact loops (3/3) 2 accumulators to 2 of 3 intact loops (2/3) no accumulators required (0/3)
	3	2 accumulators to 2 of 2 intact loops (2/2) 1 accumulator to 1 of 2 intact loops (1/2) no accumulators required (0/2)
	2	1 accumulator to 1 of 1 intact loop (1/1) no accumulators required (0/1)
Medium and Small	4	3 accumulators to 3 of 3 intact loops (3/3)
	3	2 accumulators to 2 of 2 intact loops (2/2)
	2	1 accumulator to 1 of 1 intact loop (1/1)

The success criteria considered in this analysis were comprehensive and considered conservative in many cases. For example, many plants indicated the accumulator success criteria for medium and small LOCA events resulted from their role in an alternate success path, in which high pressure injection (HPI) had already failed. Additionally, the NRC staff's review of a number of the original individual plant examinations (IPEs) indicated that no accumulator was needed at all for many medium LOCA sequences and for most of small LOCA sequences.

The fault trees that model accumulator unavailabilities were evaluated. The assumptions made in the fault tree modeling were detailed and were found to be reasonable. For example, the model assumed that the total CT would be used for each corrective maintenance, and this was considered conservative. A comprehensive list of failure mechanisms was considered, and potential common cause failures for check valves and motor-operated valves were also included. Westinghouse used the Multiple Greek Letter technique to determine the common cause failure contributions to the accumulator injection failure.

The component failure rates were taken from the Advanced Light Water Utility Requirements Document.⁵ Accumulator unavailabilities due to boron concentration out-of-limit and due to other reasons were calculated based on a survey of a number of Westinghouse plants. The values for component failure rates and accumulator unavailabilities were within reasonable range. The common cause factors used were also comparable to those used in other PRAs. The accumulator fault trees were quantified using the WesSAGE computer code. The code

⁵"Advanced Light Water Utility Requirements Document," Volume II, ALWR Evolutionary Plant, Chapter 1, Appendix A, PRA Key Assumptions and Ground Rules, Rev. 5, Issued December 1992.

provided information on the unavailability and cutsets related to the component failures and maintenance activities modeled in the fault trees. A separate hand calculation was used to determine the unavailability due to potential common cause failures. Evaluation of some of the cutsets provided in the topical report did not reveal any unexpected results.

The NRC staff examined the accident sequence identification for each LOCA category. The probability of the sequence leading to core damage involving accumulator failure is summarized for each LOCA category as follows:

Large LOCA	(Large LOCA IE frequency) x (accumulator unavailability)
Medium LOCA	(Medium LOCA IE frequency) x (unavailability of HPI) x (accumulator unavailability)
Small LOCA	(Small LOCA IE frequency) x (unavailability of HPI) x (accumulator unavailability)

The LOCA IE frequencies used for WCAP-15049 are summarized below. Also listed are the LOCA frequencies used in NUREG/CR-4550⁶ (the NUREG-1150 study) for pressurized water reactors (PWRs) and those in the original IPEs.

	<u>WCAP-15049</u>	<u>NUREG-1150</u>	<u>IPE Average (High; Low)</u>
Large LOCA	3x10 ⁻⁴ /yr	5x10 ⁻⁴ /yr	3.3x10 ⁻⁴ /yr (5x10 ⁻⁴ /yr; 1x10 ⁻⁵ /yr)
Medium LOCA	8x10 ⁻⁴ /yr	1x10 ⁻³ /yr	7.9x10 ⁻⁴ /yr (2.6x10 ⁻³ /yr; 1x10 ⁻⁴ /yr)
Small LOCA	7x10 ⁻³ /yr	1x10 ⁻³ /yr	8.9x10 ⁻³ /yr (2.9x10 ⁻² /yr; 3.7x10 ⁻⁴ /yr)

Westinghouse indicated that the IE frequencies for WCAP-15049 were based on the plant-specific information contained in the WOG PSA Comparison Database, which documented the PRA modeling methods and results of the updated PRAs for Westinghouse plants. The mean IE frequencies were used for the risk analysis. These were comparable to the values used for the NUREG-1150 study and the average values in the original IPEs. The NRC staff also found that the IE frequency values in high range among the original IPEs were not much higher than those used for this topical report. The HPI unavailability values used were 7x10⁻³ and 1x10⁻³/yr for medium and small LOCA events, respectively. The NRC staff's examination revealed that the HPI unavailability values were generally comparable to those used in other PRAs, and were generally conservative.

The risk measures calculated to determine the impact on plant risk were based on three different cases. The risk measures considered in each case included the impact on CDF and ICCDP for a single CT, and the impact on LERF and ICLERP for a single CT were qualitatively considered. The three cases considered were:

⁶NUREG/CR-4550, "Analysis of Core Damage Frequency: Internal Events Methodology," Vol. 1, Rev. 1, January 1990.

Design basis case. This case required accumulator injection only for mitigation of large LOCA events (3/3 for 4-loop, 2/2 for 3-loop, and 1/1 for 2-loop).

Case 1. This case credited realistic accumulator success criteria (2/3 for 4-loop, ½ for 3-loop, and 0/1 for 2-loop) for large LOCA events and credited the use of accumulators in responding to medium and small LOCA events (3/3, 2/2, and 1/1 for 4-loop, 3-loop, and 2-loop, respectively) following failure of HPI.

Case 2. This case credited more realistic improved accumulator success criteria (no accumulator required) for large LOCA events and credited the use of accumulators in responding to medium and small LOCA events (3/3, 2/2, and 1/1 for 4-loop, 3-loop, and 2-loop, respectively) following failure of HPI.

The results were summarized as follows:

<u>Case</u>	<u>LOCA CDF(/yr)</u> <u>(Current)</u>	<u>LOCA CDF(/yr)</u> <u>(Proposed)</u>	<u>ΔCDF</u>	<u>ICCDP</u>
4-loop Design Basis	6.93x10 ⁻⁷	9.24x10 ⁻⁷	2.31x10 ⁻⁷	8.20x10 ⁻⁷
4-loop Case 1	6.23x10 ⁻⁸	7.77x10 ⁻⁸	1.54x10 ⁻⁸	5.53x10 ⁻⁸
4-loop Case 2	4.57x10 ⁻⁸	6.09x10 ⁻⁸	1.52x10 ⁻⁸	5.41x10 ⁻⁸
3-loop Design Basis	4.62x10 ⁻⁷	6.18x10 ⁻⁷	1.56x10 ⁻⁷	8.21x10 ⁻⁷
3-loop Case 1	4.27x10 ⁻⁸	5.31x10 ⁻⁸	1.04x10 ⁻⁸	5.48x10 ⁻⁸
3-loop Case 2	3.05x10 ⁻⁸	4.08x10 ⁻⁸	1.03x10 ⁻⁸	5.42x10 ⁻⁸
2-loop Design Basis	2.31x10 ⁻⁷	3.09x10 ⁻⁷	7.80x10 ⁻⁸	8.21x10 ⁻⁷
2-loop Case 1	1.52x10 ⁻⁸	2.04x10 ⁻⁸	5.20x10 ⁻⁹	5.42x10 ⁻⁸
2-loop Case 2	1.52x10 ⁻⁸	2.04x10 ⁻⁸	5.20x10 ⁻⁹	5.42x10 ⁻⁸

For both realistic cases, the ΔCDFs and ICCDPs were very small for 2-loop, 3-loop, and 4-loop plants, and were much below the numerical guidelines in the RGs 1.174 and 1.177. The NRC staff also noted that the values were considered still bounding in the sense that the risk analysis used a multitude of conservative assumptions and data in the modeling. For many Westinghouse plants, the realistic impact on risk would be much smaller than the values above.

A set of sensitivity cases were also calculated using higher IE frequencies for small and medium LOCAs. The results of the sensitivity calculations did not cause the overall risk impact to increase significantly.

Westinghouse indicated that accumulator success or failure has no direct impact on the containment performance, and that the LERF would therefore increase only in direct proportion to the increased CDF due to accumulator failures. Westinghouse concluded that, since the impact on CDF was small, the impact on LERF would also be small. The NRC staff found the Westinghouse argument to be acceptable; therefore, the impact on LERF and ICLERP for a single CT was very small.

One of the potential benefits of the proposed extended CT was the averted risk associated with avoiding a forced plant shutdown and startup. The risk associated with a forced plant shutdown and ensuing startup due to the inflexibility in current TS could be significant in comparison with the risk increase due to the proposed accumulator CT increase.

Based on the NRC staff's Tier 1 review, the quality of risk analysis used to calculate the risk impact of the proposed accumulator CT extension was reasonable and generally conservative. It was also found that the risk impact of the proposed change was below the NRC staff guidelines in RGs 1.174 and 1.177.

Tiers 2 and 3: Configuration Risk Control

Tier 2 of RG 1.177 addresses the need to preclude potentially high risk configurations which could result if certain equipment is taken out-of-service during implementation of the proposed TS change (in this case accumulator CT). If such configurations are identified, the licensee should also identify appropriate measures to avoid them.

The accumulators are always needed to mitigate large size LOCAs. Large LOCAs require accumulators to inject as analyzed under Tier 1 in order to avoid core damage. This means that if a large LOCA occurs without the accumulator function, the core will be damaged independently of whether other systems, such as HPI, function properly or not. However, the probability that a large LOCA occurs in the 24-hour CT is extremely small (in the order of 1E-7 or less). Furthermore, no compensatory or other measures are possible. Due to the negligible risk increase associated with this scenario and the fact that there are no measures to take once a large LOCA occurs, no "high risk" configurations are associated with this scenario.

In general, medium LOCAs do not require accumulators if at least one HPI train is available. This means that if a medium LOCA occurs when minimum accumulator functionality is unavailable and at the same time HPI is unavailable, the core will be damaged. However, the probability that a medium LOCA occurs in the 24-hour CT and at the same time both trains of HPI are unavailable is extremely small (in the order of 1E-8 or less), because it is assumed that the plant is not operating at power with both HPI trains out-of-service. This assumption is based on current STS that limit operation at power with no HPI capability. Therefore, no Tier 2 restrictions beyond those currently in the STS are deemed necessary.

Tier 3 calls for a program to identify "risk significant" configurations beyond those identified in Tier 2 resulting from maintenance or other operational activities and take appropriate compensatory measures to avoid such configurations. Because the accumulator sequence modeling is relatively independent of that for other systems, the Tier 2 analysis by itself is sufficient.

Furthermore, Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.65(a)(4) (Maintenance Rule) requires that licensees assess the risk any time maintenance is being considered on safety-related equipment. This requirement serves the objectives of Tier 3.

In summary, the Tier 2 evaluation did not identify the need for any additional constraints or compensatory actions that, if implemented, would avoid or reduce the probability of a risk-significant configuration. The current TS provisions were found to be sufficient to address the Tier 2 issue. Because the accumulator sequence modeling is relatively independent of that

for other systems and the implementation of the Maintenance Rule, the NRC staff concluded that application of Tier 3 to the proposed accumulator CT was not necessary.

The NRC staff finds that the proposed changes will allow safe operation with the changes in CT from 1-hour to 24 hours for Condition B of TS LCO 3.5.1, "Accumulators." The NRC staff also finds that the proposed changes are consistent with the ICCDPs calculated in WCAP-15049 for the accumulator AOT increase and meet the criterion of 5E-07 in RGs 1.174 and 1.177. The analysis and acceptance provided in this SE, as demonstrated by WCAP-15049, covers all Westinghouse nuclear steam system supplier plants regardless of plant vintage and number of loops. The licensee confirmed the applicability of the analyses and the NRC staff's model safety evaluation in its application. The NRC staff, therefore, concludes that the proposed changes are acceptable.

The change affects the discussion in the Bases section for TS 3.5.1. The licensee has included the changes with the amendment request and, for convenience, the revised Bases pages are being issued with this amendment.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the South Carolina State official and the North Carolina State official were notified of the proposed issuance of the amendments. The State officials had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (68 FR 59214). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. Reckley

Date: December 23, 2003

McGuire Nuclear Station
Catawba Nuclear Station

cc:

Ms. Lisa F. Vaughn
Duke Energy Corporation
Mail Code - PB05E
422 South Church Street
P.O. Box 1244
Charlotte, North Carolina 28201-1244

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. C. Jeffrey Thomas
Regulatory Compliance Manager
Duke Energy Corporation
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Anne Cottingham, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. Peter R. Harden, IV
VP-Customer Relations and Sales
Westinghouse Electric Company
6000 Fairview Road
12th Floor
Charlotte, North Carolina 28210

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. Michael T. Cash
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

NCEM REP Program Manager
4713 Mail Service Center
Raleigh, North Carolina 27699-4713

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Mary Olson
Director of the Southeast Office
Nuclear Information and Resource Service
729 Haywood Road, 1-A
P. O. Box 7586
Asheville, North Carolina 28802

McGuire Nuclear Station
Catawba Nuclear Station

cc:

Lee Keller
Regulatory Compliance Manager
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

North Carolina Municipal Power
Agency Number 1
1427 Meadowwood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626-0513

County Manager of York County
York County Courthouse
York, South Carolina 29745

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Henry Porter, Assistant Director
Division of Waste Management
Bureau of Solid and Hazardous Waste
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
4830 Concord Road
York, South Carolina 29745

Mr. Dhiaa Jamil
Vice President
Catawba Nuclear Station
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Mr. G. R. Peterson
Vice President
McGuire Nuclear Station
Duke Energy Corporation
2700 Hagers Ferry Road
Huntersville, North Carolina 28078