

From: David Proulx, *ETD*
 To: CSM; Dwight Chamberlain; Mike Runyan; Nease, Rebecca; Replogle, George; WBJ
 Date: 6/3/03 12:07PM
 Subject: Review of Manual Actions for DC Fire Protection

The licensee came to me today and presented an NRC letter that [redacted] NRC has previously approved of all of their manual actions in a fire scenario. The licensee applied for an exemption to Appx R so that they could take credit for flashlights in lieu of 8 hr. emergency lights. As a companion to this request, the licensee submitted their safe shutdown analysis to show where the flashlights would be needed. The NRC reviewed this application and denied the exemption to do without emergency lights.

[Large redacted block]

I will forward (fax?) the letter to you (Rebecca) for your take on it as well.

DP

BB/11