

119

11/26/03
68FR66501

From: Lisa Cohen <lcohen@cloud9.net>
To: <nrcprep@nrc.gov>
Date: Mon, Jan 5, 2004 3:26 PM
Subject: RE: PUBLIC COMMENT ON DRAFT CRITERIA ON MANUAL ACTIONS TO ACHIEVE POST-FIRE SAFE SHUTDOWN

To Whom It May Concern:

As a result of the near catastrophic fire at Browns Ferry nuclear power station in 1975, NRC is mandated by federal law to require electrical systems used for the automated shutdown of the reactor from the control room be maintained free from fire damage in the event of a serious fire. I am opposed to the proposed relaxation of enforcement of current fire code that would allow non-compliant reactor operators to sacrifice automated reactor shutdown electrical systems and instead substitute non-validated manual actions that increase unacceptable and undue risks to public health and safety and the environment in the event of fire.

Mrs. Lisa Cohen
 179 Old Post Road North
 Croton-on-Hudson, NY 10520
 January 5th, 2004

RECEIVED
 2001 JAN -6 PM 2: 00
 Rules and Directives
 Branch
 USNRC

Template = ADM-013

E-RIDB = ADM-03
 all = R. Insley (RFD)
 R. Gallucci (RHE)