

HARRIS  
OPEN ITEM



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II

SAM NUNN ATLANTA FEDERAL CENTER  
61 FORSYTH STREET SW SUITE 23785  
ATLANTA, GEORGIA 30303-8931

October 4, 2002

EA-00-022  
EA-01-310

Carolina Power & Light Company  
ATTN: Mr. James Scarola  
Vice President - Harris Plant  
Shearon Harris Nuclear Power Plant  
P. O. Box 165, Mail Code: Zone 1  
New Hill, NC 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT - NRC SUPPLEMENTAL  
INSPECTION REPORT 50-400/02-08

Dear Mr. Scarola:

On September 6, 2002, the Nuclear Regulatory Commission (NRC) performed a supplemental inspection associated with a White finding identified in the mitigating systems cornerstone at your Shearon Harris Nuclear Power Plant. The White finding involved a violation of your fire protection program resulting from a Thermo-Lag fire barrier assembly (wall) which had an indeterminate fire resistance rating. The NRC determined that portions of your corrective actions to resolve this issue were appropriate. However, the NRC noted that your planned corrective actions included the use of local manual actions as opposed to one of the protection methods identified in NRC Position C.5.b.(2) of Branch Technical Position (BTP) CMEB 9.5-1. As a result, the White finding remained open pending further NRC review of your corrective actions and the development of internal NRC inspection guidance in this area. The inspection report documenting this was transmitted to you on September 9, 2002.

Subsequent to the completion of the inspection, a Senior Reactor Analyst evaluated the risk significance of the non-conforming Thermo-Lag barrier taking into consideration your corrective actions accomplished to date. These actions included separating the auxiliary control panel room, containing the Thermo-Lag fire barrier in question, from the B Train switchgear room. This resulted in two separate fire areas, and reduced the ignition frequency of fires capable of challenging the Thermo-Lag barrier by an order of magnitude. This translated into a corresponding reduction in the core damage frequency and reduced the risk significance of the degraded Thermo-Lag barrier to that of a Green finding. Based on this, the White finding will be removed from the NRC performance summary effective the date of this letter. However,

NOTE: THE WHITE FINDING HAS NOT BEEN REMOVED FROM THE NRC PERFORMANCE SUMMARY, FOUR QUARTERS WILL TIME OUT AROUND 12/19/02, AT WHICH TIME IT WILL AUTOMATICALLY GO AWAY.

NN-29

CP&L

2

Violation (VIO) 50-400/02-08-01: Failure to Implement and Maintain NRC Approved Fire Protection Program Safe Shutdown System Separation Requirements, remains open pending further NRC review of your corrective actions and the development of internal NRC inspection guidance in this area. Please inform us when your corrective actions are sufficiently complete to permit our inspection.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publically Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Charles R. Ogle, Chief  
Engineering Branch 1  
Division of Reactor Safety

Docket No.: 50-400  
License No.: NPF-63

cc: Terry C. Morton, Manager  
Performance Evaluation and  
Regulatory Affairs - CPB 9  
Carolina Power & Light Company  
Electronic Mail Distribution

Robert J. Duncan II  
Director of Site Operations  
Carolina Power & Light Company  
Shearon Harris Nuclear Power Plant  
Electronic Mail Distribution

Benjamin C. Waldrep  
Plant General Manager--Harris Plant  
Carolina Power & Light Company  
Shearon Harris Nuclear Power Plant  
Electronic Mail Distribution

James W. Holt, Manager  
Support Services  
Carolina Power & Light Company

CP&amp;L

3

Shearon Harris Nuclear Power Plant  
Electronic Mail Distribution

John R. Caves, Supervisor  
Licensing/Regulatory Programs  
Carolina Power & Light Company  
Shearon Harris Nuclear Power Plant  
Electronic Mail Distribution

(cc cont'd - See page 3)

(cc cont'd)

William D. Johnson  
Vice President & Corporate Secretary  
Carolina Power & Light Company  
Electronic Mail Distribution

John H. O'Neill, Jr.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, NW  
Washington, DC 20037-1128

Beverly Hall, Acting Director  
Division of Radiation Protection  
N. C. Department of Environmental  
Commerce & Natural Resources  
Electronic Mail Distribution

Peggy Force  
Assistant Attorney General  
State of North Carolina  
Electronic Mail Distribution

Public Service Commission  
State of South Carolina  
P. O. Box 11649  
Columbia, SC 29211

Chairman of the North Carolina  
Utilities Commission  
P. O. Box 29510  
Raleigh, NC 27626-0510

Robert P. Gruber  
Executive Director  
Public Staff NCUC  
4326 Mail Service Center  
Raleigh, NC 27699-4326

Linda Coleman, Chairman

CP&amp;L

4

Board of County Commissioners  
of Wake County  
P. O. Box 550  
Raleigh, NC 27602

(cc cont'd - See page 4)

(cc cont'd)  
Gary Phillips, Chairman  
Board of County Commissioners  
of Chatham County  
Electronic Mail Distribution

Distribution:  
RIDSNRDDIPMLIPB  
PUBLIC

OFFICE	RII:DRS	RII:DRS	RII:DRS	RII:DRP	RII:EICS		
SIGNATURE	OGLE	CHRISTENSEN	OGLE	SHANNON	EVANS		
NAME	LENAHAN	CASTO	PAYNE	BONSER	EVANS		
DATE	10/02/2002	10/4/2002	10/2/2002	10/02/2002	10/02/2002	11/ /2002	11/ /2002
E-MAIL COPY?	YES	YES NO	YES NO	YES NO	YES	YES	YES NO
PUBLIC DOCUMENT	YES						

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRS\Eng Branch 1\Fire Protection\Harris Thermo-Lag White  
Finding\harris\_fp\_thermolagbarrier\_response.wpd