

From: "Clifford Anderson" <torvesta@surewest.net>
To: <nrcprep@nrc.gov>
Date: Fri, Jan 9, 2004 12:42 AM
Subject: Fire protection law

To Whom It May Concern:

The NRC is mandated by federal law to require electrical systems used for the automated shutdown of the reactor from the control room be maintained free from fire damage in the event of a serious fire. I am opposed to the proposed relaxation of enforcement of current fire code that would allow non-compliant reactor operators to sacrifice automated reactor shutdown electrical systems and instead substitute non-validated manual actions that increase unacceptable and undue risks to public health and safety and the environment in the event of fire.

Clifford E. Anderson
1408 La Sierra Dr.
Sacramento, CA 95864
January 8, 2004

11/26/03
68 FR FR 66501
129

RECEIVED
2004 JAN -9 PM 2:25
Rules and Directives
Branch
USNRC

E-RFDS = ADM-03
Add = R. Doolley (RFJ)
R. Gallucci (RHE)

Amplified = ADM-013