

January 14, 2004

Mr. J. A. Scalice  
Chief Nuclear Officer and  
Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2, AND 3 — APPROVAL TO USE MORE RECENT EDITION OF THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS BOILER AND PRESSURE VESSEL CODE FOR ALTERNATIVE QUALIFICATION OF VT-2 EXAMINATION PERSONNEL (TAC NOS. MC0879, MC0880, AND MC0881)

Dear Mr. Scalice:

By letter dated September 26, 2003, the Tennessee Valley Authority (TVA or the licensee) requested the U.S. Nuclear Regulatory Commission's (NRC's) approval to use a more recent edition of the American Society of Mechanical Engineers Boiler and Pressure Vessel (ASME) Code for the alternative qualification of VT-2 (visual) examination personnel. The current ASME Codes of record for the system pressure test program are the 1974 Edition, Summer of 1975 Addenda for Browns Ferry Nuclear Plant (BFN), Unit 1; 1995 Edition, 1996 Addenda for BFN Unit 2; and 1989 Edition and no Addenda for BFN Unit 3. The licensee requested approval to use paragraph IWA-2316 of the 1998 ASME Section XI Code related to the alternative qualification of VT-2 examination personnel for the remainder of the current 10-year inservice inspection interval for each unit. BFN Unit 1 is currently in the first inservice inspection interval, which began on August 1, 1974, and ends 1 year after restart of BFN Unit 1. BFN Unit 2 is currently in the third inservice inspection interval, which began on May 25, 2001, and ends on May 24, 2011. BFN Unit 3 is currently in the second inservice inspection interval, which began on November 19, 1996, and ends on November 18, 2005.

The licensee stated that paragraph IWA-2316 provides an alternative to the requirements in the ASME Section XI and that the embedded vision test requirements specified in IWA-2321, IWA-2322, and Table IWA-2322-1, are the only related requirements from the 1998 Edition which are associated with IWA-2316. The 1998 Edition up to and including the 2000 Addenda of the ASME Section XI Code were incorporated in 10 CFR 50.55a(b)(2)(xviii), with one limitation placed on the use of IWA-2316. The limitation states that it may only be used to qualify personnel that observe for leakage during system leakage and hydrostatic tests conducted in accordance with the IWA-5211(a) and (b), 1998 Edition through the latest edition and addenda incorporated by reference in paragraph (b)(2).

Title 10, *Code of Federal Regulations* (10 CFR), Section 50.55a(g)(4)(iv), states that the inservice examination of components and system pressure tests may meet the requirements set forth in subsequent editions and addenda that are incorporated by reference in Section 50.55a(b), subject to the limitations and modifications listed therein and NRC approval. Portions of the editions or addenda may be used provided that all related requirements of the

respective editions and addenda are met. TVA's request to use the portions of the 1998 ASME Section XI Code associated with alternative qualification of VT-2 examination personnel for observation of leakage during system leakage and hydrostatic tests is approved pursuant to 10 CFR 50.55a(g)(4)(iv), for the remainder of the current inservice inspection interval for each unit, subject to the following limitation: paragraph IWA-2316 of the 1998 ASME Code may only be used to qualify alternate VT-2 examiners who observe system leakage tests or fluid hydrostatic tests conducted in accordance with the IWA-5211(a) and (b), 1998 Edition through the latest edition and addenda incorporated by reference in paragraph (b)(2).

Sincerely,

*/RA/*

Allen G. Howe, Chief, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-259, 50-260, and 50-296

cc: See next page

respective editions and addenda are met. TVA's request to use the portions of the 1998 ASME Section XI Code associated with alternative qualification of VT-2 examination personnel for observation of leakage during system leakage and hydrostatic tests is approved pursuant to 10 CFR 50.55a(g)(4)(iv), for the remainder of the current inservice inspection interval for each unit, subject to the following limitation: paragraph IWA-2316 of the 1998 ASME Code may only be used to qualify alternate VT-2 examiners who observe system leakage tests or fluid hydrostatic tests conducted in accordance with the IWA-5211(a) and (b), 1998 Edition through the latest edition and addenda incorporated by reference in paragraph (b)(2).

Sincerely,  
*/RA/*

Allen G. Howe, Chief, Section 2  
 Project Directorate II  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-259, 50-260, and 50-296

cc: See next page

DISTRIBUTION:

- PUBLIC
- PDII-2 R/F
- BClayton (hard copy)
- AHowe
- KJabbour
- EHackett
- TChan
- G Hill (6 hard copies)
- SRosenberg
- OGC
- ACRS
- SCahill RII

ADAMS Accession No: ML040140762

\* See previous concurrence

OFFICE	PDII-2/PM	PDII-2/LA	EMCB/SC	OGC	PDII-2/SC
NAME	KJabbour:as	BClayton	TChan*	RHoefling*	AHowe
DATE	1/12/2004	1/12/2004	12/22/2003	1/5/2004	1/13/2004

**OFFICIAL RECORD COPY**

Mr. J. A. Scalice  
Tennessee Valley Authority

**BROWNS FERRY NUCLEAR PLANT**

cc:

Mr. Karl W. Singer, Senior Vice President  
Nuclear Operations  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager  
Nuclear Licensing  
Tennessee Valley Authority  
4X Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. James E. Maddox, Vice President  
Engineering & Technical Services  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Timothy E. Abney, Manager  
Licensing and Industry Affairs  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Mr. Ashok S. Bhatnagar, Site Vice President  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Browns Ferry Nuclear Plant  
10833 Shaw Road  
Athens, AL 35611

General Counsel  
Tennessee Valley Authority  
ET 11A  
400 West Summit Hill Drive  
Knoxville, TN 37902

State Health Officer  
Alabama Dept. of Public Health  
RSA Tower - Administration  
Suite 1552  
P.O. Box 303017  
Montgomery, AL 36130-3017

Mr. Michael J. Fecht, Acting General Manager  
Nuclear Assurance  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Chairman  
Limestone County Commission  
310 West Washington Street  
Athens, AL 35611

Mr. Michael D. Skaggs, Plant Manager  
Browns Ferry Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Decatur, AL 35609