

Susquehanna Learning Center
707 Salem Boulevard
P.O. Box 467
Berwick, PA 18603-0467
570-542-3353



November 13, 2003

Mr. John Caruso
USNRC Chief Examiner
USNRC Region 1
475 Allendale Road
King of Prussia, PA 19406-1415

Susquehanna Learning Center
Proposed Examination Materials
PLA 005695 File A14-13D

Dear Mr. Caruso:

Enclosed for your review and approval are Proposed Examination Materials for the PPL Susquehanna, LLC Initial Licensed Operator Examination Retest scheduled for Monday, December 15, 2003. These materials are submitted in accordance with NUREG 1021, "Operator Licensing Examination Standards for Power Reactors" (Draft Revision 9). The following materials are enclosed:

- Form ES-201-3, Examination Security Agreement (Up-to-Date Copy)
- **SRO Written Outline**
 - Form ES-401-1, BWR Examination Outline - SRO - Rev. 1 (5 Pages)
 - Form ES-401-3, Generic Knowledge and Abilities Outline Tier 3-SRO - Rev. 1 (1 Page)
- Form ES-401-4, Record of Rejected K/As - Rev. 1
- Form ES-401-6, Written Examination Quality Checklist - Rev. 1 (Signed)
- 25 Written Examination Questions and Answers
- Requested References
 - Full Color set of EOPs and Bases
 - Reference pages for each written question's correct answer
 - References provided to the candidates for the written examination

Modifications to the previously submitted written examination outlines have been documented and justified on Form ES-401-4, Record of Rejected K/As - Rev.1. All rejected K/As that were added to Form ES-401-4, Record of Rejected K/As - Rev.0, are highlighted in bold italics.

All Proposed Examination Materials have been validated by a Team of licensed personnel in accordance with the guidance provided within NUREG 1021, "Operator Licensing Examination Standards for Power Reactors" (Draft Revision 9).

We request these materials be withheld from public disclosure until after the completion of the exam. If you have any questions, please feel free to contact me at 570-542-3326 or Rich Brooks at 570-542-3081.

Sincerely,



Kenneth M. Roush
Manager-Nuclear Training

Response: No

Enclosures: Listed

cc: R. R. Boesch
Ops Letter File
Nuc Records-Site

rb for kr - proposed exam materials - pla 005695

RB/KMR/vah














1. Pre-Examination

Susquehanna

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of 12/15/03 as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC. Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of _____. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE	NOTE
1. Richard J. Brooks	Exam Developer		10/1/03			
2. R. H. HALL	EXAM Developer		10/1/03			
3. Terry W. Logsdon	Exam Developer		10/1/03			
4. K M Roush	Mgr Nuclear Training ^{Facility} Reviewer		10/9/03			
5. Robert Boesch	Supv. - Ops Instruction		10/9/03			
6. James K. Williams	Unit Supervisor		10/28/03			
7. Mike Boyle	Unit Supervisor		10/28/03			
8. Bill Morris	Unit Supervisor		11/04/03			
9. Abdul Kadir	Unit Superv / Exam Review		11/4/03			
10. Greg Foster	Project Digital Control Analyst		11/4/03		11/4/03	
11. John PETRILLA III	UNIT SUPERVISOR		11/12/03			
12. Tom Fedorko	Unit Supervisor		11/12/03			
13.						
14.						
15.						

NOTES:

SSES SRO NRC Re-Exam

- 1 Unit 1 is at 100% power with total core flow of 102 mlbm/hr.

A scoop tube lock occurred during a pressure transient on Recirc MG A lube oil system.

During this locked scoop tube condition, how will a flow runback and/or recirc pump trip transient affect final position on power to flow map, compared to normal recirculation conditions?

- A. Either RRP tripping will now result in invalid total core flow indication. Use of core pressure drop to calculate core flow would be necessary before power to flow map position can be determined.
- B. A limiter 1 or 2 flow runback will result in no difference in power and flow conditions.
- C. RRP A will not automatically trip from a EOC-RPT condition. A higher power and flow condition will result.
- D. A limiter 2 flow runback will now result in a higher power and flow condition.

Question Data

D A limiter 2 flow runback will now result in a higher power and flow condition.

Explanation/Justification:

- A. when the operating RRP speed is above 75% core flow indication is accurate, below 75% speed core pressure drop is used to calculate total core flow.
- B. a flow runback from limiter 1 or 2 will not affect RRP A, therefore a higher power to flow condition is expected when the plant stabilizes.
- C. a scoop tube lock does not prevent a trip.
- D. is correct. RRP A will not respond to a runback signal while the scoop tube is locked, therefore a higher power to flow condition is expected when the plant stabilizes. The situation given is a compound problem which is beyond RO expectations. The information for the original problem, scoop tube lock, needs to be assimilated with the additional information or potential problem of trip and or runback.

Sys #	System	Category	KA Statement
295001	Partial or Complete Loss of Forced Core Flow Circulation	Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION:	Power/flow map
K/A#	295001.AA2.01	K/A Importance 3.8	Exam Level SRO
References provided to Candidate	None	Technical References:	ON-164-002
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 4
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	1357	Determine if the Plant responded correctly to an off-normal situation.	
Training Task:	64ON010	Implement Loss Of Reactor Recirculation Flow	

SSES SRO NRC Re-Exam

- 2 Both Units were at 100% initial power when a station blackout occurs.

Which of the Emergency Diesel Generators should you select to substitute with E Emergency Diesel Generator and why?

- A. Substitute for A or B Emergency Diesel Generators to eliminate the need for hooking up 'Blue Max'.
- B. Substitute for D Emergency Diesel Generator to supply class 1E 250 VDC loads with their chargers.
- C. Substitute for A or B Emergency Diesel Generators because 125 VDC control power availability is maximized.
- D. Substitute for C Emergency Diesel Generator to make one loop of RHR suppression pool cooling operable.

Question Data

C Substitute for A or B Emergency Diesel Generators because 125 VDC control power availability is maximized.

Explanation/Justification:

- A. the portable diesel generator is required for 125 VDC channel B.
- B. all class 1E 250 VDC loads are not supplied from bus 1D.
- C. is correct. Core Damage is four times less likely if A and B Emergency Diesel Generators are aligned compared to C and D Emergency Diesel Generators.
- D. an operable loop of RHR SPC is not available with bus 1C energized.

Sys #	System	Category	KA Statement
<u>295003</u>	Partial or Complete Loss of A.C. Power	Emergency Procedures and Plan	Knowledge of the bases for prioritizing safety functions during abnormal/emergency operations.
K/A#	<u>295003.2.4.22</u>	K/A Importance <u>4.0</u>	Exam Level <u>SRO</u>
References provided to Candidate	None	Technical References:	<u>EO-100-030</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Fundamental	10 CFR Part 55 Content:	55.43
Training Objective:	2645	Prioritize the order in which multiple Emergency Support procedures are to be performed. {SRO only}	
Training Task:	00EO024	Implement Unit 1(2) Response To Station Blackout	

SSES SRO NRC Re-Exam

- 3 Unit 1 is in MODE 2.
During performance of SO-150-002, "Quarterly RCIC Flow Verification" annunciator, 250V DC PANEL 1L650 SYSTEM TROUBLE (AR-106-A11) is received.

The 1L650 reflash panel alarm 250 VDC System Low Voltage is present and battery terminal voltage is 218 VDC.

What actions are required?

- A. Direct performance of SM-188-002, "250 VDC Station Batteries Quarterly Electrical Parameter Checks". Verify pilot cell parameters meet Table 3.8.6-1 Category C limits within 1 hour or declare 1D650 inoperable.
- B. Direct performance of SM-188-002, "250 VDC Station Batteries Quarterly Electrical Parameter Checks". Enter the E-plan under an ALERT classification.
- C. Declare 250 VDC battery 1D650 inoperable. Ensure MODE 1 is not entered until the battery is operable.
- D. Declare 250 VDC battery 1D650 inoperable. Entry into MODE 1 is allowed with this battery inoperable.

Question Data

C Declare 250 VDC battery 1D650 inoperable. Ensure MODE 1 is not entered until the battery is operable.

Explanation/Justification:

- A. SM-188-002 verifies battery cell parameters for category B limits. TS required actions verify category C limits are being met.
- B. E-Plan entry is not required based on a single DC system being inoperable.
- C. is correct. The AR addresses compliance with numerous TS, since SR 3.8.4.1 requires 250 VDC battery voltage equal to or greater than 258 VDC for battery operability.
- D. entry into Mode 1 is not allowed since the action for an inop battery will require going to mode 3.

Sys #	System Partial or Complete Loss of D.C. Power	Category Emergency Procedures and Plan	KA Statement Knowledge of annunciator response procedures.
K/A#	295004.2.4.10	K/A Importance 3.1	Exam Level SRO
References provided to Candidate	Tech Specs, AR-106-A11	Technical References:	AR-106-A11, TS 3.8.4 & 3.8.6
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis		10 CFR Part 55 Content: 55.43
Training Objective:	1397	Predict how each supported system will be affected by any of the following 250 Volt DC System failures. a. Blown Fuse b. Ground c. Battery Charger Trip (Effect on Tech Spec LCO) d. Loss of 250 VDC System	
Training Task:	88ON003	Implement Loss Of 250V DC Bus	

SSES SRO NRC Re-Exam

4

Unit 1 was at 100% power when grid instabilities result in activation of EHC power load unbalance protection circuitry. Subsequent to the reactor scram the unit is stabilized with the following conditions:

- Reactor water level + 5 inches
- Reactor pressure ~955 psig controlled with bypass valves
- RPV bottom head drain temperature is 380 deg F

Which of the following subsequent operator actions for reactor water level control should you direct based on these conditions?

- A. Maintain level -30 to +5 inches.
- B. Restore level +13 to +30 inches.
- C. Restore and maintain level +45 to +54 inches.
- D. Restore level +13 to +54 inches.

Question Data

B Restore level +13 to +30 inches.

Explanation/Justification:

- A. no bases for level band, -30 inches is initiation setpoint for RCIC
- B. correct level band with stratification and no recirc pump in service. Must determine the delta T between bottom head temp and saturation temp using steam tables, recognize delta T is greater than 145 deg F and from memory know the proper level band for control of +13 to +30 inches.
- C. level band when delta T is equal to or less than 145 deg F
- D. level band requires at least one recirc pump in service

Sys #	System	Category	KA Statement
	SCRAM	Conduct of Operations	Ability to direct personnel activities inside the control room.
K/A#	295006.2.1.9	K/A Importance 4.0	Exam Level SRO
References provided to Candidate	Steam Tables	Technical References:	ON-100-101
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	1364	Explain the reasons for steps contained in an off-normal procedure.	
Training Task:	00ON018	Implement Scram	

SSES SRO NRC Re-Exam

- 5 A control room evacuation was required. A transfer switch malfunction caused loss of RHR pump control at Unit 1 Remote Shutdown Panel 1C201.

As Unit Supervisor what direction will be given to start an RHR pump when using the MANUAL method for suppression pool cooling?

- A. At 1A20102 RHR PUMP 1A breaker, transfer DC Trip and Control power to alternate, pull the lateral control switch to HANDLE OUT position and place the lateral control switch to CLOSE for RHR pump 1A.
- B. At 1A20102 RHR PUMP 1A breaker, pull the lateral control switch to HANDLE OUT position and place the lateral control switch to CLOSE for RHR pump 1A.
- C. At 1A20⁴202 RHR PUMP ^{1D}~~1A~~ breaker, pull the lateral control switch to HANDLE OUT position and place the lateral control switch to CLOSE for RHR pump ~~1A~~ ^{1B}. ^D
- D. At 1A20202 RHR PUMP 1B breaker, OPEN the DC Trip and Control knife switch and place the lateral control switch to CLOSE for RHR pump 1B.

Question Data

B At 1A20102 RHR PUMP 1A breaker, pull the lateral control switch to HANDLE OUT position and place the lateral control switch to CLOSE for RHR pump 1A.

Explanation/Justification:

- A. DC trip and control power is not transferred to alternate for this evolution.
- B. is correct. The B loop of RHR is controlled from the Remote Shutdown Panel, the manual backup method uses the RHR loop A. In addition to manual valve alignment required to use RHR loop A, pump operation is accomplished by pulling the lateral control switch to the out position thereby transferring control locally at the breaker. Placing the control switch to CLOSE will start the RHR pump A providing 125 VDC control power is available. SRO responsible to implement an off normal situation
- C. 1B RHR pump is not the manual method for Unit 1.
- D. DC trip and control power is not opened for this evolution.

Sys #	System	Category	KA Statement
	Control Room Abandonment	Conduct of Operations	Ability to locate and operate components, including local controls.
K/A#	<u>295016.2.1.30</u>	K/A Importance <u>3.4</u>	Exam Level <u>SRO</u>
References provided to Candidate	None	Technical References:	<u>OP-149-005</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>3</u>
Question Cognitive Level:	Fundamental	10 CFR Part 55 Content:	<u>55.43</u>
Training Objective:	1489	List the RPV Instrumentation functions and components that can be operated from the Remote Shutdown Panel.	
Training Task:	00ON025	Implement Plant Shutdown From Outside Control Room	

SSES SRO NRC Re-Exam

6 Unit 1 is at 100% power.

A RWCU pump trip and system isolation was preceded by the following two alarms:

- AR-101-B01, RWCU FILTER INLET HI TEMP
- AR-101-A01, RWCU FILTER INLET HI TEMP ISO

Which of the following events is responsible for the RWCU response and what administrative action is required?

- A. Insufficient RWCU blowdown flow to main condenser or Liquid Radwaste. Notify chemistry to align reactor coolant sampling to Reactor Recirc Loop B.
- B. High Reactor Building Chilled Water temperature caused isolation of RBCCW to RWCU non-regenerative heat exchanger. Perform an eight hour ENS notification due to an unplanned actuation of systems that mitigate the consequences of significant events.
- C. TCV 11028 SW Temperature Control valve for RBCCW failed closed. Obtain a grab sample conductivity measurement every 24 hours.
- D. Low flow in Reactor Building Chilled Water caused isolation of RBCCW to RWCU non-regenerative heat exchanger. Obtain an in-line conductivity measurement once per 4 hours.

Question Data

D Low flow in Reactor Building Chilled Water caused isolation of RBCCW to RWCU non-regenerative heat exchanger. Obtain an in-line conductivity measurement once per 4 hours.

Explanation/Justification:

- A. excessive blowdown flow can lead to high temperature isolation, not insufficient flow. Continuous conductivity monitoring is continued by aligning sampling to reactor recirc loop B.
 - B. high RBCW temperature will not cause isolation of RBCCW to RWCU non-regenerative heat exchanger. High temperature isolation of RWCU is not reportable IAW NDAP-QA-720.
 - C. loss of service water cooling would lead to high temperature isolation of RWCU. If continuous conductivity recording is not available from RWCU grab sample conductivity measurement is required one per 4 hours per TRO 3.4.1
 - D. is correct. A low RBCW flow signal with a 13 second time delay will cause isolation of RBCCW to RWCU non-regenerative heat exchanger. If continuous conductivity recording is not available, in-line conductivity measurement is required one per 4 hours per TRO 3.4.1.
- Continuous conductivity monitoring is continued by aligning sampling to reactor recirc loop B.

Sys #	System	Category	KA Statement
295018	Partial or Complete Loss of Component Cooling Water	Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER:	Cause for partial or complete loss
K/A#	295018.AA2.03	K/A Importance 3.5	Exam Level SRO
References provided to Candidate	TRO 3.4.1	Technical References:	ON-134-001
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	1358	Determine a course of action to mitigate or correct an off-normal situation.	
Training Task:	34ON005	Implement Loss Of Reactor Building Chilled Water	

SSES SRO NRC Re-Exam

7 Unit 1 was at 100% power when a reactor scram occurred with the following conditions:

- No control rod movement.
- Equipment failures require boron injection with RCIC.
- The RCIC suction hose connection uncouples and drains ~600 gallon to the RCIC room floor before it is isolated.
- Initial SBLC tank level was 4900 gallons.
- Suction line repairs have allowed boron injection with RCIC.

For these conditions what is the maximum SBLC tank level before you direct RPV water level restored and maintained +13 to +54 inches?

- A. 2500 gallons
- B. 2800 gallons
- C. 1800 gallons
- D. 200 gallons

Question Data

A 2500 gallons

Explanation/Justification:

- A. correct based upon injection started at 4300 gallons minus 1800 gallons injection required for hot shutdown boron weight.
- B. value directed from EOP assuming Tech Spec minimum SBLC tank volume or 4587 gallons.
- C. no bases for this tank volume, this value is the amount required to be injected as listed in the procedure.
- D. tank volume required to trip SBLC pumps, per EOP direction. Also, at this volume cold shutdown boron weight should have been injected.

Sys #	System	Category	KA Statement
295037	SCRAM Condition Present and Reactor Power Above APRM Downscale or Unknown	Ability to determine and/or interpret the following as they apply to SCRAM CONDITION PRESENT AND REACTOR POWER ABOVE APRM DOWNSCALE OR UNKNOWN:	SBLC tank level
K/A#	295037.EA2.03	K/A Importance 4.4	Exam Level SRO
References provided to Candidate	None	Technical References:	EO-000-113 step LQ/L
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Fundamental	10 CFR Part 55 Content:	55.43
Training Objective:	1215	Define and/or discuss the operational implications of the following terms for the Standby Liquid Control System:	
		a. Hot Shutdown boron weight	
		b. Cold Shutdown boron weight	
Training Task:	00EO031	Implement Level/Power Control	

SSES SRO NRC Re-Exam

- 8 Both Units are in MODE 1 at 100% power.
 E Emergency Diesel Generator is not aligned for Standby Automatic Operation.
 The fire protection system auto initiated and suppressed a fire in C Emergency Diesel panel 0C519C.
 Emergency Diesel Generator C was transferred to Local while a damage assessment is completed.
 B SGTS is out of service for replacement of 'B' SBTG FAN INLET DAMPER HD-07553B.

Given the following time line:

10/5/03 0500 B SGTS is inoperable.

10/6/03 0920 Emergency Diesel Generator C transferred to Local.

The maximum time permitted for both units to enter MODE 3 is:

- A. 0220 on 10/7/03
- B. 2120 on 10/12/03
- C. 2120 on 10/9/03
- D. 0520 on 10/7/03

Question Data

D 0520 on 10/7/03

Explanation/Justification:

- A. Time permitted to enter MODE 3 if LCO 3.03 was entered after SBTGS A was declared inoperable in accordance with TS 3.8.1.B.2.
- B. time permitted to enter MODE 3 for failure of D/G C only per TS 3.8.1. Action B.4 requires D/G restoration in 6 days from discovery of failure to meet LCO (0920 10/12/03); enter TS 3.8.1 Condition E, be in MODE 3 in 12 hours (2120 10/12/03).
- C. time to enter MODE 3 for failure of D/G C only per TS 3.8.1. Action B.4 requires D/G restoration in 72 hours (0920 10/9/03); enter TS 3.8.1 Condition E, be in MODE 3 in 12 hours (2120 10/9/03).
- D. is correct D/G C being inoperable per TS 3.8.1 Condition B at 0920 on 10/6/03; TS 3.8.1 required action B.2 declares A SBTGS inoperable after 4 hours since B SBTGS has been inoperable (1320 on 10/6/03); enter TS 3.6.4.3 Condition D for 2 SBTGS subsystems inoperable with completion time of 4 hours (1320 on 10/6/03); Enter TS 3.6.4.3 Condition E after 4 hours (1720 10/6/03); TS 3.6.4.3 required action be in MODE 3 in 12 hours (0520 on 10/7/03)

Sys #	System Plant Fire On Site	Category Conduct of Operations	KA Statement Knowledge of conditions and limitations in the facility license.
K/A#	600000.2.1.10	K/A Importance 4.0	Exam Level SRO
References provided to Candidate	Tech Spec 3.8.1, 3.6.4.3 & SO-024-013	Technical References:	TS 3.8.1, TS 3.6.4, 3.6.4.3, SO-024-013
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 4
Question Cognitive Level:	Analysis		10 CFR Part 55 Content: 55.43
Training Objective:	2263	Given a set of Unit 1(2) Technical Specifications and a set of plant conditions, determine if a Diesel Generator is required to be operable per Technical Specifications.	
Training Task:	00TS001	Ensure Plant Operates In Accordance With The Operating License, Technical Specifications (TS), and Technical Requirements Manual (TRM)	

SSES SRO NRC Re-Exam

- 9 Unit 1 has scrammed from 100% power when MSIVs closed and the following conditions exist:
- EO-100-102 has been entered.
 - HPCI and RCIC injected for level control
 - HPCI now in service CST to CST for pressure control.
 - RCIC shutdown
 - Suppression Pool Cooling has not been placed in service.
 - Suppression Pool bulk water temperature, point MAT37 on the PICSY format, CONTAINMENT ATMOSPHERIC CONTROL, indicates Red at 90 deg F.
 - Alarms on 1C601, SUPP POOL DIV 1 AVERAGE TEMP HI (AR-111-F04) and SUPP POOL DIV 2 AVERAGE TEMP HI (AR-112-F04) have been received.
 - SPOTMOS Div I & II are in alarm indicating 101 deg F and 103 deg F respectively.

Assess these Suppression Pool water temperature indications and determine what actions are required.

- A. The SRV used for pressure control should have caused the MAT 37 point to indicate the same as SPOTMOS, contact I&C to investigate failed temperature input. Direct RHR Suppression Pool Cooling to be placed in service.
- B. The MAT 37 point on the PICSY format has failed, contact I&C to investigate failed temperature input. Direct RHR Suppression Pool Cooling to be placed in service.
- C. HPCI exhaust steam has heated the bulk of the Suppression Pool. Direct 'A' Loop of RHR Suppression Pool Cooling to be placed in service.
- D. HPCI exhaust steam is heating a local area of the Suppression Pool. Direct 'B' Loop of RHR Suppression Pool Cooling to be placed in service.

Question Data

- D HPCI exhaust steam is heating a local area of the Suppression Pool. Direct 'B' Loop of RHR Suppression Pool Cooling to be placed in service.

Explanation/Justification:

- A. Use of one SRV for pressure control could cause local high temperatures. The temperature elements used for MAT 37 do not indicate in the local area of the HPCI exhaust into the Suppression Pool. MAT 37 uses 6 temp elements at the pool surface plus 4 temp elements located at the bottom of the pool. The 4 temps at the bottom of the pool will be much cooler than the 6 surface elements used for SPOTMOS. Since MAT 37 uses the 4 lower temp elements with the 6 upper elements and SPOTMOS uses only the 6 upper elements it is expected that SPOTMOS will indicate higher than the mat 37 POINT. With no RHR Suppression Pool Cooling in service there is no mixing of the bulk sup pool water allowing a local area and the surface of the pool water to indicate high temperature which will be seen by the averaging circuit.
- B. The temperature elements used for MAT 37 do not indicate in the local area of the HPCI exhaust into the Suppression Pool. MAT 37 uses 6 temp elements at the pool surface plus 4 temp elements located at the bottom of the pool. The 4 temps at the bottom of the pool will be much cooler than the 6 surface elements used for SPOTMOS. Since MAT 37 uses the 4 lower temp elements with the 6 upper elements and SPOTMOS uses only the 6 upper elements it is expected that SPOTMOS will indicate higher than the mat 37 POINT. With no RHR Suppression Pool Cooling in service there is no mixing of the bulk sup pool water allowing a local area and the surface of the pool water to indicate high temperature which will be seen by the averaging circuit.
- C. indications provided are a result of local heating of the suppression pool not an over all heatup of the water.
- D. Correct answer, With HPCI in service and no Suppression Pool mixing, a local area of the Suppression Pool will heat up and the procedure directs that 'B' loop of RHR be placed in Suppression Pool Cooling. 'B' Loop is the preferred loop due to the location of the RHR suction and discharge in relation to the HPCI exhaust. SRO responsible to determine if preferred loop is the appropriate loop to place in service based on overall conditions.

Sys #	System	Category	KA Statement
-------	--------	----------	--------------

SSES SRO NRC Re-Exam

295013 High Suppression Pool Ability to determine and/or interpret the following as Localized heating/stratification
 Temperature they apply to HIGH SUPPRESSION POOL
 TEMPERATURE:

K/A# 295013.AA2.02 K/A Importance 3.5 Exam Level SRO

References provided to Candidate None Technical References: AR-112-001

Question Source: New Susquehanna, 10/2/2003 Level Of Difficulty: (1-5) 3

Question Cognitive Level: Analysis 10 CFR Part 55 Content: 55.43

Training Objective: 337 Determine if SPOTMOS readings are appropriate for stated Suppression Pool level.

Training Task: 59ON006 Implement Containment Isolation

SSES SRO NRC Re-Exam

- 10 A large primary system line break has occurred with blowout panel actuation and the following conditions are indicated:

Noble gas activity has been detected by OSCAR at the site boundary.
 Area Radiation Monitors in Unit 1 Reactor Building unchanged.
 Area Radiation Monitors on 818' Elevation for Unit 1 and Unit 2 unchanged.
 Unit 1 Reactor Building SPING Noble Gas channel unchanged.
 Area Radiation Monitors in Unit 1 Turbine Building trending upward.
 Unit 1 Turbine Building SPING Noble Gas channel trending upward.
 Security reports vapor plumes above the Unit 1 CST, and from the upper west side of Unit 1 Reactor Building.

The TSC Dose calculator calls the Control Room Emergency Director to find out the source of the release. What response should the Control Room Emergency Director provide to the Dose Calculator?

The source of the release is:

- A. Reactor Water Cleanup primary coolant line break in the RWCU room.
- B. HPCI Room Steam Line break.
- C. Main Steam Line Break in the Reactor Building Steam Tunnel
- D. Main Steam Line Break in the Turbine Building at the Reactor Feed Pumps

Question Data

C Main Steam Line Break in the Reactor Building Steam Tunnel

Explanation/Justification:

- A. For a break in the RWCU room there would be no release into the Reactor Building because the Reactor Water Cleanup Room has BDIDs isolating the building ventilation. A major line break in the Reactor Water Cleanup room will cause the rupture disk for the room to actuate releasing energy/radioactive material to the environment in the Unit 1 CST area.
- B. HPCI Room does not have Back Draft Isolation Dampers (BDIDs) and would cause radiation levels in the Reactor Building to increase and only one vapor plume from the CST berm area
- C. Correct answer, steam line break in the Reactor Building Steam Tunnel will not be seen on any radiation monitors in the Reactor Building due to back draft isolation dampers going closed. A major steam leak in the RB Steam Tunnel will lift the blow out panels in the steam tunnel to the atmosphere and to the Turbine Building which provides a vapor plume in two places.
- D. There will be no release into the Reactor Building and no vapor plume into the CST berm area.

Sys #	System	Category	KA Statement
295017	High Off-Site Release Rate	Ability to determine and/or interpret the following as they apply to HIGH OFF-SITE RELEASE RATE:	Source of off-site release
K/A#	295017.AA2.04	K/A Importance 4.3	Exam Level SRO
References provided to Candidate	None	Technical References:	FSAR APPENDIX 3.6A
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 4
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	EP010-3	List common pathways for radioactive source terms to exit the plant and the impact of the off-site exposure based on the pathway.	
Training Task:	00EO028	Implement Secondary Containment Control	

SSES SRO NRC Re-Exam

- 11 Which combination of Reactor building Area temperatures would indicate equipment operability has degraded to the point where procedure EO-100-104, "Secondary Containment Control" would require a reactor shutdown?
- A. RWCU Pump Room 165 deg F AND RCIC Equipment Area 175 deg F.
 - B. HPCI Equipment Area 175 deg F AND HPCI Emerg Area Cooler 173 deg F.
 - C. CS Pump Room B 148 deg F AND RHR Equipment Area 1 128 deg F.
 - D. CS Pump Room A 116 deg F AND CS Pump Room B 120 deg F.

Question Data

A RWCU Pump Room 165 deg F AND RCIC Equipment Area 175 deg F.

Explanation/Justification:

- A. correct, Two areas are addressed and both are above max safe values.
- B. Both temperatures are greater than max safe values but only affect one area.
- C. Two areas are addressed. CS PUMP ROOM B is greater than max safe area for one area, but RHR is below max safe value.
- D. Two areas are addressed but neither room is above max safe value.

Sys #	System	Category	KA Statement
295032	High Secondary Containment Area Temperature	Ability to determine and/or interpret the following as they apply to HIGH SECONDARY CONTAINMENT AREA TEMPERATURE:	Equipment operability
K/A#	<u>295032.EA2.02</u>	K/A Importance <u>3.5</u>	Exam Level <u>SRO</u>
References provided to Candidate	EO-100-104	Technical References:	EO-100-104
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 2
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	2597	Explain the basis for each caution and note in EO-100-100.	
Training Task:	00EO028	Implement Secondary Containment Control	

SSES SRO NRC Re-Exam

- 12 Unit 1 is operating normally at 100 % power, when a leak into the 'B' Core Spray Pump Room occurs. The leak is isolated and water level stops rising when it reaches "Max Safe Level" for the room.

In addition to the Core Spray equipment, the 'B' Core Spray Room contains the HPCI SYSTEM INSTR RACK, 1C014, which has one division of HPCI Turbine Trip pressure switches located on it.

Which of the following Technical Specification actions if any, are required as a result of reaching "Max Safe Level" water level for the room?

- A. Immediately verify by administrative means that RCIC is operable and restore HPCI to OPERABLE status within 14 days and restore low pressure ECCS injection/spray subsystem to OPERABLE status within 7 days.
- B. Place the affected HPCI instrument channels to trip within 24 hours then immediately verify by administrative means that RCIC is operable and restore HPCI to operable status within 14 days.
- C. 'B' Core Spray and HPCI are both operable. No Technical Specification actions are required.
- D. Restore low pressure ECCS injection/spray subsystem to OPERABLE status and be in MODE 3 within 12 hours.

Question Data

- B** Place the affected HPCI instrument channels to trip within 24 hours then immediately verify by administrative means that RCIC is operable and restore HPCI to operable status within 14 days.

Explanation/Justification:

- A. Distracter fails to recognize the that the Max Safe Level for the 'B' Core Spray room is the HPCI high pressure exhaust pressure switches. The max safe level does not impact any equipment associated with Core Spray.
- B. Correct answer. To correctly answer, the definition of max safe water level must be understood. Definition: Max Safe operating water levels are ECCS room water levels at or above the elevation that would submerge equipment necessary to assure safe shutdown of the plant. The 'B' Core Spray room contains the HPCI high pressure exhaust switches which are noted in the EOP basis. Given the definition of max safe water level, it is assumed that the pressure switches would be inop. Inop pressure switches require that the channel be placed in trip in 24 hours which would inop HPCI.
- C. 'B' Core Spray is operable and not affected by the water level at Max Safe, HPCI is inoperable due to instrumentation on the instrument rack being under water at the Max Safe level.
- D. The Core Spray equipment is not affected with the water level in the room at the Max Safe Level.

Sys #	System	Category	KA Statement
295036	Secondary Containment High Sump/Area Water Level	Ability to determine and/or interpret the following as they apply to SECONDARY CONTAINMENT HIGH SUMP/AREA WATER LEVEL:	Operability of components within the affected area
K/A#	<u>295036.EA2.01</u>	K/A Importance <u>3.2</u>	Exam Level <u>SRO</u>
References provided to Candidate	Tech Spec	Technical References:	<u>TS 3.3.6.1, 3.5.1</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>3</u>
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	<u>55.43</u>
Training Objective:	2598	For each Symptom Based EOP: Explain the basis for each step.	
Training Task:	00EO028	Implement Secondary Containment Control	

SSS SRO NRC Re-Exam

- 13 Unit 1 at ~7 % power, Reactor pressure 955 psig, 2 Bypass Valves open, starting up from refueling. Plant startup on hold to perform HPCI Post Maintenance Testing, and quarterly flow verification surveillance before transferring the mode switch to RUN.

At 0100 hours the Reactor pressure and flow conditions necessary to perform the test were met.

At 0130 hours SO-152-002, "Quarterly HPCI Flow Verification" test was begun.

At 0145 hours with HPCI turbine at 2500 rpm valve HPCI L-O CLG WTR HV-156-F059 unexpectedly closes, and cannot be re-opened.

If the HPCI turbine continues to run, what alarms ~~should~~ actuate?

What, if any, ~~Technical Specification~~ actions will be required?

- A. Only HPCI TURBINE OIL COOLER DSCH HI TEMP (AR-114-D03) alarm will actuate.
HPCI remains OPERABLE. No ~~Technical Specification~~ actions required.
- B. HPCI TURBINE OIL COOLER DSCH HI TEMP (AR-114-D03) and HPCI BARO CDSR VACUUM TANK HI PRESSURE (AR-114-G01) alarms will actuate.
After 1300 hours, declare HPCI INOPERABLE and apply ~~Technical Specification Action 3.5.1 for Condition D.~~
- C. Only the HPCI BARO CDSR VACUUM TANK HI PRESSURE (AR-114-G01) alarm will actuate.
HPCI remains OPERABLE. No ~~Technical Specification~~ actions required.
- D. HPCI TURBINE OIL COOLER DSCH HI TEMP (AR-114-D03) and HPCI BARO CDSR VACUUM TANK HI PRESSURE (AR-114-G01) alarms will actuate.

Immediately declare HPCI INOPERABLE and apply ~~Technical Specification Action 3.5.1 for Condition D.~~

Question Data

D HPCI TURBINE OIL COOLER DSCH HI TEMP (AR-114-D03) and HPCI BARO CDSR VACUUM TANK HI PRESSURE (AR-114-G01) alarms will actuate.

Immediately declare HPCI INOPERABLE and apply Technical Specification Action 3.5.1 for Condition D.

Explanation/Justification:

- A. The HPCI BARO CDSR VACUUM TANK HI PRESSURE (AR-114-G01) alarm will also actuate. Cooling water for the RCIC turbine is a parallel flowpath, candidate may confuse HPCI and RCIC cooling water flowpaths. IF candidate does not recognize that this is a necessary support system for HPCI to perform its function, then the candidate would select HPCI remains OPERABLE. No Technical Specification actions required.
- B. The alarms listed are correct, however the Technical Specification 12 hour allowance to complete the surveillance does not allow for waiting until the original 12 hour period expires before declaring the system INOPERABLE. Since the cooling subsystem is a necessary support system for HPCI to perform its function, HPCI should be declared INOPERABLE and Technical Specification Action 3.5.1 for Condition D is applied.

SSES SRO NRC Re-Exam

- C. The HPCI TURBINE OIL COOLER DSCH HI TEMP (AR-114-D03) alarm will also actuate. IF candidate does not recognize that this is a necessary support system for HPCI to perform its function, then the candidate would select HPCI remains OPERABLE. No Technical Specification actions required.
- D. Correct Answer, With F059 closed cooling water to the lube oil cooler and the barometric condenser is isolated. Lube oil will heat up and the barometric condenser pressure will increase causing both alarms listed. The cooling subsystem is a necessary support system for HPCI to perform its function, HPCI should be declared INOPERABLE and Technical Specification action 3.5.1 for Condition D is applied.

Sys #	System	Category	KA Statement
206000	High Pressure Coolant Injection System	Ability to (a) predict the impacts of the following on the HIGH PRESSURE COOLANT INJECTION SYSTEM (HPCI); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:	Valve closures: BWR-2, 3, 4
K/A#	<u>206000.A2.02</u>	K/A Importance <u>3.5</u>	Exam Level <u>SRO</u>
References provided to Candidate	Tech Specs 3.5	Technical References:	AR-114-D03 & G01, TS 3.5.1, (178)
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	2030	Describe the flowpaths for any mode of operation of the High Pressure Coolant Injection System, including the following components in the description as appropriate.	
		a. Main Steam Line	b. Containment Isol
Training Task:	52EO008	Implement HPCI Turbine Isolation, Trip And Initiation Bypass	

SSES SRO NRC Re-Exam

- 14 Which of the following proposed changes will require a complete 10 CFR 50.59 "EVALUATION", prior to implementing the change?
- A. Moving the TSC emergency response facility from the Control Structure to the West Building located outside the fence.
 - B. Permanently raising the S&A Building channel ARM Hi Alarm setpoint.
 - C. Moving the Security perimeter fence to include the entire 500kV yard as part of the onsite facilities.
 - D. Permanently removing the motor operator and check valve internals for the FW INLET LINE A & B STOP CKV (HV-141F032A&B)

Question Data

D Permanently removing the motor operator and check valve internals for the FW INLET LINE A & B STOP CKV (HV-141F032A&B)

Explanation/Justification:

- A. Emergency Plan facilities are regulated by 10 CFR 50.47.
- B. ARM setpoints have no automatic function and apply to 10 CFR 20 not to any SCC.
- C. Security systems and designs are regulated by 10 CFR 73.
- D. Correct answer, these check valves are on the main feedwater header and are part of the containment boundary, as described in the FSAR.

Sys #	System	Category	KA Statement
	Reactor Water Level Control System	Equipment Control	Knowledge of the process for determining if the proposed change, test or experiment increases the probability of occurrence or consequences of an accident during the change, test or experiment.
K/A#	<u>259002.2.2.9</u>	K/A Importance <u>3.3</u> <i>NONE</i>	Exam Level <u>SRO</u>
References provided to Candidate	50.59 Screen Att <i>^</i>	Technical References:	<u>NDAP-QA-0726</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>4</u>
Question Cognitive Level:	Analysis		10 CFR Part 55 Content: <u>55.43</u>
Training Objective:	3925	Be able to DEFINE:	
		a. Commitment Document	
		b. Expedited Review Revision	
		c. Intent Change	
		d. Interim Approval	
		e. Quality Assurance Document Review (QADR)	
		f. Safety-Related	
		g. Technical Review	
		h. 50.59 Evaluation	
Training Task:	00AD028	Implement Nuclear Department Procedure Program	

SSES SRO NRC Re-Exam

15 A loss of coolant is in progress on Unit 1 with the following plant conditions:

- No offsite power, all Emergency Diesel Generators running and loaded.
- EO-100-114 "RPV Flooding" implemented to step RF-13.
- Division I & II Core Spray and RHR LPCI at rated flow with Reactor Pressure at 95 psig.

Predict the response of the 'A' loop of LPCI if the 'C' Emergency Diesel Generator trips and describe directions provided to control the situation.

- A. 'C' RHR Pump will coast down, 'A' RHR pump trips on over current. Place RHRSW X-Tie in service to regain RPV level, monitor RPV to Suppression Chamber pressure differential and reset the time RPV Flooding conditions were met, as required.
- B. 'C' RHR Pump will trip, 'A' RHR pump not in runout condition. Monitor RPV to Suppression Chamber pressure differential and reset the time RPV Flooding conditions were met, as required.
- C. 'C' RHR Pump will trip, 'A' RHR pump in runout condition. Throttle LPCI injection flow, Monitor RPV to Suppression Chamber pressure differential and reset the time RPV Flooding conditions were met, as required.
- D. 'C' RHR Pump will coast down, 'A' RHR pump trips on over current. Monitor 'B' loop LPCI not in runout and contact TSC to enter EP-DS-003 "RPV Level Determination".

Question Data

B 'C' RHR Pump will trip, 'A' RHR pump not in runout condition. Monitor RPV to Suppression Chamber pressure differential and reset time of RPV Flooding conditions met, as required.

Explanation/Justification:

- A. 'C' pump will trip and not coast down, the 'A' pump will not trip on over current due to the orifice in the discharge line.
- B. correct answer, 'C' RHR pump will trip on loss of voltage due to D/G tripping. Flow limited to 13,500 gpm due to orifice in discharge of each RHR pump to prevent pump trip on over current. Loss of water source will require monitoring level and flooded criteria. If delta p between RPV and Suppression Chamber drop less than 81 psid the flooded time will have to be reset.
- C. 'A' RHR pump will not trip on over current for given conditions due to the flow orifice in the pump discharge.
- D. 'C' pump will trip and not coast down, the 'A' pump will not trip on over current due to the orifice in the discharge line. The 'B' loop will not be in a runout condition due to flow orifices in the pump discharge lines even though the total head the system is pumping against is reduced.

Sys #	System	Category	KA Statement
203000	RHR/LPCI: Injection Mode (Plant Specific)	Ability to (a) predict the impacts of the following on the RHR/LPCI: INJECTION MODE; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:	Emergency generator failure
K/A#	<u>203000.A2.06</u>	K/A Importance <u>3.9</u>	Exam Level <u>SRO</u>
References provided to Candidate	None	Technical References:	<u>TM-OP-049</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>3</u>
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	<u>55.43</u>
Training Objective:	2680	Determine the correct course of action when given plant conditions.	
Training Task:	00EO032	Implement RPV Flooding	

SSES SRO NRC Re-Exam

16 Unit 1 is operating at 50% power.

- The static inverter for Vital UPS 1D666 is tagged out for maintenance.
- Vital Distribution Panel 1Y629 is being powered by the alternate power supply MCC 1B246 through the manual bypass switch.

MCC 1B246 voltage begins to drop. When voltage drops to zero volts and alarm VITAL AC UPS PANEL 1L666 TROUBLE/ABNORMAL (AR-106-E11) is received:

How will Vital UPS 1D666 respond to this zero voltage condition on MCC 1B246, and what operator actions will you direct, in response to these conditions?

Vital UPS 1D666 will:

- A. Automatically swap to the preferred source. Direct the PCOM to reset the runbacks and the scoop tube positioners on the A and B MG sets.
- B. NOT automatically swap to the preferred source. Direct the PCOM to perform Scram imminent actions, Scram the reactor and trip all feed pumps.
- C. NOT automatically swap to the preferred source. Direct the NPO to place the static switch to "Alternate load".
- D. Automatically swap to the preferred source. Direct the PCOM to perform Scram imminent actions, Scram the reactor and trip all feedpumps IF RPV water level approaches either the low or the high alarm points.

Question Data

- B NOT automatically swap to the preferred source. Direct the PCOM to perform Scram imminent actions, Scram the reactor and trip all feed pumps.

Explanation/Justification:

- A. Is incorrect. Static switch will only automatically transfer if bypass switch is in "Normal Mode". If candidate believes MCC 1B246 provides the preferred power to 1Y128 distribution panel in addition to 1D666, then these actions would be necessary IAW ON-117-001
- B. Correct answer. To arrive at this answer the candidate must know from memory that this Vital UPS has only one AC source and not 2 like most of the other Vital UPS, and must know from memory that the static switch will not Automatically transfer when it is in the Manual bypass position. Candidate must then conclude that the distribution panel would be de-energized, and follow the AR procedure. The AR then references the ON and the ON must be followed correctly to apply the appropriate directed actions. 50% power was chosen as a starting point to avoid an immediate automatic scram on low level when the feed pump recirc valves go open on the loss of power to the panel.
- C. Is incorrect. The static switch will not automatically transfer, however placing the static switch to Alternate load position will not restore the bus since the power feed to the distribution panel is the same power source that has just degraded to zero volts.
- D. Is incorrect. Static switch will only automatically transfer if bypass switch is in "Normal Mode" to begin the transient. The actions are addressed as necessary in ON-117-001.

Sys #	System	Category	KA Statement
262002	Uninterruptable Power Supply (A.C./D.C.)	Ability to (a) predict the impacts of the following on the UNINTERRUPTABLE POWER SUPPLY (A.C./D.C.); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:	Under voltage

SSSES SRO NRC Re-Exam

K/A#	<u>262002.A2.01</u>	K/A Importance	<u>2.8</u>	Exam Level	<u>SRO</u>
References provided to Candidate	AR-106-E11, and ON-117-001			Technical References:	AR-106-E11, and ON-117-001
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5)	4	
Question Cognitive Level:	Analysis			10 CFR Part 55 Content:	55.43
Training Objective:	1358	Determine a course of action to mitigate or correct an off-normal situation.			
Training Task:	17ON003	Implement Loss Of Reactor Building Chilled Water			

SSES SRO NRC Re-Exam

17 Unit 1 is at 100% power.

Annunciator alarm AR-107-D04 ARI DIV 1 INOP/BYPASS was received. Electrical Maintenance investigated cause of the alarm and reports a loss of power to the ARI DIV 1 logic.

What is the impact of this failure and what actions are required?

- A. CRD backup scram protection for Div 1 is unavailable. Restore backup scram protection within 1 hour.
- B. Manual and automatic actuation of ARI are inoperable. Restore ATWS-ARI trip capability within 14 days.
- C. Div 2 ATWS-ARI remains operable with rod scram times extended to 25 seconds. Restore Div 1 ATWS-ARI to operable within 14 days and evaluate for potential violation of 10 CFR 50.62.
- D. ATWS-ARI trip input signals to Division 1 RPS logic are inoperable. Place channel in trip condition within 12 hours.

Question Data

B Manual and automatic actuation of ARI are inoperable. Restore ATWS-ARI trip capability within 14 days.

Explanation/Justification:

- A. A separate 125 VDC source provides power to Div 1 backup scram valves, therefore, the function remains operable.
- B. Is correct. Both divisions must energize to cause scram air header isolation and venting. Since a power loss is involved neither manual nor automatic actuation is operable. TRO 3.1.1 requires trip capability restored within 14 days.
- C. Div 2 ATWS-ARI remains operable, however, both divisions must energize to cause scram air header isolation and venting. Rods scram times are not extended to 25 seconds in this condition.
- D. ATWS-ARI does not provide trip signals to RPS, it is an independent function to RPS.

Sys #	System	Category	KA Statement
201001	Control Rod Drive Hydraulic System	Ability to (a) predict the impacts of the following on the CONTROL ROD DRIVE HYDRAULIC SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:	Power supply failures
K/A#	<u>201001.A2.03</u>	K/A Importance <u>3.1</u>	Exam Level <u>SRO</u>
References provided to Candidate	<u>TRO 3.1.1</u>	Technical References:	<u>TRO 3.1.1</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>3</u>
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	<u>55.43</u>
Training Objective:	2328	Given various instrumentation and computer indications, determine if RPS and supported system(s) response(s) are correct for each of the following conditions:	
		a. Normal operation	
		b. Loss of offsite power	
		c. Loss of RPS bus power to one RPS Division	

Training Task: 58ON004 Implement Loss Of RPS

SSES SRO NRC Re-Exam

18 An accident is in progress on Unit 1 with the following parameters:

- All rods fully inserted.
- Drywell pressure is 10 psig and slowly increasing.
- HPCI and RCIC are controlling RWL +13 to +54 inches.
- Reactor pressure is 940 psig and slowly lowering.
- SPOTMOS temperature is 89 deg F and slowly increasing.
- Suppression Chamber pressure is 5 psig and slowly increasing.

Five minutes after Suppression Chamber Sprays were initiated on RHR loop A, the following containment data was reported:

- Drywell pressure is 11 psig and slowly increasing.
- SPOTMOS temperature is 91 deg F and slowly increasing.
- Suppression Chamber pressure is 6 psig and slowly increasing.
- Suppression Chamber vapor space temperature is 91 deg F.

Explain the Suppression Pool response and the proper containment pressure control action you will direct?

- A. Suppression Pool water temperature is too high to reduce vapor space pressure, place B loop RHR in Suppression Chamber Spray mode using RHRSW before Suppression Chamber pressure reaches 13 psig.
- B. The Suppression Chamber vapor space contained mostly steam prior to initiating sprays, place a second RHR loop in Suppression Chamber Spray mode before Suppression Chamber pressure reaches 13 psig.
- C. The Suppression Chamber vapor space contained no steam prior to initiating sprays, when Suppression Chamber pressure exceeds 13 psig spray the Drywell.
- D. Leaking Suppression Chamber vacuum breakers have bypassed the pressure suppression function, when Suppression Chamber pressure exceeds 13 psig spray the Drywell.

Question Data

- C The Suppression Chamber vapor space contained no steam prior to initiating sprays, when Suppression Chamber pressure exceeds 13 psig spray the Drywell.

Explanation/Justification:

- A. 91 deg F water temperature is not too high to reduce vapor space pressure. Using sprays from RHRSW is not warranted in this condition.
- B. If the vapor space contained steam following initiation of sprays a reduction in Drywell pressure should occur. Use of a second loop of Suppression Chamber sprays is not directed since a single spray header exists by design with either RHR loop supplying that header.
- C. is correct. Vapor space pressure is caused by accumulation of nitrogen, use of sprays in the vapor space will have little affect on pressure. Drywell spray is not permitted until Suppression Chamber pressure exceeds 13 psig.
- D. If vacuum breaker valves were leaking the d/p between the Drywell and Suppression Chamber vapor space would be less than 5 psig. At this point there is no basis for performing rapid depressurization.

SSES SRO NRC Re-Exam

Sys #	System	Category	KA Statement
	RHR/LPCI: Torus/Suppression Pool Spray Mode	Conduct of Operations	Ability to execute procedure steps.
K/A#	<u>230000.2.1.20</u>	K/A Importance <u>4.2</u>	Exam Level <u>SRO</u>
References provided to Candidate	None	Technical References:	EO-100-103 step PC/P-4
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	2598	For each Symptom Based EOP: Explain the basis for each step.	
Training Task:		Implement Secondary Containment Control	

SSES SRO NRC Re-Exam

- 19 Unit 1 is at 100% reactor power.
Operations has been notified a calibration error for D MSL Flow-High isolation instrumentation has resulted in the following trip setpoint data:

<u>D MSL Flow-High Instrument Number</u>	<u>Trip Setpoint</u>
FIS-B21-1N009A	135 psid
FIS-B21-1N009B	136 psid
FIS-B21-1N009C	134 psid
FIS-B21-1N009D	134 psid

What Technical Specification required action and completion time, if any, is applicable at the time of discovery?

- A. None, LCO is met.
- B. Enter the Condition referenced in Table immediately.
- C. Restore Isolation capability within 1 hour.
- D. Be in MODE 2 in 7 hours.

Question Data

C Restore Isolation capability within 1 hour.

Explanation/Justification:

- A. LCO is not met, Table 3.3.6.1-1 requires each trip system to have 2 channels/steam line operable.
- B. Entering the Condition from Table 3.3.6.1-1 is not done until the Condition A or B completion time is exceeded.
- C. is correct. MSL isolation function is not operable if 4 channels from D MSL are inoperable. The issue of calibration error adds complexity since have to make decision if equipment is broke or not. Have to determine from data if sufficient number of instruments and then determine if function is available.
- D. time from LCO 3.0.3 which is not applicable.

Sys #	System	Category	KA Statement
		Conduct of Operations	Ability to apply technical specifications for a system.
K/A#	<u>2.1.12</u>	K/A Importance <u>4.0</u>	<u>SRO</u>
References provided to Candidate	Tech Spec	Exam Level	Technical References: <u>TS 3.3.6.1</u>
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) <u>3</u>
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	<u>55.43</u>
Training Objective:	1642	Given a set of U-1 (U-2) Technical Specifications, determine the ability to determine Main Steam System operability by locating the applicable LCO Action Statement. (SRO only)	
Training Task:	00TS001	Ensure Plant Operates In Accordance With The Operating License, Technical Specifications (TS), and Technical Requirements Manual (TRM)	

SSES SRO NRC Re-Exam

- 20 Technical Specification Surveillance Requirement SR 3.3.1.1.2 was last performed at 2145 on 10/5/03 prior to a reactor scram.

Given the following times and data:

- Plant Start-up on 10/14/03.
- 1115 on 10/15/03 MODE 1 entered.
- 1740 on 10/15/03 power initially exceeded 25%.
- 1830 on 10/15/03 power was subsequently reduced to 22% before SR 3.3.1.1.2 was completed.
- 2020 on 10/15/03 power exceeded 25%.
- No LCO required actions were entered.

What is the maximum time for completion of SR 3.3.1.1.2 to comply with Technical Specification requirements without using frequency interval extensions?

- A. 0540 on 10/16/03
- B. 0940 on 10/16/03
- C. 0820 on 10/16/03
- D. 2315 on 10/15/03

Question Data

C 0820 on 10/16/03

Explanation/Justification:

- A. This time and date is based on initially starting the clock for performance of SR 3.3.1.1.2. When power was reduced below 25% the clock is reset since the conditions are no longer met to perform the surveillance.
- B. This time and date is based on the initial power increase above 25% plus the 25% frequency interval extension.
- C. correct. This time and date is based on meeting the conditions for performance of the surveillance the second time. There is no violation, even with the 7 day frequency not met, provided operation does not exceed 12 hours with power greater than 25%.
- D. This time and date is based upon entering MODE 1. Entering MODE 1 is not a trigger to complete the surveillance. SR 3.3.1.1.2 is modified by a note for the 7 day frequency such that it is not required to be performed until 12 hours after thermal power is greater than 25%.

Sys #	System	Category Equipment Control	KA Statement Knowledge of surveillance procedures.
K/A#	<u>2.2.12</u>	K/A Importance <u>3.4</u>	Exam Level <u>SRO</u>
References provided to Candidate	Tech Spec	Technical References:	TS 3.3.1
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	1398	Determine if a component or system is required to be operable per Technical Specifications.	
Training Task:	00TS001	Ensure Plant Operates In Accordance With The Operating License, Technical Specifications (TS), and Technical Requirements Manual (TRM)	

SSES SRO NRC Re-Exam

21 Unit 1 is in REFUELING mode with the following plant conditions:

- Refueling cavity water level is 22.5 feet above the top of the RPV flange and stable
- B and D RHR pumps are out of service for maintenance
- C RHR pump is running
- A RHR pump is in standby
- Irradiated fuel assemblies are in the RPV
- An irradiated fuel assembly is being loaded into the RPV

The C RHR pump trips on overcurrent and cannot be restarted. The PCOM attempts to start A RHR pump, however, it will NOT start.

What Technical Specification actions, if any, are REQUIRED within 1 hour, for these conditions?

- A. Immediately suspend loading irradiated fuel assemblies into the RPV.
- B. Verify an alternate method of decay heat removal is available, AND verify reactor coolant circulation by an alternate method AND monitor reactor coolant temperature.
- C. No Technical Specification actions required, RHR may be removed from service for 2 hours per 8 hour period.
- D. Verify two alternate methods of decay heat removal are available, AND verify reactor coolant circulation by an alternate method AND monitor reactor coolant temperature.

Question Data

B Verify an alternate method of decay heat removal is available, AND verify reactor coolant circulation by an alternate method AND monitor reactor coolant temperature.

Explanation/Justification:

- A. Incorrect. These actions need to be taken only if Condition A actions are NOT met.
- B. Correct answer. Information given in the stem of the question makes TS 3.9.7 applicable. Actions A and C are appropriate since this is the last operating RHR shutdown cooling subsystem.
- C. Incorrect. TS 3.9.7 Note that allows RHR shutdown for 2 hours in any 8 hour period is an allowance for specific planned evolutions and does NOT apply to unplanned losses of RHR. If a candidate does not understand these restrictions, the candidate will incorrectly choose this distracter
- D. Incorrect. These are the required actions if Refueling cavity water level is < 22 feet

Sys #	System	Category	KA Statement
		Equipment Control	Knowledge of refueling administrative requirements.
K/A#	2.2.26	K/A Importance 3.7	Exam Level SRO
References provided to Candidate	TS 3.9.7	Technical References:	TS 3.9.7
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 3
Question Cognitive Level:	Analysis	10 CFR Part 55 Content:	55.43
Training Objective:	12473	During refueling operations, given a set of conditions and a copy of Technical Specifications or the Technical Requirements Manual, determine applicable Limiting Conditions of Operations/Technical Requirements for Operation (LCO/TRO), required actions and/or required Surveillances. (SRO only)	

Training Task:

SSES SRO NRC Re-Exam

- 22 The Unit Supervisor is preparing a prejob brief per OP-AD-004, "Operations Standards For Error And Event Prevention" with Unit 1 at 100% power. The prejob brief is to support valve lineup checks for Maintenance in the Reactor Water Cleanup (RWCU) Backwash Receiving Tank Room while RWCU system remains in service.

Due to a broken reach rod, entry is required to check position of 166004, RWCU BKWSH TK DRAIN TO LRW and other valves as shown on the attached Area Survey Map .

The operator being sent in the area has a total dose for the year of 400 mrem TEDE.

A 600 mrem allowance for checking the other valves and to exit the area must be factored into the maximum stay time calculations.

SSS Administrative dose limits shall not be exceeded and no dose extensions have been authorized.

Based on these conditions, how should system blocking requirements and maximum stay time be addressed during the ALARA briefing?

- A. System blocking is not required to prevent introducing resin into the Backwash Receiving Tank.
Maximum stay time is 60 minutes.
- B. System blocking is not required to prevent introducing resin into the Backwash Receiving Tank.
Maximum stay time is 24 minutes.
- C. System blocking is required to prevent introducing resin into the Backwash Receiving Tank.
Maximum stay time is 36 minutes.
- D. System blocking is required to prevent introducing resin into the Backwash Receiving Tank.
Maximum stay time is 12 minutes.

Question Data

- D System blocking is required to prevent introducing resin into the Backwash Receiving Tank.
Maximum stay time is 12 minutes.

Explanation/Justification:

- A. 60 minutes is calculated using the administrative limit of 4000 which requires a dose extension and subtracting the present dose and dose for checking the other valves and exiting.
- B. Inside the shield wall requires ALARA blocking. 24 minutes is calculated using the administrative limit of 2000 and not accounting for the present dose and dose for checking the other valves and exit time.
- C. 36 minutes is calculated using the administrative limit of 4000 which requires a dose extension and subtracting the present dose and dose for checking the other valves and exiting.
- D. Correct Answer, Candidate will need to use attached figure to determine the location of the valve is inside the shield wall. Entrance inside the shield wall requires ALARA blocking to be initiated. Candidate must then calculate max stay time not to exceed SSES Administrative limit of 2000 mrem (w/o a dose extension) (2000 limit minus 400 present dose, minus 600 for checking other valves and exit, leaves 1000 to check 166004 position. 1000 divided by 5rem/hr is 200 minutes.

Sys #	System	Category	KA Statement
-------	--------	----------	--------------

SSES SRO NRC Re-Exam

Radiological Controls

Ability to perform procedures to reduce excessive levels of radiation and guard against personnel exposure.

K/A#	<u>2.3.10</u>	K/A Importance	<u>3.3</u>	Exam Level	<u>SRO</u>
References provided to Candidate	None	Technical References:	NDAP-QA-0696, 1191		
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5)	2	
Question Cognitive Level:	Fundamental	10 CFR Part 55 Content:	55.43		
Training Objective:	4347	DESCRIBE the access and control requirements for:			
		a. Radiation Areas			
		b. High and Very High Radiation Areas			
Training Task:	00AD018	Implement Appropriate Portions Of Radiologically Controlled Area Access And RWP System			

SUSQ SES - AREA SURVEY MAP				H2	scfm	Rx PWR	%
UNIT: 1	BUILDING: REACTOR	Elev. 761'	ROOM: RWCU BWRT Room	I-509			
RWP# <u>####</u>	DATE: <u>Today</u>	TIME: <u>Now</u>	SURVEY BY: <u>H.P. Ted</u>				
RAD. INST. <u>###</u>	HP # <u>##</u>	CAL DUE <u>12/30/03</u>	SOURCE CHECK SAT <u>YES</u>				
AIR SAMPLER <u>N/A</u>	HP # <u>N/A</u>	CAL DUE <u>N/A</u>	ACTIVITY <u>N/A</u> $\mu\text{Ci/cc}$				
CONTAM. INST. <u>N/A</u>	HP # <u>N/A</u>	CAL DUE <u>N/A</u>	EFF. <u>N/A</u> % BKGD. <u>N/A</u> cpm				
SMEAR RESULTS (dpm/100cm ²)							
1. _____	5. _____	9. _____	14. _____				
2. _____	6. _____	10. _____	15. _____				
3. _____	7. _____	11. _____	16. _____				
4. _____	8. _____	12. _____	17. _____				
		13. _____	18. _____				
REASON FOR SURVEY							

RAD READINGS IN mR/hr

SMEAR LOCATIONS CIRCLED.

CONTACT RAD READINGS

■ = S.O.P.

β- = BETA DOSE RATE (mRad/hr)

(M) = LARGE AREA SMEAR (ccpm)

GENERAL AREA DOSE RATES


--- = RAD TAPE

-X-X- = RAD TAPE & ROPE

X X X X = RAD ROPE

@ = A/S LOCATION

→ N



REVIEWED:

Supv H.P. Ted
Health Physics

1

Today
Date

SSES SRO NRC Re-Exam

- 23 OP-069-050, "Release of Liquid Radioactive Waste" is being performed for the Laundry Drain Sample Tank (OT312). All required channel checks have been completed satisfactorily with the EXCEPTION of the Unit 1 Cooling Tower Blowdown Flow Instrumentation Channel Check, which failed.

What actions need to be completed for disposition of the release permit initiated for the Laundry Drain Sample Tank (OT312)?

Release of the Laundry Drain Sample Tank (OT312) may:

- A. NOT be completed. Discharging Laundry Drain Sample Tank requires all Blowdown Flow instrumentation to be operable.
- B. be completed with Shift Supervision approval, and analyze at least two independent samples in accordance with TRO 3.11.1.1 AND Independently determine release rates for samples analyzed per Action B.1 actions.
- C. be completed with Shift Supervision approval, and greater than 5500 gpm flow from Unit 2 Cooling Tower Blowdown Flow.
- D. NOT be completed, until TR 3.11.1.4 Condition E actions complete and post release samples are analyzed in accordance with Table 3.11.1.1-1.

Question Data

C be completed with Shift Supervision approval, and greater than 5500 gpm flow from Unit 2 Cooling Tower Blowdown Flow.

Explanation/Justification:

- A. only one channel is required by the procedure and the technical requirements.
- B. TR 3.11.1.1 is not required to be entered and the sampling requirement is for an inop rad monitor.
- C. correct answer, there are three possible flow instruments that may be selected to satisfy the blowdown flow interlock and to satisfy the procedure and Technical Requirements manual. The three position switch is labeled; Unit 1 or 2 or BOTH.
- D. TR 3.11.1.4 condition is applicable for an inoperable rad monitor and the post sampling is required always per the ODCM to verify the composite of all samples has not exceeded any limits.

Sys #	System	Category	KA Statement
		Radiological Controls	Knowledge of the requirements for reviewing and approving release permits.
K/A#	2.3.6	K/A Importance 3.1	Exam Level SRO
References provided to Candidate	TR 3.11	2.0.7	Technical References: TR 3.11.1.4
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 2
Question Cognitive Level:	Analysis		10 CFR Part 55 Content: 55.43
Training Objective:	789	Complete Form OP-069-050, Attachment F for a Liquid Radwaste Release.	
Training Task:	69OP001	Complete Form OP-069-050 ATT F For A Liquid Radwaste Release	

SSES SRO NRC Re-Exam

- 24 The Control Room Emergency Director has declared a GENERAL EMERGENCY due to an offsite gaseous release. Dose Projections indicate a 545 mrem Thyroid CDE at two (2) miles from the plant.

What, if any, Protective Action Recommendation should be issued to the State and Local Agencies?

- A. Evacuate 0-2 miles and shelter 2-10 miles.
- B. No protective actions required at this time, continue assessment.
- C. Evacuate 0-10 miles.
- D. Evacuate 0-2 miles downwind sectors and shelter 2-10 miles downwind sectors.

Question Data

A Evacuate 0-2 miles and shelter 2-10 miles.

Explanation/Justification:

- A. Correct answer, using PAR Airborne Releases Tab 5 provided. Dose projection indicates less than 5 Rem CDE requiring partial evacuation.
- B. A General Emergency has been declared and continued assessment is not valid.
- C. A valid dose projection has been performed thus a PAR of evacuation of 0-10 miles is not valid.
- D. SSES does not issue protective actions by sector.

Sys #	System	Category	KA Statement
		Emergency Procedures and Plan	Knowledge of emergency plan protective action recommendations.
K/A#	<u>2.4.44</u>	K/A Importance	<u>4.0</u>
References provided to Candidate	Tab 5 EP-PS-100	Exam Level	<u>SRO</u>
Question Source:	New	Technical References:	Tab 5 EP-PS-100
Question Cognitive Level:	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5)	3
Training Objective:	Comprehension	10 CFR Part 55 Content:	55.43
Training Task:	EP-010-6	Apply the guidance in the Public Protective Action Recommendation Guide for selection of a protective action recommendation (PAR).	

SSES SRO NRC Re-Exam

25 EO-100-113 "Level/Power Control" Sheet 1 is being implemented up to LQ/L-13.

Prolonged operation with RPV level in the yellow area of Figure 8 may:

- A. increase power instabilities, cause fuel clad melt, shorten the time that steam cooling can be maintained..
- B. make boron mixing less efficient, maximize core inlet subcooling, make core power more responsive to core flow.
- C. cause containment design pressure to be exceeded, make RCIC boron injection less effective, produce more steam than open SRVs and Bypass Valves can relieve.
- D. make reactor water level control more difficult, increase core inlet subcooling, make RCIC boron injection less effective.

Question Data

D make reactor water level control more difficult, increase core inlet subcooling, make RCIC boron injection less effective.

Explanation/Justification:

- A. Steam cooling is addressed in the Flooding Emergency Operating procedure and has no relation to the caution. Water level is reduced to near the MSIV isolation setpoint and could cause the MSIVs to close but a preceding step bypasses the MSIV closure on low low level.
- B. The first two reasons given are correct. Core power more responsive to core flow is not a documented reason for maintaining level in the target band. Core flow when in the target band is natural circulation since the RRP's are shutdown.
- C. The first two reasons given are correct. The plant is designed to have enough Safety Valve capacity for complete relief of steam. Lowering level will cause power to lower to much less than 100 % steam flow thus this is not a valid reason.
- D. Correct answer. Makes level control easier by maintaining level above the narrow region of the downcomer. Below -110" the downcomer free area reduces from 300 ft² to 88 ft² resulting in increased magnitude of indicated level oscillations. The purpose of the upper limit is to uncover the feedwater spargers sufficiently to reduce core inlet subcooling. As level is decreased below -110", boron mixing efficiency is reduced because the natural circulation flow rate through the jet pumps is reduced and not as efficient at carrying the injected boron from the lower plenum upward into the core.

Sys #	System	Category	KA Statement
		Emergency Procedures and Plan	Knowledge of operational implications of EOP warnings, cautions, and notes.
K/A#	2.4.20	K/A Importance 4.0	Exam Level SRO
References provided to Candidate	EOP Flow Charts	Technical References:	EO-000-100
Question Source:	New	Susquehanna, 12/15/2003	Level Of Difficulty: (1-5) 2
Question Cognitive Level:	Comprehension	10 CFR Part 55 Content:	55.43
Training Objective:	2598	For each Symptom Based EOP: Explain the basis for each step.	
Training Task:	00EO026	Implement Secondary Containment Control	