

January 7, 2004

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Catawba Nuclear Station, Unit 1  
Docket No. 50-413  
Errata: Steam Generator Tube Inspection Report  
Unit 1 End of Core (EOC) 14

By letter dated December 23, 2003, Catawba Nuclear Station submitted its Steam Generator Tube Inspection Report for Unit 1 EOC 14 pursuant to Technical Specifications 5.6.8.a. and 5.6.8.b. Your staff identified an error contained in the cover letter; specifically, the unit and docket numbers were incorrect. The submittal should have referenced Unit 1, Docket No. 50-413. Accordingly, please replace the effected cover letter dated December 23, 2003 with the attached cover letter dated January 7, 2004 that accurately reflects Unit 1 information.

Thank you for pointing out this error. If you have any questions, please contact Kay Nicholson at 803-831-3237.

Sincerely,



Dhiaa M. Jamil

\ken

xc: L. A. Reyes  
U. S. Nuclear Regulatory Commission  
Regional Administrator, Region II  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, GA 30333

S. E. Peters (addressee only)  
U. S. Nuclear Regulatory Commission  
Project Manager  
Mail Stop 0-8 G9  
Washington, D. C. 20555-0001

E. F. Guthrie, Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
Catawba Nuclear Station – CN01NC

A047  
A07

January 7, 2004

*803 831 4251  
803 831 3221 fax*

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Catawba Nuclear Station, Unit 1  
Docket No. 50-413  
Steam Generator Tube Inspection Report  
Unit 1 End of Core (EOC) 14

Catawba Nuclear Station (CNS) Technical Specifications 5.6.8.a. and 5.6.8.b., requires the number of tubes plugged in each steam generator to be reported within 15 days and requires the complete results of the Steam Generator Tube Surveillance Program to be reported within 12 months, respectively, following the completion of the program.

The following provides the quantity of tubes inspected and tubes removed from service by plugging:

Steam Generator	Tubes Inspected Full Length	Tubes Inspected Partial Length	Tubes Removed by Plugging
A	6625	0	0
B	0	6663	0
C	0	6626	7
D	6629	0	0

Attachments 1, 2, 3, and 4 identify tube imperfections in steam generators A, B, C, and D respectively. The location and size of the imperfections are also provided.

Attachments 5, 6, 7, and 8 identify tubes removed from service by plugging in steam generators A, B, C, and D respectively. The tubes to be plugged are also provided.

U. S. Nuclear Regulatory Commission  
Steam Generator Tube Inspection Report for 1 EOC 14  
January 7, 2004  
Page 2

Any questions concerning this submittal may be directed to Kay Nicholson at 803-831-3237.

Sincerely,



Dhiaa M. Jamil

Ken

xc: L. A. Reyes  
U. S. Nuclear Regulatory Commission  
Regional Administrator, Region II  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, GA 30333

S. E. Peters (addressee only)  
U. S. Nuclear Regulatory Commission  
Project Manager  
Mail Stop 0-8 G9  
Washington, D. C. 20555-0001

E. F. Guthrie, Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
Catawba Nuclear Station – CN01NC